

# Answer to Bill Fowler's Question Made at the April RC Meeting - Final

NEPOOL Reliability Committee Meeting  
May 2, 2006

# Summer 2006 System Conditions

## System Conditions for July and August 2006 (MW)

	July	August
Installed Resources (May SCC) Report	30,015	30,015
Import	410	410
Export	915	915
Total Available Resources	29,510	29,510
ICR (Pending FERC Approval)	30,933	30,941
HQICC	1,200	1,200
Resource Needed to meet ICR	29,733	29,741
System Surplus	-223	-231

Rumford and Tiverton (490 MW) assumed available.