



Eastern Interconnection Planning Collaborative

Gas-Electric System Interface Study

Target 4

Fuel Assurance:

Dual-Fuel Capability v. Firm Transportation

November 14, 2014

LEVITAN & ASSOCIATES, INC.

MARKET DESIGN, ECONOMICS AND POWER SYSTEMS

Acknowledgement and Disclaimer

The EIPC appreciates and acknowledges the support of DOE for the Eastern Interconnections Studies Project

Acknowledgement:

- ♦ This material is based upon work supported by the Department of Energy, National Energy Technology Laboratory, under Award Number DE-OE0000343.

Disclaimers:

- ♦ This report was prepared as an account of work sponsored by an agency of the United States Government. Neither the United States Government nor any agency thereof, nor any of their employees, makes any warranty, express or implied, or assumes any legal liability or responsibility for the accuracy, completeness, or usefulness of any information, apparatus, product, or process disclosed, or represents that its use would not infringe privately owned rights. Reference herein to any specific commercial product, process, or service by trade name, trademark, manufacturer, or otherwise does not necessarily constitute or imply its endorsement, recommendation, or favoring by the United States Government or any agency thereof. The views and opinions of authors expressed herein do not necessarily state or reflect those of the United States Government or any agency thereof.

Agenda

- ◆ Overview of Target 4 research goals
- ◆ Specific analyses
 - Simple Cycle and Combined Cycle Storage Capability
 - Dual-Fuel Operating Characteristics and Costs
 - Oil Market Availability and Resupply Options
 - Fuel Switching Design and Practice
 - Economic Tradeoffs between Dual-Fuel v. Firm Transportation
- ◆ Q&A

Target 4 Study Limitations

- ◆ Fuel assurance from PPAs' perspective
- ◆ No quantification of wholesale energy price effects with Firm Transportation v. Dual-fuel capability
- ◆ Other factors affecting generators' willingness to invest in Firm Transportation
 - Different performance on gas v. ULSD
 - Profit margin from incremental energy sales
 - Increased permitting difficulty to store and burn ULSD
 - Penalty avoidance as a capacity resource

Target 4 Highlights

Primary Findings

- ◆ Going forward, new gas-fired plants are expected to use ultra low sulfur diesel (ULSD) as the primary back up fuel
- ◆ Anticipated heavy reliance on ULSD represents a major change in the distillate oil market
 - ULSD supply chain is robust
- ◆ Air permits typically cap oil use to 720 hours, but some permits have established lower annual hourly limits
- ◆ At most locations, the cost of dual-fuel capability is much less expensive than the incremental cost of firm transportation to satisfy the fuel assurance objective

Target 4 Approach

- ◆ Identify constrained locations across the Study Region from Target 2 Frequency – Duration results
- ◆ Define gas turbine technology types in Simple Cycle (SC) and Combined Cycle (CC) mode
- ◆ Design cost model to account for regional differences in dual-fuel capability, firm transportation (FT)
 - Account for non-firm transportation costs
 - Account for local facility improvements where applicable
- ◆ Develop a flexible financial modeling tool that can be updated by the PPAs in response to changing market and operational dynamics

Current Dual-Fuel Capability

- ◆ Liquid Fuel Storage and Resupply Methods
 - Focus on backup fuel storage capacity and backup fuel consumption at full load
 - Data on resupply/delivery logistics
- ◆ Data pieced together from public and confidential data sources, i.e., PPAs, generators, air permit applications, U.S. EPA
- ◆ Database contains consistent storage and fuel use data for 52 units (CTs and CCs)
 - Unit-specific details will not be published

CT Characteristics & Costs

- ◆ Focus on differential performance and cost for
 - Single Fuel (natural gas)
 - Dual-Fuel (natural gas and ULSD)
- ◆ Selected CT models representative of recent and near future new SC and CC plants
 - Heavy frame units using “F” technology:
 - GE 7FA (7F.05)
 - Siemens SGT6-5000F
 - Aero-derivative units:
 - GE LM6000
 - GE LMS100

Information Sources

- ◆ Review and reliance on 2014 PJM CONE Study
 - Capital and operating cost account structure
 - SC and CC 7FA-based plants
 - Single fuel and dual-fuel cost estimates
 - Cost adjustments for multiple locations
 - Labor cost
 - Property, sales, and income taxes
 - Environmental regulation
- ◆ Review and reliance on 2013 NYISO CONE study
 - Capital costs for LMS100 SC
 - Single fuel and dual-fuel configurations
 - Different site conditions, including NYC/LI
- ◆ Fuel storage tank construction cost information from NYSERDA study prepared by ICF
- ◆ Discussions with CT manufacturers

Cost Models

- ◆ Cost models developed for incremental dual-fuel capability
 - Three plant types
 - Standard CC plant (2x1 7FA)
 - Heavy-frame SC plant (2 x 7FA, no SCR)
 - Aero-derivative SC plant (2 x LMS100, with SCR)
 - Location-specific parameters
 - Labor cost factors
 - Taxes (sales, property, income)
 - NO_x limitations (attainment v. non-attainment zone)
 - Liquid fuel inventory and tankage requirements
 - Capital cost and fixed operating cost differentials

Dual-Fuel Capital Cost for 2x7FA CC

Location	Base	RTO	EMAAC	SWMAAC	WMAAC	Dominion
<i>Locational Assumptions</i>	OH	OH	NJ	MD	PA	VA
<i>Nominal Capital \$MM for 2018 CO</i>						
Gas Turbine Scope	\$4.700	\$4.700	\$4.700	\$4.700	\$4.700	\$4.700
Other major equipment	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000
Other construction labor	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000
Liquid Fuel, Demin water handling (Mat'l)	\$0.900	\$0.900	\$0.900	\$0.900	\$0.900	\$0.900
Liquid Fuel, Demin water handling (Labor)	\$0.900	\$0.900	\$1.170	\$0.887	\$0.920	\$0.804
Liquid fuel storage tank (Mat'l)	\$0.827	\$0.827	\$0.846	\$0.843	\$0.825	\$0.838
Liquid fuel storage tank (Labor)	\$0.556	\$0.556	\$0.740	\$0.559	\$0.568	\$0.504
Demin water storage tank (Mat'l)	\$0.498	\$0.498	\$0.498	\$0.498	\$0.498	\$0.498
Demin water storage tank (Labor)	\$0.335	\$0.335	\$0.436	\$0.331	\$0.343	\$0.300
Incremental Land for Tanks	\$0.038	\$0.038	\$0.066	\$0.074	\$0.042	\$0.054
Startup Testing ULSD	\$5.087	\$5.087	\$5.244	\$5.217	\$5.070	\$5.179
Startup Testing Energy Sales on ULSD	(\$1.611)	(\$1.611)	(\$1.812)	(\$1.647)	(\$1.605)	(\$1.636)
Inventory carrying cost as O&M	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000	\$0.000
Total Incremental Direct Cost	\$12.232	\$12.232	\$12.788	\$12.362	\$12.261	\$12.142
Sales tax on equipment and materials	\$0.416	\$0.416	\$0.488	\$0.418	\$0.413	\$0.434
EPC Fee	\$1.096	\$1.096	\$1.173	\$1.096	\$1.100	\$1.077
EPC Contingency	\$1.023	\$1.023	\$1.095	\$1.023	\$1.027	\$1.005
Development Cost	\$0.563	\$0.563	\$0.602	\$0.563	\$0.565	\$0.553
Mobilization & Startup	\$0.113	\$0.113	\$0.120	\$0.113	\$0.113	\$0.111
Non-fuel Inventories	\$0.056	\$0.056	\$0.060	\$0.056	\$0.056	\$0.055
Owner's Contingency	\$0.332	\$0.332	\$0.331	\$0.343	\$0.331	\$0.339
Financing Fees	\$0.380	\$0.380	\$0.400	\$0.383	\$0.381	\$0.377
Indirect (factored) Costs	\$3.977	\$3.977	\$4.271	\$3.996	\$3.986	\$3.951
Total Overnight Cost	\$16.209	\$16.209	\$17.059	\$16.357	\$16.247	\$16.093
Total Installed Cost	\$17.765	\$17.765	\$18.697	\$17.928	\$17.806	\$17.638
Installed Cost per kW of ICAP	\$27.29	\$27.29	\$27.99	\$27.00	\$27.44	\$26.72

Dual-Fuel O&M Costs

CT Model and Configuration	2x1 7FA CC	2x7FA SC	2xLMS100 SC
Location	Base	Base	Base
<i>Locational Assumptions</i>	OH	OH	Newburgh
<i>Annual Fixed O&M Cost (2018 \$MM /yr)</i>			
Materials & Contract Services	\$0.118	\$0.044	\$0.011
Administrative & General Expense	\$0.023	\$0.047	\$0.011
ULSD for Regular Testing	\$1.060	\$1.070	\$0.491
Energy Offset for Testing	(\$0.336)	(\$0.223)	(\$0.116)
Property Taxes	\$0.259	\$0.303	\$0.068
Insurance	\$0.107	\$0.126	\$0.054
ULSD Inventory Carrying Cost as Fixed O&M	\$0.203	\$0.206	\$0.094
Total Fixed O&M (2018 \$MM/yr)	\$1.435	\$1.572	\$0.612
Total Fixed O&M (2018 \$kW-yr)	\$2.20	\$4.08	\$3.32

Fuel Oil Market Assessment

- ◆ Continued discussions with generators re backup fuel issues
 - Going forward most backup fuel use will be ULSD
 - Reduction in seasonal supply constraints
 - Some constraints on supply reported for last winter
 - Weather conditions affecting deliveries by truck
 - Confusion between low sulfur diesel and ULSD
- ◆ Data from refiners, suppliers and distributors re availability, costs, and storage issues
 - Some storage and use considerations, i.e., lubricity and microbiological contamination
 - Treatment with additives and biocide applications to storage tanks

Fuel Switching (Manufacturer View)

- ◆ Fuel switching capability is common design option
- ◆ Switching can be “on the fly”
 - Frame units drop load (e.g. 80%) to switch
 - Easier for aero-derivatives (e.g. LMS100) to switch at 100% load
- ◆ Entire process takes a few minutes if systems ready
 - Liquid fuel systems are on stand-by (recirculating between tank and CT)
 - Water injection systems (not required for gas firing)
- ◆ Switching can be automatic (based on delivery pressure signal) or operator-initiated

Testing of Switchover Capability

- ◆ Regular testing of liquid fuel systems
 - Testing does not require a 100% switchover
 - Liquid fuel only needs to be fired for a few minutes
 - Long-term service agreements which guarantee emissions may require weekly testing

- ◆ Water injection for heavy frame CTs on liquid fuel
 - Needed to meet NO_x limits
 - Additional equipment to maintain in ready status
 - Additional extreme cold-weather concerns

Fuel Switching – Operator View

Operator (Genco) Perspective: Costs & Benefits

- ◆ Reasons for periodic oil operation
 - Reliable switching requires training and practice
 - Service Agreements may require testing to maintain oil firing and emission guarantees
 - Fuel and water systems tested and ready
 - Operator training critical due to frame CT complexities
- ◆ Benefits of periodic oil operation
 - Systems and operators ready if called upon
 - Less chance of trip or emission excursion
- ◆ Costs of periodic oil operation
 - High ULSD price relative to LMPs
 - Higher maintenance accrual rate is not an issue

Fuel Switching – Operator View (2)

Operator (Genco) Perspective: Would Periodically Test on Oil if Costs Were Recoverable through Tariff

♦ Fuel switching practices

- GTs can run at reduced load if gas pressure drops
- If need to switch, GT load reduced to minimize chance of trip and avoid emission exceedance
- Problems with oil and water systems in cold weather
- GTs injecting water for gas are less vulnerable
- Switching virtually always by operators; seldom automatic


♦ Gencos do not test / practice on oil

- Costs > benefits (higher chance of successful switch)
- Inadequate financial incentive to test on oil


Dual-Fuel v. Firm Transportation

- ◆ 27 constrained locations selected by PPAs
 - Target 2 Frequency – Duration results
 - Focus on areas where new development likely
- ◆ Natural gas supply and delivery by location
 - Identification of pipeline path from a production basin to plant location
 - FT reservation rates (incremental), avoided IT costs
 - Lateral as proxy for LDC upgrade costs, if applicable
 - Net Cost of FT
 - FT rate less the avoided cost associated with non-firm transportation costs

Net Cost of FT



Components of Net Cost of FT



Dual-Fuel v. Firm Transportation


◆ ULSD Logistics by Location

- Identification of depot
- Identification of transport mode (truck or barge)
- Estimation of normal delivery lag (order to receipt)
- Estimation of potential weather delays (snow, ice)
- Net price based on rack price, shipping, demurrage


◆ Target Inventory and Fuel Storage Tank Volume

- Expressed in days of full load burn
- Location-specific variables
 - Severity of natural gas delivery constraint
 - Delivery lag and potential weather delay
 - Expected capacity factor when operating on ULSD
 - Tank volume allowance for “lumpy” barge delivery size

ULSD Tank Capacities by Location




ULSD Tank Capacity Drivers




Dual-Fuel v. Firm Transportation

- ◆ Levelized Annual Cost of Fuel Assurance (2018 \$/kW-yr)
 - Dual-fuel capability
 - Capital Recovery
 - CT supply scope (burners, I&C, etc.)
 - Fuel and demin water storage / handling / receipt
 - Other construction costs
 - Emission reduction credits
 - Net cost of startup testing on ULSD
 - Carrying charges on ULSD Inventory
 - Fixed O&M Costs
 - Incremental labor, services and materials
 - Net cost of annual testing on ULSD
 - Incremental insurance and property taxes
 - Net cost of FT – Monthly rate x 12 * MDQ / ICAP


Cost of Dual-Fuel Capability



Comparison Results for Combined Cycle



Comparison Results for Simple Cycle



Conclusions (1)

- ◆ The cost of dual-fuel capability is relatively consistent over the range of locations
 - Primary driver is inventory and storage requirements for barge delivery
 - Unit cost is higher for simple cycle due to higher heat rates (partially offset by lower capacity factor)
- ◆ Cost of fuel assurance through FT varies widely by location
 - Primary drivers are the cost of incremental FT and the cost of local improvements
 - Unit cost is higher for SC due the higher heat rate and the lower installed capacity
- ◆ Dual-fuel capability has a lower cost than net FT cost (with few exceptions)

Conclusions (2)

- ◆ In some locations where incremental FT = embedded costs, FT has a comparable cost to dual-fuel for CCs
- ◆ Dual-fuel capability is the lower cost fuel assurance alternative for SCs at all sites
- ◆ Study limitations
 - Fuel assurance from PPAs' perspective
 - Other factors affecting generators' willingness to invest in FT
 - Different performance on gas v ULSD
 - Profit margin from incremental energy sales
 - Increased permitting difficulty to store & burn ULSD
 - Penalty avoidance as a capacity resource

Target 4 Production Schedule

♦ Proposed key milestones

- Report to stakeholders: 11/07/2014
- SSC webinar re results: 11/14/2014
- Stakeholder comments due: 11/21/2014
- Final draft report to DOE: 12/05/2014