

# 2015 Economic Studies Common Assumptions Scope of Work – Revised Draft

---



*Planning Advisory Committee Meeting*

Wayne Coste

PROJECT MANAGER, ECONOMIC PLANNING



# Outline

- Summary
- Stakeholder Input for 2015 Economic Studies
- Economic Study Metrics
- Economic Study Assumptions Affecting Energy Cost Results
- Assumptions
  - Demand
  - Development of the base network model
  - Resource modeling
  - Interchange modeling
  - Operating reserve
  - Fuel prices



# Three 2015 Economic Study Requests

- Keene Rd. Interface (SunEdison)


[http://www.iso-ne.com/static-assets/documents/2015/04/a6\\_sun\\_edison\\_presentation\\_economic\\_study\\_keene\\_rd.pdf](http://www.iso-ne.com/static-assets/documents/2015/04/a6_sun_edison_presentation_economic_study_keene_rd.pdf)

- Impact of Offshore Wind Deployment on New England's Wholesale Electricity Markets and Operations [Massachusetts Clean Energy Center ]

[http://www.iso-ne.com/static-assets/documents/2015/04/a6\\_cec\\_presentation\\_economic\\_study\\_offshore\\_wind.pdf](http://www.iso-ne.com/static-assets/documents/2015/04/a6_cec_presentation_economic_study_offshore_wind.pdf)

- Impact of Maine Upgrades Identified in ISO-NE's Strategic Transmission Analysis for Wind Integration [RENEW Northeast (RENEW)]

[http://www.iso-ne.com/static-assets/documents/2015/04/a6\\_presentation\\_renew\\_strategic\\_transmission\\_analysis\\_wind\\_integration\\_economic\\_study\\_req.pdf](http://www.iso-ne.com/static-assets/documents/2015/04/a6_presentation_renew_strategic_transmission_analysis_wind_integration_economic_study_req.pdf)



# Summary

- The ISO will perform all three Economic Studies
  - Draft results to be presented to PAC by late 2015 or early 2016
  - Final reports completed after consultation with the PAC
- The studies will compare the performance of the future system with additional representative future system improvements
  - The studies will not include detailed transmission planning analysis, such as new system impact studies
- The results *may* be used to
  - Identify the need for future Market-Efficiency Transmission Upgrades (METU)
  - Inform Public Policy requests for projects facilitating the integration of wind resources
    - Onshore wind resources in ME
    - Offshore wind resources in MA/RI
- These 2015 Economic Studies do not include comprehensive transmission planning analysis required for full development of transmission improvements, but build upon Strategic Transmission Analysis previously presented to the PAC

# Stakeholder Input for 2015 Economic Studies

- The ISO is seeking input from the PAC today
  - Revised high level scope of work
  - General study assumptions
- Later PAC input will be sought on
  - Overall study results and conclusions
  - Review of draft report
- Special economic study working groups *may* be formed to provide the ISO input on very detailed technical modeling and simulation methods not of interest to the general PAC audience
  - This has been done to support past Economic Studies
  - Past study groups required a very limited number of conference calls
  - May have different study working groups for each of the Economic Studies
- ***Alternatively or in addition to the economic study working group***
  - PAC presentations will be structured to discuss the general PAC economic study issues upfront
  - More technical discussions will be discussed with PAC members as a last meeting agenda item

# Economic Study Metrics

- Production Costs for the system
- Load Serving Entity Energy Expenses by RSP bubble
- Congestion for the system
- Flow Duration Curves by Interface
- Generation Energy Production by Fuel Type
- Environmental Air Emissions by Electric Generator Type
- **New:** Approximate cost estimates of representative transmission upgrades that can relieve congestion
  - Comparison of Annual Carrying Charges (assumed at 14%-16% of capital cost estimates) of transmission improvements with the production cost savings resulting from transmission improvements



# Economic Study Assumptions Affecting Energy Cost Results

- Demand forecasts
- Energy Efficiency growth rates
- Renewable development and integration
- Types and locations of new resource development
- Potential retirements
  - Coal
  - Oil
  - Nuclear
- Fuel price
- Environmental emission allowance prices




# Key Simulation Data

- Demand (Reduced local load in Keene Road area will be reflected)
- Transmission
  - Transmission network – reflect RSP net forecast, transmission improvements, etc.
  - Internal interface limits
  - Phase shifters
  - Line monitoring
  - Contingencies
- Resources
  - Thermal units
  - Hydro units
  - Pumped storage
  - Wind units
  - Active Demand Resources, Energy Efficiency and Real-time Emergency Generators
  - Imports/Exports
  - Operating reserve requirements





# Questions



# APPENDIX

# SIMULATION METHODOLOGY


*Development of Base Model*

# Overview of Assumptions – Consistent with 2015 CELT

- Demand
  - Net of Energy Efficiency (EE) and Photovoltaic (PV) – including forecasts
  - Active Demand Resources (DR) treated as supply
  - Hourly load profile based on 2006 weather (synchronized with wind / PV)
- Supply resources considered
  - Results from Forward Capacity Auction #9 for (2018/2019)
  - Energy Only Resources
  - Wind resources in the each study was specified by the economic study requestor

# 50/50 Summer Peak Load Forecast

## Effect of Behind-the-Meter PV and Passive DR



# Network Modeling

- Modeling of Transmission Network
  - Detailed modeling of ISO-NE region only
  - Representation for neighboring systems
    - Detailed network modeling not required for NY, NB, and HQ
    - Tie-line flows modeled by dummy resources at external nodes
    - Base flows based on historical line flows
- Transmission projects\*
  - May 18, 2015 RSP Project List used to select transmission projects
    - All Proposed, Planned and Under Construction reliability upgrades
    - Excluded – RSP 1269, RSP 1280 and RSP 1517
    - Upgrades associated with the ISO Interconnection Queue projects that had PPA approval as of April 1, 2015
  - Generators
    - In the ISO Interconnection Queue with PPA approval as of April 1, 2015
    - Generators without PPA approval but have an obligation through FCA9

\* Source: [http://www.iso-ne.com/static-assets/documents/2015/06/draft\\_summary\\_of\\_steady\\_state\\_basecases\\_for\\_TPL\\_001\\_4.docx](http://www.iso-ne.com/static-assets/documents/2015/06/draft_summary_of_steady_state_basecases_for_TPL_001_4.docx)

# Network Modeling (cont)

- Modeling of Internal Interface Limits
  - Internal interface limits in ME are mostly voltage or stability
  - Model major interfaces consistent with RSP15 transfer capability assumptions and the Strategic Transmission Analysis
- Modeling of transmission lines
  - All 230 kV and 345kV circuits ISO-NE region are monitored
    - Nearly 300 branches monitored
    - Includes transformers that step up to 230 kV and above
- Monitoring of transmission lines
  - 115 kV and above lines in areas of concern as appropriate
    - Maine for
      - Strategic Transmission Analysis – Wind Integration study
      - Keene Road study
    - SEMA / RI for off-shore wind study



# Network Modeling (cont)

- Modeling of contingencies
  - Modeled same contingencies as defined in previous GridView cases
    - Based on 3 years of historical binding contingencies in Day-Ahead Market
    - 100 out of 160 frequently occurring identified and modeled
      - Full set of transmission planning contingences (OP-19) not modeled
  - Additional system contingencies identified by relevant Needs Assessments, Solution Studies and the Strategic Transmission Alternatives



# Thermal Units

- Resources / assets / interconnected at specific buses
- For existing thermal units, use:
  - Production cost parameters such as: Heat rate curve, Start-up cost, No-load cost and etc.
  - Primary and secondary fuel definition are based on 2015 CELT
- Operational limits assumed same as previous economic study
  - Minimum up time, Minimum down time and Start up time
  - Ramp rate limits
- Energy limits: assume no energy limits
- Future thermal units
  - Generic
  - Production cost parameters based on: unit type, technology and rating





# Thermal Units (Cont.)

- For combined cycle units
  - Individual machines for a combined cycle plant will be modeled separately
  - Typically interconnecting at different buses
- Outages
  - Thermal units derated to reflect the forced outages using Equivalent Forced Outage Rate (EFOR)
  - Planned maintenance schedule will be developed and held constant across cases



# Hydro Units

- Hydro units modeled using
  - Hourly energy generation profiles
  - Used in previous economic studies
    - Generates more on-peak than off-peak
    - Reflects a minimum “must-run” value
- Hydro units in wind development areas
  - Hydro profiles will compliment wind profiles
  - Hydro prescheduled so that
    - With known wind profiles, low hydro generation during periods of low wind generation is discouraged
    - Facilitates maximize flows across export constrained interfaces



# Pumped Storage Units


- Modeled in peak shaving mode
  - Pumping during off-peak hours
  - Generating during on-peak hours
- Pumped Storage physical parameters
  - Minimum pond size
  - Maximum pond size
  - Plant Capacity Factor
  - Based on assumptions used in previous studies



# Wind Units

- Wind output modeled as hourly resources
  - Based on NREL Eastern Wind dataset
  - Simulated wind farm data points
    - For the eastern United States
    - For 2004, 2005, and 2006
    - Update in 2012 use newer composite power curves
      - Composite commercial megawatt-class power curves for onshore
      - Separate composite power curve for offshore
- Dispatch Hierarchy
  - Wind will be last resource curtailed (dispatch at \$0/MWh)
  - Hydro will be next to last resource curtailed (dispatch at \$5/MWh)
  - Imports will be curtailed before hydro (dispatch at \$10/MWh)
  - Allows observation of transmission limitations by wind, hydro and imports

# Location of Synthetic Updated EWITS Wind Data




# EWITS Wind Profiles Similar to NEWIS Profiles


Hourly Profile (to be used in the simulations)

Smoothed Hourly Profile (conceptual visualization)

**Offshore: SEMA**



**Offshore: SEMA (rolling 24 hour average)**




# EWITS Wind Profiles Similar to NEWIS Profiles


Hourly Profile (to be used in the simulations)

Smoothed Hourly Profile (conceptual visualization)

**On-shore: BHE**



**On-shore: BHE (rolling 24 hour average)**



# Photovoltaic

- Model forecasted PV resources and loads
- Incorporating a time stamped, chronological solar PV profile
- National Renewable Energy Laboratory (NREL) has developed a simulated solar PV dataset based on 2006 weather
  - New England specific
  - Profiles by RSP area available
- Consistent with methodology used for wind profile
- Profiles to be developed consistent with the PV forecast discussed with the DGFWG




# Demand Side Resources

- Active DR, EE and RTEG are modeled explicitly
  - Hourly profile for each category of demand side resource
  - FCA amounts assumed after capacity commitment periods
  - Modeled the same as previous economic studies
    - Explicitly shows that Active DR and RTEG are expected to be used
    - Price based modeling of Active DR / RTEG is problematic
- EE Forecasts
  - The latest EE forecast through the year 2024 is reflected
  - Active DR and RTEG are held constant for years beyond capacity commitment period (same as other FCM resources)


# Load Modifiers (Base Case)

## Energy Efficiency (EE), Active Demand Resources (DR) and Real-Time Emergency Generation (RTEG)




# Imports and Exports

- Hourly imports and exports over the following external interconnections are modeled based on the **average** of 2012, 2013 and 2014 historical interchange values\*
  - Highgate
  - HQ Phase II
  - New York AC (includes NNC)
  - New York DC-Cross Sound Cable
- Maritimes (New Brunswick)
  - Hourly imports and exports are modeled based on the highest diurnal values for the years 2013 and 2014
  - Sensitivity with 1000 MW import flow




\*The same approach used in previous economic studies for representing import/export assumptions

# Quebec to New England: Phase II



Note: negative values represent imports; positive values represent exports.

# Quebec to New England: Highgate




Note: negative values represent imports; positive values represent exports.

# Maritimes to New England


## Interchange - Maritimes

Diurnal Profile Showing Max Import of 2013 - 2014




Note: negative values represent imports; positive values represent exports.

# New England to New York - AC Interface



Note: negative values represent imports; positive values represent exports.

# New England to New York - DC Interface



Note: negative values represent imports; positive values represent exports.



# Modeling of Operating Reserves

- Operating reserve requirement is determined in real time
  - Based on the first and second largest system contingencies
  - Resource profiles (hydro / wind / interchange etc) excluded
- Current operating reserve requirements
  - 125% of the first contingency in ten minutes split between
    - Ten-Minute spinning Reserve (TMSR) = 50%
    - Ten-Minute Non-Spinning Reserve (TMNSR) = 50%
  - Thirty-Minute Operation Reserve (TMOR) not modeled
    - Assumed to be adequate
    - Provided by hydro, pumped storage and quick-start resources
    - Reasonable assumption except, possibly, at times of peak loads




# ISO-NE Reserve Requirement

Modeled	Not Modeled (assumed not a constraint)	
<p data-bbox="318 392 666 521"><b>On-line: “Ten-Minute Spinning Reserve” (TMSR)</b></p> <ul data-bbox="260 535 705 913" style="list-style-type: none"> <li>• Capability of on-line unit to provide increased energy within 10 minutes</li> <li>• Partially loaded on-line generator</li> <li>• Limited by ramp rate and Economic Maximum</li> </ul>	<p data-bbox="821 392 1188 521"><b>Off-line: “Ten-Minute Non-Spinning Reserve” (TMSNR)</b></p> <ul data-bbox="772 535 1217 1006" style="list-style-type: none"> <li>• Capability of off-line resources to provide energy within 10 minutes</li> <li>• Off-line generation turbine, diesel or hydro generators</li> <li>• Load interruption – Dispatchable Asset Related Demand (DARD)</li> </ul>	<p data-bbox="1294 392 1729 521"><b>On-line or Off-line: “Thirty-Minute Operating Reserve” (TMOR)</b></p> <ul data-bbox="1284 535 1729 1035" style="list-style-type: none"> <li>• Capability of resources to provide energy within 30 minutes</li> <li>• Can be either on-line or off-line resource</li> <li>• Generally the larger generation turbines</li> <li>• Load Interruption – DARD can also qualify</li> </ul>


Reference: Introduction to Wholesale Electricity Markets (WEM 101) - Reserve Market Overview  
[http://www.iso-ne.com/support/training/courses/wem101/17\\_reserve\\_market\\_overview\\_likover.pdf](http://www.iso-ne.com/support/training/courses/wem101/17_reserve_market_overview_likover.pdf)

# Fuel Price Forecast – EIA’s 2015 AEO Base



# Monthly Gas Price Profile

January, February and December gas prices equal residual oil in each year (\$/MBtu)



# Questions

