

Preliminary Results for 2010 Economic Study Request

Planning Advisory Committee
February 16, 2011

Wayne Coste
Principal Engineer

Overview

- Economic studies are performed under ISO New England's Open Access Transmission Tariff (OATT), Attachment K process (FERC Order 890)
 - ISO performs up to three economic planning studies each year
 - 2010 NESCOE request encompasses the breadth of requests
- Study Assumptions
 - Several “high level” scenarios were defined as the initial phase of the analysis
 - 2009 Governors' Study Assumptions adopted as the basic framework for base case
 - Refinement of assumptions developed as available

Assumptions

- Assumptions and process discussed at previous PAC meetings

May 25 PAC Meeting: Process

http://www.iso-ne.com/committees/comm_wkgrps/prtcpnts_comm/pac/mtrls/2010/may252010/eco_study_requests.pdf

June 16 PAC Meeting: Assumptions

http://www.iso-ne.com/committees/comm_wkgrps/prtcpnts_comm/pac/mtrls/2010/jun162010/economic_studies.pdf

July 15 PAC Meeting: Assumptions

http://www.iso-ne.com/committees/comm_wkgrps/prtcpnts_comm/pac/mtrls/2010/jul152010/eco_study_assumptions.pdf

Framework for Analysis


- Build off of the 2009 Governors' Study
 - Evaluate hypothetical New England system in 2030
- Supply resources considered
 - Energy Efficiency and Active Demand Resources
 - Wind generation modeling
 - Based on ISO New England Queue
 - New England Wind Integration Study Profile and Locations (NEWIS)
 - Combined-cycle resources
 - Canadian imports
 - Solar and biomass
- Replace existing carbon-heavy resources

NEWIS and the 2010 Economic Study Requests

- The purpose of ISO New England's New England Wind Integration Study (NEWIS) is:
 - To evaluate the **operational impacts** of a range of hypothetical large-scale wind-integration scenarios
 - The need to forecast wind energy
 - The need for flexible resources to balance the increased variability in “net load” due to increased wind generation
- Economic study requests provide a forum for stakeholder discussions of alternative future system scenarios
 - Results include production cost, load serving entity expenses, congestion, environmental emissions, and other metrics
 - Show potential effects of alternative resource mixes and relieving transmission constraints

Load Forecast

- Summer peak load for (nominal) 2030 assumed 34,300 MW
 - 2009 Governor's Study was 200 MW higher at 34,500 MW
 - With an 11.3% reserve margin, Installed Capacity Requirement (ICR) would be 38,200 MW



Interfaces

- Interfaces to be evaluated two ways
 - Unconstrained transmission
 - Energy Initiatives Group (EIG) transmission expansion assumed to create unconstrained transmission system for integrating new wind resources, Canadian imports and Joint Coordinated System Plan (JCSP) alternatives
 - Constrained using 2009 Regional System Plan (RSP09) interface limit assumptions
 - RSP09 assumptions include
 - New England East West Solution (NEEWS)
 - Maine Power Reliability Program (MPRP) Note: changes not quantified
 - Remaining constraints likely to impede delivery of energy

Note: RSP10 assumptions are the same as RSP09

Base Interface Limits

| Single-Value Summer Peak Transmission Interface Limits for Use in Subarea Transportation Models | | | | | | | | | |
|---|-----------------------|----------|----------|----------|----------|----------|----------|----------|----------|
| Interface | 2010 | 2011 | 2012 | 2013 | 2014 | 2015 | 2016 | 2017 | 2018 |
| New Brunswick-New England | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 | 1000 |
| Orrington South Export | 1200 | 1200 | 1200 | 1200 | 1200 | 1200 | 1200 | 1200 | 1200 |
| Surowiec South | 1150 | 1150 | 1150 | 1150 | 1150 | 1150 | 1150 | 1150 | 1150 |
| Maine-New Hampshire | 1600 | 1575 | 1550 | 1525 | 1500 | 1475 | 1450 | 1450 | 1450 |
| Wyman Bigelow Export | 350 MW Assumed -----> | | | | | | | | |
| Northern NH to Southern NH | 9999 | 9999 | 9999 | 9999 | 9999 | 9999 | 9999 | 9999 | 9999 |
| North-South | 2700 | 2700 | 2700 | 2700 | 2700 | 2700 | 2700 | 2700 | 2700 |
| Boston Import | 4900 | 4900 | 4900 | 4900 | 4900 | 4900 | 4900 | 4900 | 4900 |
| SEMA Export | No Limit | No Limit | No Limit | No Limit | No Limit | No Limit | No Limit | No Limit | No Limit |
| SEMA/RI Export | 3000 | 3000 | 3000 | 3000 | 3300 | 3300 | 3300 | 3300 | 3300 |
| East-West | 2800 | 2800 | 2800 | 2800 | 3500 | 3500 | 3500 | 3500 | 3500 |
| Connecticut Import | 2500 | 2500 | 2500 | 2500 | 3600 | 3600 | 3600 | 3600 | 3600 |
| Southwest Connecticut Import | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 | 3200 |
| Norwalk / Stamford | 1650 | 1650 | 1650 | 1650 | 1650 | 1650 | 1650 | 1650 | 1650 |
| Cross-Sound Cable (CSC) (Out) | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 | 330 |
| Cross-Sound Cable (CSC) (In) | 346 | 346 | 346 | 346 | 346 | 346 | 346 | 346 | 346 |
| NY-NE Summer | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |
| NY-NE Winter | 1875 | 1875 | 1875 | 1875 | 1875 | 1875 | 1875 | 1875 | 1875 |
| NE-NY Summer | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |
| NE-NY Winter | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |
| HQ-NE (Highgate) | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 | 200 |
| HQ-NE (Phase II) | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 | 1400 |




Pre-Specified Profiles for Selected Resource Types


- Wind
 - Meteorologically co-occurring wind / loads based on NEWIS data
 - ME-BHE (On-shore)
 - ME-CMP (On-shore)
 - NH (On-shore)
 - RI (Off-shore)
 - SEMA (Off-shore)
 - VT (On-shore)
 - WEMA (On-shore)
- Canadian hydro imports (65% capacity factor)
- Solar based on co-occurring insolation (Thompson Island)
- Energy Efficiency is a discrete “supply side” resource
 - 38% in west side of East / West interface (based on load share)
 - 62% in east side of East / West interface (based on load share)

Full Build-out of Wind in the Queue

Total: 4.36 GW (*Base case for 2010 study*)

| State | Onshore | | | Offshore | | | Capacity Factor (%) | | |
|-------|------------|-----------------|--------------|------------|-----------------|--------------|---------------------|-----------|-------|
| | Site Count | Name Plate (GW) | Energy (GWh) | Site Count | Name Plate (GW) | Energy (GWh) | On shore | Off shore | Total |
| CT | - | - | - | - | - | - | 0% | 0% | 0% |
| ME | 30 | 2.888 | 8,043 | - | - | - | 32% | 0% | 32% |
| MA | 2 | 0.044 | 135 | 1 | 0.460 | 1,615 | 35% | 40% | 40% |
| NH | 5 | 0.400 | 1,290 | - | - | - | 37% | 0% | 37% |
| RI | - | - | - | 1 | 0.360 | 1,295 | 0% | 41% | 41% |
| VT | 5 | 0.209 | 584 | - | - | - | 32% | 0% | 32% |
| Total | 42 | 3.541 | 10,053 | 2 | 0.820 | 2,910 | 32% | 41% | 34% |




-  Partial Queue
-  Additional Queue
-  Additional to 20% Energy




1.5GW Offshore + Remainder Best Onshore + Full Queue

Total: 8.79 GW (*New England renewables for 2010 study*)

| State | % Energy by State | Onshore | | | Offshore | | | Capacity Factor (%) | | |
|-------|-------------------|------------|-----------------|--------------|------------|-----------------|--------------|---------------------|-----------|-------|
| | | Site Count | Name Plate (GW) | Energy (GWh) | Site Count | Name Plate (GW) | Energy (GWh) | On shore | Off shore | Total |
| CT | 0% | - | - | - | - | - | - | 0% | - | 0% |
| ME | 115% | 33 | 3.377 | 9,619 | 4 | 1.500 | 5,169 | 33% | 39% | 35% |
| MA | 9% | 2 | 0.044 | 135 | 2 | 1.498 | 5,800 | 35% | 44% | 44% |
| NH | 19% | 8 | 0.647 | 2,096 | - | - | - | 37% | 0% | 37% |
| RI | 44% | - | - | - | 7 | 1.513 | 5,657 | 0% | 43% | 43% |
| VT | 7% | 5 | 0.209 | 584 | - | - | - | 32% | 0% | 32% |
| Total | 20% | 48 | 4.278 | 12,435 | 13 | 4.511 | 16,625 | 33% | 42% | 38% |

-  Partial Queue
-  Additional Queue
-  Additional to 20% Energy



Solar PV Model


- Capturing PV volatility was viewed as important
- Developed a time stamped, chronological solar PV profile
 - Limited data sources for 2006
 - Thompson Island
 - Near Boston
 - Single site is a drawback due to lack of diversity
 - Approach is consistent with wind model generator output, but concentrated at a single location
- Temperature effect was identified as a factor to consider
 - PV output reduced with higher ambient temperature
 - New England demand tends to increase at higher temperatures

Temperature Adjustments for PV

- Temperature effect referenced to 25 deg C
 - Approximate adjustment for planning purposes
 - This study is not a PV design exercise for a specific facility
- Overall temperature degradation factor is 89 percent
 - Estimated PC plate temp: $T_{\text{plate}} = T_{\text{ambient}} * (1 + \text{Sunlight Factor})$
where: $\text{Sunlight Factor} = \text{Sunlight}_h / \text{Sunlight}_{\text{max in year}}$
 - For each degree C, the efficiency degrades 0.5 percent
 - Assumed linear over entire temperature range
 - Below 25 degrees C the efficiency is better than nominal
 - Above 25 degrees C the efficiency is lower than nominal
- $F(t) = 89 \text{ percent} * \{ (T_{\text{plate}} - 25) * (0.5/100) \}$
- For Thompson Island, $\sum F(t)$ averages to 89 percent


PV Temperature Adjustment Factor

Solar Array Temperature Effect Assumed Heat Related Efficiency Factor Annual for Thompson Island Data is 89 percent




Hourly Chronological PV w/o Temperature Adjustment Factor

2006 Raw Pyrometer Data




Hourly Chronological PV with Temperature Adjustment Factor


2006 PV with Temperature Effect



PV Affects Net Loads to be Served



August Peak Week: RTEG and Active DR



Cases and Sensitivities

Cases Considered

(Base case and non-renewables cases)

| | Case | Description |
|-------|----------------------------------|--|
| 1 | Base | <p>One Year 2030 Only; All resources in with no retirements</p> <ul style="list-style-type: none"> All resources in with no retirements Passive Demand Resources (EE) of 5,000 MW (14.7 percent of peak; note 21.4 percent of N.E. energy) Active Demand Resources of 4,300 MW (14.7 percent after EE) Real Time Emergency Generation of 800 MW No Additional purchases from Canada or New York No Additional purchases from assumed EIPC renewable resources Wind expansion from NEWIS "Full Queue Build-Out" CO2 Allowance Price at \$10/ton |
| 2 | Base – Natural Gas | Same as "Base" except add 1,500 MW of new efficient natural gas combined cycle (CC) units in place of the NEWIS "Full Queue Build-Out" wind capacity. This replaces the energy from those wind resources |
| 3 | Base – Plug-in Electric Vehicles | Same as "Base" except add 3,000 MW for 1.8 million PEVs |
| 4 | Base – Higher CO2 | Same as "Base" except CO2 Allowance Price at \$40/ton |
| 5 | Base – Natural Gas - Higher CO2 | Same as "Base - Natural Gas" except CO2 Allowance Price at \$40/ton |
| 6 | Retire Coal | Same as "Base" except 2518 MW of coal units older than 50 years old will be retired and replaced with an equal amount of repowered gas combined cycle (CC) with 8500 Btu/kWh heat rate |
| 7 | Retire Residual Oil | Same as "Base" except 6,006 MW of residual oil units older than 50 years old will be retired and replaced with an equal amount of repowered gas combined cycle (CC) with 8500 Btu/kWh heat rate |
| 8 | Retire Carbon-Heavy | Same as "Base" except 8,523 MW of carbon heavy older than 50 years old will be retired and replaced with an equal amount of repowered gas combined cycle (CC) with 8500 Btu/kWh heat rate |
| 6_ACC | Retire Coal | Same as "Base" except 2518 MW of coal units older than 50 years old will be retired and replaced with an equal amount of new efficient advanced gas combined cycle (ACC) with 6500 Btu/kWh heat rate |
| 7_ACC | Retire Residual Oil | Same as "Base" except 6,006 MW of residual oil units older than 50 years old will be retired and replaced with an equal amount of new efficient advanced gas combined cycle (ACC) with 6500 Btu/kWh heat rate |
| 8_ACC | Retire Carbon-Heavy | Same as "Base" except 8,523 MW of carbon heavy older than 50 years old will be retired and replaced with an equal amount of new efficient advanced gas combined cycle (ACC) with 6500 Btu/kWh heat rate |

Cases Considered (Expanded Renewables)

Revised

| | <i>Case</i> | <i>Description</i> |
|----|---|---|
| 9 | <i>New England Renewables and Imports – wind weighted</i> | <i>Same as "Base" except 8,523 MW of carbon heavy units older than 50 years old will be replaced by a percentage (X%) of New England wind (1.5 GW Off-shore, + Remainder Best On-Shore plus Full Queue, totaling 8.79 GW), photovoltaic (1000 MW), biomass (500 MW), plus imported energy from Canada (3000 MW from two new 1,500 MW DC transmission lines) Note: that X% is 158% for an installed amount of 13,885 MW of wind which is documented later.</i> |
| 10 | <i>New England Renewables and Imports – import weighted</i> | <i>Same as "Base" except 8,523 MW of carbon heavy units older than 50 years old will be replaced by a percentage (Y%) of New England wind (1.5 GW Off-shore, + Remainder Best On-Shore plus Full Queue, totaling 8.79 GW), photovoltaic (1500 MW) biomass (500 MW), plus imported energy from Canada (6000 MW from four new 1,500 MW DC transmission lines) Note: that Y% is 26% for an installed amount of 2,285 MW of wind which is documented later.</i> |
| 11 | <i>New England Renewables and Imports – solar weighted</i> | <i>Same as "Base" except 8,523 MW of carbon heavy units older than 50 years old will be replaced by New England wind (1.5 GW Off-shore, + Remainder Best On-Shore plus Full Queue, totaling 8.79 GW), a percentage (Z%) of photovoltaic (3000 MW), biomass (500 MW), plus imported energy from Canada (3000 MW from two new 1,500 MW DC transmission lines) Note: that Z% is 153% for an installed amount of 4,600 MW of PV which is documented later.</i> |

Retirement Scenarios

- Resource retirement assumptions
 - Approach to coal, residual oil, and all carbon heavy (coal and oil) unit retirements
 - Retirement of units over 50 years old as of 2030
 - Retired resources replaced with Natural Gas Combined Cycle
 - Repowered as a combined cycle with a heat rate of 8500 Btu/kWh
 - Advanced Combined Cycle (ACC) with a heat rate of 6500 Btu/kWh
 - Renewable cases assume all retired resources replaced by:
 - Wind,
 - Solar PV
 - Biomass from New England
 - Imports from Eastern Canada (Hydro)
 - Renewable ‘capacity’ added adjusted to “*equal*” retired capacity (this is a highly approximate estimate)

Carbon Heavy Resources Assumed to be Replaced

| ASSET ID | Year | Generator Name | Summer (MW) | Coal-or-Not | Primary Fuel Category | Alternate Fuel Category | Decade Total | Fuel Total |
|----------|------|---------------------|-------------|-------------|-----------------------|-------------------------|--------------|------------|
| 551 | 1952 | SALEM HARBOR 1 | 82.0 | Coal | BIT | FO6 | | |
| 552 | 1952 | SALEM HARBOR 2 | 80.0 | Coal | BIT | FO6 | | |
| 556 | 1952 | SCHILLER 4 | 47.5 | Coal | BIT | FO6 | | |
| 558 | 1957 | SCHILLER 6 | 47.9 | Coal | BIT | FO6 | | |
| 553 | 1958 | SALEM HARBOR 3 | 149.8 | Coal | BIT | FO6 | | |
| 577 | 1959 | SOMERSET 6 | 109.1 | Coal | BIT | | 516.3 | |
| 498 | 1960 | MT TOM | 143.6 | Coal | BIT | | | |
| 489 | 1961 | MERRIMACK 1 | 112.5 | Coal | BIT | | | |
| 350 | 1963 | BRAYTON PT 1 | 228.2 | Coal | BIT | NG | | |
| 351 | 1964 | BRAYTON PT 2 | 225.8 | Coal | BIT | NG | | |
| 340 | 1968 | BRIDGEPORT HARBOR 3 | 380.0 | Coal | BIT | FO6 | | |
| 490 | 1968 | MERRIMACK 2 | 320.0 | Coal | BIT | | | |
| 352 | 1969 | BRAYTON PT 3 | 591.5 | Coal | BIT | NG | 2001.6 | 2517.9 |
| 493 | 1954 | MONTVILLE 5 | 81.0 | Not-Coal | FO6 | NG | | |
| 1694 | 1957 | WEST SPRINGFIELD 3 | 94.3 | Not-Coal | NG | FO2 | | |
| 639 | 1957 | YARMOUTH 1 | 51.8 | Not-Coal | FO6 | | | |
| 480 | 1958 | MIDDLETOWN 2 | 117.0 | Not-Coal | FO6 | NG | | |
| 640 | 1958 | YARMOUTH 2 | 51.1 | Not-Coal | FO6 | | 395.2 | |
| 519 | 1960 | NORWALK HARBOR 1 | 162.0 | Not-Coal | FO6 | | | |
| | 1961 | BRIDGEPORT HARBOR 2 | 130.5 | Not-Coal | FO6 | | | |
| 520 | 1963 | NORWALK HARBOR 2 | 168.0 | Not-Coal | FO6 | | | |
| 481 | 1964 | MIDDLETOWN 3 | 236.0 | Not-Coal | FO6 | NG | | |
| 641 | 1965 | YARMOUTH 3 | 115.5 | Not-Coal | FO6 | | | |
| 365 | 1968 | CANAL 1 | 550.4 | Not-Coal | FO6 | | 1362.4 | |
| 494 | 1971 | MONTVILLE 6 | 407.4 | Not-Coal | FO6 | | | |
| 554 | 1972 | SALEM HARBOR 4 | 436.8 | Not-Coal | FO6 | | | |
| 482 | 1973 | MIDDLETOWN 4 | 400.0 | Not-Coal | FO6 | | | |
| 353 | 1974 | BRAYTON PT 4 | 422.0 | Not-Coal | FO6 | NG | | |
| 508 | 1974 | NEWINGTON 1 | 400.2 | Not-Coal | FO6 | NG | | |
| 502 | 1975 | MYSTIC 7 | 577.6 | Not-Coal | NG | FO6 | | |
| 513 | 1975 | NEW HAVEN HARBOR | 447.9 | Not-Coal | FO6 | NG | | |
| 366 | 1976 | CANAL 2 | 553.0 | Not-Coal | FO6 | NG | | |
| 642 | 1978 | YARMOUTH 4 | 603.5 | Not-Coal | FO6 | | 4248.4 | 6006.0 |
| | | | 8523.9 | | | | 8523.9 | 8523.9 |

Three Renewable Cases with Focus on Different Technologies

- Renewable Case: Weighted for Wind
 - 3,000 MWs Canadian imports
 - New England resources
 - 1,000 MW solar, 500 MW biomass, remainder from wind (increase)
- Renewable Case: Weighted for Canadian Imports
 - 6,000 MWs Canadian imports
 - New England resources
 - 1,500 MW solar, 500 MW biomass, remainder from wind (decrease)
- Renewable Case: Weighted for Solar
 - 3,000 MW Canadian imports
 - New England resources
 - 4,600 MW solar, 500 MW biomass, 8.79 GW of Wind

Development of Renewable Expansion to Replace Retirements

- Renewable scenarios are designed to consider:
 - Retirement of existing “carbon heavy” resources
 - Replacement with various renewable technologies
 - Wind “weighted” scenario
 - Import (hydro) “weighted” scenario
 - Solar photovoltaic “weighted” scenario
 - Conceptually replace the capacity equivalent amount of retired capacity with renewable capacity
 - Assume capacity values based on:
 - 90% for steam / biomass units
 - 39.4% for solar photovoltaic (based on reliability hour calculation)
 - 27.6% for composite wind (based on reliability hour calculation)
 - 100% for imports from Canada

Development of Renewable Expansion to Replace Retirements (Case 09)

- Retirement of 8523 MW of “carbon heavy” –7671 MW
- Addition of 500 MW of biomass + 450 MW
- Addition of 3000 MW of imports +3000 MW
- Addition of 1000 MW of photovoltaic + 394 MW
- Addition of 13,885 MW of wind +3832 MW
 - Note: For the ‘wind weighted’ case, more wind than the 8.79 GW was needed to compensate for the retirements. Therefore, 158% of the wind was assumed installed at all locations uniformly.
 - For the ‘import weighted’ case, 26% of 8.79 GW was needed
 - For the ‘solar weighted’ case, 4600 MW of PV was needed


Development of Renewable Expansion to Replace Retirements - Summary

| | | Case 9 | Case 10 | Case 11 |
|--------------------------|------------------------------|---------------|-----------------|----------------|
| | | Wind Weighted | Import Weighted | Solar Weighted |
| Retirements | Installed Capacity (MW) | -8523 | -8523 | -8523 |
| | Capacity Value (pu) | 0.900 | 0.900 | 0.900 |
| | Equivalent Capacity (MW) | -7671 | -7671 | -7671 |
| Biomass | Installed Capacity (MW) | 500 | 500 | 500 |
| | Capacity Value (pu) | 0.900 | 0.900 | 0.900 |
| | Equivalent Capacity (MW) | 450 | 450 | 450 |
| Solar PV | Installed Capacity (MW) | 1000 | 1500 | 4600 |
| | Capacity Value (pu) | 0.394 | 0.394 | 0.394 |
| | Equivalent Capacity (MW) | 394 | 591 | 1812 |
| Hydro Imports | Installed Capacity (MW) | 3000 | 6000 | 3000 |
| | Capacity Value (pu) | 1.000 | 1.000 | 1.000 |
| | Equivalent Capacity (MW) | 3000 | 6000 | 3000 |
| Wind | NEWIS 8.79 GW Case (M) | 8788 | 8788 | 8788 |
| | Wind Multiplier | 1.580 | 0.260 | 1.000 |
| | Installed Capacity (MW) | 13885 | 2285 | 8788 |
| | Capacity Value (pu) | 0.276 | 0.276 | 0.276 |
| | Equivalent Capacity (MW) | 3832 | 631 | 2425 |
| Summary | Carbon Heavy Retirement (MW) | -7671 | -7671 | -7671 |
| | Addition Biomass (MW) | 450 | 450 | 450 |
| | Addition: PV (MW) | 394 | 591 | 1812 |
| | Addition: Hydro Imports (MW) | 3000 | 6000 | 3000 |
| | Addition: Wind (MW) | 3832 | 631 | 2425 |
| Net Capacity Change (MW) | | 6 | 1 | 17 |

Sensitivity Cases

- Base Case with unconstrained transmission
- Constrained transmission sensitivity
- “Higher” fuel prices with unconstrained transmission
 - U.S. DOE *2009 Annual Energy Outlook* fuel price as base price
 - ISO doubled natural gas and increased oil-based fuels


Fuel Price Forecast – 2009 Annual Energy Outlook (AEO) Base



Fuel Price Forecast – High Sensitivity

| Multiplier | Fuel |
|------------|---------------------|
| 1.00 | Coal |
| 2.00 | Natural Gas |
| 1.75 | Distillate Fuel Oil |
| 1.50 | Residual Fuel Oil |
| 1.00 | Biomass |
| 1.00 | Nuclear |

Higher New England Fuel Price Sensitivity



Evaluation Metrics


Metrics and Sensitivities

- Metrics
 - Economic (Production Cost, LSE Energy Expense, Congestion)
 - Environmental
 - Fuel consumption/energy by fuel type
 - Congestion (FTR / ARR)
 - Resource revenues from the energy market
- Sensitivities modeled to show impact of
 - Transmission constraints
 - High fuel prices
 - Maritimes energy flows (Labrador Hydro and Maritimes nuclear could be considered part of several new 1,500 MW DC lines)

Fuel Consumption Metric


- Generation (GWh and percent) by fuel type
 - Wind and Demand Resources have no associated MBtus
 - Shows amount of energy assumed to be served by
 - Energy Efficiency
 - Active Demand Resources
 - Wind
 - PV
 - Hydro / Pumped Storage
 - Coal
 - Nuclear
 - Natural Gas
 - Net Imports

Energy Generation by Fuel Type



Note: Other ("Other") is Biomass, Waste, Residual, Distillate fuels and Imports (except HQP3)


Effect of Higher Fuel Prices



Note: Other (“Other”) is Biomass, Waste, Residual, Distillate fuels and Imports (except HQP3)

Effect of Relieving Transmission Constraints


Revised



Note: Other ("■") is Biomass, Waste, Residual, Distillate fuels and Imports (except HQP3)


Annual New England Energy Clearing Prices

Revised




Annual New England LSE Energy Expense


Revised




Annual New England Production Cost




Hedgeable Congestion for all Cases




Hedgeable Congestion by Interface




Annual New England CO2 Emissions




Annual New England SO₂ Emissions




Annual New England NOx Emissions




Contributions to Fixed Costs Combined Cycle in Southern Connecticut



Contributions to Fixed Costs Inland Wind New Hampshire




Contributions to Fixed Costs Inland Wind Central Maine





Price Duration Curves for Selected Cases

Base Case vs Wind Weighted Renewable (Central Massachusetts)



Import and Solar Weighted Renewable (Central Massachusetts)




Understanding the Shape of the Price Duration Curves

- The shape of hourly clearing price duration curves for all of New England can be explained for some cases:
 - Many load modifiers are used
 - “Load Modifiers” are not dispatched
 - They are “price takers” at zero dollars per MWh
 - Wind
 - Photovoltaic
 - Hydro Imports
 - Energy efficiency / Demand Response
 - Can displace nuclear units

Understanding the Shape of the Price Duration Curves


- Distributions of Net New England Loads to be served from Legacy Generating Technologies
 - New England loads minus
 - EE/DR
 - Wind
 - PV
 - Nuclear (assumed to be 4000 MW for this graph)
 - Can show low, or negative residual
- Other load modifiers are also used
 - Function of gross loads ... not prices after wind, EE/DR, PV
 - Conventional hydro
 - Pumped storage

Net Load for 'Legacy' Generating Units Base Case



Net Load for 'Legacy' Generating Units


Renewables - Wind Focused Case



Net Load for 'Legacy' Generating Units


Renewables - Import Focused Case


Load Net of Wind, EE/DR, PV, Imports, Nuke
Import Focus Case (8800 MW Wind)



Net Load for 'Legacy' Generating Units


Renewables – Solar PV Focused Case






Appendix 1: Weekly Energy Profiles for Selected Cases and Selected Weeks (Week 11 and Peak Week)


Week 11: Case 1




Week 11: Case 2




Week 11: Case 3




Week 11: Case 4




Week 11: Case 5




Week 11: Case 6




Week 11: Case 7




Week 11: Case 8




Week 11: Case 9




Week 11: Case 10




Week 11: Case 11




Peak Week: Case 1




Peak Week: Case 2




Peak Week: Case 3




Peak Week: Case 4




Peak Week: Case 5




Peak Week: Case 6




Peak Week: Case 7




Peak Week: Case 8




Peak Week: Case 9



Peak Week: Case 10



Peak Week: Case 11



Appendix 2: Assumptions Discussed Previously

Areas Modeled

| RSP Areas | Area Name | | | Internal Areas | Area Name |
|-----------|---------------------------|--|--|----------------|--------------------------------|
| BHE | Bangor Hydro | | | DRCT | WESTERN DEMAND RESPONSE |
| BOST | Boston | | | EECT | WESTERN ENERGY EFFICIENCY |
| CMAN | Central Massachusetts | | | EGCT | WESTERN EMERGENCY GENERATION |
| CT | Connecticut | | | | |
| ME | Central Maine | | | DRMA | EASTERN DEMAND RESPONSE |
| NH | New Hampshire | | | EEMA | EASTERN ENERGY EFFICIENCY |
| N-NH | Northern New Hampshire | | | EGMA | EASTERN EMERGENCY GENERATION |
| NOR | Norwalk | | | | |
| RI | Rhode Island | | | External Areas | Area Name |
| SEMA | Southeastern Masachusetts | | | JCSP | JCSP INTERCONNECTION |
| SME | Southern Maine | | | HQHG | HQHG |
| SWCT | Southwestern Connecticut | | | HQP2 | HQ PHASE II ECONOMIC MWH |
| VT | Vermont | | | HQP3 | HQ PHASE III HYDRO OR ECONOMIC |
| WMA | Western Massachusetts | | | XSND | CROSS SOUND CABLE |
| | | | | NY | NEW YORK |
| | | | | MARI | MARITIMES |
| | | | | MPS | MPS |


Additional Wind and DR Areas Modeled For Reporting

Modeling External Areas


- Base Models for External Areas
 - No loads or resources modeled for New York, Maritimes, or Quebec
 - Existing Phase II modeled with economic opportunity blocks
 - Block 1: 300 MW at Natural Gas based on 8,400 Btu/kWh Combined Cycle (CC)
 - Block 2: 300 MW at Natural Gas based on 10,349 Btu/kWh Steam
 - Block 3: 300 MW at Distillate Fuel Oil based 12,593 Btu/kWh Combustion Turbine (CT)
 - Maritimes bubble has no loads or resources
 - Sensitivity case will investigate the effect of Maritimes
 - Maine Public Service (MPS) modeled using a BHE load shape
 - Connected via the Maritimes bubble
 - Limited number of resource
 - 100 MW Cross Sound Cable export assumed
 - NYPA purchases assumed to continue
 - Vermont Joint Owners (VJO) purchases assumed to continue

Canadian Hydro Imports

- Assumed 65.0% capacity factor
 - Consistent with 2007 Scenario Analysis
 - Peak-shaving bias for energy deliveries
 - 8.5 TWh of energy is comparable to Firm Energy Contract (7 TWh)
 - Several lines (~1,500 MW each) added to supplement other resources required for the retirement of carbon heavy resources



Energy Efficiency (EE) / Demand Resources (DR) / Real-Time Emergency Generation (RTEG) Load Modifiers (Base Case)



Wind Models


- Based on NEWIS
 - New England sites
 - Neighboring area sites
- Multiple wind models have been developed
 - Hourly granularity
 - Site specific (aggregated to an RSP bubble)
 - Correlated to meteorology present in the loads
 - Intention
 - Not intended to be estimates for specific project
 - Intended to be regional estimates

Wind Profiles Based on NEWIS Profiles


Hourly Profile (to be used in the simulations)

Smoothed Hourly Profile (conceptual visualization)

Offshore: SEMA



Offshore: SEMA (rolling 24 hour average)




Offshore wind energy production: 42 percent capacity factor

Wind Profiles Based on NEWIS Profiles


Hourly Profile (to be used in the simulations)

Smoothed Hourly Profile (conceptual visualization)

On-shore: BHE




On-shore: BHE (rolling 24 hour average)




Onshore wind energy production: 34 percent capacity factor

Thompson Island Diurnal Monthly Insolation Profiles 2006



Higher Temperatures Derate PV Resources



Plug-in Electric Vehicles

- Sensitivity case assumes 1.8 Million Plug-in Electric Vehicles (PEVs) by 2030
 - Maximum charging of 3000 MW after midnight
 - Charging load diminishes to zero MW by 8 AM
 - No discharging energy from vehicles to grid assumed

