

NEPOOL Participants Committee Report

April 2014



Vamsi Chadalavada

EXECUTIVE VICE PRESIDENT AND CHIEF OPERATING OFFICER



Table of Contents

| | | |
|--|-------------|------------|
| • Highlights | Page | 3 |
| • System Operations | Page | 8 |
| • Market Operations | Page | 21 |
| • Back-Up Detail | Page | 35 |
| – Load Response | Page | 36 |
| – New Generation | Page | 38 |
| – Forward Capacity Market | Page | 45 |
| – Reliability Costs - Net Commitment Period Compensation (NCPC) Operating Costs | Page | 51 |
| – Regional System Plan (RSP) & Interregional Planning | Page | 82 |
| – Operable Capacity Analysis – Winter 2014 | Page | 99 |
| – Operable Capacity Analysis – Preliminary Summer 2014 | Page | 106 |
| – Operable Capacity Analysis – Appendix | Page | 113 |

Highlights

- Day-Ahead (DA), Real-Time (RT) Prices and Transactions
 - March natural gas prices over the period were 19.3% lower, while oil prices were 0.3% lower than February 2014 average values
 - Average RT Hub Locational Marginal Prices (LMPs) over the period were 17.6% lower than February 2014 averages
 - Average March 2014 natural gas prices and RT Hub LMPs were up 149% and 133%, respectively, from March 2013 averages
- Average daily (peak hour) DA cleared physical energy as percent of forecasted load was 98.6% in March and 98.4% in February

All data through March 26, unless otherwise noted.

*DA Cleared Physical Energy is the sum of Generation and Net Imports cleared in the DA Energy Market

Underlying natural gas data furnished by:



Highlights, cont.

- Daily Net Commitment Period Compensation (NCPC)*
 - March payments totaled \$16.8M, up \$673K from February
 - First Contingency payments totaled \$15.0M, up \$322K from February
 - \$11.6M paid to internal resources, down \$241k from February
 - \$5.5M charged to DALO, \$6.1M to RT Deviations
 - \$3.4M paid to resources at external locations, up \$563K from February
 - \$3.4M charged to DALO at external locations, \$15K to RT Deviations
 - Second Contingency payments totaled \$1.8M, up \$344K from the February total of \$1.5M
 - Voltage payments were \$0, unchanged from February
 - Distribution payments totaled \$9K, up \$6K from February
 - NCPC payments over the period as percent of Energy Market value were 1.3%

*Total includes NCPC payments to eligible resources at external locations.

Highlights, cont.

- The lowest 50/50 and 90/10 Spring Operable Capacity Margin is projected for week beginning May 17th.
- The lowest 50/50 and 90/10 Summer Operable Capacity Margin is projected for weeks beginning May 31st, June 7th, June 14th.



Highlights, cont.

- The final interim photovoltaic forecast will be discussed with the Distributed Generation Forecast Working Group on April 2
- The draft Northeast Coordinated System Plan was discussed with the Inter-Area Planning Stakeholder Advisory Committee on March 28. Final stakeholder comments are due by April 8.
- Economic Study requests are due to ISO by April 1
- Work continues on identifying capacity zones for the ninth Forward Capacity Auction (FCA #9)
- Initial meeting of the Variable Resource Working Group is scheduled for April 17 in Springfield, MA

Highlights, cont.

Forward Capacity Market Update

- CCP #5
 - Annual Reconfiguration Auction #3 (ARA-3) was held March 3-5 and results were posted on March 19
- CCP #6 (2015-2016)
 - ARA-2 Bilateral Period to open on May 1 and close on May 7
- CCP #7 (2016-2017)
 - ARA-1 Bilateral Period to open on April 1 and close on April 7
- CCP #8 (2017-2018)
 - A supplemental filing was made on March 25 indicating that Groton Wind received a capacity supply obligation in accordance with the tariff
- CCP #9 (2018-2019)
 - On January 31, the ISO submitted tariff changes related to the modeling of capacity zones. FERC has yet to approve those changes.
 - Discussions with the PAC continue regarding zones to be modeled for FCA #9. Final list of zones to be determined by the April/May time frame.
 - Show of Interest window closed on March 4

CCP – Capacity Commitment Period

SYSTEM OPERATIONS

System Operations

| | | | | |
|--------------------------------|--------|--|----------|--|
| <u>Weather Patterns</u> | Boston | Temperature – Below Average (-6.3) Max - 60, Min - 11 Precipitation 3.55” (Liquid) Below Average Normal 3.85” Snowfall = 1.30” | Hartford | Temperature – Below Average (-7.8) Max - 59, Min - 0 Precipitation 3.77” (Liquid) – Below Average Normal = 3.88” Snowfall = 1.92” |
|--------------------------------|--------|--|----------|--|

| | | | |
|--------------------------|-----------|---------------|-------|
| <u>Peak Load:</u> | 19,700 MW | March 3, 2014 | 19:00 |
|--------------------------|-----------|---------------|-------|

| | | | |
|----------------------|---------------|--------------------|----------|
| <u>MLCC2:</u> | | | |
| 3/4/2014 | 12:30 – 20:00 | All of New England | Capacity |

OP-4: None

| | | |
|---|--------|--------|
| <u>NPCC Simultaneous Activation of Reserve Events:</u> | | |
| 03/01/14 | PJM | 800MW |
| 03/03/14 | ISO-NE | 557MW |
| 03/04/14 | NYISO | 1290MW |
| 03/10/14 | NYISO | 1290MW |
| 03/14/14 | IESO | 800MW |

System Operations

Minimum Generation Warnings & Events:

| | | |
|---------------------------------|---------------------|--|
| Minimum Generation Warning | 03/09/14 | Start - 04:00, Expired - 08:00 Interchange Cuts Only |
| Minimum Generation Warning | 03/09/14 | Start - 15:00, Expired - 18:00 Interchange Cuts Only |
| Minimum Generation Warning | 03/10/14 | Start - 04:00, Expired - 07:00 Interchange Cuts & SS Denied |
| Minimum Generation Warning | 03/10/14 – 03/11/14 | Start - 23:00, Expired - 07:00 Interchange Cuts Only |
| Minimum Generation Warning | 03/11/14 | Start - 15:00, Expired - 18:00 SS Denied Only |
| Minimum Generation Warning | 03/11/14 | Start - 23:00, Expired - 23:59 No Actions Taken |
| Minimum Generation Warning | 03/12/14 | Start - 00:01, Expired - 08:00 Interchange Cuts & SS Denied |
| Minimum Generation Warning | 03/12/14 | Start - 09:00, Expired - 17:00 No Actions Taken |
| Minimum Generation Warning | 03/12/14 – 03/13/14 | Start - 21:00, Expired - 07:00 Interchange Cuts & SS Denied |
| Minimum Generation Warning | 03/15/14 | Start - 14:00, Expired - 19:00 Interchange Cuts Only |
| Minimum Generation <u>Event</u> | 03/15/14 | Start - 07:16, Expired - 19:00 Interchange Cuts Only |

System Operations

Minimum Generation Warnings & Events: Continued

| | | |
|---------------------------------|---------------------|--|
| Minimum Generation Warning | 03/15/14 – 03/16/14 | Start - 23:00, Expired - 09:00 Interchange Cuts & SS Denied |
| Minimum Generation <u>Event</u> | 03/16/14 | Start – 00:01, Expired - 04:00 Interchange Cuts Only |
| Minimum Generation <u>Event</u> | 03/16/14 | Start – 07:05, Expired - 09:00 No Actions Taken |
| Minimum Generation Warning | 03/16/14 | Start - 16:00, Expired - 20:00 SS Denied Only |
| Minimum Generation Warning | 03/19/14 – 03/20/14 | Start - 22:00, Expired - 06:00 Interchange Cuts Only |
| Minimum Generation Warning | 03/20/14 – 03/21/14 | Start - 23:00, Expired - 06:00 Interchange Cuts & SS Denied |
| Minimum Generation Warning | 03/21/14 | Start - 23:00, Expired - 23:59 Interchange Cuts Only |
| Minimum Generation Warning | 03/22/14 | Start – 00:01, Expired - 07:00 Interchange Cuts & SS Denied |
| Minimum Generation Warning | 03/22/14 | Start – 18:00, Expired – 19:00 No Actions Taken |
| Minimum Generation Warning | 03/22/14 – 03/23/14 | Start – 22:00, Expired – 10:00 Interchange Cuts Only |
| Minimum Generation <u>Event</u> | 03/23/14 | Start – 00:01, Expired – 08:30 Interchange Cuts Only |

System Operations

Minimum Generation Warnings & Events: Continued

| | | |
|-----------------------------------|----------------------------|---|
| Minimum Generation Warning | 03/24/14 | Start – 00:01, Expired - 06:00 No Actions Taken |
| Minimum Generation Warning | 03/29/14 | Start – 01:00, Expired - 06:00 No Actions Taken |
| Minimum Generation Warning | 03/29/14 – 03/30/14 | Start – 23:00, Expired - 10:00 Interchange Cuts & SS Denied |
| Minimum Generation Warning | 03/30/14 – 03/31/14 | Start – 23 ;00, Expired - 06:00 Interchange Cuts & SS Denied |




2014 System Operations – Load Forecast Accuracy



All Hours
Monthly Average, Daily Maximum and Minimum,
Based on forecast published by 1000 on day before Operating Day

Rest of Year Goal < 1.5%
 Summer Goal < 2.6%



Mo. Avg Day Max Day Min Summer Goal Rest of Year Goal

| | J | F | M | A | M | J | J | A | S | O | N | D | Avg |
|---------------------|------|------|------|------|------|-----|-----|-----|------|------|------|------|------|
| Mo Avg | 1.60 | 1.63 | 1.35 | | | | | | | | | | 1.52 |
| Day Max | 3.95 | 3.34 | 2.73 | | | | | | | | | | 3.34 |
| Day Min | 0.63 | 0.66 | 0.41 | | | | | | | | | | 0.56 |
| Summer Goal | | | | | | 2.6 | 2.6 | 2.6 | | | | | |
| Rest of Year Goal | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | | | | 1.50 | 1.50 | 1.50 | 1.50 | |
| Rest of year Actual | 1.60 | 1.63 | 1.35 | | | | | | | | | | 1.52 |
| Summer Actual | | | | | | | | | | | | | |

Summer Goal - 2.6%, Rest of Year Goal - 1.5%
 Summer consists of June, July & August




2014 System Operations - Load Forecast Accuracy cont.

Dashboard Indicator ●

Peak Hours
Monthly Average, Daily Maximum and Minimum
 Based on forecast published by 1000 on day before Operating Day

Rest of Year Goal < 1.5%
 Summer Goal < 2.6%



| | J | F | M | A | M | J | J | A | S | O | N | D | Avg |
|---------------------|------|------|------|------|------|-----|-----|-----|------|------|------|------|------|
| Mo Avg | 1.82 | 1.54 | 1.41 | | | | | | | | | | 1.59 |
| Day Max | 7.56 | 3.42 | 3.88 | | | | | | | | | | 5.00 |
| Day Min | 0.03 | 0.11 | 0.09 | | | | | | | | | | 0.08 |
| Summer Goal | | | | | | 2.6 | 2.6 | 2.6 | | | | | |
| Rest of Year Goal | 1.50 | 1.50 | 1.50 | 1.50 | 1.50 | | | | 1.50 | 1.50 | 1.50 | 1.50 | |
| Rest of year Actual | 1.82 | 1.54 | 1.41 | | | | | | | | | | 1.59 |
| Summer Actual | | | | | | | | | | | | | |


Summer Goal - 2.6%, Rest of Year Goal - 1.5%
 Summer consists of June, July & August

2014 System Operations - Load Forecast Accuracy

Percent of Hours Actual Load
Above vs. Below Forecast

Based on LF published by 1000, day before Operating Day

Target = 50%
Plus/Minus 5%




| | J | F | M | A | M | J | J | A | S | O | N | D | Avg |
|-----------|--------|--------|--------|---|---|---|---|---|---|---|---|---|--------|
| Above % | 48.5 | 40.2 | 46.8 | | | | | | | | | | 45.3 |
| Below % | 51.5 | 59.8 | 53.2 | | | | | | | | | | 54.7 |
| Avg Above | 167.0 | 192.0 | 139.0 | | | | | | | | | | 165.1 |
| Avg Below | -230.0 | -181.0 | -161.0 | | | | | | | | | | -191.0 |
| Avg All | -52.0 | -21.0 | -27.0 | | | | | | | | | | -33.7 |

Percent of hours that the actual load was above versus below the forecast


2014 System Operations - Load Forecast Accuracy

Deviation of Actual Load from Forecasted Load Year to Date 2014




Monthly Recorded Net Energy for Load (NEL) and Weather Normalized NEL

Net Energy for Load (NEL)




Weather Normalized NEL




NEPOOL NEL is the total net energy required to serve load for the month, in GWh. NEL is calculated as: Generation – pumping load + net interchange. Current month's data may be preliminary. Weather normalized NEL may be reported on a one-month lag.

Monthly Peak Loads and Weather Normalized Seasonal Peak History

System Peak Load



Weather Normalized Seasonal Peaks




Winter beginning in year displayed

* F – designates forecasted values, which are updated in April/May of the following year.



Wind Power Forecast Error Statistics: Mean Absolute Error (MAE)




Dashboard Indicator



Ideally, MAE and Bias would be both equal to zero. As is typical, MAE increases with the forecast horizon. MAE and Bias for the fleet of wind power resources are less due to offsetting errors. Across all time frames, the ISO-NE/GH forecast is very good compared to industry standards, and is within the yearly performance targets specified in the forecast RFP.

Wind Power Forecast Error Statistics: Bias




Dashboard Indicator 

Ideally, MAE and Bias would be both equal to zero. Positive bias means less windpower was actually available compared to forecast. Negative bias means more windpower was actually available compared to forecast. Across all time frames, the ISO-NE/GH forecast is very good compared to industry standards, and is within the yearly performance targets specified in the forecast RFP.

MARKET OPERATIONS

Daily DA and RT ISO-NE Hub Prices and Input Fuel Prices: March 1-26, 2014



Underlying natural gas data furnished by:




Average price difference over this period (DA-RT): \$-3.00

Average price difference over this period ABS(DA-RT): \$22.72

Average percentage difference over this period ABS(DA-RT)/RT Average LMP: 18%

Gas price is average of Massachusetts delivery points; No6 Oil is New York Spot Price from DOE's Energy Information Administration


DA LMPs Average by Zone & Hub, March 2014



ME - Maine
 NH - New Hampshire
 VT - Vermont
 CT - Connecticut


RI - Rhode Island
 SEMA - Southeastern Massachusetts
 WCMA - Western/Central Massachusetts
 NEMA - Northeastern Massachusetts

RT LMPs Average by Zone & Hub, March 2014



Components of Cleared DA Supply and Demand – Last Three Months


Supply



■ Gen ■ Incs
■ Imports ◇ DA Fcst Load

Gen – Generation
 Incs – Increment Offers
 DA Fcst Load – Day-Ahead Forecast Load

Demand




■ Fixed Dem ■ PrSens Dem ■ Decs
■ Losses ■ Exports ◇ Act Load

Fixed Dem – Fixed Demand
 PrSens Dem – Price Sensitive Demand
 Decs – Decrement Bids
 Act Load – Actual Load




Components of RT Supply and Demand – Last Three Months


Supply



Demand




DA Cleared Physical Energy as Percent of Forecast (peak hour): March 2014



Note: Percentages were derived for the peak hour of each day.

DA Cleared Physical Energy is the physical supply (Gen + Net Imports) cleared in the DA Market
--Analysis reflects the peak forecasted hour--


DA Cleared Physical Energy as Percent of Forecast (peak hour): February 2014



Note: Percentages were derived for the peak hour of each day.

DA Cleared Physical Energy is the physical supply (Gen + Net Imports) cleared in the DA Market
--Analysis reflects the peak forecasted hour--

DA Cleared Physical Energy as Percent of Forecast (peak hour): Last 13 Months




Note: Percentages were derived for the peak hour of each day, then averaged over the month.

DA Cleared Physical Energy is the physical supply (Gen + Net Imports) cleared in the DA Market
--Analysis reflects the peak forecasted hour--

Variable Production Cost of Fuels: Monthly


Variable Cost Comparison: Oil vs. Gas



Note: Assumes proxy heat rates of 10,100,000 Btu/MWh for oil and 7,800,000 Btu/MWh for gas units.

Variable Production Cost of Fuels: Daily


Variable Cost Comparison: Oil vs. Gas



Note: Assumes proxy heat rates of 10,100,000 Btu/MWh for oil and 7,800,000 Btu/MWh for gas units.


Hourly DA LMPs, March 1-26, 2014

Hourly Day-Ahead LMPs




Hourly RT LMPs, March 1-26, 2014

Hourly Real-Time LMPs



System Unit Availability



| Year | Jan | Feb | Mar | Apr | May | Jun | Jul | Aug | Sep | Oct | Nov | Dec | YTD |
|------|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| 2014 | 87 | 92 | 84 | | | | | | | | | | 88 |
| 2013 | 89 | 87 | 85 | 76 | 81 | 90 | 90 | 92 | 88 | 80 | 81 | 92 | 86 |
| 2012 | 93 | 92 | 88 | 75 | 83 | 93 | 95 | 95 | 91 | 76 | 80 | 89 | 88 |
| 2011 | 92 | 89 | 83 | 74 | 76 | 95 | 96 | 95 | 90 | 73 | 83 | 89 | 86 |

Data as of 3/31/14

BACK-UP DETAIL

LOAD RESPONSE

Capacity Supply Obligation (CSO) MW by Demand Resource Type for April 2014

| Load Zone | RTDR* | RTEG** | On Peak | Seasonal Peak | Total |
|--------------|---------------|---------------|---------------|---------------|-----------------|
| ME | 138.64 | 8.03 | 86.83 | 0.00 | 233.50 |
| NH | 4.13 | 13.51 | 64.72 | 0.00 | 82.37 |
| VT | 24.50 | 2.46 | 86.79 | 0.00 | 113.75 |
| CT | 86.63 | 74.82 | 80.92 | 299.33 | 541.69 |
| RI | 12.86 | 9.54 | 75.61 | 0.00 | 98.01 |
| SEMA | 9.59 | 11.34 | 111.51 | 0.00 | 132.44 |
| WCMA | 21.43 | 22.45 | 102.67 | 28.69 | 175.25 |
| NEMA | 16.23 | 21.17 | 204.55 | 0.00 | 241.94 |
| Total | 314.01 | 163.32 | 813.60 | 328.02 | 1,618.96 |

* Real Time Demand Response

** Real Time Emergency Generation

NOTE: CSO values include T&D loss factor (8%) and, as applicable, a reserve margin gross-up of either 14.3% or 16.1%, respectively, for portions of resources that selected a multi-year obligation in the FCA 1 or FCA 2. Otherwise, reserve margin gross-ups were discontinued with FCA 3.

NEW GENERATION


New Generation Update

Based on 4/1/14 Queue Update

- Seven new projects, with a total rating of 928 MW, have applied for interconnection study since the last update
 - The new projects consist of three combustion turbines, a wind project, a fuel cell, and two combined cycle facilities with expected in-service dates ranging from 2018 to 2019
- One project withdrew from the Queue, resulting in a net increase in new generation projects of 854 MW
- In total, 56 generation projects are currently being tracked by the ISO, totaling 6,900 MW



Actual and Projected Annual Capacity Additions By Supply Fuel Type and Demand Resource Type



| | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | Total MW | % of Total ¹ |
|------------------------------------|------------|------------|--------------|--------------|--------------|-----------|--------------|-------------------------|
| Demand Response - Passive | 188 | 157 | -12 | 330 | 0 | 0 | 663 | 9.9 |
| Demand Response - Active | 19 | 3 | -868 | -37 | 0 | 0 | -883 | -13.2 |
| Wind & Other Renewables | 166 | 236 | 1,479 | 360 | 0 | 85 | 2,326 | 34.7 |
| Oil | 0 | 0 | 0 | 0 | 245 | 0 | 245 | 3.7 |
| Natural Gas/Oil² | 8 | 0 | 745 | 736 | 1,008 | 0 | 2,497 | 37.3 |
| Natural Gas | 21 | 0 | 716 | 0 | 1,110 | 0 | 1,847 | 27.6 |
| Totals | 402 | 396 | 2,060 | 1,389 | 2,363 | 85 | 6,695 | 100.0 |


¹ Sum may not equal 100% due to rounding

² The projects in this category are dual fuel, with either gas or oil as the primary fuel

- Active DR value reflects the 600 MW limit on Real-Time Emergency Generation resources
- DR reflects changes from the initial FCM Capacity Supply Obligations in 2010-11

Actual and Projected Annual Generator Capacity Additions

By State



| | 2014 | 2015 | 2016 | 2017 | 2018 | 2019 | Total MW | % of Total ¹ |
|----------------------|------------|------------|--------------|--------------|--------------|-----------|--------------|-------------------------|
| Vermont | 30 | 60 | 33 | 20 | 48 | 0 | 191 | 2.8 |
| Rhode Island | 0 | 0 | 29 | 0 | 0 | 0 | 29 | 0.4 |
| New Hampshire | 89 | 65 | 0 | 0 | 0 | 0 | 154 | 2.2 |
| Maine | 52 | 93 | 868 | 340 | 0 | 85 | 1,438 | 20.8 |
| Massachusetts | 24 | 18 | 1,265 | 736 | 1,346 | 0 | 3,389 | 49.0 |
| Connecticut | 0 | 0 | 745 | 0 | 969 | 0 | 1,714 | 24.8 |
| Totals | 195 | 236 | 2,940 | 1,096 | 2,363 | 85 | 6,915 | 100.0 |

¹ Sum may not equal 100% due to rounding

New Generation Projection

By Fuel Type

| Fuel Type | Total | | Green | | Yellow | |
|--------------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) |
| Biomass/Wood Waste | 3 | 138 | 1 | 68 | 2 | 70 |
| Hydro | 5 | 62 | 0 | 0 | 5 | 62 |
| Landfill Gas | 0 | 0 | 0 | 0 | 0 | 0 |
| Natural Gas | 7 | 1,847 | 0 | 0 | 7 | 1,847 |
| Natural Gas/Oil | 11 | 2,497 | 0 | 0 | 11 | 2,497 |
| Oil | 1 | 245 | 0 | 0 | 1 | 245 |
| Solar | 3 | 16 | 2 | 10 | 1 | 6 |
| Wind | 26 | 2,110 | 4 | 77 | 22 | 2,033 |
| Total | 56 | 6,915 | 7 | 155 | 49 | 6,760 |

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel
- Green denotes projects with a high probability of going into service
- Yellow denotes projects with a lower probability of going into service or new applications

New Generation Projection

By Operating Type

| Operating Type | Total | | Green | | Yellow | |
|----------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) |
| Baseload | 4 | 144 | 1 | 68 | 3 | 76 |
| Intermediate | 13 | 3,180 | 0 | 0 | 13 | 3,180 |
| Peaker | 13 | 1,481 | 2 | 10 | 11 | 1,471 |
| Wind Turbine | 26 | 2,110 | 4 | 77 | 22 | 2,033 |
| Total | 56 | 6,915 | 7 | 155 | 49 | 6,760 |

- Green denotes projects with a high probability of going into service
- Yellow denotes projects with a lower probability of going into service or new applications

New Generation Projection

By Operating Type and Fuel Type

| Fuel Type | Total | | Baseload | | Intermediate | | Peaker | | Wind Turbine | |
|--------------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|-----------------|---------------|
| | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) | No. of Projects | Capacity (MW) |
| Biomass/Wood Waste | 3 | 138 | 3 | 138 | 0 | 0 | 0 | 0 | 0 | 0 |
| Hydro | 5 | 62 | 0 | 0 | 4 | 12 | 1 | 50 | 0 | 0 |
| Landfill Gas | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 | 0 |
| Natural Gas | 7 | 1,847 | 1 | 6 | 3 | 1,255 | 3 | 586 | 0 | 0 |
| Natural Gas/Oil | 11 | 2,497 | 0 | 0 | 6 | 1,913 | 5 | 584 | 0 | 0 |
| Oil | 1 | 245 | 0 | 0 | 0 | 0 | 1 | 245 | 0 | 0 |
| Solar | 3 | 16 | 0 | 0 | 0 | 0 | 3 | 16 | 0 | 0 |
| Wind | 26 | 2,110 | 0 | 0 | 0 | 0 | 0 | 0 | 26 | 2,110 |
| Total | 56 | 6,915 | 4 | 144 | 13 | 3,180 | 13 | 1,481 | 26 | 2,110 |

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel

FORWARD CAPACITY MARKET

Capacity Supply Obligation FCA 4

| Resource Type | Resource Type | FCA 4 | Proration | | Annual Bilateral Period 1 for ARA 2 | | ARA 2 | | Annual Bilateral Period 2 for ARA 2 | | Annual Bilateral 3 Period | | ARA 3 | |
|-----------------|------------------|------------|------------|------------|-------------------------------------|----------|------------|----------|-------------------------------------|----------|---------------------------|----------|------------|----------|
| | | *CSO | CSO | **Change | ARA 2 | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 2,051.536 | 1,860.060 | -191.476 | 1,681.032 | -179.028 | 1,482.357 | -198.675 | 1,367.357 | -115.000 | 1,021.146 | -346.211 | 700.637 | -320.509 |
| | Passive Demand | 1,297.906 | 1,154.626 | -143.280 | 1,135.705 | -18.921 | 1,163.465 | 27.760 | 1,163.465 | 0.000 | 1,123.515 | -39.950 | 1,149.743 | 26.228 |
| Demand Total | | 3,349.442 | 3,014.686 | -334.756 | 2,816.737 | -197.949 | 2,645.822 | -170.915 | 2,530.822 | -115.000 | 2,144.661 | -386.161 | 1,850.380 | -294.281 |
| Generator | Non-Intermittent | 31,161.623 | 27,655.394 | -3,506.229 | 27,839.130 | 183.736 | 28,386.625 | 547.495 | 27,890.197 | -496.428 | 28,354.572 | 464.375 | 28,812.896 | 458.324 |
| | Intermittent | 1,085.540 | 979.072 | -106.468 | 972.075 | -6.997 | 857.886 | -114.189 | 865.064 | 7.178 | 841.517 | -23.547 | 784.778 | -56.739 |
| Generator Total | | 32,247.163 | 28,634.466 | -3,612.697 | 28,811.205 | 176.739 | 29,244.511 | 433.306 | 28,755.261 | -489.250 | 29,196.089 | 440.828 | 29,597.674 | 401.585 |
| Import Total | | 1,992.600 | 1,726.449 | -266.151 | 1,726.449 | 0.000 | 1,396.258 | -330.191 | 1,396.258 | 0.000 | 1,296.258 | -100.000 | 1,182.869 | -113.389 |
| ***Grand Total | | 37,589.205 | 33,375.601 | -4,213.604 | 33,354.391 | -21.210 | 33,286.591 | -67.800 | 32,682.341 | -604.250 | 32,637.008 | -45.333 | 32,630.923 | -6.085 |

* Real-time Emergency Generators (RTEG) CSO not capped at 600.000 MW

** Change columns contains the changes in CSO amount resulting from the specific FCM Event as well as adjustments for Delisted MW released according to MR 1, Section 13.2.5.2, and changes that occurred (terminations etc.) prior to the event reported in the column.

*** Grand Total reflects both CSO Grand Total and the net total of the Change Column.

Capacity Supply Obligation FCA 5

| Resource Type | Resource Type | FCA 4 | Proration | | Annual Bilateral for ARA 2 | | ARA 2 | | Annual Bilateral for ARA 3 | | ARA 3 | |
|------------------------|------------------|-------------------|-------------------|-------------------|----------------------------|-------------------|-------------------|----------------|----------------------------|-----------------|------------------|-----------------|
| | | *CSO | CSO | **Change | ARA 2 | Change | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 2,104.141 | 2,001.126 | -103.015 | 1,385.670 | -615.456 | 1,074.461 | -311.21 | 899.125 | -175.336 | 699.930 | -199.195 |
| | Passive Demand | 1,485.713 | 1,397.586 | -88.127 | 1,345.283 | -52.303 | 1,348.593 | 3.31 | 1,365.947 | 17.354 | 1399.564 | 33.617 |
| Demand Total | | 3,589.854 | 3,398.712 | -191.142 | 2,730.953 | -667.759 | 2,423.054 | -307.90 | 2,265.072 | -157.982 | 2099.494 | -165.578 |
| Generator | Non-Intermittent | 30,558.220 | 28,337.481 | -2,220.739 | 27,917.690 | -419.791 | 28,364.588 | 446.90 | 28,517.097 | 152.509 | 28557.855 | 40.758 |
| | Intermittent | 880.737 | 827.804 | -52.933 | 778.165 | -49.639 | 795.545 | 17.38 | 795.767 | 0.222 | 718.908 | -76.859 |
| Generator Total | | 31,438.957 | 29,165.285 | -2,273.672 | 28,695.855 | -469.430 | 29,160.133 | 464.28 | 29,312.864 | 152.731 | 29276.763 | -36.101 |
| Import Total | | 2,011.001 | 1,831.372 | -179.629 | 1,831.372 | 0.000 | 1,635.835 | -195.54 | 1,635.835 | 0.000 | 1382.551 | -253.284 |
| ***Grand Total | | 37,039.812 | 34,395.369 | -2,644.443 | 33,258.180 | -1,137.189 | 33,219.022 | -39.16 | 33,213.771 | -5.251 | 32758.808 | -454.963 |

* Real-time Emergency Generators (RTEG) CSO not capped at 600.000 MW

** Change columns contain the changes in CSO amount resulting from the specific FCM Event as well as adjustments for Delisted MW released according to MR 1, Section 13.2.5.2, and changes that occurred (terminations, etc.) prior to the event reported in the column.

*** Grand Total reflects both CSO Grand Total and the net total of the Change Column.

Capacity Supply Obligation FCA 6

| Resource Type | Resource Type | FCA | Proration | | Annual Bilateral for ARA 1 | | ARA 1 | | Annual Bilateral for ARA 2 | | ARA 2 | | Annual Bilateral for ARA 3 | | ARA 3 | |
|------------------------|------------------|-------------------|-------------------|-------------------|----------------------------|-----------------|-------------------|-----------------|----------------------------|--------|-------|--------|----------------------------|--------|-------|--------|
| | | *CSO | CSO | **Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 2,001.510 | 1,918.662 | -82.848 | 1,368.608 | -550.054 | 1,271.984 | -96.624 | | | | | | | | |
| | Passive Demand | 1,643.334 | 1,553.054 | -90.280 | 1,521.535 | -31.519 | 1,521.535 | 0.000 | | | | | | | | |
| Demand Total | | 3,644.844 | 3,471.716 | -173.128 | 2,890.143 | -581.573 | 2,793.519 | -96.624 | | | | | | | | |
| Generator | Non-Intermittent | 29,866.098 | 27,957.613 | -1,908.485 | 28,121.731 | 164.118 | 28,343.440 | 221.709 | | | | | | | | |
| | Intermittent | 891.069 | 840.563 | -50.506 | 827.047 | -13.516 | 828.252 | 1.205 | | | | | | | | |
| Generator Total | | 30,757.167 | 28,798.176 | -1,958.991 | 28,948.778 | 150.602 | 29,171.692 | 222.914 | | | | | | | | |
| Import Total | | 1,924.000 | 1,768.111 | -155.889 | 1,768.111 | 0.000 | 1,641.821 | -126.290 | | | | | | | | |
| ***Grand Total | | 36,326.011 | 34,038.003 | -2,288.008 | 33,607.032 | -430.971 | 33,607.032 | 0.000 | | | | | | | | |

* Real-time Emergency Generators (RTEG) CSO not capped at 600.000 MW

** Change columns contain the changes in CSO amount resulting from the specific FCM Event as well as adjustments for Delisted MW released according to MR 1, Section 13.2.5.2, and changes that occurred (terminations, etc.) prior to the event reported in the column.

*** Grand Total reflects both CSO Grand Total and the net total of the Change Column.

Capacity Supply Obligation FCA 7

| Resource Type | Resource Type | FCA | Proration | | Annual Bilateral for ARA 1 | | ARA 1 | | Annual Bilateral for ARA 2 | | ARA 2 | | Annual Bilateral for ARA 3 | | ARA 3 | |
|------------------------|------------------|-------------------|-------------------|-------------------|----------------------------|--------|-------|--------|----------------------------|--------|-------|--------|----------------------------|--------|-------|--------|
| | | *CSO | CSO | **Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 1,116.698 | 1,043.719 | -72.979 | | | | | | | | | | | | |
| | Passive Demand | 1,631.335 | 1,519.740 | -111.595 | | | | | | | | | | | | |
| Demand Total | | 2,748.033 | 2,563.459 | -184.574 | | | | | | | | | | | | |
| Generator | Non-Intermittent | 30,704.578 | 28,146.837 | -2,557.741 | | | | | | | | | | | | |
| | Intermittent | 936.913 | 893.710 | -43.203 | | | | | | | | | | | | |
| Generator Total | | 31,641.491 | 29,040.547 | -2,600.944 | | | | | | | | | | | | |
| Import Total | | 1,830.000 | 1,606.862 | -223.138 | | | | | | | | | | | | |
| ***Grand Total | | 36,219.524 | 33,210.868 | -3,008.656 | | | | | | | | | | | | |

* Real-time Emergency Generators (RTEG) CSO not capped at 600.000 MW

** Change columns contain the changes in CSO amount resulting from the specific FCM Event as well as adjustments for Delisted MW released according to MR 1, Section 13.2.5.2, and changes that occurred (terminations, etc.) prior to the event reported in the column.

*** Grand Total reflects both CSO Grand Total and the net total of the Change Column.

Capacity Supply Obligation FCA 8

| Resource Type | Resource Type | FCA | Annual Bilateral for ARA 1 | | ARA 1 | | Annual Bilateral for ARA 2 | | ARA 2 | | Annual Bilateral for ARA 3 | | ARA 3 | |
|------------------------|------------------|-------------------|----------------------------|--------|-------|--------|----------------------------|--------|-------|--------|----------------------------|--------|-------|--------|
| | | *CSO | CSO | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change | CSO | Change |
| | | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW | MW |
| Demand | Active Demand | 1,080.079 | | | | | | | | | | | | |
| | Passive Demand | 1,960.517 | | | | | | | | | | | | |
| Demand Total | | 3,040.596 | | | | | | | | | | | | |
| Generator | Non-Intermittent | 28,547.813 | | | | | | | | | | | | |
| | Intermittent | 876.925 | | | | | | | | | | | | |
| Generator Total | | 29,424.738 | | | | | | | | | | | | |
| Import Total | | 1,237.034 | | | | | | | | | | | | |
| ***Grand Total | | 33,702.368 | | | | | | | | | | | | |

* Real-time Emergency Generators (RTEG) CSO not capped at 600.000 MW

** Change columns contain the changes in CSO amount resulting from the specific FCM Event as well as adjustments for Delisted MW released according to MR 1, Section 13.2.5.2, and changes that occurred (terminations, etc.) prior to the event reported in the column.

*** Grand Total reflects both CSO Grand Total and the net total of the Change Column.

RELIABILITY COSTS – NET COMMITMENT PERIOD COMPENSATION (NCPC) OPERATING COSTS

What are Daily NCPC Payments?

- “Make-whole” payments made to resources whose hourly commitment and dispatch by ISO-NE resulted in a shortfall between the resource’s offered value in the Energy and Regulation Markets and the revenue earned from output over the course of the day
- Typically, this is the result of some out-of-merit operation of resources occurring in order to protect the overall resource adequacy and transmission security of specific locations or of the entire control area



Definitions


| | |
|---|--|
| 1 st Contingency NCPC Payments | Reliability costs paid to eligible resources that are providing first contingency (1stC) protection (including low voltage, system operating reserve, and load serving) either system-wide or locally. |
| 2 nd Contingency NCPC Payments | Reliability costs paid to resources providing capacity in constrained areas to respond to a local second contingency. They are committed based on 2 nd Contingency (2ndC) protocols, and are also known as Local Second Contingency Protection Resources (LSCPR). |
| Voltage NCPC Payments | Reliability costs paid to resources operated by ISO-NE to provide voltage support or control in specific locations. |
| Distribution NCPC Payments | Reliability costs paid to units dispatched at the request of local transmission providers for purpose of managing constraints on the low voltage (distribution) system. These requirements are not modeled in the DA Market software. |
| Delisted Units | Resources within the control area that have requested to be classified as a non-installed capacity (ICAP) resource, and as such, are not required to offer their capacity into the DA Energy Market. |
| OATT | Open Access Transmission Tariff. |

Charge Allocation Key


| Allocation Category | Market / OATT | Allocation |
|---|---------------|---|
| System 1 st Contingency | Market | DA 1 st C (excluding at external nodes) is allocated to system DALO. RT 1 st C (at all locations) is allocated to System 'Daily Deviations'. Daily Deviations = sum of(generator deviations, load deviations, generation obligation deviations at external nodes, increment offer deviations) |
| External DA 1 st Contingency | Market | DA 1 st C at external nodes (from imports, exports, Incs and Decs) are allocated to activity at the specific external node or interface involved |
| Zonal 2 nd Contingency | Market | DA and RT 2 nd C NCPC are allocated to load obligation in the Reliability Region (zone) served |
| System Low Voltage | OATT | (Low) Voltage Support NCPC is allocated to system Regional Network Load and Open Access Same-Time Information Service (OASIS) reservations |
| Zonal High Voltage | OATT | High Voltage Control NCPC is allocated to zonal Regional Network Load |
| Distribution - PTO | OATT | Distribution NCPC is allocated to the specific Participant Transmission Owner (PTO) requesting the service |

Year-Over-Year Total NCPC Dollars and Energy

NCPC Dollars




NCPC Energy*



* NCPC Energy GWh reflect the DA and/or RT economic minimum loadings of all units receiving DA or RT NCPC credits, assessed during hours in which they are NCPC-eligible. All NCPC components (1st Contingency, 2nd Contingency, Voltage, and RT Distribution) are reflected.


DA and RT NCPC Charges

MAR-14 Total = \$16.81 M



Day-Ahead Real-Time


Last 13 Months



Day-Ahead Real-Time


NCPC Charges by Type

MAR-14 Total = \$16.81 M



■ 1st C ■ 2nd C
■ Distrib


Last 13 Months



■ 1st C ■ 2nd C
■ Voltage ■ Distrib


1st C – First Contingency
 2nd C – Second Contingency
 Distrib – Distribution
 Voltage – Voltage

Daily NCPC Charges by Type




NCPC Charges by Allocation

MAR-14 Total = \$16.81 M




Last 13 Months




RT First Contingency Charges by Deviation Type

MAR-14 Total = \$6.07 M




Gen – Generator deviations
 Inc – Increment Offer deviations
 Imp – Import deviations
 Load – Load obligation deviations


Last 13 Months



LSCPR Charges by Zone




NCPC Charges for Voltage Support and High Voltage Control




NCPC Charges by Type

Value of Charges





NCPC Charges as Percent of Energy Market

NCPC By Type as Percent of Energy Market




First Contingency NCPC Charges




Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market

Second Contingency NCPC Charges

Value of Charges




% of Energy Market Value




Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market

Voltage and Distribution NCPC Charges

Value of Charges



% of Energy Market Value



Note: Energy Market value is the hourly locational product of load obligation and price in the DA Market plus the hourly locational product of price and RT Load Obligation Deviation in the RT Market

DA vs. RT Pricing

The following slides outline:

- This month vs. prior year's average LMPs and fuel costs
- Reserve Market results
- DA cleared load vs. RT load
- Zonal and total incs and decs
- Self-schedules
- DA vs. RT net interchange




DA vs. RT LMPs (\$/MWh)

| Year 2012 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
|------------|---------|---------|---------|---------|---------|---------|---------|---------|---------|
| Day-Ahead | \$36.48 | \$37.09 | \$36.20 | \$36.24 | \$36.57 | \$36.56 | \$36.44 | \$37.29 | \$36.43 |
| Real-Time | \$36.22 | \$36.95 | \$35.25 | \$36.00 | \$36.22 | \$35.96 | \$36.22 | \$36.97 | \$36.17 |
| RT Delta % | -0.7% | -0.4% | -2.6% | -0.7% | -0.9% | -1.7% | -0.6% | -0.8% | -0.7% |
| Year 2013 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
| Day-Ahead | \$56.90 | \$55.43 | \$54.48 | \$55.98 | \$55.36 | \$57.80 | \$57.02 | \$56.38 | \$56.43 |
| Real-Time | \$56.32 | \$55.90 | \$53.23 | \$55.15 | \$55.08 | \$56.10 | \$56.43 | \$56.12 | \$56.06 |
| RT Delta % | -1.0% | 0.8% | -2.3% | -1.5% | -0.5% | -2.9% | -1.0% | -0.5% | -0.7% |

| March-13 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
|---------------|----------|----------|----------|----------|----------|----------|----------|----------|----------|
| Day-Ahead | \$53.06 | \$52.70 | \$50.93 | \$52.74 | \$52.55 | \$53.31 | \$53.29 | \$53.22 | \$53.09 |
| Real-Time | \$54.14 | \$53.81 | \$51.96 | \$53.41 | \$53.31 | \$54.08 | \$54.32 | \$54.04 | \$54.01 |
| RT Delta % | 2.0% | 2.1% | 2.0% | 1.3% | 1.5% | 1.5% | 1.9% | 1.5% | 1.7% |
| March-14 | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
| Day-Ahead | \$123.53 | \$120.61 | \$118.23 | \$121.19 | \$120.81 | \$124.46 | \$124.14 | \$122.76 | \$122.84 |
| Real-Time | \$126.69 | \$124.05 | \$118.76 | \$122.49 | \$121.85 | \$126.58 | \$127.09 | \$125.87 | \$125.91 |
| RT Delta % | 2.6% | 2.9% | 0.5% | 1.1% | 0.9% | 1.7% | 2.4% | 2.5% | 2.5% |
| Annual Diff. | NEMA | CT | ME | NH | VT | RI | SEMA | WCMA | Hub |
| Yr over Yr DA | 132.8% | 128.9% | 132.1% | 129.8% | 129.9% | 133.5% | 133.0% | 130.7% | 131.4% |
| Yr over Yr RT | 134.0% | 130.5% | 128.6% | 129.3% | 128.6% | 134.0% | 134.0% | 132.9% | 133.1% |


Monthly Average Fuel Price and RT Hub LMP Indexes



Underlying natural gas data furnished by:



Monthly Average Fuel Price and RT Hub LMP



Underlying natural gas data furnished by:




Reserve Market Results – March 2014

- Maximum potential Forward Reserve Market payments of \$9.8M were reduced by credit reductions of \$336K, failure-to-reserve penalties of \$508K and failure-to-activate penalties of \$0M, resulting in a net payout of \$9.0M or 91% of maximum
 - Rest of System: \$5.35M/\$5.94M (90%)
 - Southwest Connecticut: \$0.54M/\$0.56M (95%)
 - Connecticut: \$3.11M/\$3.34M (93%)
- \$2.8M total Real-Time credits were reduced by \$98K in Forward Reserve Energy Obligation Charges for a net of \$2.7M in Real-Time Reserve payments
 - Rest of System: 49 hours, \$1.7M
 - Southwest Connecticut: 49 hours, \$501K
 - Connecticut: 49 hours, \$366K
 - NEMA: 49 hours, \$106K

* “Failure to reserve” results in both credit reductions and penalties in the Locational Forward Reserve Market.


LFRM Charges to Load by Load Zone (\$)

LFRM Charges by Zone, Last 13 Months




DA vs. RT Load Obligation: March, This Year vs. Last Year

Monthly, Last 13 Months




Daily, This Year vs. Last Year




Zonal Increment Offers and Cleared Amounts

March Monthly Totals by Zone




Zonal Decrement Bids and Cleared Amounts

March Monthly Totals by Zone



Total Increment Offers and Decrement Bids


Zonal Level, Last 13 Months



Data excludes nodal offers and bids

Dispatchable vs. Non-Dispatchable Generation


Total Monthly Energy; Dispatchable % Shown




DA vs. RT Net Interchange

March 2014 vs. March 2013

Hourly Average by Day, Last Year




Hourly Average by Day, This Year



Net Interchange is the sum of daily imports minus the sum of daily exports
 Positive values are net imports


Rolling Average Peak Energy Rent (PER)



Rolling Average PER is currently calculated as a rolling twelve month average of individual monthly PER values for the twelve months preceding the obligation month.

Individual monthly PER values are published to the ISO web site here: [Home > Markets > Other Markets Data > Forward Capacity Market > Reports](#) and are subject to resettlement.

PER Adjustments



PER Adjustments are reductions to Forward Capacity Market monthly payments resulting from the rolling average PER.

REGIONAL SYSTEM PLAN (RSP) AND INTERREGIONAL PLANNING

Planning Advisory Committee (PAC)

- Economic Study requests are due to ISO by April 1
 - The ISO will advise all requestors of all received requests and the time allotted for each presentation by April 3
 - Presentation materials are due to the ISO by April 9
- April 29 PAC Agenda Topics
 - EIPC Gas/Electric Interface Study Update
 - SEMA Load Pocket Nodal Market Resource Alternative Analysis Update
 - 2014 ICF Benchmarking Study
 - 2014-2023 Regional State Energy and Peak Forecast Update
 - RSP14 Resource Adequacy Related Studies Scope of Work
 - RSP14 Load and Capacity Resource Overview
 - 2013 Economic Study Update
 - Stakeholder Proposals for 2014 Economic Studies

Distributed Generation Forecast Working Group (DGFWG)

- The Final Interim PV Forecast, DG location and modeling issues, status of interconnection issues and ISO plans for use of the DG forecast, DG in FCM, and next steps will be discussed at the April 2 meeting
 - ISO is reflecting information received from the distribution owners for additional information
 - The Final Interim PV Forecast is being refined with only minor changes and will appear as part of the CELT 2014
- Follow-up discussions will be held at DGFWG meetings and the PAC will be kept advised of DGFWG activities with the goal of developing an overall DG forecast for CELT 2015
- ISO is working with the transmission owners, distribution owners, and the states to resolve interconnection issues
- ISO will utilize its normal transparent process that allows all stakeholders to provide input on the use of the DG forecast
 - Uses of the DG forecast will be vetted through PAC and NEPOOL committees as necessary

Inter-Area Planning Stakeholder Advisory Committee (IPSAC) and Environmental Advisory Group (EAG)

- An IPSAC webinar was held on March 28 to discuss the draft Northeast Coordinated System Plan
 - See http://www.iso-ne.com/committees/comm_wkgrps/othr/ipsac/mtrls/2014/mar282014/index.html
 - Final stakeholder comments are due April 8
- On a March 26 conference call, state air quality regulators requested ISO-NE, NYISO and PJM assist in developing an emissions methodology that allows quantification of avoided emissions due to energy efficiency and renewable energy production
 - The next call will be scheduled in April to discuss the states' request in more detail

Variable Resource Working Group (VRWG)

- The VRWG is a NEPOOL advisory stakeholder group that will provide a forum for the exchange of information and ideas on issues affecting participation by variable resources in New England
- The VRWG will hold its initial meeting on April 17 at the Sheraton Springfield Monarch Place Hotel in Springfield, MA
- Materials will be posted at http://www.iso-ne.com/committees/comm_wkgrps/other/index.html

RSP Project Stage Descriptions

| Stage | Description |
|-------|--|
| 1 | Planning and Preparation of Project Configuration |
| 2 | Pre-construction (e.g., material ordering, project scheduling) |
| 3 | Construction in Progress |
| 4 | In Service |

North Shore Upgrades – Salem Harbor Non-Price Retirement

Status as of 3/31/14

Project Benefits: Allows for the Non-Price Retirement of the Salem Harbor Plant

| Upgrade | Expected In-service | Present Stage |
|--|----------------------------|----------------------|
| Reconductor Y-151 Tewksbury Jct. - West Methuen 115 kV | Feb-14 | 4 |
| Reconductor B-154N King St. - South Danvers 115 kV | Feb-13 | 4 |
| Reconductor C-155N King St. - South Danvers 115 kV | Feb-13 | 4 |
| Reconductor S-145 Tewksbury - North Reading 115 kV | Aug-13 | 4 |
| Reconductor T-146 Tewksbury - North Reading 115 kV | Aug-13 | 4 |



Lower Southeastern Massachusetts (SEMA) Proposed Long-term Upgrades

Status as of 3/31/14

Project Benefit: Improves system reliability for the Lower SEMA area

| Upgrade | Expected In-service | Present Stage |
|--|----------------------------|----------------------|
| Expand the Carver Substation | Jun-13 | 4 |
| Build New 345 kV Line from Carver to Vicinity of Bourne Substation and connect to Line 120. Expand Bourne with one breaker position. | Jun-13 | 4* |
| Construct New 115 kV Substation with 345-115 kV Autotransformer and Loop Line 115 into the new substation | Dec-13 | 4 |
| Upgrade the 115 kV Bell Rock to High Hill D21 Line | May-13 | 4 |
| Separate the 345 kV (342 / 322) Double Circuit Tower Lines | Jun-13 | 4 |

Project approved by MA EFSB on 4/27/12

* The work is in service in a temporary configuration. The final in-service configuration will be completed May 2014.

NEEWS: Interstate Reliability Project

Status as of 3/31/14

Plan Benefit: Improves New England reliability by increasing transfer limits of three critical interfaces

| Upgrade | Expected In-service | Present Stage |
|---|----------------------------|----------------------|
| Build New 345 kV Line 3271 Card - Lake Road | Dec-15 | 3 |
| Card 345 kV Substation Expansion | Dec-15 | 3 |
| Lake Road 345 kV Substation Expansion | Dec-15 | 2 |
| Build New 345 kV Line 341 Lake Road to CT/RI Border | Dec-15 | 3 |
| Build New 345 kV Line 341 CT/RI Border to West Farnum | Dec-15 | 1 |
| West Farnum 345 kV Substation Additions (New Line Terminations) | Dec-15 | 1 |
| New Sherman Road 345 kV Substation | Dec-15 | 1 |
| West Farnum 115 kV Substation Upgrades | Sep-14 | 3 |
| Reconductor 345 kV Line 328 West Farnum to Sherman Road | Dec-15 | 1 |
| Riverside Substation Relay Upgrades | Sep-14 | 3 |
| Woonsocket Substation Relay Upgrades | Sep-14 | 3 |
| Hartford Avenue Substation Relay Upgrades | Sep-14 | 3 |
| Build New 345 kV Line 366 West Farnum to MA/RI Border | Dec-15 | 1 |
| Build New 345 kV Line 366 MA/RI Border to Millbury 3 | Dec-15 | 1 |
| Millbury 3 Substation Expansion | Dec-15 | 2 |
| Carpenter Hill Substation Relay Upgrades | Dec-15 | 2 |

NEEWS: Central Connecticut Reliability Project

Status as of 3/31/14

Plan Benefit: Improves New England reliability by increasing transfer limits of three critical interfaces

| Upgrade | Expected In-service | Present Stage |
|---|----------------------------|----------------------|
| Central Connecticut Reliability Project (CCRP)* | Jun-17 | 1 |

* Combined with Greater Hartford Central Connecticut Study



Maine Power Reliability Program (MPRP)

Status as of 3/31/14

Project Benefit: Addresses long-term system needs of Emera Maine and Central Maine Power, thermal and voltage issues in western Maine and supports load growth in southern Maine

| New 345 kV Lines | Expected In-Service | Present Stage |
|---|----------------------------|----------------------|
| Construct New Section 3023 Orrington to Albion Road | May-13 | 4 |
| Construct New Section 3024 Albion Road to Coopers Mills | Jan-15 | 3 |
| Construct New Section 3025 Coopers Mills to Larrabee Road | Mar-15 | 3 |
| Construct New Section 3026 Larrabee Road to Surowiec | Dec-12 | 4 |
| Construct New Section 3020 Surowiec to Raven Farm | Nov-13 | 4 |
| Construct New Section 3021 South Gorham to Maguire Road | Apr-14 | 3 |
| Construct New Section 3022 Maguire Road to Eliot | Jun-14 | 3 |

- The above listing focuses on major transmission line construction and rebuilding.



Maine Power Reliability Program, *cont.*

Status as of 3/31/14

Project Benefit: Addresses long-term system needs of Emera Maine and Central Maine Power, thermal and voltage issues in western Maine and supports load growth in southern Maine

| | Expected In-Service | Present Stage |
|--|----------------------------|----------------------|
| New 115 kV Lines | | |
| Construct New Section 254 Orrington to Coopers Mills | Feb-15 | 3 |
| Construct New Section 243A Livermore Falls to Junction Section 243 | May-14 | 3 |
| Construct New Section 251 Livermore Falls to Larrabee Road | May-14 | 3 |
| Construct New Section 255 Larrabee Road to Middle Street | Apr-15 | 3 |
| Construct New Section 86A Tap to Belfast | Jul-14 | 3 |
| Construct New Section 256 Middle Street to Lewiston Lower | April-15 | 1 |

- The above listing focuses on major transmission line construction and rebuilding.



Maine Power Reliability Program, *cont.*

Status as of 3/31/14

Project Benefit: Addresses long-term system needs of Emera Maine and Central Maine Power, thermal and voltage issues in western Maine and supports load growth in southern Maine

| 115 kV Lines Rebuilds | Expected In-Service | Present Stage |
|---|----------------------------|----------------------|
| Rebuild Section 60 Coopers Mills to Bowman Street | Feb-15 | 3 |
| Rebuild Section 88 Coopers Mills to Augusta East Side | Feb-15 | 3 |
| Rebuild Section 89 Livermore Falls to Riley | May-14 | 3 |
| Rebuild Section 229 Riley to Rumford IP | May-13 | 4 |
| Rebuild Section 212 Monmouth to Larrabee Road | Feb-13 | 4 |
| Rebuild Section 269 Bowman Street to Monmouth | May-12 | 4 |
| Rebuild Section 238 Loudon to Maguire Road | Feb-12 | 4 |
| Rebuild Section 250 Maguire Road to Three Rivers | Dec-13 | 4 |

- The above listing focuses on major transmission line construction and rebuilding.

Maine Power Reliability Program, *cont.*

Status as of 3/31/14

Project Benefit: Addresses long-term system needs of Emera Maine and Central Maine Power, thermal and voltage issues in western Maine and supports load growth in southern Maine

| 345/115 kV Autotransformers | Expected In-Service | Present Stage |
|---|----------------------------|----------------------|
| Install One 345/115 kV Autotransformer at Albion Road | Apr-13 | 4 |
| Install One 345/115 kV Autotransformer at Coopers Mills | Jan-15 | 3 |
| Install One 345/115 kV Autotransformer at Larrabee Road | Dec-12 | 4 |
| Install One 345/115 kV Autotransformer at Maguire Road | Apr-14 | 3 |
| Install One 345/115 kV Autotransformer at South Gorham | Nov-09 | 4 |

- The above listing focuses on major transmission line construction and rebuilding.



Transmission Siting Update


- NEEWS
 - Rhode Island Reliability Project
 - Project completed
 - Greater Springfield Reliability Project
 - Project completed
 - Interstate Reliability Project
 - National Grid siting application was filed in MA on 6/21/12
 - National Grid siting application was filed in RI on 7/19/12
 - CL&P's siting hearings in CT were completed on 8/30/12
 - Received siting approval from CT on 1/2/13. The RI Energy Facilities Siting Board approved the project on 6/14/13. MA EFSB directed the drafting of a Tentative Decision approving the project on 1/30/14
- MPRP
 - Project filed with the Maine Public Utility Commission on 7/1/08
 - Maine PUC approved most of the project on 6/10/10
 - Hearings are complete - written order received on Lewiston Loop

NSTAR Cable Rating Changes – Boston Area

- In April 2013, NSTAR presented updates to the cable ratings to the PAC¹
- The changes were driven by the following:
 - Moving ratings to a consistent time period for emergency ratings – 12 hours for summer LTE and 4 hours for winter LTE
 - Multiple rating sets to reflect status of forced cooling systems and/or status of adjacent transmission cables
 - A total of (35) 115 kV cables and (10) 345 kV cables had their ratings change
- As of March 2014, NSTAR has submitted a portion of the summer cable ratings to ISO-NE for inclusion in the NX-9 database
 - These are anticipated to go into effect spring 2014
- In the coming months, NSTAR will also be providing updated winter ratings for these cables
 - These would have an anticipated effective date of November 1, 2014

¹https://smd.iso-ne.com/committees/comm_wkgrps/prtcpnts_comm/pac/ceii/mtrls/2013/apr242013/a10_nstar_greater_boston_cable_ratings.pdf

Status of Tariff Studies



OPERABLE CAPACITY ANALYSIS

Spring 2014

Spring 2014 Operable Capacity Analysis

| 50/50 Load Forecast (Reference) | May -2014 ² CSO | May -2014 ² SCC |
|---|-------------------------------|-------------------------------|
| Generator Operable Capacity MW ¹ | 29,627 | 34,022 |
| OP CAP From OP-4 RTDR (+) | 418 | 418 |
| OP CAP From OP-4 RTEG (+) | 234 | 234 |
| Operable Capacity Generator with OP-4 DR and RTEG | 30,279 | 34,674 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 1,083 | 1,083 |
| Non Commercial Capacity (+) | 68 | 68 |
| Non Gas-fired Planned Outage MW (-) | 2,267 | 2,386 |
| Allowance for Unplanned Outages (-) | 3,400 | 3,400 |
| Gas Generator Outages MW (-) | 2,020 | 2,126 |
| Generation at Risk Due to Gas Supply (-) ⁴ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) ³ | 23,743 | 27,913 |
| Peak Load Forecast MW (adjusted for Other Demand Resources) ² | 21,216 | 21,216 |
| Operating Reserve Requirement MW | 2,375 | 2,375 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 23,591 | 23,591 |
| Operable Capacity Margin ³ | 152 | 4,322 |

¹ Generator Operable Capacity is based on data as of March 18th, 2014 and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity.

² Based on week with lowest Operable Capacity Margin, week beginning May 17th, 2014

³ Includes OP4 actions associated with RTEG and RTDR

⁴ Total of (Gas at Risk MW) – (Gas Gen Outages MW)

Spring 2014 Operable Capacity Analysis

| 90/10 Load Forecast (Extreme) | May -2014 ² CSO | May -2014 ² SCC |
|---|-------------------------------|-------------------------------|
| Generator Operable Capacity MW ¹ | 29,627 | 34,022 |
| OP CAP From OP-4 RTDR (+) | 418 | 418 |
| OP CAP From OP-4 RTEG (+) | 234 | 234 |
| Operable Capacity Generator with OP-4 DR and RTEG | 30,279 | 34,674 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 1,083 | 1,083 |
| Non Commercial Capacity (+) | 68 | 68 |
| Non Gas-fired Planned Outage MW (-) | 2,267 | 2,386 |
| Allowance for Unplanned Outages (-) | 3,400 | 3,400 |
| Gas Generator Outages MW (-) | 2,020 | 2,126 |
| Generation at Risk Due to Gas Supply (-) ⁴ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) ³ | 23,743 | 27,913 |
| Peak Load Forecast MW (adjusted for Other Demand Resources) ² | 23,058 | 23,058 |
| Operating Reserve Requirement MW | 2,375 | 2,375 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 25,433 | 25,433 |
| Operable Capacity Margin ³ | (1690) | 2,480 |

¹ Generator Operable Capacity is based on data as of March 18th, 2014 and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity.

² Based on week with lowest Operable Capacity Margin, week beginning May 17th, 2014.


³ Includes OP4 actions associated with RTEG and RTDR

⁴ Total of (Gas at Risk MW) – (Gas Gen Outages MW)

Spring 2014 Operable Capacity Analysis(MW)

50/50 Forecast (Reference)


New England Operable Capacity Margins - CSO with RTDR & RTEG
50/50 FORECAST



April 5, 2014 - May 24, 2014, W/B Saturday

Spring 2014 Operable Capacity Analysis(MW)

90/10 Forecast (Extreme)



Spring 2014 Operable Capacity Analysis(MW)

50/50 Forecast (Reference)

ISO-NE 2014 OPERABLE CAPACITY ANALYSIS

April 4, 2014 - 50/50- FORECAST - CSO

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, and August and Mid September.

| STUDY WEEK (Week Beginning, Saturday) | OPCAP SUPPLY | | | | | | | | LOAD OBLIGATIONS | | | OPCAP MARGINS | | | | |
|--|-----------------------|--|-------------------------------------|---|---|---------------------------------------|-------------------|------------------------|-----------------------------|--------------------------------------|------------------------------|-----------------------|---|---|---|--|
| | AVAILABLE OPCAP MW | EXTERNAL NODE AVAIL CAPACITY MW | NON COMMERCIAL CAPACITY MW | NON-GAS PLANNED OUTAGES CSO MW | ALLOWANCE FOR UNPLANNED OUTAGES MW | GAS GENERATOR OUTAGES CSO MW | GAS AT RISK MW | NET OPCAP SUPPLY MW | PEAK LOAD FORECAST MW | OPER RESERVE REQUIREMENT MW | NET LOAD OBLIGATION MW | OPCAP MARGIN MW | OPCAP FROM OP4 ACTIVE REAL-TIME DR MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 2 MW | OPCAP FROM OP4 REAL-TIME EMER. GEN MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 6 MW |
| | [1] | [2] | [3] | [4] | [5] | [6] | [7] | [8] | [9] | [10] | [11] | [12] | [13] | [14] | [15] | [16] |
| 4/5/2014 | 30,121 | 757 | 68 | 6,048 | 2,700 | 2,038 | 0 | 20,160 | 17,524 | 2,375 | 19,899 | 261 | 314 | 575 | 163 | 738 |
| 4/12/2014 | 30,121 | 757 | 68 | 5,567 | 2,700 | 2,281 | 0 | 20,398 | 17,271 | 2,375 | 19,646 | 752 | 314 | 1,066 | 163 | 1,229 |
| 4/19/2014 | 30,121 | 757 | 68 | 5,995 | 2,700 | 2,152 | 0 | 20,099 | 16,757 | 2,375 | 19,132 | 967 | 314 | 1,281 | 163 | 1,444 |
| 4/26/2014 | 29,627 | 1,083 | 68 | 5,242 | 3,400 | 2,108 | 0 | 20,028 | 16,490 | 2,375 | 18,865 | 1,163 | 418 | 1,581 | 234 | 1,815 |
| 5/3/2014 | 29,627 | 1,183 | 68 | 5,776 | 3,400 | 2,205 | 0 | 19,497 | 16,463 | 2,375 | 18,838 | 659 | 418 | 1,077 | 234 | 1,311 |
| 5/10/2014 | 29,627 | 889 | 68 | 3,164 | 3,400 | 1,871 | 0 | 22,149 | 20,223 | 2,375 | 22,598 | (449) | 418 | (31) | 234 | 203 |
| 5/17/2014 | 29,627 | 1,083 | 68 | 2,267 | 3,400 | 2,020 | 0 | 23,091 | 21,216 | 2,375 | 23,591 | (500) | 418 | (82) | 234 | 152 |
| 5/24/2014 | 29,627 | 1,083 | 68 | 1,750 | 3,400 | 1,166 | 0 | 24,462 | 22,138 | 2,375 | 24,513 | (51) | 418 | 367 | 234 | 601 |

1. Available OPCAP MW based on resource Capacity Supply Obligations, CSO. Does not include Settlement Only Generators.
 2. External Node Available Capacity MW based on the sum of external Capacity Supply Obligations (CSO) imports and exports.
 3. New resources that have acquired a CSO but have not become commercial.
 4. Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
 5. Allowance for Unplanned Outages includes forced outages and maintenance outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
 6. All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
 7. Generation at Risk due to Gas Supply pertains to gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
 8. Net OpCap Supply MW Available (1 + 2 + 3 - 4 - 5 - 6 - 7 = 8)
 9. Peak Load Forecast as provided in the 2013 CELT Report and adjusted for Passive Demand Resources.
 10. Operating Reserve Requirement based on 125% of first largest contingency plus 50% the second largest contingency.
 11. Total Net Load Obligation per the formula(9 + 10 = 11)
 12. Net OPCAP Margin MW = Net Op Cap Supply MW minus Net Load Obligation (8 - 11 = 12)
 13. OP 4 Action 2 Real-time Demand Response based on OP4 Appendix A. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 14. OPCAP Margin taking into account Real Time Demand Response through OP4 Step 2 (12 + 13 = 14)
 15. OP 4 Action 6 Emergency Generation Response without the Voltage Reduction requiring > 10 Minutes based on OP4 Appendix A. Real Time Emergency Generation is capped at 600MW. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 16. OPCAP Margin taking into account Real Time Demand Response and Real Time Emergency Generation through OP4 Step 6 (14 + 15 = 16)
- This does not include Emergency Energy Transactions (EETs).

Spring 2014 Operable Capacity Analysis(MW)

90/10 Forecast (Extreme)

ISO-NE 2014 OPERABLE CAPACITY ANALYSIS

April 4, 2014 - 90/10- FORECAST - CSO

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, and August and Mid September.

| STUDY WEEK (Week Beginning, Saturday) | OPCAP SUPPLY | | | | | | | | LOAD OBLIGATIONS | | | OPCAP MARGINS | | | | |
|--|-----------------------|--|-------------------------------------|---|---|---------------------------------------|-------------------|------------------------|-----------------------------|--------------------------------------|------------------------------|-----------------------|---|---|---|--|
| | AVAILABLE OPCAP MW | EXTERNAL NODE AVAIL CAPACITY MW | NON COMMERCIAL CAPACITY MW | NON-GAS PLANNED OUTAGES CSO MW | ALLOWANCE FOR UNPLANNED OUTAGES MW | GAS GENERATOR OUTAGES CSO MW | GAS AT RISK MW | NET OPCAP SUPPLY MW | PEAK LOAD FORECAST MW | OPER RESERVE REQUIREMENT MW | NET LOAD OBLIGATION MW | OPCAP MARGIN MW | OPCAP FROM OP4 ACTIVE REAL-TIME DR MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 2 MW | OPCAP FROM OP4 REAL-TIME EMER. GEN MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 6 MW |
| | [1] | [2] | [3] | [4] | [5] | [6] | [7] | [8] | [9] | [10] | [11] | [12] | [13] | [14] | [15] | [16] |
| 4/5/2014 | 30,121 | 757 | 68 | 6,048 | 2,700 | 2,038 | 0 | 20,160 | 18,053 | 2,375 | 20,428 | (268) | 314 | 46 | 163 | 209 |
| 4/12/2014 | 30,121 | 757 | 68 | 5,567 | 2,700 | 2,281 | 0 | 20,398 | 17,792 | 2,375 | 20,167 | 231 | 314 | 545 | 163 | 708 |
| 4/19/2014 | 30,121 | 757 | 68 | 5,995 | 2,700 | 2,152 | 0 | 20,099 | 17,263 | 2,375 | 19,638 | 461 | 314 | 775 | 163 | 938 |
| 4/26/2014 | 29,627 | 1,083 | 68 | 5,242 | 3,400 | 2,108 | 0 | 20,028 | 16,989 | 2,375 | 19,364 | 664 | 418 | 1,082 | 234 | 1,316 |
| 5/3/2014 | 29,627 | 1,183 | 68 | 5,776 | 3,400 | 2,205 | 0 | 19,497 | 16,961 | 2,375 | 19,336 | 161 | 418 | 579 | 234 | 813 |
| 5/10/2014 | 29,627 | 889 | 68 | 3,164 | 3,400 | 1,871 | 0 | 22,149 | 21,983 | 2,375 | 24,358 | (2,209) | 418 | (1,791) | 234 | (1,557) |
| 5/17/2014 | 29,627 | 1,083 | 68 | 2,267 | 3,400 | 2,020 | 0 | 23,091 | 23,058 | 2,375 | 25,433 | (2,342) | 418 | (1,924) | 234 | (1,690) |
| 5/24/2014 | 29,627 | 1,083 | 68 | 1,750 | 3,400 | 1,166 | 0 | 24,462 | 24,056 | 2,375 | 26,431 | (1,969) | 418 | (1,551) | 234 | (1,317) |

1. Available OPCAP MW based on resource Capacity Supply Obligations, CSO. Does not include Settlement Only Generators.
 2. External Node Available Capacity MW based on the sum of external Capacity Supply Obligations (CSO) imports and exports.
 3. New resources that have acquired a CSO but have not become commercial.
 4. Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
 5. Allowance for Unplanned Outages includes forced outages and maintenance outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
 6. All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
 7. Generation at Risk due to Gas Supply pertains to gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
 8. Net OpCap Supply MW Available (1 + 2 + 3 - 4 - 5 - 6 - 7 = 8)
 9. Peak Load Forecast as provided in the 2013 CELT Report and adjusted for Passive Demand Resources.
 10. Operating Reserve Requirement based on 125% of first largest contingency plus 50% the second largest contingency.
 11. Total Net Load Obligation per the formula(9 + 10 = 11)
 12. Net OPCAP Margin MW = Net Op Cap Supply MW minus Net Load Obligation (8 - 11 = 12)
 13. OP 4 Action 2 Real-time Demand Response based on OP4 Appendix A. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 14. OPCAP Margin taking into account Real Time Demand Response through OP4 Step 2 (12 + 13 = 14)
 15. OP 4 Action 6 Emergency Generation Response without the Voltage Reduction requiring > 10 Minutes based on OP4 Appendix A. Real Time Emergency Generation is capped at 600MW. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 16. OPCAP Margin taking into account Real Time Demand Response and Real Time Emergency Generation through OP4 Step 6 (14 + 15 = 16)
- This does not include Emergency Energy Transactions (EETs).

OPERABLE CAPACITY ANALYSIS

Summer 2014

Summer 2014 Operable Capacity Analysis

| 50/50 Load Forecast (Reference) | June - 2014 ² CSO | June -2014 ² SCC |
|---|---------------------------------|--------------------------------|
| Generator Operable Capacity MW ¹ | 29,136 | 30,829 |
| OP CAP From OP-4 RTDR (+) | 489 | 489 |
| OP CAP From OP-4 RTEG (+) | 211 | 211 |
| Operable Capacity Generator with OP-4 DR and RTEG | 29,836 | 31,529 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 1,283 | 1,283 |
| Non Commercial Capacity (+) | 68 | 68 |
| Non Gas-fired Planned Outage MW (-) | 352 | 371 |
| Allowance for Unplanned Outages (-) | 2,800 | 2,800 |
| Gas Generator Outages MW (-) | 0 | 0 |
| Generation at Risk Due to Gas Supply (-) ⁴ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) ³ | 28,035 | 29,709 |
| Peak Load Forecast MW(adjusted for Other Demand Resources) ² | 26,929 | 26,929 |
| Operating Reserve Requirement MW | 2,375 | 2,375 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 29,304 | 29,304 |
| Operable Capacity Margin ³ | (1269) | 405 |

¹ Generator Operable Capacity is based on data as of March 18th, 2014 and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity.

² Based on week with lowest Operable Capacity Margin, weeks beginning May 31st, June 7th June 14th, 2014.

³ Includes OP4 actions associated with RTEG and RTDR

⁴ Total of (Gas at Risk MW) – (Gas Gen Outages MW)

Summer 2014 Operable Capacity Analysis

| 90/10 Load Forecast (Extreme) | June- 2014 ² CSO | June - 2014 ² SCC |
|---|--------------------------------|---------------------------------|
| Generator Operable Capacity MW ¹ | 29,136 | 30,829 |
| OP CAP From OP-4 RTDR (+) | 489 | 489 |
| OP CAP From OP-4 RTEG (+) | 211 | 211 |
| Operable Capacity Generator with OP-4 DR and RTEG | 29,836 | 31,529 |
| External Node Available Net Capacity, CSO imports minus firm capacity exports (+) | 1,283 | 1,283 |
| Non Commercial Capacity (+) | 68 | 68 |
| Non Gas-fired Planned Outage MW (-) | 352 | 371 |
| Allowance for Unplanned Outages (-) | 2,800 | 2,800 |
| Gas Generator Outages MW (-) | 0 | 0 |
| Generation at Risk Due to Gas Supply (-) ⁴ | 0 | 0 |
| Net Capacity (NET OPCAP SUPPLY MW) ³ | 28,035 | 29,709 |
| Peak Load Forecast MW (adjusted for Other Demand Resources) ² | 29,259 | 29,259 |
| Operating Reserve Requirement MW | 2,375 | 2,375 |
| Operable Capacity Required (NET LOAD OBLIGATION MW) | 31,634 | 31,634 |
| Operable Capacity Margin ³ | (3,599) | (1,925) |

¹ Generator Operable Capacity is based on data as of March 18th, 2014 and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity.

² Based on week with lowest Operable Capacity Margin, weeks beginning May 31st, June 7th June 14th, 2014


³ Includes OP4 actions associated with RTEG and RTDR

⁴ Total of (Gas at Risk MW) – (Gas Gen Outages MW)

Summer 2014 Operable Capacity Analysis(MW)

50/50 Forecast (Reference)

New England Operable Capacity Margins - CSO with RTDR & RTEG
50/50 FORECAST




May 31, 2014 - September 13, 2014, W/B Saturday

Summer 2014 Operable Capacity Analysis(MW)

90/10 Forecast (Extreme)

New England Operable Capacity Margins - CSO with RTDR & RTEG
90/10 FORECAST



May 31, 2014 - September 13, 2014, W/B Saturday

Summer 2014 Operable Capacity Analysis(MW)

50/50 Forecast (Reference)

ISO-NE 2014 OPERABLE CAPACITY ANALYSIS

April 4, 2014 - 50/50- FORECAST - CSO

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, and August and Mid September.

| STUDY WEEK (Week Beginning, Saturday) | OPCAP SUPPLY | | | | | | | | LOAD OBLIGATIONS | | | OPCAP MARGINS | | | | |
|--|-----------------------|--|-------------------------------------|---|---|---------------------------------------|-------------------|------------------------|-----------------------------|--------------------------------------|------------------------------|-----------------------|---|---|---|--|
| | AVAILABLE OPCAP MW | EXTERNAL NODE AVAIL CAPACITY MW | NON COMMERCIAL CAPACITY MW | NON-GAS PLANNED OUTAGES CSO MW | ALLOWANCE FOR UNPLANNED OUTAGES MW | GAS GENERATOR OUTAGES CSO MW | GAS AT RISK MW | NET OPCAP SUPPLY MW | PEAK LOAD FORECAST MW | OPER RESERVE REQUIREMENT MW | NET LOAD OBLIGATION MW | OPCAP MARGIN MW | OPCAP FROM OP4 ACTIVE REAL-TIME DR MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 2 MW | OPCAP FROM OP4 REAL-TIME EMER. GEN MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 6 MW |
| | [1] | [2] | [3] | [4] | [5] | [6] | [7] | [8] | [9] | [10] | [11] | [12] | [13] | [14] | [15] | [16] |
| 5/31/2014 | 29,136 | 1,283 | 68 | 352 | 2,800 | 0 | 0 | 27,335 | 26,929 | 2,375 | 29,304 | (1,969) | 489 | (1,480) | 211 | (1,269) |
| 6/7/2014 | 29,136 | 1,283 | 68 | 352 | 2,800 | 0 | 0 | 27,335 | 26,929 | 2,375 | 29,304 | (1,969) | 489 | (1,480) | 211 | (1,269) |
| 6/14/2014 | 29,136 | 1,283 | 68 | 352 | 2,800 | 0 | 0 | 27,335 | 26,929 | 2,375 | 29,304 | (1,969) | 489 | (1,480) | 211 | (1,269) |
| 6/21/2014 | 29,136 | 1,283 | 68 | 58 | 2,800 | 0 | 0 | 27,629 | 26,929 | 2,375 | 29,304 | (1,675) | 489 | (1,186) | 211 | (975) |
| 6/28/2014 | 29,136 | 1,283 | 68 | 57 | 2,800 | 0 | 0 | 27,630 | 26,929 | 2,375 | 29,304 | (1,674) | 489 | (1,185) | 211 | (974) |
| 7/5/2014 | 29,136 | 1,283 | 68 | 57 | 2,100 | 0 | 0 | 28,330 | 26,929 | 2,375 | 29,304 | (974) | 489 | (485) | 211 | (274) |
| 7/12/2014 | 29,136 | 1,283 | 68 | 134 | 2,100 | 0 | 0 | 28,253 | 26,929 | 2,375 | 29,304 | (1,051) | 489 | (562) | 211 | (351) |
| 7/19/2014 | 29,136 | 1,283 | 68 | 57 | 2,100 | 0 | 0 | 28,330 | 26,929 | 2,375 | 29,304 | (974) | 489 | (485) | 211 | (274) |
| 7/26/2014 | 29,136 | 1,283 | 68 | 57 | 2,100 | 0 | 0 | 28,330 | 26,929 | 2,375 | 29,304 | (974) | 489 | (485) | 211 | (274) |
| 8/2/2014 | 29,136 | 1,283 | 68 | 40 | 2,100 | 0 | 0 | 28,347 | 26,929 | 2,375 | 29,304 | (957) | 489 | (468) | 211 | (257) |
| 8/9/2014 | 29,136 | 1,283 | 68 | 40 | 2,100 | 0 | 0 | 28,347 | 26,929 | 2,375 | 29,304 | (957) | 489 | (468) | 211 | (257) |
| 8/16/2014 | 29,136 | 1,283 | 68 | 48 | 2,100 | 0 | 0 | 28,339 | 26,929 | 2,375 | 29,304 | (965) | 489 | (476) | 211 | (265) |
| 8/23/2014 | 29,136 | 1,283 | 68 | 40 | 2,100 | 0 | 0 | 28,347 | 26,929 | 2,375 | 29,304 | (957) | 489 | (468) | 211 | (257) |
| 8/30/2014 | 29,136 | 1,283 | 68 | 0 | 2,100 | 0 | 0 | 28,387 | 26,929 | 2,375 | 29,304 | (917) | 489 | (428) | 211 | (217) |
| 9/6/2014 | 29,136 | 1,283 | 68 | 0 | 2,100 | 0 | 0 | 28,387 | 26,929 | 2,375 | 29,304 | (917) | 489 | (428) | 211 | (217) |
| 9/13/2014 | 29,136 | 1,283 | 68 | 157 | 2,100 | 428 | 0 | 27,802 | 23,248 | 2,375 | 25,623 | 2,179 | 489 | 2,668 | 211 | 2,879 |

1. Available OPCAP MW based on resource Capacity Supply Obligations, CSO. Does not include Settlement Only Generators.
 2. External Node Available Capacity MW based on the sum of external Capacity Supply Obligations (CSO) imports and exports.
 3. New resources that have acquired a CSO but have not become commercial.
 4. Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
 5. Allowance for Unplanned Outages includes forced outages and maintenance outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
 6. All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
 7. Generation at Risk due to Gas Supply pertains to gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
 8. Net OpCap Supply MW Available (1 + 2 + 3 - 4 - 5 - 6 - 7 = 8)
 9. Peak Load Forecast as provided in the 2013 CELT Report and adjusted for Passive Demand Resources.
 10. Operating Reserve Requirement based on 125% of first largest contingency plus 50% the second largest contingency.
 11. Total Net Load Obligation per the formula(9 + 10 = 11)
 12. Net OPCAP Margin MW = Net Op Cap Supply MW minus Net Load Obligation (8 - 11 = 12)
 13. OP 4 Action 2 Real-time Demand Response based on OP4 Appendix A. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 14. OPCAP Margin taking into account Real Time Demand Response through OP4 Step 2 (12 + 13 = 14)
 15. OP 4 Action 6 Emergency Generation Response without the Voltage Reduction requiring > 10 Minutes based on OP4 Appendix A. Real Time Emergency Generation is capped at 600MW. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 16. OPCAP Margin taking into account Real Time Demand Response and Real Time Emergency Generation through OP4 Step 6 (14 + 15 = 16)
- This does not include Emergency Energy Transactions (EETs).

Summer 2014 Operable Capacity Analysis(MW)

90/10 Forecast (Extreme)

ISO-NE 2014 OPERABLE CAPACITY ANALYSIS

April 4, 2014 - 90/10- FORECAST - CSO

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week during June, July, and August and Mid September.

| STUDY WEEK (Week Beginning, Saturday) | OPCAP SUPPLY | | | | | | | | LOAD OBLIGATIONS | | | OPCAP MARGINS | | | | |
|--|--------------------|---------------------------------|----------------------------|--------------------------------|------------------------------------|------------------------------|----------------|---------------------|-----------------------|-----------------------------|------------------------|-----------------|---------------------------------------|---|---------------------------------------|---|
| | AVAILABLE OPCAP MW | EXTERNAL NODE AVAIL CAPACITY MW | NON COMMERCIAL CAPACITY MW | NON-GAS PLANNED OUTAGES CSO MW | ALLOWANCE FOR UNPLANNED OUTAGES MW | GAS GENERATOR OUTAGES CSO MW | GAS AT RISK MW | NET OPCAP SUPPLY MW | PEAK LOAD FORECAST MW | OPER RESERVE REQUIREMENT MW | NET LOAD OBLIGATION MW | OPCAP MARGIN MW | OPCAP FROM OP4 ACTIVE REAL-TIME DR MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 2 MW | OPCAP FROM OP4 REAL-TIME EMER. GEN MW | OPCAP MARGIN w/ OP4 actions through OP4 Step 6 MW |
| | [1] | [2] | [3] | [4] | [5] | [6] | [7] | [8] | [9] | [10] | [11] | [12] | [13] | [14] | [15] | [16] |
| 5/31/2014 | 29,136 | 1,283 | 68 | 352 | 2,800 | 0 | 0 | 27,335 | 29,259 | 2,375 | 31,634 | (4,299) | 489 | (3,810) | 211 | (3,599) |
| 6/7/2014 | 29,136 | 1,283 | 68 | 352 | 2,800 | 0 | 0 | 27,335 | 29,259 | 2,375 | 31,634 | (4,299) | 489 | (3,810) | 211 | (3,599) |
| 6/14/2014 | 29,136 | 1,283 | 68 | 352 | 2,800 | 0 | 0 | 27,335 | 29,259 | 2,375 | 31,634 | (4,299) | 489 | (3,810) | 211 | (3,599) |
| 6/21/2014 | 29,136 | 1,283 | 68 | 58 | 2,800 | 0 | 0 | 27,629 | 29,259 | 2,375 | 31,634 | (4,005) | 489 | (3,516) | 211 | (3,305) |
| 6/28/2014 | 29,136 | 1,283 | 68 | 57 | 2,800 | 0 | 0 | 27,630 | 29,259 | 2,375 | 31,634 | (4,004) | 489 | (3,515) | 211 | (3,304) |
| 7/5/2014 | 29,136 | 1,283 | 68 | 57 | 2,100 | 0 | 0 | 28,330 | 29,259 | 2,375 | 31,634 | (3,304) | 489 | (2,815) | 211 | (2,604) |
| 7/12/2014 | 29,136 | 1,283 | 68 | 134 | 2,100 | 0 | 0 | 28,253 | 29,259 | 2,375 | 31,634 | (3,381) | 489 | (2,892) | 211 | (2,681) |
| 7/19/2014 | 29,136 | 1,283 | 68 | 57 | 2,100 | 0 | 0 | 28,330 | 29,259 | 2,375 | 31,634 | (3,304) | 489 | (2,815) | 211 | (2,604) |
| 7/26/2014 | 29,136 | 1,283 | 68 | 57 | 2,100 | 0 | 0 | 28,330 | 29,259 | 2,375 | 31,634 | (3,304) | 489 | (2,815) | 211 | (2,604) |
| 8/2/2014 | 29,136 | 1,283 | 68 | 40 | 2,100 | 0 | 0 | 28,347 | 29,259 | 2,375 | 31,634 | (3,287) | 489 | (2,798) | 211 | (2,587) |
| 8/9/2014 | 29,136 | 1,283 | 68 | 40 | 2,100 | 0 | 0 | 28,347 | 29,259 | 2,375 | 31,634 | (3,287) | 489 | (2,798) | 211 | (2,587) |
| 8/16/2014 | 29,136 | 1,283 | 68 | 48 | 2,100 | 0 | 0 | 28,339 | 29,259 | 2,375 | 31,634 | (3,295) | 489 | (2,806) | 211 | (2,595) |
| 8/23/2014 | 29,136 | 1,283 | 68 | 40 | 2,100 | 0 | 0 | 28,347 | 29,259 | 2,375 | 31,634 | (3,287) | 489 | (2,798) | 211 | (2,587) |
| 8/30/2014 | 29,136 | 1,283 | 68 | 0 | 2,100 | 0 | 0 | 28,387 | 29,259 | 2,375 | 31,634 | (3,247) | 489 | (2,758) | 211 | (2,547) |
| 9/6/2014 | 29,136 | 1,283 | 68 | 0 | 2,100 | 0 | 0 | 28,387 | 29,259 | 2,375 | 31,634 | (3,247) | 489 | (2,758) | 211 | (2,547) |
| 9/13/2014 | 29,136 | 1,283 | 68 | 157 | 2,100 | 428 | 0 | 27,802 | 25,275 | 2,375 | 27,650 | 152 | 489 | 641 | 211 | 852 |

- Available OPCAP MW based on resource Capacity Supply Obligations, CSO. Does not include Settlement Only Generators.
 - External Node Available Capacity MW based on the sum of external Capacity Supply Obligations (CSO) imports and exports.
 - New resources that have acquired a CSO but have not become commercial.
 - Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
 - Allowance for Unplanned Outages includes forced outages and maintenance outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
 - All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
 - Generation at Risk due to Gas Supply pertains to gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
 - Net OpCap Supply MW Available (1 + 2 + 3 - 4 - 5 - 6 - 7 = 8)
 - Peak Load Forecast as provided in the 2013 CELT Report and adjusted for Passive Demand Resources.
 - Operating Reserve Requirement based on 125% of first largest contingency plus 50% the second largest contingency.
 - Total Net Load Obligation per the formula(9 + 10 = 11)
 - Net OPCAP Margin MW = Net Op Cap Supply MW minus Net Load Obligation (8 - 11 = 12)
 - OP 4 Action 2 Real-time Demand Response based on OP4 Appendix A. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 - OPCAP Margin taking into account Real Time Demand Response through OP4 Step 2 (12 + 13 = 14)
 - OP 4 Action 6 Emergency Generation Response without the Voltage Reduction requiring > 10 Minutes based on OP4 Appendix A. Real Time Emergency Generation is capped at 600MW. Reserve Margins and Distribution Loss Factor Gross Ups are Included.
 - OPCAP Margin taking into account Real Time Demand Response and Real Time Emergency Generation through OP4 Step 6 (14 + 15 = 16)
- This does not include Emergency Energy Transactions (EETs).

OPERABLE CAPACITY ANALYSIS

Appendix

Possible Relief Under OP4 based on OP4 Appendix A

| OP 4 Action Number | Page 1 of 2 Action Description | Amount Assumed Obtainable Under OP 4 (MW) |
|--------------------|---|---|
| 1 | Implement Power Caution and advise Resources with a CSO to prepare to provide capacity and notify "Settlement Only" generators with a CSO to monitor reserve pricing to meet those obligations. Begin to allow depletion of 30-minute reserve. | 0 ¹ 600 |
| 2 | Dispatch real time Demand Resources. | April = 314 ³ May = 418 ³ June-September = 489 ³ |
| 3 | Voluntary Load Curtailment of Market Participants' facilities. | 40 ² |
| 4 | Implement Power Watch | 0 |
| 5 | Schedule Emergency Energy Transactions and arrange to purchase Control Area-to-Control Area Emergency | 1,000 |
| 6 | Voltage Reduction requiring > 10 minutes Dispatch real time Emergency Generation | 134 ⁴ April = 163 ³ May = 234 ³ June-September = 211 ³ |
| 7 | Request generating resources not subject to a Capacity Supply Obligation to voluntarily provide energy for reliability purposes | 0 |

Possible Relief Under OP4 based on OP4 Appendix A

| OP 4 Action Number | Page 2 of 2 Action Description | Amount Assumed Obtainable Under OP 4 (MW) |
|--------------------|---|---|
| 8 | Voltage Reduction requiring 10 minutes or less | 267 ⁴ |
| 9 | Transmission Customer Generation Not Contractually Available to Market Participants during a Capacity Deficiency. Voluntary Load Curtailment by Large Industrial and Commercial Customers. | 5 200 ² |
| 10 | Radio and TV Appeals for Voluntary Load Curtailment Implement Power Warning | 200 ² |
| 11 | Request State Governors to Reinforce Power Warning Appeals. | 100 ² |
| Total | | April = 3,023 MW May = 3,198 MW June-September = 3,246 MW |

NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The RTDR and RTEG MW values are based on FCM results as of March 18th, 2014.
4. The MW values are based on a 26,690 MW system load and the most recent voltage reduction test % achieved.