



**Joanne Bialas**  
Outage Coordination

To: NEPOOL Participants

From: Joanne Bialas

**Subject: 2008 Annual Maintenance Schedule – June Edition**

Date: June 5, 2008

Following this transmittal letter, you will find the 2008 Annual Maintenance Schedule (AMS) – June Edition dated June 5, 2008, with rounded weekly planned outage totals only, and an Operable Capacity Analysis (with forecasted external transactions) for 2008. Periodically, individual Participants will receive a copy of the AMS that depicts only the maintenance requests that they submitted to ISO New England. Participants that own entitlements in units must contact the Lead Participant to obtain the maintenance schedule for each unit.

**2008 AMS – JUNE EDITION - DATED JUNE 5, 2008**

The June Edition of the 2008 AMS - dated June 5, 2008 reflects all planned maintenance requests for 2008 that have been submitted to the ISO through June 3, 2008. Those generator owners who have not yet submitted their anticipated maintenance schedules for 2008 are encouraged to do so.

**2008 OPERABLE CAPACITY ANALYSIS**

The Operable Capacity Analysis for 2008 presently forecasts the lowest Long Term Operable Capacity Margin, LTOCM, of negative 1,900 MW for week beginning June 28<sup>th</sup>. Negative capacity margins are also being forecasted for all remaining weeks in June, July and August with positive capacity margins for most the remaining weeks of the year. However, it is possible that additional maintenance that may be added in upcoming editions of the 2008 AMS will reduce those margins.

**Peak Load Exposures (PLE)**

The Peak Load Exposures (PLE) for the winter and summer of 2008 are 23,030 MW and 27,970 MW respectively, and reflect the seasonal peak loads based on the 2008 CELT Report.

**Generating Unit Capabilities**

Generating unit capabilities are based upon the June 1, 2008 Seasonal Claimed Capabilities report and includes assets receiving credit as part of the Energy Management System (EMS). New unit additions are factored into the New Generation column at the appropriate points in time.

**Miscellaneous Assumptions**

The weekly Total Known Maintenance values include all generation scheduled out-of-service as reflected within this edition of the 2008 AMS.

Only known capacity-backed (ICAP) contracts have been included in the Interchange column of the

2008 Operable Capacity Analysis. This column combines monthly data, as it becomes available, with contract totals recorded in the 2008 CELT Report.

Allowances for unplanned outages, as documented in ISO New England OP-5, range from 2,100 MW during the summer months to 3,600 MW.

External Transmission

Known maintenance of Hydro-Quebec Phase II and Highgate has been included in the analysis.

Weekly Operating Reserve

The weekly operating reserve is equal to one hundred percent (100%) of the largest contingency plus one-half (50%) of the second-largest contingency.

Generation at Risk Due to Gas Supply Issues

A column has been included in the Operable Capacity Analysis to reflect natural gas-fired generating capability that may not be available around the time of the winter peak load due to the unavailability of gas.

If you have any questions or comments concerning this edition of the 2008 AMS or Operable Capacity Analysis, please feel free to contact me at (413) 535-4162 or by email at [opamoreq@iso-ne.com](mailto:opamoreq@iso-ne.com).

# 2008 ANNUAL MAINTENANCE SCHEDULE

Edition: June Edition dated June 5, 2008

Information Received through June 3, 2008

Dates indicate Saturday week beginning

Sorted by Area and Local Control Center

Plant Name	Asset ID	S. Name	RSP	LCC	PipeCompany	Blackstart	Type	WCC	SCC	June				July				August				September				October				November				December							
										31	7	14	21	28	5	12	19	26	2	9	16	23	30	6	13	20	27	4	11	18	25	1	8	15	22	29	6	13	20	27	
										round planned	0	0	0	0	0	0	0	0	0	0	0	0	0	100	900	1800	2000	3400	4100	4800	6700	5800	5600	5300	2500	2400	3200	1700	500	100	100
										TOTAL	0	0	0	0	0	0	0	0	0	0	0	0	0	100	900	1800	2000	3400	4100	4800	6700	5800	5600	5300	2500	2400	3200	1700	500	100	100

# ISO-NE 2008 OPERABLE CAPACITY ANALYSIS

## June 3, 2008 - WITH KNOWN EXTERNAL CONTRACTS - 50/50 FORECAST

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week.

It is not expected that the system peak will occur every week during June, July, and August.

Week Beginning, Saturday																
Year	Month	Day	Installed Seasonal Claimed Capability (SCC) [Note 1] (MW)	Net Interchange (NYPP, NB, HQ, Highgate) [Note 2] (MW)	Net	New Generation [Note 3] (MW)	De-listed ICAP resources [Note 4] (MW)	Net Capacity [Note 5] (MW)	Peak Load Exposure [Note 6] (MW)	Operating Reserve Requirement [Note 7] (MW)	Total Known Maintenance (MW)	Allowance for Unplanned Outages [Note 8] (MW)	Generation at Risk Due to Gas Supply [Note 9] (MW)	Total Capacity (MW)	Operable Capacity Margin (+/-) (MW)	Extent of OP 4 Actions That May be Necessary (OP 4 Actions up to and including) [Note 10]
2008	May	31	30,559	2,100		0	290	32,660	27,970	1,800	0	3,400	0	29,260	(510)	Action 6
	June	7	30,559	2,100		0	290	32,660	27,970	1,800	0	3,400	0	29,260	(510)	Action 6
		14	30,559	2,100		0	290	32,660	27,970	1,800	0	3,400	0	29,260	(510)	Action 6
		21	30,559	2,100		0	290	32,660	27,970	1,800	0	3,400	0	29,260	(510)	Action 6
		28	30,513	58		0	290	30,568	27,970	1,800	0	2,700	0	27,868	(1,900)	Action 11
2008	July	5	30,513	58		0	290	30,568	27,970	1,800	0	2,200	0	28,368	(1,400)	Action 11
		12	30,513	58		0	290	30,568	27,970	1,800	0	2,200	0	28,368	(1,400)	Action 11
		19	30,513	58		0	290	30,568	27,970	1,800	0	2,200	0	28,368	(1,400)	Action 11
		26	30,513	58		0	290	30,568	27,970	1,800	0	2,200	0	28,368	(1,400)	Action 11
2008	August	2	30,498	58		0	290	30,558	27,970	1,800	0	2,200	0	28,358	(1,410)	Action 11
		9	30,498	58		0	290	30,558	27,970	1,800	0	2,200	0	28,358	(1,410)	Action 11
		16	30,498	58		0	290	30,558	27,970	1,800	0	2,200	0	28,358	(1,410)	Action 11
		23	30,498	58		0	290	30,558	27,970	1,800	0	2,200	0	28,358	(1,410)	Action 11
		30	30,493	58		100	290	30,648	25,721	1,800	100	2,200	0	28,348	830	
2008	September	6	30,493	58		100	290	30,648	24,331	1,800	900	2,200	0	27,548	1,420	
		13	30,493	58		100	290	30,648	23,962	1,800	1,800	2,200	0	26,648	890	
		20	30,493	58		100	290	30,648	23,870	1,800	2,000	2,200	0	26,448	780	
		27	30,493	58		100	290	30,648	18,108	1,800	3,400	2,900	0	24,348	4,440	
2008	October	4	32,070	58		100	290	32,228	18,145	1,800	4,100	2,900	0	25,228	5,280	
		11	32,070	58		100	290	32,228	19,103	1,800	4,800	2,900	0	24,528	3,630	
		18	32,070	58		100	290	32,228	19,481	1,800	6,700	2,900	0	22,628	1,350	
		25	32,070	58		100	290	32,228	19,695	1,800	5,800	2,900	0	23,528	2,030	
2008	November	1	32,099	58		100	290	32,258	19,815	1,800	5,600	3,700	0	22,958	1,340	
		8	32,099	58		100	290	32,258	20,172	1,800	5,300	3,700	0	23,258	1,290	
		15	32,099	58		100	290	32,258	20,937	1,800	2,500	3,700	0	26,058	3,320	
		22	32,099	58		100	290	32,258	21,683	1,800	2,400	3,700	0	26,158	2,680	
		29	32,097	58		100	290	32,258	21,890	1,800	3,200	3,300	0	25,758	2,070	
2008	December	6	32,097	58		100	290	32,258	22,189	1,800	1,700	3,300	0	27,258	3,270	
		13	32,097	58		100	290	32,258	22,201	1,800	500	3,300	0	28,458	4,460	
		20	32,097	58		100	290	32,258	22,265	1,800	100	3,300	0	28,858	4,790	

Notes: Please note that the information contained within the Capacity Analysis is a deterministic projection of system conditions which could materialize during any given week of the year

1. Installed Capacity per the June 1, 2008 SCC report, Energy Management System units, with an adjustment for capacity increases and decreases expected during the analysis period (SCC = Seasonal Claimed Capacity). The Operable Capacity does not reflect possible transmission constraints within the ISO New England system.
2. Net Interchange is based on known capacity-backed (ICAP) contracts. This column combines monthly data, as it becomes available, with contract totals recorded in the 2008 Capacity, Energy, Loads, and Transmission - CELT Report.
3. New Generation information includes a) generation recently commercial but not yet reflected in the ISO New England SCC Report totals used in the Installed Capacity Column, and b) future generation as assumed by ISO-NE System Planning Department. This value is rounded to the nearest hundred.
4. Delisted capacity is only known for the current month. Projections are based on known delisted capacity sales.
5. Net Capacity = (SCC) + (Interchange) + (New Generation) - (Delisted ICAP Sold) In this equation, values for SCC, Interchange and De-listed ICAP sold are rounded to the nearest ten (SCC = Seasonal Claimed Capacity).
6. Peak Load Exposure per data to be included in the 2008 CELT Report.
7. Operating Reserve Requirement based on first largest contingency plus 1/2 the second largest contingency.
8. Allowance for Unplanned Outages includes forced outages and maintenance outages scheduled less than 14 days in advance.
9. Generation at Risk due to Gas Supply reflects dual fuel conversions scheduled to be complete prior to the upcoming winter.
10. Relief from certain OP 4 Actions varies depending on system conditions.

New England Operable Capacity Margins  
WITH KNOWN EXTERNAL TRANSACTIONS - 50/50 FORECAST

