

Rachel Wilkins-Thurman Outage Coordination

To: NEPOOL Participants

From: Rachel Wilkins-Thurman

Subject: 2010-11 Annual Maintenance Schedule – October Edition

Date: October 7, 2010

Following this transmittal letter, you will find the 2010-11 Annual Maintenance Schedule (AMS) – October Edition dated October 7, 2010, with rounded weekly planned outage totals only, and an Operable Capacity Analysis for October 2010 through May 2011. This schedule covers the remainder of the first Forward Capacity Market procurement period. Periodically, individual Participants will receive a copy of the AMS that depicts only the maintenance requests that they submitted to ISO New England. Participants that own entitlements in units must contact the Lead Participant to obtain the maintenance schedule for each unit.

2010-11 AMS - OCTOBER EDITION - DATED OCTOBER 7, 2010

October Edition of the 2010-11 AMS - dated October 7, 2010 reflects all planned maintenance requests for October 2010- May 2011 that have been submitted to the ISO through October 1, 2010. Those generator owners who have not yet submitted their anticipated maintenance schedules for the AMS covering the Procurement Period 2010-11 are encouraged to do so.

2010-11 OPERABLE CAPACITY ANALYSIS

The Operable Capacity Analysis for October 2010 through May 2011 presently forecasts the lowest Long Term Operable Capacity Margin, LTOCM, of positive 970 MW for week beginning May 7^{th} . However, it is possible that additional maintenance that may be added in upcoming editions of the 2010-11 AMS will reduce those margins.

Peak Load Exposures (PLE)

After being adjusted for Other Demand Resources, ODR, the Peak Load Exposure (PLE) for the summer and winter of the 2010-11 procurement period is 26,618 MW and 21,526 MW respectively, and reflects the seasonal peak load based on the 2010 CELT Report.

Generating Unit Capabilities

Resource Capacity Supply Obligations, CSO, are based upon data as of October 1, 2010 and includes Energy Management System (EMS) assets. New unit additions are factored into the New Generation column at the appropriate points in time.

Miscellaneous Assumptions

The weekly Total Known Maintenance values include all generation scheduled out-of-service as reflected within this draft of the 2010-11 AMS.

2010-11 Annual Maintenance Schedule – October Edition Page 2 of 2

Unplanned Outage Allotment

Allowances for unplanned outages, as documented in ISO New England OP-5, range from 2,100 MW during the summer months to 3,600 MW.

External Transmission

No maintenance of Hydro-Quebec Phase II or Highgate has been included in the analysis.

Weekly Operating Reserve


The weekly operating reserve is equal to one hundred percent (100%) of the largest contingency plus one-half (50%) of the second-largest contingency.

Generation at Risk Due to Gas Supply Issues

A column has been included in the Operable Capacity Analysis to reflect natural gas-fired generating capability that may not be available around the time of the winter peak load due to the unavailability of gas.

If you have any questions or comments concerning this edition of the 2010-11 AMS or Operable Capacity Analysis, If you have any comments or suggestions please feel free to contact Rachel Wilkins-Thurman at (413) 540-4261 or Joanne Bialas at (413) 535-4162 or by email at opamoreq@isone.com

	This analysis is a tabulation of weekly assessments shown in one single table. The informati OPCAP SUPPLY								LOAD OBLIGATIONS			OPCAP MARGINS				
STUDY WEEK Week Beginning,	AVAILABLE OPCAP MW	EXTERNAL NODE AVAIL OPCAP MW	NON COMMERCIAL CAPACITY MW	KNOWN OUTAGES	UNPLANNED OUTAGES MW	GEN RISK DUE TO GAS SUP MW	EXPORT LTD AVAIL OPCAP MW(with no outages	NET OPCAP SUPPLY MW	PEAK LOAD FORECAST MW	OPER RESERVE REQUIREME NT MW	NET LOAD OBLIGATION MW	MW	OPCAP FROM OP4 ACTIVE REAL-TIME DR MW	OPCAP MARGIN w/ OP4 actions through OP4 Step 2 MW	OPCAP FROM OP4 REAL- TIME EMER. GEN MW	through OP4 Step MW
Saturday)	[1]	[2]	[3]	[4]	[5]	[6]	04.000	[7]	[8]	[9]	[10]	[11]	[12]	[13]	[14] 520	[15]
10/23/2010 10/30/2010	30,291 30,259	300 424	0	5,700 6,300	2,800	0	24,630 23,986	22,090 21,580	18,110 16,484	1,800	19,910 18,284	2,180 3,300	670 670	2,850 3,970	520	400
11/6/2010	30,259	424	0	4,000	2,800	0	23,986	23,080	18,430	1,800	20,230	2.850	670	3,970	520	400
11/13/2010	30,259	424	0	3,700	3,600	0	26,249	23,080	18,430	1,800	20,230	2,850	670	3,520	520	400
									17,555			-	670		520	
11/20/2010	30,259	424	0	2,800	3,600	0	27,482	24,280		1,800	19,355	4,920		5,590		400
11/27/2010	30,259	424	0	900	3,600	0	29,383	26,180	20,234	1,800	22,034	4,150	670	4,820	520	400
12/4/2010	30,394 30,394	368	0	1,300	3,200	0	29,093	26,260	20,433	1,800	22,233	4,030	670	4,700	520	400 400
12/11/2010		368	0	700	3,200		29,718	26,860	20,720	1,800	22,520	4,340	670	5,010	520	
12/18/2010	30,394 30,394	368 368	0	300 300	3,200 3,200	0	30,062 30,096	27,260 27,260	20,731 20,793	1,800	22,531 22,593	4,730 4,670	670 670	5,400 5,340	520 520	400
1/1/2011							30,096				22,593	4,800	670	5,340	520	400
1/8/2011	30,394 30,394	368 368	0	300 300	2,800	0 2.000	30,097	27,660 25.660	21,064 21,526	1,800	22,864	2,330	670	3,000	520	400
1/15/2011	30,394	368	0	300	2,800	2,000	30,097	25,660	21,526	1,800	23,326	2,330	670	3,000	520	400
1/13/2011	30,394	368	0	300	2,800	2,000	30,066	25,660	21,526	1,800	23,326	2,330	670	3,000	520	400
1/22/2011	30,394	368	0	600	3,100	2,000	29.825	25,060	21,526	1,800	23,326	2,330	670	2.620	520	400
2/5/2011	30,394	368	0	1.000	3,100	2,000	29,440	24,660	21,000	1,800	22,840	1,820	670	2,020	520	400
2/3/2011	30,394	368	0	1,500	3,100	2,000	29,440	24,000	21,040	1,800	22,840	1,350	670	2,490	520	400
2/12/2011	30,394	368	0	1,600	3,100	2,000	28,755	24,060	20,751	1,800	22,551	1,510	670	2,020	520	400
2/19/2011	30,394	368	0	2,000	3,100	2,000	28,433	25.660	19,770	1,800	21,570	4.090	670	4,760	520	400
3/5/2011	30,394	300	0	2,000	2,200	0	27,701	25,790	19,424	1,800	21,370	4,030	670	5.240	520	400
3/12/2011	30,394	300	0	2,100	2,200	0	28,304	26,390	19,424	1,800	21,224	5,360	670	6,030	520	400
3/12/2011	30,394	300	0	1,900	2,200	0	28,515	26,590	18,867	1,800	20,667	5,920	670	6,590	520	400
3/26/2011	30,196	300	0	3,400	2,200	0	26,841	24,400	18,306	1,800	20,007	4.290	670	4,960	520	400
4/2/2011	30,196	300	0	4,400	2,700	0	25,758	23,400	17,803	1,800	19,603	3,800	670	4,470	520	400
4/9/2011	30,196	300	0	4,500	2,700	0	25,651	23,300	17,553	1,800	19,353	3,950	670	4,620	520	400
4/16/2011	30,196	300	0	4,800	2,700	0	25,400	23,000	17,047	1,800	18,847	4,150	670	4,820	520	400
4/23/2011	30,196	300	0	3,800	2,700	0	26,395	24.000	16,785	1,800	18,585	5,410	670	6,080	520	400
4/30/2011	30,196	300	0	5,100	3,400	0	25.142	22.000	16,758	1.800	18,558	3,440	670	4,110	520	400
5/7/2011	30,196	300	0	4,000	3,400	0	26,161	23,100	20,325	1,800	22,125	970	670	1,640	520	400
5/14/2011	30,196	300	0		3,400	0	28,359	25.300			23.096	2,200				400
	,	300	0	500	3,400	0	29.670				- /	,		3,270	520	400
		300	0	100	3.400	0	30.089							2,890	520	400
5/14/2011 5/21/2011 5/28/2011 Available OP(parate LTOCK External Node New resource Planned Outa Jone Outa OCM applicat Generation at Fotal OpCap Peak Load Ex	30,196 30,196 30,196 CAP MW base 4 run without a e Available OF es that have nr gges includes that have nr unplanned C tion Case Outp t Risk due to C Supply Availa	300 300 300 CAP MW base of yet acquirer outages sche utages incluc ut-System Res bas Supply pe ble per the foi ble per the foi	0 0 Capacity Supply utages, tab Case 0 d on external Ca d a CSO but will I duled greater tha les forced outage utis-UNPLAINNED rtains to gas fire- rmula (1 + 2 + 3 - the 2010 CELT Fi	1,800 500 100 Obligations, C Dutput-System F pacity Supply become commen n or equal to 1 is and mainten OUTAGES MW d capacity expet 4 - 5 - 6 = 7) Report. (LTOC	3,400 3,400 3,400 SO, from Forw Results-column L Obligations, C3 cricial in the fut 5 days in advar ance outages s 0) excted to be at ri M application-C	0 0 0 2 EXPORT SO. (LTOC! ure. Ince.	28,359 29,670 30,089 ty Tracking LTD AVAIL <i>A</i> application ess than 14 cold weather t-System R	25,300 26,600 27,000 J System, FCTS OPCAP MW) n Case Output-Sy d days in advance er conditions. (esuits-LOAD FC	21,296 22,198 22,976 Does not inc rstem Results-E e per ISO New LTOCM applica RECAST MW)	1,800 1,800 1,800 Iude Settleme XTERNAL NC England Ope	23,096 23,998 24,776 ent Only Gene DDE AVAIL OP erating Procee put-System Re	2,200 2,600 2,220 rators. CAP MW) dure No. 5 Appen isults-GEN RISK D	670 670 670 dix A.	2,870 3,270 2,890	520	4(
Peak Load Ex Operating Re D. Total Load C Net OPCAP 2. OP 4 Action 3. OPCAP Marg 4. OP 4 Action	cposure per da serve Require Dbligation per Supply minus 2 Real-time D gin taking into 6 Emergency	ata included ir ment based o the formula (f Net Load Obl emand Respo account Rea Generation R	n the 2010 CELT F n first largest cor	Report. (LTOC ntingency plus 1) 4 Appendix A. esponse throu the Voltage Re	1/2 the second Reserve Margi gh OP4 Step 2	largest co ins and Dis (11 - 12 = 1	ntingency. tribution Lo 3).	(LTOCM applica	tion Case Outp s Ups are Inclu	out-System R Ided.						



New England Operable Capacity Margins 50/50 FORECAST

October 2010 - May 2011, W/B Saturday