

Peak Data Summary

System Load Summer Peak									
	Date	Day Type	Hour Ending	Actual Peak (MW)	Reconst. Peak (MW)	Wthr Norm Peak (MW)	50-50 Frcst Peak (MW)	Percent Change	90-10 Frcst Peak (MW)
2000	June 27, 2000	Tuesday	13:00(A);14:00(R)	22,005	22,203	23,150		1.4%	
2001	August 9, 2001	Thursday	15:00(A);16:00(R)	25,072	25,660	23,790		2.8%	
2002	August 14, 2002	Wednesday	15:00	25,422	25,590	24,590		3.4%	
2003	August 22, 2003	Friday	15:00	24,685	24,692	25,170		2.4%	
2004	August 30, 2004	Monday	16:00	24,116	24,116	25,760		2.3%	
2005	July 27, 2005	Wednesday	15:00	26,885	27,166	26,305		2.1%	
2006	August 2, 2006	Wednesday	15:00	28,130	28,772	26,700		1.5%	
2007	August 3, 2007	Friday	15:00	26,145	26,364	27,220		1.9%	
2008	June 10, 2008	Tuesday	17:00	26,111	26,487	27,525		1.1%	
2009	August 18, 2009	Tuesday	15:00	25,100	25,782	27,220		-1.1%	
2010							27,190	-0.1%	29,310

System Load Winter Peak									
	Date	Day Type	Hour Ending	Actual Peak (MW)	Reconst. Peak (MW)	Wthr Norm Peak (MW)	50-50 Frcst Peak (MW)	Percent Change	90-10 Frcst Peak (MW)
00/01	December 8, 2000	Friday	18:00	20,138	20,138	20,630		0.3%	
01/02	December 17, 2001	Monday	18:00	19,902	19,902	20,785		0.8%	
02/03	January 22, 2003	Wednesday	19:00	21,533	21,533	21,010		1.1%	
03/04	January 15, 2004	Monday	19:00	22,818	22,818	21,250		1.1%	
04/05	December 20, 2004	Monday	19:00	22,635	22,635	21,790		2.5%	
05/06	December 14, 2005	Wednesday	19:00	21,733	21,785	21,960		0.8%	
06/07	February 5, 2007	Monday	19:00	21,640	21,745	21,870		-0.4%	
07/08	January 3, 2008	Thursday	19:00	21,782	22,124	22,215		1.6%	
08/09	December 8, 2008	Monday	18:00	21,022	21,581	22,190		-0.1%	
09/10	December 17, 2009	Thursday	18:00	20,791	21,557	22,030		-0.7%	
10/11							22085	0.2%	22765

Notes: MW values are System Load. See Notes page of file SMD_Hourly.xls at this link for more information: [ISO New England - Hourly Zonal Information](#)
 Reconstituted Load is MW of load reconstitution for the effects of Operating Procedure No. 4, Actions in a Capacity Deficiency and Other Demand Resources.
 For the RSP10 forecast cycle ISO-NE updated the historical weather dataset used for seasonal peak forecasting and peak weather normalization.
 The 2005 to 2009 weather normal summer peaks and the RSP10 peak forecasts are based on an updated historical weather dataset.