

# ISO-NE PAC MEETING

09/18/2024

## 302 345 kV Line Asset Condition Refurbishment

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

**nationalgrid**



# Outline

- Purpose
  - Discuss the asset condition needs driving the refurbishment of the 345 kV 302 line and alternatives to address the identified issues
- Background
- Geographic Location
- Project Needs
- Solution Alternatives
- Questions


This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

# Background

- The 345 kV 302 Line from Carpenter Hill No. 435 substation to Millbury 3 substation was energized in 1968.
- 15.9 miles in length. Originates at Carpenter Hill substation in Charlton, MA and terminates at Millbury 3 substation in Millbury, MA
- Contains 194 structures. 191 Wood Pole, 3 Steel Pole
- Existing conductor: bundled 900 AAC “Cockscomb” from 1968. 2050 Transmission Study did not identify a need for higher capacity on the line.
- Existing shieldwire: 7 No.9 Alumoweld from 1968
- In 2006, a refurbishment project was completed on the line which replaced 36 wood structures in kind due to asset condition and replaced 134 wood crossarms with steel
- The driver for this project is asset condition
- 302 (15.9 miles): 100% PTF

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

# Geographic Location



This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

**National Grid 302 345 kV Line Asset Condition Refurbishment - 09/18/24**

# Project Needs

## Asset Condition

The asset condition information is derived from the following sources:

- Engineering Ground Line Inspection – 2023
- Aerial Comprehensive Inspection – 2019
- Cyclical inspections

## Asset issues found include:

- Woodpecker damage
- Pole top deterioration
- Flashed/damaged insulators have also been observed
- Structure Bonding on 3-pole suspension pull-off structure - Original zinc bonding strips breaking down creating grounding/bonding issues. History of pole fires due to breakdown in these zinc bonding strips
- Structures identified for replacement are original vintage structures from 1968. Project aims to replace the high priority structures and opportunity structures were evaluated but no candidates were identified for replacement.

| Structures Replaced for Deteriorated Condition |        |                 |          |
|--|--------|-----------------|----------|
| Pole Type                                      | Rating | Description     | Quantity |
| Wood   | 2      | Priority Reject | 19       |
| Total Replacements                             |        |                 | 19       |


### Wood Ratings:

1. Immediate Replacement
- 2: Priority Reject,
- 3: Reject,
- 4: Serviceable

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

National Grid 302 345 kV Line Asset Condition Refurbishment - 09/18/24

# Project Needs – Points of Concern: Woodpecker




**Str 375**



**Str 301**



**Str 321**



**Str 261**



**Str 369**



**Str 408**



**Str 417**



**Str 393**

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

National Grid 302 345 kV Line Asset Condition Refurbishment - 09/18/24



# Project Needs – Points of Concern: Pole Top Deterioration



**Str 316**



**Str 321**



**Str 408**



**Str 389**

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

**National Grid** 302 345 kV Line Asset Condition Refurbishment - 09/18/24


# Project Needs– Points of Concern: Insulators




**Str 206**



**Str 374**



**Str 374**



**Str 443**

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

**National Grid** 302 345 kV Line Asset Condition Refurbishment - 09/18/24



# Solution Alternatives

## Base Alternative: Targeted Structure Replacement (Preferred)

- Replace 19 wooden pole structures with engineered H-frame steel pole structures
- Replace damaged/flashed insulators at three (3) structures
- Perform minor maintenance activities (e.g. tightening loose bolts/nuts/cotter pins) at ten (10) structures

**Total Project Cost: \$19.36M (+50/-25%), 100% PTF**

**Estimated construction start date: Q1 2025**

**Estimated in-service date: Q2 2025**

## Option 2: Wood Structure Replacement

- Replace all 191 wood pole structures with engineered steel pole structures

**Total Project Cost: \$180M (+200/-50%), 100% PTF**

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

# Solution Alternatives

## Option 3: Full Rebuild with OPGW and reconductoring

- Replace all 191 wood pole structures with engineered steel pole structures
- Replace all 3 steel structures with engineered steel pole structures
- Reconductor 15.9 miles of 2-900 AAC conductor with 2-1590 ACSS conductor
- Replace shieldwires with two (2) OPGW

**Total Project Costs: \$240M (+200/-50%), 100% PTF**

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

# Questions

## 302 345 kV Line Asset Condition Refurbishment

Project Point of Contact: Rafael Panos [Rafael.Panos@nationalgrid.com](mailto:Rafael.Panos@nationalgrid.com)

Please submit any written comments or feedback by October 02, 2024

This document has been reviewed and does not contain Critical Energy/Electric Infrastructure Information (CEII).

**nationalgrid**



national**grid**