

# NEPOOL Participants Committee Report

---

*November 2024*



Vamsi Chadalavada

EXECUTIVE VICE PRESIDENT AND CHIEF OPERATING OFFICER



# Table of Contents

• Highlights	Page	3
• System Operations	Page	9
• Market Operations	Page	18
– Supply and Demand Volumes	Page	19
– Market Pricing	Page	30
• Back-Up Detail	Page	40
– Demand Response	Page	41
– New Generation	Page	43
– Forward Capacity Market	Page	50
– Net Commitment Period Compensation (NCPC)	Page	58
– ISO Billings	Page	65
– Regional System Plan (RSP)	Page	67
– Operable Capacity Analysis –Fall 2024 Analysis	Page	93
– Operable Capacity Analysis – Winter 24/25 Analysis	Page	98
– Operable Capacity Analysis – Appendix	Page	103





# Regular Operations Report - Highlights

---



# Highlights: October 2024

- **Peak Hour** on October 28
  - 14,736 MW system peak (Revenue Quality Metered/RQM); hour ending 7:00 P.M.
- **Average Pricing**
  - Day Ahead (DA) Hub Locational Marginal Price (LMP): \$35.94/MWh
  - Real Time (RT) Hub LMP: \$34.86/MWh
  - Natural Gas: \$1.79/Mmbtu (MA Natural Gas Avg)
- **Energy Market** value \$338M up from \$259M in October 2023
  - Ancillary Markets\* value \$6.5M down from \$11.6M in October 2023
  - Average DA cleared physical energy\*\* during the peak hours as percent of forecasted load was 99.1% during October, down from 100.3% during September
  - Updated September Energy Market value: \$320M
- **Net Commitment Period Compensation (NCPC)** total \$3.4M
  - Represents 1% of monthly Energy Market value
  - First Contingency \$3.4M
    - Dispatch Lost Opportunity Cost (DLOC) - \$346.5K; Rapid Response Pricing (RRP) Opportunity Cost - \$297.1K; Posturing - \$0; Generator Performance Auditing (GPA) - \$172.6K
    - \$1.1M paid to resources at external locations, up \$403.7K from September
      - \$1.1M charged to Day Ahead Load Obligation (DALO) at external locations, \$34K to RT Deviations
  - 2nd Contingency, Distribution and Voltage payments were zero
- **Forward Capacity Market (FCM)** market value \$119.7M
  - FCM peak for 2024 is currently 24,366 MWh

\*Ancillaries = Reserves, Regulation, NCPC, less Marginal Loss Revenue Fund

\*\*DA cleared physical energy is the sum of Generation and Net Imports cleared in the DA Energy Market

Underlying natural gas data furnished by:



ISO-NE PUBLIC

# Year-to-Date Peak Load\* Statistics

- Telemetered System Peak Load: **24,310 MW**
  - hour ending 7:00 P.M. on Tuesday, July 16
- RQM System Peak Load: **24,816 MW**
  - hour ending 6:00 P.M. on Tuesday, July 16
- FCM Peak Load: **24,366 MW**
  - hour ending 6:00 P.M. on Tuesday, July 16
  - At this hour, the capacity zone-level FCM peak loads were 3,296 MW in Northern New England, 1,919 MW in Maine, 9,096 MW in Rest-of-Pool, and 10,054 MW in Southeast New England.

\*Telemetered loads are as reported by the Control Room. RQM loads are of settlement quality and reflect the contribution of Settlement Only Generation (SOG). Due to the difference in calculation methodologies and the impact of SOGs, these values can occur on different days and/or hours. Both are 'net energy for load' concepts and include transmission losses. FCM load values reflect the sum of active, normal load assets that are non-dispatchable, are included in the FCM settlement and do not include transmission losses.



# Highlights

- A new hourly forecast methodology is being implemented as part of the 2024/25 load forecasting cycle, and is being discussed at the Load Forecast Committee
- The final EPCET report was issued on October 24
- 2050 Transmission Study draft report on additional analysis to address stakeholder comments is expected to be issued by the end of 2024
- 2024 Economic Study Benchmark Scenario has been completed and the Policy and Stakeholder-Requested Scenarios are being analyzed between now and Q1 2025

# Forward Capacity Market (FCM) Highlights

- CCP 15 (2024-2025)
  - The ISO held the third annual reconfiguration auction (ARA3) over March 1-5 and posted the results on April 3
- CCP 16 (2025-2026)
  - The ISO held the second annual reconfiguration auction (ARA2) over August 1-5 and posted the results on August 30
- CCP 17 (2026-2027)
  - The ISO held the first annual reconfiguration auction (ARA1) over June 3-5 and posted the results on July 2

# FCM Highlights, cont.

- CCP 18 (2027-2028)
  - The ISO filed the auction results with FERC on February 21 and, on June 18, FERC issued an order accepting the results effective June 20
  - The ISO presented the ICR and related values for the ARAs to be conducted in 2025 at the October 18 PSPC and October 22 RC meetings; the RC voted to approve the values
- CCP 19 (2028-2029)
  - The ISO filed market rule changes to delay FCA 19 for two additional years with FERC on April 5
    - On May 20, FERC issued an order accepting the additional delay to FCA 19
  - 2024 interim RA qualification process
    - The Show of Interest submission window for the 2024 interim RA qualification process opened on April 17 and closed on April 30
    - The New Capacity Qualification Package submission window opened on June 13 and closed on June 21
    - The ISO issued qualification determination notifications on October 18
  - No ICR and related values will be calculated for CCP 19 until the CAR project is completed



# SYSTEM OPERATIONS

# System Operations

<b><u>Weather Patterns</u></b>	Boston	Temperature: Above Normal (1.7°F) Max: 83°F, Min: 36°F Precipitation: 0.91" – Below Normal Normal: 4.03"	Hartford	Temperature: Above Normal (4.3°F) Max: 86°F, Min: 32°F Precipitation: 0.52" - Below Normal Normal: 4.52"
--------------------------------	--------	---	----------	---

<b><u>Peak Load:</u></b>	14,627 MW	October 28, 2024	19:00 (ending)
--------------------------	-----------	------------------	----------------

Emergency Procedure Events (OP-4, M/LCC 2, Minimum Generation Emergency)

Procedure	Declared	Cancelled	Note
None			



# System Operations

## NPCC Simultaneous Activation of Reserve Events


Date	Area	MW Lost
10/10/2024	IESO	945



# 2024 System Operations - Load Forecast Accuracy cont.

Dashboard Indicator 


Daily Energy  
 Monthly Average, Daily Maximum and Minimum,  
 Based on forecast published at 1000 on day before Operating Day



Month	J	F	M	A	M	J	J	A	S	O	N	D	
Day Max	4.02	4.89	5.56	5.09	4.84	4.73	5.13	6.75	2.82	3.46			6.75
Day Min	0.00	0.12	0.02	0.09	0.07	0.11	0.10	0.12	0.03	0.08			0.00
MAPE	1.38	1.54	1.82	1.52	1.40	1.79	1.94	2.06	0.94	1.37			1.58
Goal	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00	2.00			

# 2024 System Operations - Load Forecast Accuracy cont.


Dashboard Indicator 



Month	J	F	M	A	M	J	J	A	S	O	N	D	
Day Max	2.90	3.17	7.45	3.99	6.46	10.30	9.30	8.86	3.96	9.78			10.30
Day Min	0.08	0.10	0.02	0.03	0.01	0.14	0.00	0.08	0.28	0.01			0.00
MAPE	1.10	1.39	1.54	1.02	1.66	2.32	2.70	2.76	1.16	1.08			1.68
Goal	1.80	1.80	1.80	1.80	2.00	2.60	2.60	2.60	2.00	1.80			


# 2024 System Operations - Load Forecast Accuracy

Dashboard Indicator 




Month	J	F	M	A	M	J	J	A	S	O	N	D	
Day Max	4.03	5.00	5.67	5.18	5.04	4.99	5.02	6.94	4.15	3.41			6.94
Day Min	0.73	0.64	0.76	1.59	1.00	0.81	1.20	0.74	0.62	0.73			0.62
MAPE	1.83	2.24	2.72	2.66	2.46	2.57	2.49	2.68	1.65	1.74			2.30
Goal	1.80	1.80	1.80	1.80	2.00	2.60	2.60	2.60	2.00	1.80			

# 2024 System Operations - Load Forecast Accuracy cont.



	J	F	M	A	M	J	J	A	S	O	N	D	Avg
Above %	67.9	37.4	53.3	55.8	48.7	47.2	62.4	42.5	41.9	56.2			51
Below %	32.1	62.6	46.7	44.2	51.3	52.8	37.6	57.5	58.1	43.8			49
Avg Above	260.5	155.2	254.6	254.9	245.5	267.4	320.4	267.8	150.6	196.7			320
Avg Below	-155.5	-292.3	-253.5	-239.2	-223.2	-265.6	-270.5	-298.2	-181.5	-97.0			-298
Avg All	132	-130	39	38	11	-16	82	-58	-29	76			16

# 2024 System Operations - Load Forecast Accuracy cont.





# Note on Wind and Solar Forecast Error Statistics

- With the launch of solar do-not-exceed dispatch in December 2023, the ISO is now able to provide the same forecast error statistics for do-not-exceed dispatchable generator (DDG) solar resources as it does for DDG wind resources
- For stakeholders' information, from now on, these monthly updates will be posted on two new pages that have been created in ISO Express:
  - [ISO Express > Operations Reports > System > Wind Forecast MAE and Bias](#)
  - [ISO Express > Operations Reports > System > Solar Forecast MAE and Bias](#)
- The ISO also provides an **annual** analysis of forecasting error statistics to the [Emerging Technologies Working Group \(ETWG\)](#)


# MARKET OPERATIONS

# SUPPLY AND DEMAND VOLUMES




# DA Cleared Native Load by Composition Compared to Native RT Load


## Daily Average MW




Day of Month



## Monthly Average MW



Month




Native Day-Ahead Load Obligation (DALO) is the sum of all day-ahead cleared load, excluding modeled transmission losses and exports


Native Real-Time Load Obligation (RTLO) is the sum of all real-time load, excluding exports

# DA Volumes as % of Forecast in Peak Hour

## Daily: This Month



## Monthly, Last 13 Months




— DA Cleared Physical Energy — DALO — 100% Line

— DA Cleared Physical Energy — DALO — 100% Line


The number of system-level manual supplemental commitments for capacity required during the Reserve Adequacy Assessment (RAA) period during the month was: [none](#)

# Resource Mix


## Daily Average MW




Day of Month



## Monthly Average MW




Month



# Renewable Generation by Fuel Type


## Daily Average MW



Day of Month



## Monthly Average MW



Month




CSF = Continuous Storage Facilities (a.k.a. Batteries)




# RT Net Interchange

## Average Daily Net Interchange MW



## Average Monthly Net Interchange MW




Export Import Net Tie

Export Import Net Tie

Net Interchange is the participant sum of daily imports minus the sum of daily exports; positive values are net imports




# RQM System Peak Load MW by Month




Shaded columns reflect current month and the same month the last 2 years

# Monthly Recorded Net Energy for Load (NEL) and Weather Normalized NEL

## Net Energy for Load (NEL)




## Weather Normalized NEL




NEPOOL NEL is the total net revenue quality metered energy required to serve load and is analogous to 'RT system load.' NEL is calculated as: Generation + Demand Response Resource output - pumping load + net interchange where imports are positively signed. Current month's data may be preliminary. Weather normalized NEL is typically reported on a one-month lag.

# DA Cleared Physical Energy Difference from RT System Load at Forecasted Peak Hour

Daily: This Month




Monthly, Last 13 Months




Negative values indicate DA Cleared Physical Energy value below its RT counterpart.

# Capacity Surplus\* Cleared in the DA Market Relative to Forecasted Peak-Hour Requirements

### Daily MW Surplus at Peak



### Monthly Avg. MW Surplus at Peak




● Surplus at Fcst Peak — Average

● Surplus at Fcst Peak — Average

\*DA capacity surplus includes DA offered ECO max above cleared amounts for cleared resources + offered reserves from available non-cleared resources + DA scheduled net interchange, reflected for the peak hour

# RT Generation Output Offered as Must Run vs Dispatchable

Participant Must Run Supply as % of Total Generation



Includes generation and DRR. Must Run (non-dispatchable) category reflects full output of settlement-only generation (SOG) as well as must run offers from modeled units

# MARKET PRICING

# DA vs. RT LMPs (\$/MWh)


Arithmetic Average

Year 2023	Hub	ME	NH	VT	CT	RI	SEMA	WCMA	NEMA
Day-Ahead	\$85.59	\$84.20	\$85.77	\$84.48	\$84.07	\$85.39	\$86.05	\$85.69	\$86.12
Real-Time	\$84.89	\$83.06	\$85.05	\$83.64	\$83.80	\$84.69	\$85.35	\$84.97	\$85.40
RT Delta %	-0.82%	-1.35%	-0.84%	-0.99%	-0.32%	-0.82%	-0.81%	-0.84%	-0.84%
Year 2022	Hub	ME	NH	VT	CT	RI	SEMA	WCMA	NEMA
Day-Ahead	\$37.04	\$36.59	\$37.22	\$36.78	\$36.25	\$36.89	\$37.34	\$37.07	\$37.35
Real-Time	\$35.91	\$35.36	\$36.05	\$35.55	\$35.26	\$35.71	\$36.17	\$35.92	\$36.21
RT Delta %	-0.82%	-1.35%	-0.84%	-0.99%	-0.32%	-0.82%	-0.81%	-0.84%	-0.84%

October-23	Hub	ME	NH	VT	CT	RI	SEMA	WCMA	NEMA
Day-Ahead	\$26.33	\$26.20	\$26.47	\$26.64	\$25.88	\$26.00	\$26.40	\$26.40	\$26.48
Real-Time	\$24.29	\$24.09	\$24.39	\$24.54	\$24.00	\$23.99	\$24.34	\$24.36	\$24.42
RT Delta %	-7.75%	-8.05%	-7.86%	-7.88%	-7.26%	-7.73%	-7.80%	-7.73%	-7.78%
October-24	Hub	ME	NH	VT	CT	RI	SEMA	WCMA	NEMA
Day-Ahead	\$35.94	\$36.22	\$36.51	\$36.39	\$34.95	\$35.27	\$35.97	\$35.96	\$36.36
Real-Time	\$34.86	\$35.16	\$35.44	\$35.32	\$34.03	\$34.25	\$34.81	\$34.87	\$35.26
RT Delta %	-3.01%	-2.93%	-2.93%	-2.94%	-2.63%	-2.89%	-3.22%	-3.03%	-3.03%
Annual Diff.	Hub	ME	NH	VT	CT	RI	SEMA	WCMA	NEMA
Yr over Yr DA	36.50%	38.24%	37.93%	36.60%	35.05%	35.65%	36.25%	36.21%	37.31%
Yr over Yr RT	43.52%	45.95%	45.31%	43.93%	41.79%	42.77%	43.02%	43.14%	44.39%

# Hourly DA LMPs, October 1-30, 2024


## Hourly Day-Ahead LMPs






# Hourly RT LMPs, October 1-30, 2024

## Hourly Real-Time LMPs




# Wholesale Electricity vs Natural Gas Prices by Month

Daily Price



— DA LMP — RT LMP — Natural Gas

Monthly Average Price



— DA LMP — RT LMP — Natural Gas


Underlying natural gas data furnished by:




Gas price is average of Massachusetts delivery points

# New England, NY, and PJM Hourly Average RT Prices by Month

Daily: This Month




Monthly, Last 13 Months




Hourly average prices are shown

# New England, NY, and PJM RT Pricing during New England's Forecasted Daily Peak Hours

Daily: This Month




Monthly, Last 13 Months




Monthly chart reflects the average of daily values

# Zonal Increment Offers and Decrement Bid Amounts

## October Inc Monthly Totals By Zone



## October Dec Monthly Totals By Zone




Includes nodal activity within the zone; excludes external nodes



# Total Increment Offers and Decrement Bids


Zonal Level, Last 13 Months



Includes nodal activity within the zone; excludes external nodes



# System Unit Availability



	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	YTD
<b>2024</b>	91	92	89	75	79	94	93	95	92	71			87
<b>2023</b>	94	92	87	71	77	84	94	93	88	71	77	86	85
<b>2022</b>	93	93	93	77	73	94	93	94	92	74	77	88	87

Data as of 10/24/24



# BACK-UP DETAIL







# DEMAND RESPONSE

# Price Responsive Demand (PRD) Energy Market Activity by Month

DA, RT, and RT Dev MWh



Market Value



DA and RT (deviation) MWh are settlement obligations and reflect appropriate gross-ups for distribution losses.



# NEW GENERATION


# New Generation Update

*Based on Queue as of 11/01/24*

- No new projects were added to the interconnection queue since the last update
  - Any new ISO Interconnection Requests seeking to successfully enter the Order No. 2023 Transitional Cluster Study process were required to be submitted by June 13, 2024 at 23:59
    - Thereafter, the creation of new ISO Interconnection Requests is now suspended until the next Cluster Entry Window opens
- In total, 405 generation projects are currently being tracked by the ISO, totaling approximately 43,297 MW

# Projected Annual Capacity Additions

## By Supply Fuel Type and Demand Resource Type




	2024	2025	2026	2027	2028	2029	2030	Total MW	% of Total <sup>1</sup>
Other Renewables	58	2	0	0	0	0	0	60	0.2
Battery	1,114	825	3,762	6,813	6,989	704	404	20,611	57.2
Solar <sup>2</sup>	1,652	765	1,477	565	823	0	0	5,282	14.7
Wind	989	2,049	1,640	1,687	394	2,400	791	9,950	27.6
Natural Gas/Oil <sup>3</sup>	73	16	0	0	0	0	0	89	0.2
Natural Gas	26	0	0	4	0	0	0	30	0.1
<b>Totals</b>	<b>3,912</b>	<b>3,657</b>	<b>6,879</b>	<b>9,069</b>	<b>8,206</b>	<b>3,104</b>	<b>1,195</b>	<b>36,022</b>	<b>100.0</b>

<sup>1</sup> Sum may not equal 100% due to rounding

<sup>2</sup> This category includes both solar-only, and co-located solar and battery projects

<sup>3</sup> The projects in this category are dual fuel, with either gas or oil as the primary fuel

# Projected Annual Generator Capacity Additions By State



	2024	2025	2026	2027	2028	2029	2030	Total MW	% of Total <sup>1</sup>
<b>Vermont</b>	0	0	128	101	115	0	0	344	1.0
<b>Rhode Island</b>	355	704	205	830	0	0	0	2,094	5.8
<b>New Hampshire</b>	73	117	504	226	0	0	0	920	2.6
<b>Maine</b>	487	1,031	2,799	453	984	0	0	5,754	16.0
<b>Massachusetts</b>	1,872	1,461	1,923	4,670	5,710	2,650	1,195	19,481	54.1
<b>Connecticut</b>	1,125	344	1,320	2,789	1,397	454	0	7,429	20.6
<b>Totals</b>	<b>3,912</b>	<b>3,657</b>	<b>6,879</b>	<b>9,069</b>	<b>8,206</b>	<b>3,104</b>	<b>1,195</b>	<b>36,022</b>	<b>100.0</b>

<sup>1</sup> Sum may not equal 100% due to rounding

# New Generation Projection

## *By Fuel Type*

Unit Type	Total		Green		Yellow	
	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)
Biomass/Wood Waste	0	0	0	0	0	0
Battery Storage	129	20,611	2	325	127	20,286
Fuel Cell	3	32	1	20	2	12
Hydro	1	28	1	28	0	0
Natural Gas	4	30	0	0	4	30
Natural Gas/Oil	2	89	0	0	2	89
Nuclear	0	0	0	0	0	0
Solar	240	5,282	14	310	226	4,972
Wind	26	17,225	3	985	23	16,240
<b>Total</b>	<b>405</b>	<b>43,297</b>	<b>21</b>	<b>1,668</b>	<b>384</b>	<b>41,629</b>

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel
- Green denotes projects with a high probability of going into service within the next 12 months
- Yellow denotes projects with a lower probability of going into service or new applications

# New Generation Projection

## *By Operating Type*

Operating Type	Total		Green		Yellow	
	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)
Baseload	6	73	2	48	4	25
Intermediate	2	89	0	0	2	89
Peaker	371	25,910	16	635	355	25,275
Wind Turbine	26	17,225	3	985	23	16,240
<b>Total</b>	<b>405</b>	<b>43,297</b>	<b>21</b>	<b>1,668</b>	<b>384</b>	<b>41,629</b>

- Green denotes projects with a high probability of going into service within the next 12 months
- Yellow denotes projects with a lower probability of going into service or new applications



# New Generation Projection

## *By Operating Type and Fuel Type*

Unit Type	Total		Baseload		Intermediate		Peaker		Wind Turbine	
	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)	No. of Projects	Capacity (MW)
Biomass/Wood Waste	0	0	0	0	0	0	0	0	0	0
Battery Storage	129	20,611	0	0	0	0	129	20,611	0	0
Fuel Cell	3	32	3	32	0	0	0	0	0	0
Hydro	1	28	1	28	0	0	0	0	0	0
Natural Gas	4	30	2	13	0	0	2	17	0	0
Natural Gas/Oil	2	89	0	0	2	89	0	0	0	0
Nuclear	0	0	0	0	0	0	0	0	0	0
Solar	240	5,282	0	0	0	0	240	5,282	0	0
Wind	26	17,225	0	0	0	0	0	0	26	17,225
<b>Total</b>	<b>405</b>	<b>43,297</b>	<b>6</b>	<b>73</b>	<b>2</b>	<b>89</b>	<b>371</b>	<b>25,910</b>	<b>26</b>	<b>17,225</b>

- Projects in the Natural Gas/Oil category may have either gas or oil as the primary fuel

# FORWARD CAPACITY MARKET

# Capacity Supply Obligation FCA 14

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	592.043	688.07	96.027	659.671	-28.399	564.371	-95.3
	Passive Demand	3,327.071	3,327.932	0.861	3,315.207	-12.725	3,253.179	-62.028
Demand Total		3,919.114	4,016.002	96.888	3,974.878	-41.124	3,817.550	-157.328
Generator	Non-Intermittent	27,816.902	28,275.143	458.241	27,697.714	-577.429	27,684.252	-13.462
	Intermittent	1,160.916	1,128.446	-32.47	925.942	-202.504	893.444	-32.498
Generator Total		28,977.818	29,403.589	425.771	28,623.656	-779.933	28,577.696	-45.96
Import Total		1,058.72	1,058.72	0	1,029.800	-28.92	958.380	-71.42
Grand Total*		33,955.652	34,478.311	522.661	33,628.334	-849.977	33,353.626	-274.708
Net ICR (NICR)		32,490	32,980	490	31,480	-1,500	31,690	210

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond reconfiguration auctions may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2023-2027 CCP Month Capacity Supply Obligation Changes report on the ISO New England website.

# Capacity Supply Obligation FCA 15

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	677.673	673.401	-4.272	579.692	-93.709	461.416	-118.276
	Passive Demand	3,212.865	3,211.403	-1.462	3,134.652	-76.751	3,113.332	-21.32
<b>Demand Total</b>		<b>3,890.538</b>	<b>3,884.804</b>	<b>-5.734</b>	<b>3,714.344</b>	<b>-170.460</b>	<b>3,574.748</b>	<b>-139.596</b>
Generator	Non-Intermittent	28,154.203	27,714.778	-439.425	27,081.653	-633.125	27,132.413	50.76
	Intermittent	1,089.265	1,073.794	-15.471	1,056.601	-17.193	865.694	-190.907
<b>Generator Total</b>		<b>29,243.468</b>	<b>28,788.572</b>	<b>-454.896</b>	<b>28,138.254</b>	<b>-650.318</b>	<b>27,998.107</b>	<b>-140.147</b>
<b>Import Total</b>		<b>1,487.059</b>	<b>1,297.132</b>	<b>-189.927</b>	<b>1,249.545</b>	<b>-47.587</b>	<b>1,193.583</b>	<b>-55.962</b>
<b>Grand Total*</b>		<b>34,621.065</b>	<b>33,970.508</b>	<b>-650.557</b>	<b>33,102.143</b>	<b>-868.365</b>	<b>32,766.438</b>	<b>-335.705</b>
<b>Net ICR (NICR)</b>		<b>33,270</b>	<b>31,775</b>	<b>-1,495</b>	<b>31,545</b>	<b>-230</b>	<b>31,380</b>	<b>-165</b>

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond reconfiguration auctions may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2023-2027 CCP Month Capacity Supply Obligation Changes report on the ISO New England website.

# Capacity Supply Obligation FCA 16

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	765.35	589.882	-175.468	504.466	-85.416		
	Passive Demand	2,557.256	2,579.120	21.864	2,574.367	-4.753		
Demand Total		3,322.606	3,169.002	-153.604	3,078.833	-90.169		
Generator	Non-Intermittent	26,805.003	26,643.379	-161.624	26,503.730	-139.649		
	Intermittent	1,178.933	1,146.783	-32.15	989.265	-157.518		
Generator Total		27,983.936	27,790.162	-193.774	27,492.995	-297.167		
Import Total		1,503.842	1,247.601	-256.241	1,244.601	-3.000		
Grand Total*		32,810.384	32,206.765	-603.619	31,816.429	-390.336		
Net ICR (NICR)		31,645	30,585	-1,060	30,775	190.000		

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond reconfiguration auctions may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2023-2027 CCP Month Capacity Supply Obligation Changes report on the ISO New England website.

# Capacity Supply Obligation FCA 17

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	622.854	584.913	-37.941				
	Passive Demand	2,316.815	2,314.068	-2.747				
<b>Demand Total</b>		<b>2,939.669</b>	<b>2,898.981</b>	<b>-40.688</b>				
Generator	Non-Intermittent	26,507.420	26,715.489	208.069				
	Intermittent	1,356.084	1,286.589	-69.495				
<b>Generator Total</b>		<b>27,863.504</b>	<b>28,002.078</b>	<b>138.574</b>				
<b>Import Total</b>		<b>566.998</b>	<b>564.079</b>	<b>-2.919</b>				
<b>Grand Total*</b>		<b>31,370.171</b>	<b>31,465.138</b>	<b>94.967</b>				
<b>Net ICR (NICR)</b>		<b>30,305</b>	<b>30,395</b>	<b>90.000</b>				

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond reconfiguration auctions may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2023-2027 CCP Month Capacity Supply Obligation Changes report on the ISO New England website.

# Capacity Supply Obligation FCA 18

Resource Type	Resource Type	FCA	ARA 1		ARA 2		ARA 3	
		CSO	CSO	Change	CSO	Change	CSO	Change
		MW	MW	MW	MW	MW	MW	MW
Demand	Active Demand	543.580						
	Passive Demand	2,070.498						
Demand Total		2,614.078						
Generator	Non-Intermittent	27,026.635						
	Intermittent	1,450.872						
Generator Total		28,477.507						
Import Total		464.835						
Grand Total*		31,556.420						
Net ICR (NICR)		30,550						

\* Grand Total reflects both CSO Grand Total and the net total of the Change Column

Note: A resource's CSO may change for a variety of reasons outside ISO-NE administered trading windows. Reasons for CSO changes beyond reconfiguration auctions may include terminations or recent declaration of commercial operation. Details of the changes that occurred due to non-annual event purposes are contained in the 2023-2027 CCP Month Capacity Supply Obligation Changes report on the ISO New England website.

# Active/Passive Demand Response


## CSO Totals by Commitment Period

Commitment Period	Active/Passive	Existing	New	Grand Total
2021-22	Active	480.941	143.504	624.445
	Passive	2,604.79	370.568	2,975.36
	<b>Grand Total</b>	<b>3,085.734</b>	<b>514.072</b>	<b>3,599.806</b>
2022-23	Active	598.376	87.178	685.554
	Passive	2,788.33	566.363	3,354.69
	<b>Grand Total</b>	<b>3,386.703</b>	<b>653.541</b>	<b>4,040.244</b>
2023-24	Active	560.55	31.493	592.043
	Passive	3,035.51	291.565	3,327.07
	<b>Grand Total</b>	<b>3,596.056</b>	<b>323.058</b>	<b>3,919.114</b>
2024-25	Active	674.153	3.520	677.673
	Passive	3,046.064	166.801	3,212.865
	<b>Grand Total</b>	<b>3,720.217</b>	<b>170.321</b>	<b>3,890.538</b>
2025-26	Active	664.01	101.34	765.35
	Passive	2,428.638	128.618	2557.256
	<b>Grand Total</b>	<b>3,092.648</b>	<b>229.958</b>	<b>3,322.606</b>
2026-27	Active	615.369	7.485	622.854
	Passive	2,194.172	122.643	2,316.815
	<b>Grand Total</b>	<b>2,809.541</b>	<b>130.128</b>	<b>2,939.669</b>
2027-28	Active	543.58	0.0	543.58
	Passive	1,965.515	104.983	2070.498
	<b>Grand Total</b>	<b>2,509.095</b>	<b>104.983</b>	<b>2,614.498</b>



# Forward Capacity Market Auctions

## Cumulative FCM Charges by CCP




The items in the graph shaded in a lighter color represent the forecast for future months in the Capacity Commitment Period (CCP)

# NET COMMITMENT PERIOD COMPENSATION


# DA and RT NCPC Charges

Oct-24 Total = \$3.4 M



Day-Ahead Real-Time


Last 13 Months



Day-Ahead Real-Time

# NCPC Charges by Type


Oct-24 Total = \$3.4 M




100.0%



Last 13 Months




# NCPC Charges by Type as Percent of Energy Market Value




# NCPC Charge Allocations

Oct-24 Total = \$3.4 M




Last 13 Months




# RT First Contingency NCPC Paid to Units and Allocated to RTLO and/or RTGO

Oct-24 Total = \$0.8 M




Last 13 Months




The categories shown above are a subset of those reflected in First Contingency NCPC throughout this report. The above categories are allocated to RTLO, except for Min Gen Emergency credits, which are allocated to RTGO.

# RT First Contingency Charges by Deviation Type

Oct-24 Total = \$1.1 M



Last 13 Months







# ISO BILLINGS

# Total ISO Billings

## Monthly Billed Amounts



## Annual Cumulative Billed Amounts



Ancillaries = Reserves, Regulation, NCPC, minus Marginal Loss Revenue Fund. OATT = RNS, Through and Out, Schedule 9

# REGIONAL SYSTEM PLAN (RSP)

# Planning Advisory Committee (PAC)

- November 20 PAC Meeting Agenda Topics\*
  - Asset Condition Projects
    - Line 387 Asset Condition Structure Replacements Project (Eversource)
    - Line 1356 Asset Condition Structure Replacements Project (Eversource)
    - Line 191 OPGW (Eversource)
    - 337 345 kV Line Asset Condition Refurbishment (NGRID)
    - 338 345 kV Line Asset Condition Refurbishment (NGRID)
  - 2024 Economic Study: Policy Reference Results
  - Planning Process Guide for Longer Term Transmission Planning

\* Agenda topics are subject to change. Visit <https://www.iso-ne.com/committees/planning/planning-advisory> for the latest PAC agendas.

# Economic Studies: EPCET

- Economic Planning for the Clean Energy Transition (EPCET) Pilot Study
  - An effort to review all assumptions in economic planning and perform a test study consistent with the changes to the Tariff
  - This study is now complete with the issuance of the final report and two-pager on October 24
  - A webinar is planned for November

# Economic Studies: 2024 Study


- The 2024 Economic Study
  - This study is the first use of new Economic Study Process Tariff language
    - The study was initiated at the January PAC meeting
  - The Benchmark Scenario has been completed and the Policy and Stakeholder-Requested Scenarios are being analyzed between now and Q1 2025
    - The stakeholder-Requested Scenario was discussed at the June PAC meeting; it focuses on the use of peaker plants in various future power system resource mixes
  - The Market Efficiency Needs Scenario will be studied in 2025

# ISO-NE Tie Benefits Evaluation

- The ISO presented the tie benefits evaluation at the October 19, 2023, January 25, 2024, and March 15, 2024 PSPC meetings
- The ISO issued a memo on June 26, 2024 to the RC and PSPC to summarize the evaluation and provide additional next steps
  - Continue to reach out to neighboring Balancing Areas to further modeling improvements
  - Continue efforts to adapt the current tie benefit methodology into a seasonal capacity market


# New England Power System Carbon Emissions

## 2023 vs. 2024 New England Power System Estimated Carbon Dioxide (CO<sub>2</sub>) Emissions



Data as of 10/20/24

## Regional Greenhouse Gas Initiative (RGGI) Allowance Prices



- 10/21/24: RGGI allowance spot price - \$20.90
- 10/08/24: RGGI issued notice for the 66<sup>th</sup> Auction scheduled for December 4
  - Initial offering includes 15,943,608 CO<sub>2</sub> allowances
  - The Cost Containment Reserve for 2024 was depleted in Auction 63 and are not available in Auction 66




# Massachusetts CO<sub>2</sub> Generator Emissions Cap

## 2024 Estimated Emissions Under CO<sub>2</sub> Cap


- As of 10/22/24, October estimated GWSA CO<sub>2</sub> emissions range between **368,466** and **454,018** metric tons
  - Year-to-date 2024 estimated emissions range between **59.1%** and **72.7%** of the 2024 cap of 7.61 MMT

## 2024 Q1/Q2 Actual Emissions Under CO<sub>2</sub> Cap

- According to the [EPA CAMPD](#), Quarter 1 and 2 (January-June) 2024 GWSA CO<sub>2</sub> emissions were **2.74 MMT**, or **36.0%** of the 2024 cap of 7.61 MMT



## 2021-2024 Estimated Monthly Emissions (Thousand Metric Tons)



GWSA – Global Warming Solutions Act  
MMT – Million Metric Tons

Source: ISO-NE (estimated emissions)

# RSP Project Stage Descriptions

Stage	Description
1	Planning and Preparation of Project Configuration
2	Pre-construction (e.g., material ordering, project scheduling)
3	Construction in Progress
4	In Service

Note: The listings in this section focus on major transmission line construction and rebuilding.



# Greater Boston Projects

*Status as of 10/25/2024*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1213, 1220, 1365	Install new 345 kV line from Scobie to Tewksbury	Dec-17	4
1527, 1528	Reconductor the Y-151 115 kV line from Dracut Junction to Power Street	Apr-17	4
1212, 1549	Reconductor the M-139 115 kV line from Tewksbury to Pinehurst and associated work at Tewksbury	May-17	4
1549	Reconductor the N-140 115 kV line from Tewksbury to Pinehurst and associated work at Tewksbury	May-17	4
1260	Reconductor the F-158N 115 kV line from Wakefield Junction to Maplewood and associated work at Maplewood	Dec-15	4
1550	Reconductor the F-158S 115 kV line from Maplewood to Everett	Jun-19	4
1551, 1552	Install new 345 kV cable from Woburn to Wakefield Junction, install two new 160 MVAR variable shunt reactors and associated work at Wakefield Junction and Woburn*	Mar-24	4
1329	Refurbish X-24 69 kV line from Millbury to Northboro Road	Dec-15	4
1327	Reconductor W-23W 69 kV line from Woodside to Northboro Road	Jun-19	4

# Greater Boston Projects, cont.

*Status as of 10/25/2024*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1330	Separate X-24 and E-157W DCT	Dec-18	4
1363	Separate Q-169 and F-158N DCT	Dec-15	4
1637, 1640	Reconductor M-139/211-503 and N-140/211-504 115 kV lines from Pinehurst to North Woburn tap	May-17	4
1516	Install new 115 kV station at Sharon to segment three 115 kV lines from West Walpole to Holbrook	Sep-20	4
965	Install third 115 kV line from West Walpole to Holbrook	Sep-20	4
1558	Install new 345 kV breaker in series with the 104 breaker at Stoughton	May-16	4
1199	Install new 230/115 kV autotransformer at Sudbury and loop the 282-602 230 kV line in and out of the new 230 kV switchyard at Sudbury	Dec-17	4
1335	Install a new 115 kV line from Sudbury to Hudson	Mar-25	3

# Greater Boston Projects, cont.

*Status as of 10/25/2024*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1336	Replace 345/115 kV autotransformer, 345 kV breakers, and 115 kV switchgear at Woburn	Dec-19	4
1553	Install a 345 kV breaker in series with breaker 104 at Woburn	Jun-17	4
1337	Reconfigure Waltham by relocating PARs, 282-507 line, and a breaker	Dec-17	4
1339	Upgrade 533-508 115 kV line from Lexington to Hartwell and associated work at the stations	Aug-16	4
1521	Install a new 115 kV 54 MVAR capacitor bank at Newton	Dec-16	4
1522	Install a new 115 kV 36.7 MVAR capacitor bank at Sudbury	May-17	4
1352	Install a second Mystic 345/115 kV autotransformer and reconfigure the bus	May-19	4
1353	Install a 115 kV breaker on the East bus at K Street	Jun-16	4
1354, 1738	Install 115 kV cable from Mystic to Chelsea and upgrade Chelsea 115 kV station to BPS standards	Jul-21	4
1355	Split 110-522 and 240-510 DCT from Baker Street to Needham for a portion of the way and install a 115 kV cable for the rest of the way	Mar-21	4

# Greater Boston Projects, cont.

*Status as of 10/25/2024*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

<b>RSP Project List ID</b>	<b>Upgrade</b>	<b>Expected/ Actual In-Service</b>	<b>Present Stage</b>
1356	Install a second 115 kV cable from Mystic to Woburn to create a bifurcated 211-514 line	Mar-24	4
1357	Open lines 329-510/511 and 250-516/517 at Mystic and Chatham, respectively. Operate K Street as a normally closed station.	May-19	4
1518	Upgrade Kingston to create a second normally closed 115 kV bus tie and reconfigure the 345 kV switchyard	Mar-19	4
1519	Relocate the Chelsea capacitor bank to the 128-518 termination postion	Dec-16	4

# Greater Boston Projects, cont.

*Status as of 10/25/2024*

*Plan Benefit: Addresses long-term system needs in the Greater Boston area and improves system reliability*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1520	Upgrade North Cambridge to mitigate 115 kV 5 and 10 stuck breaker contingencies	Dec-17	4
1643	Install a 200 MVAR STATCOM at Coopers Mills	Nov-18	4
1341, 1645	Install a 115 kV 36.7 MVAR capacitor bank at Hartwell	May-17	4
1646	Install a 345 kV 160 MVAR shunt reactor at K Street	Dec-19	4
1647	Install a 115 kV breaker in series with the 5 breaker at Framingham	Mar-17	4
1554	Install a 115 kV breaker in series with the 29 breaker at K Street	Apr-17	4

# SEMA/RI Reliability Projects

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

<b>RSP Project List ID</b>	<b>Upgrade</b>	<b>Expected/Actual In-Service</b>	<b>Present Stage</b>
1714	Construct a new 115 kV GIS switching station (Grand Army) which includes remote terminal station work at Brayton Point and Somerset substations, and the looping in of the E-183E, F-184, X3, and W4 lines	Oct-20	4
1742	Conduct remote terminal station work at the Wampanoag and Pawtucket substations for the new Grand Army GIS switching station	Oct-20	4
1715	Install upgrades at Brayton Point substation which include a new 115 kV breaker, new 345/115 kV transformer, and upgrades to E183E, F184 station equipment	Oct-20	4
1716	Increase clearances on E-183E & F-184 lines between Brayton Point and Grand Army substations	Nov-19	4
1717	Separate the X3/W4 DCT and reconductor the X3 and W4 lines between Somerset and Grand Army substations; reconfigure Y2 and Z1 lines	Nov-19	4



# SEMA/RI Reliability Projects, cont.

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1718	Add 115 kV circuit breaker at Robinson Ave substation and re-terminate the Q10 line	Mar-22	4
1719	Install 45.0 MVAR capacitor bank at Berry Street substation	Cancelled*	N/A
1720	Separate the N12/M13 DCT and reconductor the N12 and M13 between Somerset and Bell Rock substations	Mar-27	2
1721	Reconfigure Bell Rock to breaker-and-a-half station, split the M13 line at Bell Rock substation, and terminate 114 line at Bell Rock; install a new breaker in series with N12/D21 tie breaker, upgrade D21 line switch, and install a 37.5 MVAR capacitor	Aug-23	4
1722	Extend the Line 114 from the Dartmouth town line (Eversource-National Grid border) to Bell Rock substation	Dec-25	2
1723	Reconductor L14 and M13 lines from Bell Rock substation to Bates Tap	Cancelled*	N/A

\*Cancelled per ISO-NE PAC presentation on August 27, 2020

# SEMA/RI Reliability Projects, cont.

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

<b>RSP Project List ID</b>	<b>Upgrade</b>	<b>Expected/Actual In-Service</b>	<b>Present Stage</b>
1725	Build a new 115 kV line from Bourne to West Barnstable substations which includes associated terminal work	May-24	4
1726	Separate the 135/122 DCT from West Barnstable to Barnstable substations	Dec-21	4
1727	Retire the Barnstable SPS	Nov-21	4
1728	Build a new 115 kV line from Carver to Kingston substations and add a new Carver terminal	Aug-23	4
1729	Install a new bay position at Kingston substation to accommodate new 115 kV line	Aug-23	4
1730	Extend the 114 line from the Eversource/National Grid border to the Industrial Park Tap	Dec-25	2

# SEMA/RI Reliability Projects, cont.

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1731	Install 35.3 MVAR capacitors at High Hill and Wing Lane substations	Dec-21	4
1732	Loop the 201-502 line into the Medway substation to form the 201-502N and 201-502S lines	Dec-25	3
1733	Separate the 325/344 DCT lines from West Medway to West Walpole substations	Cancelled**	N/A
1734	Reconductor and upgrade the 112 Line from the Tremont substation to the Industrial Tap	Jun-18	4
1736	Reconductor the 108 line from Bourne substation to Horse Pond Tap*	Oct-18	4
1737	Replace disconnect switches on 323 line at West Medway substation and replace 8 line structures	Aug-20	4

\* Does not include the reconductoring work over the Cape Cod canal

\*\* Cancelled per ISO-NE PAC presentation on August 27, 2020

# SEMA/RI Reliability Projects, cont.

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Southeast Massachusetts/Rhode Island area*

<b>RSP Project List ID</b>	<b>Upgrade</b>	<b>Expected/Actual In-Service</b>	<b>Present Stage</b>
1741	Rebuild the Middleborough Gas and Electric portion of the E1 line from Bridgewater to Middleborough	Apr-19	4
1782	Reconductor the J16S line	May 22	4
1724	Replace the Kent County 345/115 kV transformer	Mar-22	4
1789	West Medway 345 kV circuit breaker upgrades	Apr-21	4
1790	Medway 115 kV circuit breaker replacements	Nov-20	4

# Eastern CT Reliability Projects

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Eastern Connecticut area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1815	Reconductor the L190-4 and L190-5 line sections	Dec-24	3
1850	Install a second 345/115 kV autotransformer (4X) and one 345 kV breaker at Card substation	Dec-22	4
1851	Upgrade Card 115 kV to BPS standards	Dec-22	4
1852	Install one 115 kV circuit breaker in series with Card substation 4T	Feb-23	4
1853	Convert Gales Ferry substation from 69 kV to 115 kV	Nov-23	4
1854	Rebuild the 100 Line from Montville to Gales Ferry to allow operation at 115 kV	Jun-23	4



# Eastern CT Reliability Projects, cont.

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Eastern Connecticut area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1855	Re-terminate the 100 Line at Montville station and associated work. Energize the 100 Line at 115 kV	Jun-23	4
1856	Rebuild 400-1 Line section to allow operation at 115 kV (Tunnel to Ledyard Jct.)	Feb-23	4
1857	Add one 115 kV circuit breaker and re-terminate the 400-1 line section into Tunnel substation. Energize 400 Line at 115 kV	Feb-23	4
1858	Rebuild 400-2 Line section to allow operation at 115 kV (Ledyard Jct. to Border Bus with CMEEC)	Sept-22	4
1859	Rebuild the 400-3 Line Section to allow operation at 115 kV (Gales Ferry to Ledyard Jct.)	Feb-23	4
1860	Install a 25.2 MVAR 115 kV capacitor and one capacitor breaker at Killingly	Dec-21	4

# Eastern CT Reliability Projects, cont.

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Eastern Connecticut area*

RSP Project List ID	Upgrade	Expected/Actual In-Service	Present Stage
1861	Install one 345 kV series breaker with the Montville 1T	Nov-21	4
1862	Install a +55/-29 MVAR synchronous condenser with two 115 kV breakers at Shunock	Dec-23	4
1863	Install a 1% series reactor with bypass switch at Mystic, CT on the 1465 Line	Mar-22	4
1864	Convert the 400-2 Line Section to 115 kV (Border Bus to Buddington)	Feb-23	4
1904	Convert 69 kV equipment at Buddington to 115 kV to facilitate the conversion of the 400-2 line to 115 kV	Dec-23	4

# New Hampshire Solution Projects

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the New Hampshire area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1878	Install a +55/-32.2 MVAR synchronous condenser at N. Keene 115 kV Substation with a 115 kV breaker	Jun-25	3
1879	Install a +55/-32.2 MVAR synchronous condenser at Huckins Hill 115 kV Substation with a 115 kV breaker	Dec-24	3
1880	Install a +127/-50 MVAR synchronous condenser at Amherst 345 kV Substation with two 345 kV breakers	Dec 24	3
1881	Install two 50 MVAR capacitors on Line 363 near Seabrook Station with three 345 kV breakers	Oct-23	4





# Upper Maine Solution Projects

*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Upper Maine area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1882	Rebuild 21.7 miles of the existing 115 kV line Section 80 Highland-Coopers Mills 115 kV line	Aug-24	4
1883	Convert the Highland 115 kV substation to an eight breaker, breaker-and-a-half configuration with a bus connected 115/34.5 kV transformer	Jul-28	1
1884	Install a 15 MVAR capacitor at Belfast 115 kV substation	Jul-28	1
1885	Install a +50/-25 MVAR synchronous condenser at Highland 115 kV substation	Jul-28	1
1886	Install +50/-25 MVAR synchronous condenser at Boggy Brook 115 kV substation, and install a new 115 kV breaker to separate Line 67 from the proposed solution elements	Nov-24	3



# Upper Maine Solution Projects, cont.


*Status as of 10/25/2024*

*Project Benefit: Addresses system needs in the Upper Maine area*

RSP Project List ID	Upgrade	Expected/ Actual In-Service	Present Stage
1887	Install 25 MVAR reactor at Boggy Brook 115 kV substation	Nov-24	3
1888	Install 10 MVAR reactor at Keene Road 115 kV substation	Jul-24	4
1889	Install three remotely monitored and controlled switches to split the existing Orrington reactors between the two Orrington 345/115 kV autotransformers	Cancelled *	N/A
1914	Install a new 80 MVAR reactor, reconfigure the existing two reactors at the 345 kV Orrington substation	Dec-25	2


\* Cancelled per the Upper Maine Solutions Study Addendum that was published on January 11, 2024

# Status of Tariff Studies as of November 1, 2024



# What is in the Queue (as of November 1, 2024)

Storage Projects are proposed as stand-alone storage or as co-located with wind or solar projects



# OPERABLE CAPACITY ANALYSIS

*Fall 2024 Analysis*

# Fall 2024 Operable Capacity Analysis

50/50 Load Forecast (Reference)	Nov - 2024 <sup>2</sup> CSO (MW)	Nov - 2024 <sup>2</sup> SCC (MW)
Operable Capacity MW <sup>1</sup>	27,873	29,953
Active Demand Capacity Resource (+) <sup>5</sup>	382	340
External Node Available Net Capacity, CSO imports minus firm capacity exports (+)	1,164	1,164
Non Commercial Capacity (+)	16	16
Non Gas-fired Planned Outage MW (-)	2,917	3,449
Gas Generator Outages MW (-)	2,906	3,637
Allowance for Unplanned Outages (-) <sup>4</sup>	3,600	3,600
Generation at Risk Due to Gas Supply (-) <sup>3</sup>	0	0
Net Capacity (NET OPCAP SUPPLY MW)	20,012	20,787
Peak Load Forecast MW (adjusted for Other Demand Resources) <sup>2</sup>	18,211	18,211
Operating Reserve Requirement MW	2,125	2,125
Operable Capacity Required (NET LOAD OBLIGATION MW)	20,336	20,336
Operable Capacity Margin	-324	451

<sup>1</sup>Operable Capacity is based on data as of **Oct 31, 2024** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **Oct 31, 2024**.

<sup>2</sup> Load forecast that is based on the 2024 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **Nov 16, 2024**.

<sup>3</sup> Total of (Gas at Risk MW) – (Gas Gen Outages MW).

<sup>4</sup> Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

<sup>5</sup> Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

# Fall 2024 Operable Capacity Analysis

90/10 Load Forecast	Nov - 2024 <sup>2</sup> CSO (MW)	Nov - 2024 <sup>2</sup> SCC (MW)
Operable Capacity MW <sup>1</sup>	27,873	29,953
Active Demand Capacity Resource (+) <sup>5</sup>	382	340
External Node Available Net Capacity, CSO imports minus firm capacity exports (+)	1,164	1,164
Non Commercial Capacity (+)	16	16
Non Gas-fired Planned Outage MW (-)	2,917	3,449
Gas Generator Outages MW (-)	2,906	3,637
Allowance for Unplanned Outages (-) <sup>4</sup>	3,600	3,600
Generation at Risk Due to Gas Supply (-) <sup>3</sup>	0	0
Net Capacity (NET OPCAP SUPPLY MW)	20,012	20,787
Peak Load Forecast MW (adjusted for Other Demand Resources) <sup>2</sup>	18,921	18,921
Operating Reserve Requirement MW	2,125	2,125
Operable Capacity Required (NET LOAD OBLIGATION MW)	21,046	21,046
Operable Capacity Margin	-1,034	-259

<sup>1</sup>Operable Capacity is based on data as of **Oct 31, 2024** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **Oct 31, 2024**.

<sup>2</sup> Load forecast that is based on the 2024 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **Nov 16, 2024**.

<sup>3</sup> Total of (Gas at Risk MW) – (Gas Gen Outages MW).

<sup>4</sup> Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

<sup>5</sup> Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

# Fall 2024 Operable Capacity Analysis

## 50/50 Forecast (Reference)

### ISO-NE OPERABLE CAPACITY ANALYSIS

October 31, 2024 - 50-50 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week in November.

Report created: 10/31/2024

Study Week (Week Beginning , Saturday)	CSO Supply Resource Capacity MW	CSO Demand Resource Capacity MW	External Node Capacity MW	Non-Commercial Capacity MW	CSO Non Gas- Only Generator Planned Outages MW	CSO Gas-Only Generator Planned Outages MW	Unplanned Outages Allowance MW	CSO Generation at Risk Due to Gas Supply 50- 50PLE MW	CSO Net Available Capacity MW	Peak Load Forecast 50- 50PLE MW	Operating Reserve Requirement MW	CSO Net Required Capacity MW	CSO Operable Capacity Margin MW	Season Min Opcap Margin Flag	Season_Label
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
11/16/2024	27873	382	1164	16	2917	2906	3600	0	20012	18211	2125	20336	-324	Y	Fall 2024
11/23/2024	27873	382	1164	16	1644	696	3600	966	22529	18923	2125	21048	1481	N	Fall 2024

#### Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply MW:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
- Peak Load Forecast MW:** Provided in the annual 2024 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.



# Fall 2024 Operable Capacity Analysis

## 90/10 Forecast

### ISO-NE OPERABLE CAPACITY ANALYSIS

#### October 31, 2024 - 90/10 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week in November.

Report created: 10/31/2024

Study Week (Week Beginning , Saturday)	CSO Supply Resource Capacity MW	CSO Demand Resource Capacity MW	External Node Capacity MW	Non-Commercial Capacity MW	CSO Non Gas- Only Generator Planned Outages MW	CSO Gas-Only Generator Planned Outages MW	Unplanned Outages Allowance MW	CSO Generation at Risk Due to Gas Supply 90- 10PLE MW	CSO Net Available Capacity MW	Peak Load Forecast 90- 10PLE MW	Operating Reserve Requirement MW	CSO Net Required Capacity MW	CSO Operable Capacity Margin MW	Season Min OpCap Margin Flag	Season_Label
	1	2	3	4	5	6	7	8	9	10	11	12	13	14	15
11/16/2024	27873	382	1164	16	2917	2906	3600	0	20012	18921	2125	21046	-1034	Y	Fall 2024
11/23/2024	27873	382	1164	16	1644	696	3600	1880	21615	19658	2125	21783	-168	N	Fall 2024

#### Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply Mw:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
- Peak Load Forecast MW:** Provided in the annual 2024 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

\*Highlighted week is based on the week determined by the 50/50 Load Forecast Reference week

# OPERABLE CAPACITY ANALYSIS

*Winter 2024/25 Analysis*

# Winter 2024/25 Operable Capacity Analysis

50/50 Load Forecast (Reference)	Dec - 2024 <sup>2</sup> CSO (MW)	Dec - 2024 <sup>2</sup> SCC (MW)
Operable Capacity MW <sup>1</sup>	27,698	29,953
Active Demand Capacity Resource (+) <sup>5</sup>	331	340
External Node Available Net Capacity, CSO imports minus firm capacity exports (+)	1,596	1,596
Non Commercial Capacity (+)	16	16
Non Gas-fired Planned Outage MW (-)	3	417
Gas Generator Outages MW (-)	0	91
Allowance for Unplanned Outages (-) <sup>4</sup>	3,200	3,200
Generation at Risk Due to Gas Supply (-) <sup>3</sup>	3,733	4,050
Net Capacity (NET OPCAP SUPPLY MW)	22,705	24,147
Peak Load Forecast MW (adjusted for Other Demand Resources) <sup>2</sup>	19,849	19,849
Operating Reserve Requirement MW	2,125	2,125
Operable Capacity Required (NET LOAD OBLIGATION MW)	21,974	21,974
Operable Capacity Margin	731	2,173

<sup>1</sup>Operable Capacity is based on data as of **Oct 31, 2024** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **Oct 31, 2024**.

<sup>2</sup> Load forecast that is based on the 2024 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **Dec 28, 2024**.

<sup>3</sup> Total of (Gas at Risk MW) – (Gas Gen Outages MW).

<sup>4</sup> Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

<sup>5</sup> Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

# Winter 2024/25 Operable Capacity Analysis

90/10 Load Forecast	Dec - 2024 <sup>2</sup> CSO (MW)	Dec - 2024 <sup>2</sup> SCC (MW)
Operable Capacity MW <sup>1</sup>	27,698	29,953
Active Demand Capacity Resource (+) <sup>5</sup>	331	340
External Node Available Net Capacity, CSO imports minus firm capacity exports (+)	1,596	1,596
Non Commercial Capacity (+)	16	16
Non Gas-fired Planned Outage MW (-)	3	417
Gas Generator Outages MW (-)	0	91
Allowance for Unplanned Outages (-) <sup>4</sup>	3,200	3,200
Generation at Risk Due to Gas Supply (-) <sup>3</sup>	4,408	4,824
Net Capacity (NET OPCAP SUPPLY MW)	22,030	23,373
Peak Load Forecast MW (adjusted for Other Demand Resources) <sup>2</sup>	20,613	20,613
Operating Reserve Requirement MW	2,125	2,125
Operable Capacity Required (NET LOAD OBLIGATION MW)	22,738	22,738
Operable Capacity Margin	-708	635

<sup>1</sup>Operable Capacity is based on data as of **Oct 31, 2024** and does not include Capacity associated with Settlement Only Generators, Passive and Active Demand Response, and external capacity. The Capacity Supply Obligation (CSO) and Seasonal Claim Capability (SCC) values are based on data as of **Oct 31, 2024**.

<sup>2</sup> Load forecast that is based on the 2024 CELT report and represents the week with the lowest Operable Capacity Margin, week beginning **Dec 28, 2024**.

<sup>3</sup> Total of (Gas at Risk MW) – (Gas Gen Outages MW).

<sup>4</sup> Allowance For Unplanned Outage MW is based on the month corresponding to the day with the lowest Operable Capacity Margin for the week.

<sup>5</sup> Active Demand Capacity Resources (ADCRs) can participate in the Forward Capacity Market (FCM), have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.

# Winter 2024/25 Operable Capacity Analysis

## 50/50 Forecast (Reference)

### ISO-NE OPERABLE CAPACITY ANALYSIS

October 31, 2024 - 50-50 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week from December through March.

Report created: 10/31/2024

Study Week (Week Beginning , Saturday)	CSO Supply Resource Capacity MW	CSO Demand Resource Capacity MW	External Node Capacity MW	Non-Commercial Capacity MW	CSO Non Gas- Only Generator Planned Outages MW	CSO Gas-Only Generator Planned Outages MW	Unplanned Outages Allowance MW	CSO Generation at Risk Due to Gas Supply 50- 50PLE MW	CSO Net Available Capacity MW	Peak Load Forecast 50- 50PLE MW	Operating Reserve Requirement MW	CSO Net Required Capacity MW	CSO Operable Capacity Margin MW	Season Min Opcap Margin Flag	Season_Label
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
11/30/2024	27698	331	1596	16	1318	1397	3200	407	23319	19220	2125	21345	1974	N	Winter 2024/2025
12/7/2024	27698	331	1596	16	1086	842	3200	1526	22987	19506	2125	21631	1356	N	Winter 2024/2025
12/14/2024	27698	331	1596	16	190	60	3200	2685	23506	19517	2125	21642	1864	N	Winter 2024/2025
12/21/2024	27698	331	1596	16	172	60	3200	3074	23135	19578	2125	21703	1432	N	Winter 2024/2025
12/28/2024	27698	331	1596	16	3	0	3200	3733	22705	19849	2125	21974	731	Y	Winter 2024/2025
1/4/2025	27919	427	1161	293	23	17	2800	3711	23249	20308	2125	22433	816	N	Winter 2024/2025
1/11/2025	27919	427	1161	293	44	17	2800	3566	23373	20308	2125	22433	940	N	Winter 2024/2025
1/18/2025	27919	427	1161	293	43	17	2800	3117	23823	20308	2125	22433	1390	N	Winter 2024/2025
1/25/2025	27919	427	1161	293	23	17	2800	2818	24142	20088	2125	22213	1929	N	Winter 2024/2025
2/1/2025	27919	427	1161	293	46	17	3100	2519	24118	19824	2125	21949	2169	N	Winter 2024/2025
2/8/2025	27919	427	1161	293	41	17	3100	2220	24422	19796	2125	21921	2501	N	Winter 2024/2025
2/15/2025	27919	427	1161	293	41	17	3100	1771	24871	19536	2125	21661	3210	N	Winter 2024/2025
2/22/2025	27919	427	1161	293	20	17	3100	1472	25191	18560	2125	20685	4506	N	Winter 2024/2025
3/1/2025	27919	427	1161	293	124	516	2200	0	26960	18215	2125	20340	6620	N	Winter 2024/2025
3/8/2025	27919	427	1161	293	123	762	2200	0	26715	18022	2125	20147	6568	N	Winter 2024/2025
3/15/2025	27919	427	1161	293	103	762	2200	0	26735	17661	2125	19786	6949	N	Winter 2024/2025
3/22/2025	27919	427	1161	293	662	880	2200	0	26058	17103	2125	19228	6830	N	Winter 2024/2025
3/29/2025	27711	426	1161	293	1172	1349	2700	0	24370	16516	2125	18641	5729	N	Winter 2024/2025

#### Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply Mw:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
- Peak Load Forecast MW:** Provided in the annual 2024 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

# Winter 2024/25 Operable Capacity Analysis

## 90/10 Forecast

### ISO-NE OPERABLE CAPACITY ANALYSIS

October 31, 2024 - 90/10 FORECAST using CSO MW

This analysis is a tabulation of weekly assessments shown in one single table. The information shows the operable capacity situation under assumed conditions for each week. It is not expected that the system peak will occur every week from December through March.

Report created: 10/31/2024

Study Week (Week Beginning , Saturday)	CSO Supply Resource Capacity MW	CSO Demand Resource Capacity MW	External Node Capacity MW	Non-Commercial Capacity MW	CSO Non Gas- Only Generator Planned Outages MW	CSO Gas-Only Generator Planned Outages MW	Unplanned Outages Allowance MW	CSO Generation at Risk Due to Gas Supply 90- 10PLE MW	CSO Net Available Capacity MW	Peak Load Forecast 90- 10PLE MW	Operating Reserve Requirement MW	CSO Net Required Capacity MW	CSO Operable Capacity Margin MW	Season Min Opcap Margin Flag	Season_Label
1	2	3	4	5	6	7	8	9	10	11	12	13	14	15	
11/30/2024	27698	331	1596	16	1318	1397	3200	1395	22331	19962	2125	22087	244	N	Winter 2024/2025
12/7/2024	27698	331	1596	16	1086	842	3200	2513	22000	20258	2125	22383	-383	N	Winter 2024/2025
12/14/2024	27698	331	1596	16	190	60	3200	3804	22387	20270	2125	22395	-8	N	Winter 2024/2025
12/21/2024	27698	331	1596	16	172	60	3200	4220	21989	20333	2125	22458	-469	N	Winter 2024/2025
12/28/2024	27698	331	1596	16	3	0	3200	4408	22030	20613	2125	22738	-708	N	Winter 2024/2025
1/4/2025	27919	427	1161	293	23	17	2800	4522	22438	21089	2125	23214	-776	Y	Winter 2024/2025
1/11/2025	27919	427	1161	293	44	17	2800	4314	22625	21089	2125	23214	-589	N	Winter 2024/2025
1/18/2025	27919	427	1161	293	43	17	2800	4015	22925	21089	2125	23214	-289	N	Winter 2024/2025
1/25/2025	27919	427	1161	293	23	17	2800	4015	22945	20862	2125	22987	-42	N	Winter 2024/2025
2/1/2025	27919	427	1161	293	46	17	3100	3566	23071	20588	2125	22713	358	N	Winter 2024/2025
2/8/2025	27919	427	1161	293	41	17	3100	3267	23375	20559	2125	22684	691	N	Winter 2024/2025
2/15/2025	27919	427	1161	293	41	17	3100	2669	23973	20290	2125	22415	1558	N	Winter 2024/2025
2/22/2025	27919	427	1161	293	20	17	3100	2220	24443	19279	2125	21404	3039	N	Winter 2024/2025
3/1/2025	27919	427	1161	293	124	183	2200	1128	26165	18922	2125	21047	5118	N	Winter 2024/2025
3/8/2025	27919	427	1161	293	123	762	2200	444	26271	18722	2125	20847	5424	N	Winter 2024/2025
3/15/2025	27919	427	1161	293	103	762	2200	0	26735	18348	2125	20473	6262	N	Winter 2024/2025
3/22/2025	27919	427	1161	293	662	880	2200	0	26058	17770	2125	19895	6163	N	Winter 2024/2025
3/29/2025	27711	426	1161	293	1172	1349	2700	0	24370	17166	2125	19291	5079	N	Winter 2024/2025

#### Column Definitions

- CSO Supply Resource Capacity MW:** Summation of all resource Capacity supply Obligations (CSO). Does not include Settlement Only Generators (SOG).
- CSO Demand Resource Capacity MW:** Demand resources known as Real-Time Demand Response (RTDR) will become Active Demand Capacity Resources (ADCRs) and can participate in the Forward Capacity market (FCM). These resources will have the ability to obtain a CSO and also participate in the Day-Ahead and Real-Time Energy Markets.
- External Node Capacity MW:** Sum of external Capacity Supply Obligations (CSO) imports and exports.
- Non-Commercial capacity MW:** New resources and generator improvements that have acquired a CSO but have not become commercial.
- CSO Non Gas-Only Generator Planned Outages MW:** All Non-Gas Planned Outages is the total of Non Gas-fired Generator/DARD Outages for the period. This value would also include any known long-term Non Gas-fired Forced Outages.Outages.
- CSO Gas-Only Generator Planned Outages MW:** All Planned Gas-fired generation outage for the period. This value would also include any known long-term Gas-fired Forced Outages.
- Unplanned Outage Allowance MW:** Forced Outages and Maintenance Outages scheduled less than 14 days in advance per ISO New England Operating Procedure No. 5 Appendix A.
- CSO Generation at Risk Due to Gas Supply MW:** Gas fired capacity expected to be at risk during cold weather conditions or gas pipeline maintenance outages.
- CSO Net Available Capacity MW:** the summation of columns (1+2+3+4-5-6-7-8=9)
- Peak Load Forecast MW:** Provided in the annual 2024 CELT Report and adjusted for Passive Demand Resources assumes Peak Load Exposure (PLE) and does include credit of Passive Demand Response (PDR) and behind-the-meter PV (BTM PV).
- Operating Reserve Requirement MW:** 120% of first largest contingency plus 50% of the second largest contingency.
- CSO Net Required Capacity MW:** (Net Load Obligation) (10+11=12)
- CSO Operable Capacity Margin MW:** CSO Net Available Capacity MW minus CSO Net Required Capacity MW (9-12=13)
- Operable Capacity Season Label:** Applicable season and year.
- Season Minimum Operable Capacity Flag:** this column indicates whether or not a week has the lowest capacity margin for its applicable season.

\*Highlighted week is based on the week determined by the 50/50 Load Forecast Reference week

# Possible Relief Under OP4: Appendix A

OP 4 Action Number	Page 1 of 2 Action Description	Amount Assumed Obtainable Under OP 4 (MW)
1	Implement Power Caution and advise Resources with a CSO to prepare to provide capacity and notify "Settlement Only" generators with a CSO to monitor reserve pricing to meet those obligations. Begin to allow the depletion of 30-minute reserve.	0 <sup>1</sup>  600
2	Declare Energy Emergency Alert (EEA) Level 1 <sup>4</sup>	0
3	Voluntary Load Curtailment of Market Participants' facilities.	40 <sup>2</sup>
4	Implement Power Watch	0
5	Schedule Emergency Energy Transactions and arrange to purchase Control Area-to-Control Area Emergency	1,000
6	Voltage Reduction requiring > 10 minutes	125 <sup>3</sup>

NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The MW values are based on a 25,000 MW system load and verified by the most recent voltage reduction test.
4. EEA Levels are described in Attachment 1 to NERC Reliability Standard EOP-011 - Emergency Operations



# Possible Relief Under OP4: Appendix A

OP 4 Action Number	Page 2 of 2 Action Description	Amount Assumed Obtainable Under OP 4 (MW)
7	Request generating resources not subject to a Capacity Supply Obligation to voluntarily provide energy for reliability purposes	0
8	5% Voltage Reduction requiring 10 minutes or less	250 <sup>3</sup>
9	Transmission Customer Generation Not Contractually Available to Market Participants during a Capacity Deficiency.  Voluntary Load Curtailment by Large Industrial and Commercial Customers.	5  200 <sup>2</sup>
10	Radio and TV Appeals for Voluntary Load Curtailment Implement Power Warning	200 <sup>2</sup>
11	Request State Governors to Reinforce Power Warning Appeals.	100 <sup>2</sup>
Total		<b>2,520</b>

NOTES:

1. Based on Summer Ratings. Assumes 25% of total MW Settlement Only units <5 MW will be available and respond.
2. The actual load relief obtained is highly dependent on circumstances surrounding the appeals, including timing and the amount of advanced notice that can be given.
3. The MW values are based on a 25,000 MW system load and verified by the most recent voltage reduction test.
4. EEA Levels are described in Attachment 1 to NERC Reliability Standard EOP-011 - Emergency Operations