

To: Power Supply Planning Committee

From: Fei Zeng, Technical Manager – Resource Adequacy

Date: December 7, 2017

Subject: Operating Reserve Deficiency Information – Capacity Commitment Period 2021-2022

In response to stakeholders' request, ISO New England (ISO) conducts an annual study to forecast the expected number of system-wide operating reserve deficiency hours for capacity resource levels of the New England system, at, lower and higher than the net Installed Capacity Requirement (ICR). This forecast uses the latest available information for the Forward Capacity Auction (FCA) ICR calculation for each Capacity Commitment Period (CCP). Such studies were previously conducted in 2013 and 2016¹ for the 2016 -2017 CCP (FCA 7) and 2020-2021 CCP (FCA 11), respectively. This memorandum provides the results of the 2017 study, using the ISO planning models and assumptions for calculating the ICR and Related Values for the 2021-2022 CCP (FCA 12).

Specifically, this memorandum provides the following annual information for the 2021-2022 CCP, given system total installed capacity at net ICR and also at values lower and higher than the net ICR:

- The expected number of operating reserve deficiency hours;
- The frequency distribution (*i.e.* percentiles) of operating reserve deficiency hours; and
- A comparison of the 2016 and 2017 study results.

¹ 2013 studies available at

https://www.iso-ne.com/static-assets/documents/committees/comm_wkgrps/mrkt comm/mrkt/mtrls/2013/jul10112013/a12a_iso_memo_07_05_13.pdf

https://www.iso-ne.com/committees/comm_wkgrps/mrkt comm/mrkt/mtrls/2013/jun452013/a07b_iso_memo_05_29_13.pdf

2016 study available at

https://www.iso-ne.com/static-assets/documents/2016/12/iso_memo_operating_reserve_deficiency_dec_19_2016.pdf

Approach and Assumptions

To determine the ICR and Related Values for the Forward Capacity Market (FCM), the ISO employs the General Electric Multi-Area Reliability Simulation Program (GE MARS) probabilistic simulation model. This model provides estimates of the expected number of days per year in which supply would be insufficient to meet demand during the CCP (known as the Loss of Load Expectation, or LOLE). In addition to estimating LOLE, the same model provides estimates of the expected number of hours per year in which there would be insufficient capacity to meet the system's operating reserve requirements.

The GE MARS model, applying Monte Carlo simulation techniques, evaluates the annual (or a chosen period) bulk power system resource adequacy by simulating the availability of resources and the assumed demand on an hourly basis. If the amount of available resources in the system is not adequate to meet the system load and operating reserve requirement for the hour of interest, the program registers a shortage hour. At the end of the simulation, the total number of shortage hours for the year (or a chosen period) is summed up and reported. Here, we want to emphasize that while GE MARS provides the number of hours of operating reserve shortage, it does not provide the number of events that resulted in these shortage hours. By way of example, 20 hours of annual operating reserve shortage could represent 20 non-continuous discrete shortage hours, or one shortage of 20 hours duration, or shortages of different hours of duration. The "expected hours" of operating reserve shortage are calculated, after thousands of Monte Carlo iterations, as the average number of shortage hours during a year. As a reliability tool mainly used for assessing the resource adequacy of the system, GE MARS captures the randomness of the resources' outages. It does not, however, consider the operational parameters associated with the resources such as ramp rate, minimum up/down times, maximum number of starts per day, etc.; operational requirements associated with unit commitment/economic dispatch; or transmission constraints associated with transmission maintenance, system upgrades or unforeseen loss of transmission elements. Therefore, the shortage hours reported in this study do not reflect any shortage hours that could arise relating to operational risks like under-commitment due to load forecast error in operations, or loss of critical transmission elements or fuel supply facilities, etc.

All of the results in this memorandum are derived from the ISO's probabilistic simulation using GE MARS. The simulation results are based on the ICR and Related Values calculation inputs and assumptions for FCA 12. These inputs and assumptions are detailed in the ISO's FERC filing of Installed Capacity Requirement, Hydro Quebec Interconnection Capability Credits and Related Values for the Capacity Commitment Period 2021-2022,² and an ISO presentation to the Power Supply Planning Committee on September 25, 2017 entitled "*Estimated Hours of System Operating Reserve Deficiency - Capacity Commitment Period 2021-2022*".³

With the integration of Demand Resources into the energy and reserve markets in 2018, Real-Time Demand Response⁴ resources are assumed available for dispatch prior to the system entering an operating reserve deficiency. This is consistent with the 2016 study.

² https://www.iso-ne.com/static-assets/documents/2017/11/icr_2017_fca_12.pdf

³ https://www.iso-ne.com/static-assets/documents/2017/09/a3_pspc_est_hrs_oper_reserve_09252017.pdf

⁴ Starting with the 2018-2019 CCP, Real-Time Demand Response resources are designated as Demand Response Capacity Resources in the Tariff.

Tie Benefits (emergency assistance from neighboring Control Areas to the New England system during capacity deficiencies) are assumed available after a declaration of a reserve deficiency under ISO-NE Operating Procedure No. 4, *Actions During a Capacity Deficiency* (OP 4), consistent with prior studies.

Summary of Results

Table 1 provides summary information regarding: (a) the expected number of hours of operating reserve deficiency annually, and (b) the estimated relative frequency of hours of operating reserve deficiency conditions annually. In Table 1, entries in the column labeled ‘5 / 95’ indicate the lower 5th percentile of the simulation results for the number of hours with system operating reserve deficiency conditions; entries in the ‘50 / 50’ column indicate the median hours; and entries in the ‘95 / 5’ column show the 95th percentile.

For example, the value 0.7 in the first row and column labeled ‘5/95’ means that, based on the simulation, there is a 1-in-20 (or 5%) chance that the annual number of hours with operating reserve deficiency conditions would equal *0.7 hours or less* when the amount of installed capacity equals ICR plus 3,200 MW. Similarly, the value of 3.7 in the far-right column labeled ‘95/5’ means that, based on the simulation, there is a 19-in-20 (or 95%) chance that the number of hours with operating reserve deficiency conditions would be *3.7 or less* annually. The values listed in the column labeled “*Expected*” are calculated as the average of all outcomes for a particular capacity level.

Table 1: Estimated Hours of System Operating Reserve Deficiencies Annually

Capacity Level	Expected	5 / 95	50 / 50	95 / 5
Net ICR + 3,200 MW	1.8	0.7	1.5	3.7
Net ICR + 2,800 MW	2.3	0.9	2.1	4.6
Net ICR + 2,400 MW	3.0	1.2	2.8	5.6
Net ICR + 2,000 MW	3.8	1.7	3.6	6.7
Net ICR + 1,600 MW	4.8	2.4	4.6	7.8
Net ICR + 1,200 MW	5.9	3.2	5.7	9.1
Net ICR + 800 MW	7.1	4.2	6.9	10.4
Net ICR + 400 MW	8.4	5.4	8.1	12.1
Net ICR	10.0	6.6	9.4	15.0
Net ICR - 400 MW	11.7	7.9	10.8	19.1
Net ICR - 800 MW	13.9	9.3	12.3	23.9
Net ICR - 1,200 MW	16.8	10.7	14.6	30.5
Net ICR - 1,600 MW	20.8	12.2	18.0	38.3

Figure 1: Plot of Estimated Hours of System Operating Reserve Deficiencies Annually




Figure 1 is a ‘box-and-whisker’ plot of the data in Table 1 with the values for the 25th and 75th percentiles included in addition to the 5th, 50th and 95th percentiles shown in Table 1. In Figure 1, each shaded ‘box’ indicates the upper and lower quartiles (25th and 75th percentiles) for the distribution of the total number of hours of operating reserve deficiency conditions annually, at each level of installed capacity. The extended ‘whiskers’ show the 5th and 95th percentile values from Table 1, and the smooth line interpolates the median⁵ (‘50/50’) hours data from Table 1.

Observations

Similar to the prior studies, the results of the 2017 study demonstrate that as the level of installed capacity in the New England system decreases from the most surplus condition studied (ICR + 3200 MW) to the most deficient condition studied (ICR – 1600 MW), the estimated number of hours with operating reserve deficiency conditions increases gradually at first, then more quickly as the system becomes close to or below its criteria capacity requirement.

Figure 2 compares the expected number of hours of operating reserve deficiency between this study for the 2021-2022 CCP (FCA 12) and the 2016 study for the 2020-2021 CCP (FCA 11). The estimated annual hours of operating reserve deficiencies for the 2021-2022 CCP are slightly lower. This is mainly attributed to an improved modeling of Behind-the-Meter Photovoltaic (BTM PV) resources. In the 2016 study for the 2020-2021 CCP, BTM PV was assumed to be only available during the Reliability Hours of hour ending

⁵ The median value represents the middle value of the shortage hours in a year in which one half of the numbers are above the median and the other half are below. The expected value is the average value of the shortage hours in a year.

14:00 to hour ending 18:00 from May to September, while in the 2017 study, BTM PV is modeled using an hourly profile, capturing load reduction impacts, if any, during all hours of the CCP. This change in the BTM PV modeling methodology, as well as increased penetrations of BTM PV for 2021-2022 versus 2020-2021, are the main reasons for the slightly lower forecast of annual operating reserve deficiency hours.

Figure 2: Comparison of the 2016 (FCA 11) and 2017 (FCA 12) Study Results of Estimated Hours of Reserve Deficiency

