#### Fuel-Security Reliability Need for Mystic 8 and 9



EVP AND CHIEF OPERATING OFFICER | VP, SYSTEM OPERATIONS



**ISO** new england

# Fuel-Security Reliability Need: Determination for Loss of Mystic 8 and 9

- The ISO, for the purpose of this analysis and the upcoming FERC filing, has measured a fuel-security reliability need as both maintaining ten-minute Operating Reserves and not shedding load (OP-7)
  - Maintaining ten-minute Operating Reserves is a core NERC balancing standard
  - OP-7 conditions are not an appropriate means to maintain a reliable system
- The ISO modeled the fuel-security reliability need for Winter 2022/23 and Winter 2023/24 for Mystic 8 and 9
- The underlying model is the same as that used in the Operational Fuel Security Analysis (OFSA)
  - The inputs have been adjusted for the two relevant winter periods (slide 4)

#### **Model Assumptions**

- The model has several simplifying assumptions that are optimistic (in contrast to actual observations)
  - The model assumes an unconstrained fuel logistics deliveries LNG cargos, dual-fuel replenishments, and oil replenishments will occur with no interruption
  - The model assumes an unconstrained emissions profile All units will run as dispatched without regulatory emissions constraints
  - The model assumes an unconstrained transmission system
  - The model assumes all units that cleared in FCA12 will be available in FCA13 and FCA14
    - Model does not account for resource delist bids in FCA13 and FCA14
    - New resources that cleared in prior auctions with stated dual-fuel capability are assumed to operate at those levels; though there have been delays in the commercial operation of new resources
- The model, as previously noted in the OFSA discussions, has limitations with regards to modeling market response

#### Model Inputs for Winter 2022/2023

- Peak Load (90/10 forecast) and PV forecasts: Updated to reflect Draft 2018 CELT forecast for Winter 2022-2023
- Retirements: Mystic 7, 8, 9; Bridgeport Harbor 3; Pilgrim
- Operating Reserve requirements: Reduced from 2,300 MW to 2,100 MW; ten-minute Operating Reserve requirements reduced from 1,600 MW to 1,400 MW
  - With the modeled retirement of Mystic 8 and 9, the largest resource operating reserve requirement is expected to be reduced during the winter period
- Renewables: total 6,600 MW, based on CELT 2018
- Only variables in this model are LNG cap, imports and dual-fuel replenishments

- The sensitivities are meant to be informative
- Retirements are fixed (as described above)
- Renewables are fixed (as outlined in CELT 2018)

### 2022/2023 Winter Scenario Results



## **2022/2023** Winter Scenario Summary: *Retirement of Mystic Station and Distrigas – Lower LNG cap*

					OUTPUTS									
	INPUTS				OF	OP 4 Actions (MWh)			OP 7 Action: Load Shedding		LNG			
	FLNG	U.	l.	land.	*	*	*	*	*			295%		
INPUT CASE NUMBER	LNG Cap (Bcf/Day)	Imports (MW)	Dual-Fuel (Oil Tank Fills)	Peak Load (MW)	Action 1	Actions 2–5	Actions 6–11	Load at Risk (MWh)	Unserved Load (MWh)	Days	Max LNG Days	Days of ≥95% LNG at Assumed Cap		
1	0.8	2,500	2	20,342	163,905	113,321	55,941	85,444	34,715	7	37	39		
2	0.8	3,000	2	20,342	112,512	74,816	34,955	54,404	17,220	6	35	37		
3	0.8	3,500	2	20,342	71,981	46,543	21,956	29,832	5,139	5	34	35		
4	0.8	3,000	1	20,342	222,125	158,832	76,303	120,476	51,372	11	35	37		
5	0.9	2,500	2	20,342	112,372	72,511	36,114	52,258	19,175	6	35	36		
6	0.9	3,000	2	20,342	69,354	45,115	21,230	28,904	5,460	5	34	35		
7	0.9	3,500	2	20,342	38,807	24,196	9,545	11,349	649	1	31	35		
8	0.9	3,000	1	20,342	152,715	102,361	48,693	74,000	27,943	9	34	35		





### **2022/2023** Winter Scenario Summary: *Retirement of Mystic Station – Higher LNG cap*

					OUTPUTS									
		INP	UTS		OF	OP 4 Actions (MWh)			OP 7 Action: Load Shedding		LNG			
			L		*	*	*	*	*			295%		
IPUT CASE NUMBER	LNG Cap (Bcf/Day)	Imports (MW)	Dual-Fuel (Oil Tank Fills)	Peak Load (MW)	Action 1	Actions 2–5	Actions 6–11	Load at Risk (MWh)	Unserved Load (MWh)	Days	Max LNG Days	Days of ≥95% LNG at Assumed Cap		
9	1	2,500	2	20,342	65,482	42,189	19,970	25,568	4,307	5	34	35		
10	1	3,000	2	20,342	36,506	20,997	8,949	8,519	459	1	31	35		
11	1	3,500	2	20,342	17,511	8,853	3,635	1,715	-	-	28	33		
12	1	3,000	1	20,342	106,469	67,960	31,459	48,022	11,781	6	31	35		
13	1.1	2,500	2	20,342	33,500	19,332	7,659	6,944	269	1	31	35		
14	1.1	3,000	2	20,342	15,785	7,943	3,150	1,086	-	-	28	33		
15	1.1	3,500	2	20,342	6,775	2,596	500	55	-	-	24	31		
16	1.2	2,500	2	20,342	13,731	7,115	2,485	561	-	-	27	33		
17	1.2	3,000	2	20,342	5,501	1,795	365	-	-	-	24	31		



### **2022/2023** Winter Scenario Summary: *Contingency Scenarios with Higher LNG Cap*

 Modeled contingencies of ~1,000 - 1,250 MW, which is much lower than outages during recent cold weather snap

					OUTPUTS									
		INP	PUTS		OP 4 Actions (MWh)			10-Minute Reserve Depletion	OP 7 Action: Load Shedding		LNG			
	LNG	J.			*		*	*	*			>95%		
INPUT CASE NUMBER	LNG Cap (Bcf/Day)	lmports (MW)	Dual-Fuel (Oil Tank Fills)	Peak Load (MW)	Action 1	Actions 2–5	Actions 6–11	Load at Risk (MWh)	Unserved Load (MWh)	Days	Max LNG Days	Days of ≥95% LNG at Assumed Cap		
18	1.1	3,000	2	20,342	38,993	21,076	8,542	8,821	204	1	28	33		
19	1	3,000	2	20,342	83,911	53,857	24,237	34,960	4,974	5	31	35		



#### Conclusions for Winter 2022/2023

- The ISO is not basing its assessment on a single scenario or set of inputs, but rather across a spectrum of scenarios
  - The ISO is planning on further discussion regarding fuel security criteria with stakeholders for FCA 14
- The ISO believes that this analysis demonstrates a fuelsecurity reliability need
  - Exposure to both ten-minute Operating Reserve depletion and OP-7 conditions
  - Scenarios with higher LNG cap, when stressed modestly, also show exposure to ten-minute Operating Reserve depletion and OP-7 conditions

### 2023/2024 Winter Scenario Results

**ISO-NE PUBLIC** 



10

#### Model Inputs for Winter 2023/2024

- Peak Load (90/10 forecast) and PV forecasts: Updated to reflect Draft 2018 CELT forecast for Winter 2023-2024
- Retirements: Mystic 7, 8, 9; Bridgeport Harbor 3; Pilgrim
- Operating Reserve requirements: Reduced from 2,300 MW to 2,100 MW; ten-minute Operating Reserve requirements reduced from 1,600 MW to 1,400 MW
  - With the modeled retirement of Mystic 8 and 9, the largest resource operating reserve requirement is expected to be reduced during the winter period
- Renewables: Total 6,900 MW, based on CELT 2018
- Only variables in this model are LNG cap, imports and dual-fuel replenishments

- The sensitivities are meant to be informative
- Retirements are fixed (as described above)
- Renewables are fixed (as outlined in CELT 2018)

## **2023/2024** Winter Scenario Summary: *Retirement of Mystic Station and Distrigas – Lower LNG cap*

					OUTPUTS										
		INP	UTS		OI	OP 4 Actions (MWh)			OP 7 Action: L	.oad Shedding	LNG				
		J.			*	*	*	*	*			295%			
NPUT CASE NUMBER	LNG Cap (Bcf/Day)	Imports (MW)	Dual-Fuel (Oil Tank Fills)	Peak Load (MW)	Action 1	Actions 2–5	Actions 6–11	Load at Risk (MWh)	Unserved Load (MWh)	Days	Max LNG Days	Days of ≥95% LNG at Assumed Cap			
1	0.8	2,500	2	20,205	178,281	123,388	62,398	95,404	42,003	7	37	39			
2	0.8	3,000	2	20,205	120,405	83,170	39,333	61,875	20,363	7	35	37			
3	0.8	3,500	2	20,205	80,552	51,919	25,230	35,746	7,578	5	34	36			
4	0.8	3,000	1	20,205	237,879	175,256	87,815	138,795	60,376	12	35	37			
5	0.9	2,500	2	20,205	121,424	84,481	39,449	61,641	22,443	7	35	37			
6	0.9	3,000	2	20,205	78,894	52,263	25,173	35,534	7,904	6	34	36			
7	0.9	3,500	2	20,205	46,958	29,411	11,967	14,136	1,246	3	31	35			
8	0.9	3,000	1	20,205	164,462	112,404	53,964	83,727	32,557	10	34	36			





### **2023/2024** Winter Scenario Summary: *Retirement of Mystic Station – Higher LNG cap*

					OUTPUTS									
		INF	PUTS		OF	OP 4 Actions (MWh)			10-Minute   Reserve OP 7 Action: Load Shed   Depletion		LNG			
	LNG		<b>L</b>		*	*		*	*			≥95%		
INPUT CASE NUMBER	LNG Cap (Bcf/Day)	Imports (MW)	Dual-Fuel (Oil Tank Fills)	Peak Load (MW)	Action 1	Actions 2–5	Actions 6–11	Load at Risk (MWh)	Unserved Load (MWh)	Days	Max LNG Days	Days of ≥95% LNG at Assumed Cap		
9	1	2,500	2	20,205	76,404	50,928	23,629	33,472	6,717	6	34	35		
10	1	3,000	2	20,205	43,300	27,378	10,718	13,170	850	3	31	35		
11	1	3,500	2	20,205	24,354	12,210	4,608	3,675	-	-	29	34		
12	1	3,000	1	20,205	117,203	78,176	36,230	57,052	16,273	8	31	35		
13	1.1	2,500	2	20,205	41,193	25,024	9,621	11,391	530	1	31	35		
14	1.1	3,000	2	20,205	20,343	10,429	4,408	2,633	-	-	28	34		
15	1.1	3,500	2	20,205	9,559	4,967	1,469	378	-	-	24	31		
16	1.2	2,500	2	20,205	17,871	9,487	3,800	1,585	-	-	28	33		
17	1.2	3,000	2	20,205	7,886	3,680	932	126	-	-	24	31		





### **2023/2024** Winter Scenario Summary: *Contingency Scenarios with Higher LNG Cap*

 Modeled contingencies of ~1,000 - 1,250 MW, which is much lower than outages during recent cold weather snap

					OUTPUTS									
		INP	PUTS		OP 4 Actions (MWh)			10-Minute Reserve Depletion	O-Minute Reserve OP 7 Action: Load Shedding Depletion		LNG			
	LNG	J.			*			*	*			295%		
INPUT CASE NUMBER	LNG Cap (Bcf/Day)	Imports (MW)	Dual-Fuel (Oil Tank Fills)	Peak Load (MW)	Action 1	Actions 2–5	Actions 6–11	Load at Risk (MWh)	Unserved Load (MWh)	Days	Max LNG Days	Days of ≥95% LNG at Assumed Cap		
18	1.1	3,000	2	20,205	46,492	27,421	11,102	13,163	733	2	28	34		
19	1	3,000	2	20,205	95,406	61,097	28,647	44,804	7,928	5	31	35		

**ISO-NE PUBLIC** 

14



#### Conclusions for Winter 2023/2024

- Conclusions for 2023/24 mimic those of 2022/23
- The results for the 2023/24 year are slightly worse than the 2022/23 year because of the increased natural gas consumption by LDC's (thereby reducing availability for generation)
- The ISO believes that this analysis demonstrates a fuelsecurity reliability need
  - Exposure to both ten-minute Operating Reserve depletion and OP-7 conditions
  - Scenarios with higher LNG cap, when stressed modestly, also show exposure to ten-minute Operating Reserve depletion and OP-7 conditions

ISO-NE PUBLIC

15