



Long-Term Load Forecast Methodology Overview

Load Forecast Committee

Jon Black & Victoria Rojo

LOAD FORECASTING, SYSTEM PLANNING



Objectives

1. Discuss the methodologies used in the long-term load forecast process, including its inputs and outputs
2. Obtain LFC feedback on methodology and the presentation materials herein

Topics

- General purpose and intent of the load forecast
- Energy Efficiency (EE) Reconstitution
 - Overview of methodology changes to be effective for CELT 2021
- Behind-the-Meter Photovoltaic (BTM PV) Reconstitution
- Gross Load Forecast Inputs
 - Economics
 - Weather
- Modeling and Forecasting
 - Energy modeling and forecasting
 - Peak demand modeling and forecasting
- Net Load Forecast
 - EE Forecast
 - PV Forecast
- Reporting and Downstream Outputs



Acronyms

ARA	Annual reconfiguration auction	FITs	Feed-in-tariffs
BTM	Behind-the-meter	HDD	Heating degree day
CDD	Cooling degree day	ICR	Installed Capacity Requirement
CELT	Capacity, Energy, Load, and Transmission	ITC	Investment tax credit
DB	Dry bulb	NEL	Net energy load
DG	Distributed generation	NEM	Net energy metering
DOE	Department of Energy	OP	Operating procedure
DP	Dew point	PRD	Price-responsive demand
EE	Energy efficiency	PV	Photovoltaic
EI	Edison Electric Institute	RSP	Regional System Plan
EEM	Energy Efficiency Measures database	SBC	System benefit charges
EIA	Energy Information Administration	THI	Temperature- humidity index
EISA	Energy Independence and Security Act	WS	Wind speed
EOR	Energy only resources	WTHI	Weighted THI
FCM	Forward Capacity Market		

Purpose of Long-Term Load Forecast

“The ISO shall forecast load for the New England Control Area and for each Load Zone within the New England Control Area. The load forecasts shall be based on appropriate models and data inputs. Each year, the load forecasts and underlying methodologies, inputs and assumptions shall be reviewed with Governance Participants, the state utility regulatory agencies in New England and, as appropriate, other state agencies...” Market Rule 1, Section III.12.8

- Long-term load forecast is an important factor in:
 - Determining region’s resource adequacy requirements for future years
 - Evaluating reliability and economic performance of electric power system under various conditions
 - Planning needed transmission improvements
 - Coordinating maintenance and outages of generation and transmission infrastructure assets
- Annual forecast is reported in Capacity, Energy, Load, and Transmission (CELT) report

Forecast Timeline

The Load Forecast Committee (LFC) is the primary stakeholder forum through which the ISO's long term load forecast is discussed. Below is an approximate schedule of meetings and topics used in each forecast cycle.

September

- Discuss model methodology
- Introduce new topics and provide updates

November

- Draft electrification forecasts
- Continue discussion of new topics

December

- Macroeconomic update
- Draft energy forecast
- Final electrification forecasts

February

- Draft summer and winter demand forecasts

March

- Final draft energy and demand forecasts

What is the Load Forecast?

- ISO's long-term load forecast is a 10-year projection of *gross and net load* for each of the six states and the New England region
 - Annual gross and net energy
 - Seasonal gross and net peak demand (50/50 and 90/10)
- Gross peak demand forecast is probabilistic in nature
 - Weekly load forecast distributions are developed for each year of forecast horizon
 - Annual 50/50 and 90/10 seasonal peak values are based on calculated percentiles for the peak week in appropriate month (July for summer; January for winter)



Long-term load forecast is entirely different from the *three-day system demand forecast* used in ISO System Operations (different models, data inputs, forecast horizon, etc.)

Data Sources

Long-term load forecast utilizes a variety of data sources to develop estimates of historical and forecast gross load

Data Series	Source(s)
Economic data	Moody's Analytics
Weather	Vendor supplied
Historical electricity prices	Department of Energy (DOE)/Energy Information Administration (EIA)
Load (NEL)	ISO internal database (settlements data)
Behind-the-meter photovoltaic (BTM PV)	Internal/distribution owner/vendor supplied
Energy efficiency (EE)	ISO internal database
Passive distributed generation	ISO internal database
Price-responsive demand (PRD)	ISO internal database (settlements data)

Net Energy for Load and Reconstitution of Load Definitions


Net Energy for Load (NEL)

Determined by metering, is the net generation, plus net interchange across external tie lines, less energy required for storage at energy storage facilities:

$$NEL = \sum Generation + \sum NetInterchange_{External} - EnergyStorage$$



Energy storage facilities include pumped hydro and other energy storage devices that participate in wholesale energy market as dispatchable asset-related demand



Reconstitution of Load

- Performed by adding back historical load reductions from Demand Capacity Resources that participate as supply in Forward Capacity Market (FCM), including:
 - Price-responsive demand (PRD), which is flexible load that is dispatched in real-time
 - Passive (non-dispatchable) distributed generation (DG) resources
 - Energy-efficiency (EE)
- Behind-the-meter photovoltaic (BTM PV) installations that do not participate in wholesale markets but reduce metered load


Net Load and Gross Load Definitions

Net Load	Gross Load
$Load_{Net} = NEL + PRD$	$Load_{Gross} = NEL + PRD + EE + DG + BTMPV$

- All energy and demand forecast modeling uses historical gross load as inputs
- Reconstitution of PRD, EE, DG, and BTM PV to develop historical gross load is performed at the hourly level, for the region, and each of the six New England states




Methods used for developing the hourly EE and BTM PV reconstitution needed to *gross up* the historical loads are described in the next two sections



Example of Reconstituted Monthly Energy


New England – July



* Values shown are for demonstrative purposes. Actual reconstitution values will differ.

** EE + DG values shown **do not** reflect the revised EE reconstitution methodology to be used in the CELT 2021 load forecast.

High-Level Process Flow Chart



* Gross forecasts are also informed by post model inputs

Energy Efficiency (EE) Reconstitution

Energy Efficiency Reconstitution

Background

What are EE load reductions?*

- For EE measures, load reduction quantity is the difference between estimated energy consumption of an installed EE technology and what the energy consumption would have been had a standard technology been in place (i.e., baseline conditions)
 - What load would have been is counterfactual and cannot be observed directly
 - Measurement and verification studies conducted by EE program administrators (PAs) assume a baseline load in order to quantify the load reduction produced by an EE measure

Why reconstitute for EE?

- In the Forward Capacity Market (FCM) EE is treated as a supply-side resource, acquiring Capacity Supply Obligations (CSOs) in the same manner as any other supply-side resource
- Since EE participates as a supply-side resource in FCM, its corresponding demand reductions are reconstituted to ensure EE is not double-counted (as both supply and demand)
- Accordingly, the gross load forecast is intended to be a forecast of demand *absent* reductions from EE that participates as supply in FCM
 - This requires that the ISO reconstitute (i.e. add back) the demand savings achieved by EE supply-side resources into the historical loads used in developing the gross load forecast

* Reconstitution is done for all passive demand resources; the focus on EE is due to the fact that EE constitutes 91% of all passive demand resources



Energy Efficiency Reconstitution

Existing Methodology

Since 2010, EE reconstitution values have been based on EE performance

- EE program administrators submit monthly performance data to ISO via the energy efficiency measures (EEM) database
 - Monthly MW values reflect load reductions during seasonal performance hours
- Monthly values form the basis for developing the monthly energy reductions and hourly demand reductions that are reconstituted into historical loads

Concerns with basing EE reconstitution on EE performance

- In recent years, the ISO has observed that the EE measure installations reported by EE program administrators consistently exceed the CSOs acquired in the FCM
 - Ideally, these quantities should be the same
- The ISO has no way to differentiate which measures are installed to meet a CSO and which measures are not
- For this reason, the amount of EE reconstituted in developing the gross load forecast has exceeded the amount of CSOs that EE resources have acquired in the FCM
 - The amount reconstituted should approximate the amount of EE participating as supply in the FCA
- EE measures that will expire over the FCM horizon and can no longer participate in the upcoming FCA have not been factored into the reconstitution used to develop the forecast

Energy Efficiency Reconstitution

New Methodology

The ISO, joined by NEPOOL, submitted proposed Tariff changes that reflect a new EE reconstitution methodology to the Federal Energy Regulatory Commission (FERC) on September 11, 2020, with a requested effective date of November 10, 2020

- Under the new methodology, which will be used for the 2021 gross load forecast, EE reconstitution will be based on the total CSOs acquired by EE resources in the most recent Forward Capacity Auction (FCA)
- By calibrating to the EE Capacity Supply Obligation (CSO) from the most recently completed FCA, the new reconstitution methodology results in improved accounting for:
 - The amount of EE that participates in FCA, and not EE installations in excess of their CSO
 - EE expiring measures that are no longer participating as supply in FCM
- The new methodology also provides a framework to adjust the gross load forecast to reflect differences in FCA CSOs and those of ARAs (for details on this this topic please see materials presented at the [June 16, 2020 Reliability Committee \(RC\) meeting](#))
 - The adjusted forecasts will only be used for ICR calculations associated with the ARAs and their respective Capacity Commitment Periods (CCPs)

Energy Efficiency Reconstitution

New Methodology, continued

The revised methodology involves three steps


1. Applying a linear fit between:
 - a. The time installation of EE participating in FCA 1 began (i.e., when PDR equaled zero)
 - Assumed starting point for Summer is June 1, 2006
 - Assumed starting point for Winter is December 1, 2006
 - b. The total seasonal EE CSO from the most recent FCA for the corresponding Capacity Commitment Period (CCP)
 - June 1st for summer, December 1st for winter
2. Applying the resulting June and December points in this time series to all the appropriate EE performance months by season
3. Monthly megawatt (MW) values will be used as a starting point to estimate monthly and hourly energy needed for EE reconstitution (this step remains unchanged from prior years)

Energy Efficiency Reconstitution

New Methodology, continued

The new EE reconstitution methodology:

- Ensures that reconstituted EE is appropriately embedded in the gross load forecast by creating a smooth historical reconstitution time series
- When compared to the prior methodology, results in EE reconstitution that exhibits a lower level and slope, and will therefore result in a lower gross load forecast
 - Applying the new methodology to the CELT 2020 summer demand forecast, the result is a decrease of 652 MW for 2020, and 1,355 MW in 2029



Energy Efficiency Reconstitution

Deriving Monthly Energy Reductions and Hourly Demand Reductions

Monthly Energy Reductions

Estimated using a three-year average of monthly load factors, monthly average weekday EE performance, and number of hours in that month as follows:

$$EE_{Energy,month} = EE_{MW,month} * LoadFactor_{3yrAvg} * nHours_{month}$$

Monthly energy reductions are estimated by load zone and grossed up by 8% to account for transmission and distribution losses.

Hourly Demand Reductions

Multipliers are developed for four categories:

1. Weekday on-peak (weekdays hours 12-20)
2. Weekday off-peak (weekdays hours 5-11, 21-24)
3. Weekend on-peak (weekends hours 5-24, weekdays hours 1-4)
4. Weekend-off peak (weekends hours 1-4)

Hourly demand reductions are estimated by multiplying the monthly MW value by appropriate multiplier for each hour.

EE multipliers are solved for with multivariate Newton-Raphson using the following assumptions:

1. Sum of EE performance across all hours in a month is equal to the monthly energy found in previous step
2. Weekday on-peak multiplier = 1
3. Weekday on-peak > weekday off-peak > weekend on-peak > weekend off-peak




Energy Efficiency Reconstitution

Example of Resulting Hourly Reconstitution

June 2018 Monthly EE Value = 2,880 MW*

* Values shown do not reflect the revised EE reconstitution methodology to be used in the CELT 2021 load forecast.



Behind-the-Meter Photovoltaic (BTM PV) Reconstitution

Behind-the-Meter Photovoltaic (BTM PV) Reconstitution

Background

- BTM PV in the context of the long-term load forecast refers to small scale (<5MW) distributed PV systems that do not participate in wholesale markets
 - Example: residential rooftop PV systems
- Net load (NEL +PRD) reflects embedded load reductions that result from the presence of BTM PV
- Gross load reflects what loads would have occurred absent the impact of BTM PV
 - Producing a gross load forecast requires that hourly historical loads be reconstituted for the impacts of BTM PV
- ISO began publishing BTM PV data and accompanying documentation in July 2020
 - Most recent data are available at: https://www.iso-ne.com/static-assets/documents/2020/07/btm_pv_data.xlsx
 - Associated documentation is available at: https://www.iso-ne.com/static-assets/documents/2020/07/btm_pv_data_documentation.pdf




Behind-the-Meter Photovoltaic (BTM PV) Reconstitution

Background, continued

- The ISO does not have comprehensive visibility into the power and energy production of all BTM PV systems
 - A process of *upscaling* is applied to performance data obtained from a sample of BTM PV sites located throughout the region to infer aggregate BTM PV behavior
- Upscaling inputs
 - Town-level PV performance data
 - Aggregated from a sample of PV systems within each town
 - Installed PV capacity data
 - AC nameplate of all operating PV systems in New England
 - Sourced from a tri-annual survey submitted by the Distribution Owners
- Development of historical estimated BTM PV production
 - Infer hourly BTM PV fleet performance via upscaling by combining normalized profiles with installed capacity data
 - Hourly production of market-facing PV systems is then subtracted to yield the BTM PV production

Upscaling Source Data

Distribution Owner PV Installed Capacity




Heat map illustrates the total PV installed nameplate capacity in each town, as of 12/31/18

- Distribution Owners provide ISO with detailed PV interconnection data three times each year:
 - End of April, August, and December
- Information consists of nameplate capacity, town location, and in-service date for each installation across the region
 - Nameplate capacity reflects aggregate inverter rating
- Dataset enables ISO to monitor amounts and locations of PV installed across region over time
- Installed capacity data is filtered to omit large-scale PV systems that are not included in the long-term PV forecast

Upscaling Source Data

Behind-the-Meter Photovoltaic Performance Data


- ISO is provided performance data associated with up to 10,000 individual PV systems from a vendor
- Vendor aggregates and bins the source data at the town and 5-minute levels and normalizes all performance values as a fraction of total nameplate capacity (e.g., a value of 1 would represent that total PV output is equal to total nameplate capacity)
- Dataset provides knowledge about how BTM PV performs across the region at each 5-minute time increment of history



Heat map illustrates the data for July 31, 2019 at 2:30 p.m.

- Colors reflect BTM PV performance as a share of nameplate capacity
- Source data are unavailable for gray towns
- Data not requested for blue towns

Fictional Upscaling Example



- Assume there are five towns in a zone, towns A, B, C, D, and E
 - Towns may have normalized production data
 - All five towns have installed PV
- **Objective:** Upscale the normalized 30-minute, town-level PV data such that it reflects the aggregate BTM PV performance

Data for Fictional Upscaling Example

Normalized Photovoltaic Profiles and Installed Capacity

- Example town-level normalized production data is tabulated to the right
 - No data provided for Town E
- Total installed nameplate capacity for each town is tabulated below

Note: Town E is missing production data, but has installed capacity

	Installed Cap. (MW)
Town A	12
Town B	6
Town C	8
Town D	16
Town E	8
total	50

time	Town A	Town B	Town C	Town D	Town E
6:00	0.00	0.00	0.00	0.00	
6:30	0.03	0.03	0.03	0.03	
7:00	0.06	0.05	0.05	0.06	
7:30	0.11	0.09	0.09	0.10	
8:00	0.20	0.17	0.17	0.19	
8:30	0.31	0.28	0.27	0.29	
9:00	0.42	0.38	0.37	0.41	
9:30	0.52	0.48	0.45	0.50	
10:00	0.63	0.57	0.53	0.59	
10:30	0.75	0.67	0.63	0.70	
11:00	0.80	0.71	0.66	0.76	
11:30	0.84	0.72	0.71	0.80	
12:00	0.87	0.74	0.76	0.81	
12:30	0.88	0.76	0.76	0.81	
13:00	0.88	0.76	0.74	0.80	
13:30	0.86	0.75	0.73	0.78	
14:00	0.82	0.71	0.71	0.73	
14:30	0.74	0.63	0.66	0.66	
15:00	0.68	0.58	0.59	0.59	
15:30	0.57	0.49	0.49	0.50	
16:00	0.44	0.39	0.38	0.37	
16:30	0.30	0.27	0.26	0.26	
17:00	0.18	0.16	0.16	0.16	
17:30	0.12	0.11	0.11	0.10	
18:00	0.06	0.05	0.05	0.05	
18:30	0.00	0.00	0.00	0.00	

Determine Weights of Town-Level Profiles

- To estimate the zonal production profile, capacity-weights for town-level profiles are first developed
 - Town weights are developed using the ratio of each town's installed capacity to the sum of the installed capacities from towns with corresponding performance data
 - Towns without performance data are excluded from the capacity-weighting process
- Capacity weight calculations for the five-town zone example are tabulated below

	Installed Cap. (MW)	Calculate Weights	Weights
Town A	12	12/42	0.286
Town B	6	6/42	0.143
Town C	8	8/42	0.190
Town D	16	16/42	0.381
Town E	null	no weight	null
total	42	n/a	1.00

Weighting and Upscaling Zonal Profiles – Steps

- Upscaling is last step of data process
 - Zonal normalized profile represents production of all PV systems in zone at each time increment
 - Total power output for zone is calculated by multiplying normalized zonal profile by total zonal installed capacity
- Hourly data can then be derived from sub-hourly data

time	Town A	Town B	Town C	Town D	Town E	Calculate Zonal	Zonal Norm Profile	Installed Capacity	Zonal MW Profile
9:30	0.52	0.48	0.45	0.50		$0.286*0.52 + 0.143*0.48 + 0.190*0.45 + 0.381*0.50$	0.493	50.000	24.668
10:00	0.63	0.57	0.53	0.59		$0.286*0.63 + 0.143*0.57 + 0.190*0.53 + 0.381*0.59$	0.587	50.000	29.359
10:30	0.75	0.67	0.63	0.70		$0.286*0.75 + 0.143*0.67 + 0.190*0.63 + 0.381*0.70$	0.697	50.000	34.836
11:00	0.80	0.71	0.66	0.76		$0.286*0.80 + 0.143*0.71 + 0.190*0.66 + 0.381*0.76$	0.745	50.000	37.265

Upscaling Behind-the-Meter Photovoltaic for New England


- ISO uses process outlined on previous slides to estimate total PV production (of all PV in long-term PV forecast) for the region
- Same process can be applied to various sub-regions
 - Dispatch zone
 - Load zone
 - State
 - Region
- BTM PV reconstitution data is calculated by subtracting production from all market-facing PV from total – *refer to next slide*




Development of Hourly Behind-the-Meter Photovoltaic Reconstitution

July 4-10, 2019 Example


Total hourly PV energy for each state calculated via upscaling



Hourly PV energy in each state settling in ISO wholesale energy market



Total PV minus wholesale market PV yields BTM PV used for hourly reconstitution



Load Forecast Inputs



Macroeconomic Inputs

- Moody's Analytics provides actual and forecast data for a variety of macroeconomic indicators for the New England region and each of the six states, some of which may be used in the load forecast
 - Real gross state product
 - Population
 - Households
 - Unemployment rate
- Historical electricity prices stem from publically available EIA data (form 861)
 - These data may not be included if they do not pass statistical checks
- Forecast macroeconomic data provided in the fall of each year is utilized in the following year's long-term load forecast



Weather


Stations, Locations, and Weights

Hourly dry bulb (DB), dew point (DP), and wind speed (WS) used in long-term load forecast are associated with eight weather stations located throughout New England

Regional and state weather are derived using station weights shown in table below

Weather Station (City, State)	Weather Station	ISO-NE Summer	ISO-NE Winter	CT	MA	ME	NH	RI	VT
Boston, MA	BOS	0.201	0.214	-	0.440	-	-	-	-
Bridgeport, CT	BDR	0.070	0.075	0.170	-	-	-	-	-
Burlington, VT	BTV	0.046	0.040	-	-	-	-	-	1.000
Concord, NH	CON	0.058	0.055	-	-	-	1.000	-	-
Portland, ME	PWM	0.085	0.082	-	-	1.000	-	-	-
Providence, RI	PVD	0.049	0.048	-	0.270	-	-	1.000	-
Windsor Locks, CT	BDL	0.277	0.277	0.830	0.160	-	-	-	-
Worcester, MA	ORH	0.214	0.209	-	0.130	-	-	-	-

Locations of weather stations



Independent Weather Variables

Creating Input Variables for Modeling

- Hourly weighted weather concepts are used to create independent variable inputs to energy and demand models, according to equations listed below
- Weather is also sometimes coupled with a time trend to capture seasonal load growth patterns

Weather Variable	Abbrev.	Equation
Temperature-humidity index	THI	$THI_h = 0.5 * DB_h + 0.3 * DP_h + 15$
3-day weighted THI	WTHI	$WTHI_h = \frac{10 * THI_h + 5 * THI_{h-24} + 2 * THI_{h-48}}{17}$
Effective temperature	EffTemp	$EffTemp = DB - \left(\frac{65 - DB}{100} \right) * (WS)$
Heating degree days	HDD	$HDD = \max(65 - AvgDB_{Daily}, 0)$
Cooling degree days	CDD	$CDD = \max(AvgDB_{Daily} - 65, 0)$
THI-based CDD	CDD_{THI}	$CDD_{THI} = \max(0.4 * AvgDB_{Daily} + 0.4 * AvgDP_{Daily} + 15 - 65, 0)$

Modeling and Forecasting



Forecast Modeling

Introduction

- Long-term load forecast consists of monthly energy models and monthly peak demand models for the New England region and each of the six states
 - 168 individual models: (7 regions x 12 months x energy and demand)
 - All historical load data used for modeling is gross load
 - Regression-based modeling
- Models are estimated based on historical gross load, economics, and weather
 - Inputs are updated annually to capture the most recent trends in historical data
 - Model specification may be re-evaluated if forecast performance issues are observed


Forecast Modeling

Model Selection

- Models are selected based on a variety of statistical tests and performance metrics
- **In-sample statistics** characterize how well a model represents data used to estimate model
 - T-Statistics: explanatory power of each regressor
 - Adjusted R-squared Statistic: overall model fit
 - Tests for autocorrelation in error terms
- **Out-of-sample testing** characterizes a model's predictive accuracy on data unseen by model during model estimation process
 - Mean error (ME): average tendency of model over/under-forecast
 - Mean absolute percent error (MAPE): average magnitude of forecast errors irrespective of direction (i.e., over/under)

Graphical representations allow for visual inspection of forecast results, for example, using comparison of forecast and observed loads

Example scatter plot below illustrates a comparison of out-of-sample July/August 2018 forecast performance from two different model specifications considered during 2019 forecast cycle



Weather for Model Estimation and Forecasts

Gross monthly energy

- **Models** utilize weather aggregated to monthly level
 - Total monthly HDDs and CDDs
 - Typically includes last 27 years of weather encompassing last historical year
- **Forecasts** utilize normal monthly weather
 - Based on a 20-year historical period


Gross peak demand

- **Models** utilize weather at the hour of the daily peak
 - WTHI and effective temperature during the hour of each daily peak
 - Daily CDDs and HDDs
 - Rolling 15-year window that includes last historical year
- **Forecasts** utilize a weekly weather distribution
 - Based on a 25-year historical period

Process	Years of weather
Energy Modeling	25-30 years
Energy Forecasting	20 years
Demand Modeling	15 years
Demand Forecasting	25 years

Gross Energy Modeling

Monthly gross energy models are developed for New England region and each of the six states



* Gross forecasts may also be informed by post model inputs

Gross Energy Modeling

- Gross energy models are regression models of the general form:

$$Energy_{gross_month} = \beta_0 + \beta_1 * Economy + \beta_2 * Weather + \beta_3 * Weather * Trend_{Time}$$

Where:

$\beta_0 \dots \beta_n$ = Regression model coefficients

Economy = Annual economic variable(s)

Weather = Monthly weather variable(s)

$Trend_{Time}$ = Annual linear counter from an initial start year



- 7 regions x 12 months = 84 individual energy models
- Monthly energy forecast modeling uses *normal* weather and baseline economic forecasts as inputs
- Normal weather based on a recent 20-year history and reflects an average monthly degree days (HDDs or CDDs)
 - Period 1996-2015 was used for 2020 CELT forecast
 - Weather constructs used in 2020 CELT include monthly total HDD and CDD_{THI}

Weather Used in Energy Forecasts

Monthly Weather Normal


Gross energy forecasts are produced by using *normal weather* as inputs to monthly models

Average monthly weather over a 20 year historical period: 1996-2015



Gross Peak Demand Forecast

Monthly models of daily gross peak demand are developed for New England region and each of the six states



* Gross forecasts may also be informed by post model inputs

Gross Demand Modeling

- Gross peak demand models are regression models of the general form:

$$PeakDemand_{gross,daily} = \beta_0 + \beta_1 * Energy_{gross,month} + \beta_2 * Weather + \beta_3 * Weather * Trend_{Time} + \beta_4 * Calendar$$

Where:

$\beta_0 \dots \beta_n$ = Regression model coefficients
Weather = Weather variable(s) at the hour of the peak
Calendar = Holiday or Day of Week indicators
 $Trend_{Time}$ = Annual linear counter from an initial start year

- 7 regions x 12 months = 84 individual models
- Model estimation period is a rolling 15-year window of historical daily peak demand and weather data
 - Each year, window is rolled forward to capture last historical year
- Weather constructs used in 2020 load forecast included: WTHI, effective temperature, CDDs, and HDDs
 - Weather pertains to observed conditions at time of daily peak

Weather Used in Probabilistic Demand Forecasts

Developing Weekly Weather Distributions

- Probabilistic gross peak demand forecast is created using weekly weather distributions that serve as weather scenarios representing a range of possible weather for each week of the year
- Weather scenarios consist of the historical weather corresponding to all variables used in demand forecast models and are derived using a period of historical weather data
- For each weather variable, the most extreme weather values are selected from a range of typical (gross) peak load hours
 - Winter weeks: hours ending 18-19
 - Summer weeks: hours ending 14-17
- Daily weather points are aggregated into weeks *as illustrated on next slide*
 - Each historical year contributes 25 points per week

1991 (year 1) → 25 pts
1992 (year 2) → 25 pts
⋮
2015 (year 25) → 25 pts
Total, week n 625 pts



Mapping of weeks to months is tabulated

- Winter months/weeks are shaded **blue**
- Summer months/weeks are shaded **orange**

Month	Weeks
1	1-4
2	5-8
3	9-13
4	14-17
5	18-22
6	23-26
7	27-30
8	31-35
9	36-39
10	40-44
11	45-48
12	49-52

Weather Selection for Probabilistic Demand Forecasts


Developing Historical Weekly Weather Distributions



Developing Weekly Load Distributions

July Example

Weekly Weather Distributions




July Peak Model

Forecast is of non-holiday weekdays (other calendar variables set to zero)

Weekly weather distributions are input to monthly peak models for all weeks of 10-year forecast horizon (only July is shown)


Weekly Load Forecast Distributions




Selection of Points in Load Forecast Distribution

July Example (Weeks 27-30)

Calculate load percentiles
for each week of the forecast



Maximum percentile value across
all weeks within each month are
used as monthly percentile value




50/50 July Peak
90/10 July Peak

↑ = 95th percentile, corresponds to 50/50 peak
↑ = 99th percentile, corresponds to 90/10 peak

Resulting Weekly Gross Demand Forecasts


2019 Forecast Example



Weekly Forecast Distribution

Statistical Moments

- For each week of resulting forecast distribution, these statistical moments are calculated:
 - Mean
 - Standard deviation
 - Skewness
- Statistical moments are used to convert discrete weekly forecast distributions to a continuous forecast distribution needed for probabilistic Monte Carlo analyses used in ICR calculations
 - Plot to right shows a comparison of weekly forecast distribution and corresponding continuous forecast distribution (from 2019 CELT forecast) of the summer peak week (week 28) of forecast year 2023



Incorporating Other Trends Into Load Forecasts

- Consideration of forward-looking electricity consumption trends that are not reflected in the historical data used in econometric modeling may also be required
 - For example, the recent and projected growth of BTM PV and its impact on energy and demand
- Accounting for these anticipated impacts can often be achieved by making forecast adjustments downstream of the forecast modeling
 - For example, expected impacts of federal appliance standards promulgated by the 2007 Energy Independence and Security Act (EISA) were reflected as an adjustment to the gross energy forecast starting in CELT 2009 until CELT 2018
- Starting in CELT 2020, the development of the gross load energy and demand forecasts has included accounting for exogenous forecast information into the final gross load forecast
 - Heating and transportation electrification forecasts are added to the outputs from gross energy and demand forecast models

Net Load Forecast



Net Load Forecast

- Net load forecasts are developed by subtracting EE and BTM PV forecasts of energy and demand from respective gross forecasts
- EE and BTM PV forecasts are developed separately and in parallel to the annual gross load forecast
 - EE forecast is developed as part of [Energy Efficiency Forecast Working Group](#) (EEFWG) stakeholder process
 - BTM PV forecast is developed as part of [Distributed Generation Forecast Working Group](#) (DGFWG) stakeholder process
- A high-level summary of these forecasts is provided on the following slides

Energy Efficiency (EE) Forecast

- Each year the ISO forecasts long-term savings in peak demand and energy stemming from state-sponsored energy-efficiency (EE) programs for the New England region and for each state
- Resource links:
 - Energy-Efficiency Forecast Working Group web page: [Committees and Groups > Planning Committees > Energy Efficiency Forecast Working Group](#)
 - [Energy-Efficiency Forecast Background Report](#)
 - [Final 2020 Energy Efficiency Forecast](#)

Energy Efficiency (EE) Forecast

Model Inputs and General Assumptions

- Beginning with CELT 2021, the basis for the EE forecast will be updated to reflect changes to the methodology for reconstituting EE resources into the gross load forecast
 - Through CELT 2020, the EE forecast has been rooted in FCM qualification values from the third annual reconfiguration auction (ARA 3)
 - Starting in CELT 2021, the revised methodology for reconstituting EE resources into the gross load forecast will inform the first few years of the EE forecast, resulting in a lower EE forecast
- Forecasted incremental EE energy and peak savings are appended to basis values


EE Forecast Model Inputs	
Annual state EE budgets are provided by the Commissions or representatives on their behalf and held constant in years after latest approved budget	Production cost escalator is a graduated rate that begins in the first year of the forecast and accumulates over forecast horizon
End-use coincidence factors are based on BCR (Benefit-Cost Ratio) models submitted by EE program administrators	End-use share projections estimating where EE program activity will be concentrated are provided by EE program administrators
End-use starting production costs are derived from historical cost and savings data submitted by program administrators	Inflation rate is extracted from economic data



Energy Efficiency (EE) Forecast


Model Methodology Process Diagram

- The EE forecast model assumes future program activity will target end-uses in proportions that evolve over time (based on program administrator provided data)
 - Sector production costs will be a function of end-use shares
 - Sector energy savings will stem from weighted production costs applied to state budgets
 - Sector summer and winter peak savings will be derived separately based on weighted season-specific coincidence factors
- The process is followed separately for each sector, using sector specific inputs in each of the orange blocks



Energy Efficiency Forecast

2020 and 2019 New England Summer Peak



Photovoltaic (PV) Forecast

- Each year ISO forecasts long-term growth and impact of PV resources for the New England region and for each state
- PV forecast incorporates a policy-based forecasting approach
 - Trends in distributed PV development largely result from policy programs developed and implemented by the New England states
 - ISO does not explicitly forecast the expansion of existing state policies or the development of future state policy programs
 - ISO makes no judgment regarding state policies, but rather utilizes the state goals as a means of informing the forecast
- Resource links:
 - Distributed Generation Forecast Working Group web page: [Committees and Groups > Planning Committees > Distributed Generation Forecast Working Group](#)
 - [Final 2020 PV Forecast](#)

Photovoltaic (PV) Forecast

Considerations and Assumptions

Many factors influence the future commercialization potential of PV resources, some of which include:

- Policy drivers:
 - Feed-in-tariffs (FITs)/Long-term procurement
 - State RPS programs
 - Net energy metering (NEM)
 - Federal Investment Tax Credit (ITC)
- Other drivers:
 - Role of private investment in PV development
 - PV development occurs using a variety of business/ownership models
 - Future equipment and installation costs
 - Future wholesale and retail electricity costs




Photovoltaic (PV) Forecast

Process

- Majority of state-sponsored distributed PV (i.e., < 5 MW nameplate capacity) does not participate in wholesale markets, but reduces the system load observed by ISO
 - Therefore, forecast does not consider policy drivers supporting larger-scale projects (i.e., those >5 MW)
- To properly account for PV in long-term planning, the PV forecast is categorized as follows:
 - PV as a capacity resource in Forward Capacity Market (FCM)
 - Non-FCM Energy Only Resources (EOR) and Generators
 - Behind-the-meter photovoltaic (BTM PV)
- ISO develops estimated summer peak load reductions associated with BTM PV forecast using the methodology described at:
 - https://www.iso-ne.com/static-assets/documents/2020/04/final_btm_pv_peak_reduction.pdf


Photovoltaic (PV) Forecast

Cumulative Nameplate, MW_{ac}: Reported Historical vs. Forecast



Classification of 2020 New England Photovoltaic (PV) Forecast

Cumulative Nameplate, MW_{ac}



2020 Behind-the-Meter Photovoltaic (PV) Forecast

July 1st Cumulative Estimated Summer Peak Load Reductions

		Cumulative Total MW - Estimated Summer Seasonal Peak Load Reduction										
Category	States	2019	2020	2021	2022	2023	2024	2025	2026	2027	2028	2029
Behind-the-Meter PV	CT	165.7	184.8	193.0	216.7	222.2	243.3	255.2	267.9	279.4	288.3	292.1
	MA	351.0	384.6	409.5	423.5	431.7	444.3	454.2	462.4	468.7	476.0	482.7
	ME	18.8	20.3	19.9	26.0	32.1	37.6	40.6	40.1	39.6	39.2	38.9
	NH	31.5	36.9	41.2	43.1	44.4	46.9	49.6	52.5	55.1	57.8	60.4
	RI	16.3	23.3	25.2	27.9	30.0	32.9	36.0	39.0	41.8	44.6	47.3
	VT	121.6	136.7	138.4	136.3	133.8	133.1	133.8	135.4	136.6	138.4	140.1
Total	Cumulative	704.8	786.5	827.3	873.5	894.2	938.1	969.5	997.4	1,021.2	1,044.4	1,061.6
% of BTM AC nameplate		35.9%	34.3%	32.6%	30.8%	29.1%	27.6%	26.6%	25.8%	25.0%	24.4%	23.8%

Notes:

- (1) Forecast values are for behind-the-meter PV resources only
- (2) Values include the effect of diminishing PV production as increasing PV penetrations shift the timing of peaks later in the day; details of the methodology used to determine the estimated peak demand reductions are available at: http://www.iso-ne.com/static-assets/documents/2020/04/final_btm_pv_peak_reduction.pdf
- (3) Values include the effects of an assumed 0.5%/year PV panel degradation rate
- (4) All values represent anticipated July 1st installed PV, and are grossed up by 8% to reflect avoided transmission and distribution losses
- (5) Different planning studies may use values different that these estimated peak load reductions based on the intent of the study

Downstream Outputs



Forecast Allocations Based on Transmission Owner Load Distribution Data

- State forecasts of gross energy and demand are allocated to load zones and Regional System Plan (RSP) sub-areas via information obtained during the ISO's annual Multiregional Modeling Working Group (MMWG) network model creation process
 - Load shares by substation submitted by Transmission Owners
 - Described in Section 2.3 of the [Transmission Planning Technical Guide Appendix J: Load Modeling Guide](#)
- A list of included substations and their locational mappings can be found in each year's [Load Bus Dictionary](#)



Reporting

Forecast Modeling procedure

- A general description of the energy and peak demand forecasts
- [2020 Forecast Modeling Procedure](#)

Energy and Peak Model Details

- Model specifications, diagnostics and statistics for energy and peak models
- [2020 Regional and State Energy and Peak Model Details](#)

Hourly Profiles in EEI (Edison Electric Institute) Format

- Hourly forecasts based on the 2002 load shape for load zones, RSP sub-areas, and ISO-NE
- EEI Profiles are located on Load Forecast web page at [System Planning > System Forecasting > Load Forecast](#)

CELT Report

- Forecast Report of Capacity, Energy, Loads, and Transmission
- [2020 CELT Report](#)

Forecast Data Workbook

- A description of the contents of the forecast data workbook is tabulated on the following three slides
- [2020 Forecast Data](#)

Net Energy and Peak Load Report

- Contains monthly peak loads, monthly weather information, and monthly actual and weather-normalized energy
- [Net Energy and Peak Load Report](#)

ISO NE Seasonal Peaks since 1980

- Seasonal summer and winter peak information
- [ISO NE Seasonal Peaks Since 1980](#)



Forecast Data Workbook (1 of 3)

Description of Contents

Worksheet	Description of Contents
1	ISONE Control Area & New England States Net Energy for Load (NEL) and Seasonal Peak Load History
2A	Summer Peak Load Forecast: ISONE Control Area, States, Regional System Plan (RSP) Sub-areas, and SMD Load Zone Forecasts <ul style="list-style-type: none">Expected weather case (50th percentile), extreme weather case (90th percentile) and compound annual growth rates
2B	Winter Peak Load Forecast (Same details as 2A)
2C	Annual Energy Forecast: ISONE Control Area, States, RSP Sub-areas, and SMD Load Zones Forecasts
3	Confidence Intervals: Energy and Seasonal Peak Load Forecast and 90% confidence Intervals for ISONE Control Area, States, and RSP Sub-areas
4	ISONE Control Area and New England States Monthly Peak Load Forecast
5	Weather Normalized History & Forecast (ISONE Control Area only)

Forecast Data Workbook (2 of 3)

Description of Contents

Worksheet	Description of Contents
6	Monthly Net Energy for Load Forecast: ISONE Control Area and States
7	Seasonal Peak Load Forecast Distributions: ISONE Control Area and States
8	Energy Model Economic/Demographic Variables: ISONE Control Area and States
9	Adjusting the State Energy Forecasts to the ISONE Energy Forecast
10G	Current CELT Gross forecast differences from prior year: ISONE and the New England States
10N	Current CELT Net forecast differences from prior year: ISONE and the New England States
11	Percentage of ISONE Control Area, operating companies, and load zones portioned out to the RSP sub-areas (Summer 2019 and Summer 2028)
12	Annual Energy and Seasonal Peak Forecast (Transpose of Tab 2 data)

Forecast Data Workbook (3 of 3)

Description of Contents

Worksheet	Description of Contents
13	Westinghouse Capacity Model Program Load Inputs (Power Years)
14	Summary Tables: ISONE Control Area, States, Regional System Plan Sub-areas, and SMD Load Zones Energy and Seasonal Peak Load Forecast
15	Current CELT forecast differences from prior year: BTM PV and EE for ISONE and states
16	Heating and Transportation Electrification Forecasts



Summary

This presentation covered:

- General purpose and intent of the load forecast
- Behind-the-Meter Photovoltaic (BTM PV) Reconstitution
- Energy Efficiency (EE) Reconstitution
- Gross Load Forecast inputs
- Modeling and Forecasting
- Net Load Forecast
- Reporting and Downstream Outputs

