December 7, 2020

VIA eTARIFF FILING

The Honorable Kimberly D. Bose, Secretary

Federal Energy Regulatory Commission
888 First Street, NE
Washington, D.C. 20426

Re: Revisions in Compliance with the Order No. 841 Order on Compliance; Docket No. ER19-470-000

Dear Secretary Bose:

Pursuant to Rule 1907 of the Rules of Practice and Procedure of the Federal Energy Regulatory Commission (the "Commission"),[1] ISO New England Inc. ("ISO-NE") and the New England Power Pool ("NEPOOL") Participants Committee, (together, the "Filing Parties"), submit this transmittal letter and revisions to Market Rule 1[2] and the Open Access Transmission Tariff[3] to comply with the Commission order issued in this proceeding on August 4, 2020.[4] The August 4 Order was issued in response to the Filing

[1] 18 C.F.R. § 385.1907 (2019).

[2] Capitalized terms used but not defined herein are intended to have the meaning given to such terms in the ISO New England Inc. Transmission, Markets and Services Tariff ("Tariff"), the Second Restated NEPOOL Agreement, and the Participants Agreement. Market Rule 1 is Section III of the Tariff.

[3] The Open Access Transmission Tariff (the "OATT") is Section II of the Tariff.

[4] *See ISO New England Inc.*, 172 FERC ¶ 61,125 (August 4, 2020) ("August 4 Order").

Parties' second filing[5] to comply with Order No. 841.[6] In submitting revisions to the OATT, the Filing Parties are joined by the Participating Transmission Owners Administrative Committee (the "PTO AC") on behalf of the Participating Transmission Owners (the "PTOs").[7] The PTO AC also joins in Part II.B of this transmittal letter. As noted in Part IV of this transmittal letter, the Tariff revisions filed herewith received the unanimous support of NEPOOL participants.

I. DESCRIPTION OF THE FILING PARTIES; COMMUNICATIONS

ISO-NE is the private, non-profit entity that serves as the Regional Transmission Organization ("RTO") for New England. ISO-NE operates the New England bulk power system and administers New England's organized wholesale electricity market pursuant to the Tariff and the Transmission Operating Agreement ("TOA") with the New England PTOs. In its capacity as an RTO, ISO-NE has the responsibility to protect the short-term reliability of the New England Control Area and to operate the system according to reliability standards established by the Northeast Power Coordinating Council and the North American Electric Reliability Council.

NEPOOL is a voluntary association organized in 1971 pursuant to the New England Power Pool Agreement, and it has grown to include more than 500 members. The participants include all of the electric utilities rendering or receiving service under the Tariff, as well as independent power generators, marketers, load aggregators, brokers, consumer-owned utility systems, end users, demand resource providers, developers and a merchant transmission provider. Pursuant to revised governance provisions accepted by the Commission,[8] the participants act through the NEPOOL Participants Committee. The Participants Committee is authorized by Section 6.1 of the Second Restated NEPOOL Agreement and Section 8.1.3(c) of the Participants Agreement to represent NEPOOL in proceedings before the Commission. Pursuant to Section 2.2 of the Participants Agreement, "NEPOOL provide[s] the sole Participant Processes for advisory voting on ISO matters and the selection of ISO Board members, except for input from state regulatory authorities and as otherwise may be provided in the Tariff, TOA and the Market Participant Services Agreement included in the Tariff."

---

[5] *See ISO New England Inc. and New England Power Pool,* Revisions in Compliance with the Order No. 841 Order on Compliance, Docket No. ER19-470-004 (filed February 10, 2020) ("Second Compliance Filing").

[6] *See Electric Storage Participation in Markets Operated by Regional Transmission Organizations and Independent System Operators*, Order No. 841, 162 FERC ¶ 61,127 (2018) ("Order No. 841"), *order on reh'g*, 167 FERC ¶ 61,154 (2019) ("Order No. 841-A").

[7] The rights under Section 205 of the FPA to modify terms, conditions and rates in Section II.21 and Schedule 21-Common of the OATT are held jointly by the PTOs pursuant to Section 3.04 of the Transmission Operating Agreement ("TOA") among the PTOs and ISO-NE.

[8] *See ISO New England Inc., et al.*, 109 FERC ¶ 61,147 (2004).

The PTOs[9] are Transmission Providers providing Local Service over Non-Pool Transmission Facilities on an open-access basis under Schedule 21 of the OATT. Pursuant to the terms of the TOA among the PTOs and ISO-NE, the PTOs own, physically operate and maintain Transmission Facilities in New England and ISO-NE has Operating Authority (as defined in Schedule 3.02 of the TOA) over all of the Transmission Facilities of the PTOs, including those used to provide Local Service under Schedule 21. Section 3.04 of the TOA also grants the PTOs authority under Section 205 of the FPA to submit filings to the Commission in matters affecting the rates, terms and conditions of Local Service under Schedule 21 and rates and charges, including cost allocation, for Regional Transmission Service under the OATT.

All correspondence and communications in this proceeding should be addressed to the undersigned for ISO-NE as follows:

Jennifer Wolfson, Esq.*
ISO New England Inc.
One Sullivan Road
Holyoke, MA 01040-2841
Tel: (413) 540-4663
Fax: (413) 535-4379
E-mail: jwolfson@iso-ne.com

To NEPOOL as follows:

William Fowler*
Vice-Chair, NEPOOL Markets Committee
c/o Sigma Consultants, Inc.
20 Main Street
Acton, MA 01720
Tel: (978) 266-0220

Sebastian M. Lombardi, Esq. *
Rosendo Garza, Jr., Esq.
Day Pitney LLP
242 Trumbull Street
Hartford, CT 06103
Tel: (860) 275-0663

[9] The PTOs include: Town of Braintree Electric Light Department; Central Maine Power Company; Maine Electric Power Company; Chicopee Municipal Lighting Plant; Connecticut Municipal Electric Energy Cooperative; Connecticut Transmission Municipal Electric Energy Cooperative; Emera Maine (Bangor Hydro Division); The City of Holyoke Gas and Electric Department; Green Mountain Power Corporation; Town of Hudson Light and Power Department; Massachusetts Municipal Wholesale Electric Company; Town of Middleborough Gas & Electric Department; New England Power Company d/b/a National Grid; New Hampshire Electric Cooperative, Inc.; New Hampshire Transmission, LLC; Eversource Energy Service Company on behalf of certain of its affiliates: The Connecticut Light and Power Company and Public Service Company of New Hampshire; NSTAR Electric Company; Taunton Municipal Lighting Plant; Town of Norwood Municipal Light Department; Town of Reading Municipal Light Department; The United Illuminating Company; Unitil Energy Systems, Inc.; Fitchburg Gas and Electric Light Company; Vermont Electric Power Company; Vermont Electric Cooperative, Inc.; Vermont Transco, LLC; Vermont Public Power Supply Authority; Shrewsbury Electric and Cable Operations; Town of Wallingford, Connecticut Department of Public Utilities Electric Division; and Town of Stowe Electric Department.

Fax: (978) 263-5455
E-mail: wfowler@sigmaconsult.com

Fax: (860) 881-2493
E-mail: slombardi@daypitney.com
rgarza@daypitney.com

And to the PTO AC as follows:

Tiffany Forsyth
Chair, PTO Administrative Committee
c/o New England Power Company d/b/a
National Grid
Director, FERC Revenue Requirements
1 Metrotech Center
Brooklyn, NY 11201
Tel: (929) 324-4582
E-mail: tiffany.forsyth@nationalgrid.com

Mary E. Grover, Esq.*
Chair, PTO AC Legal Work Group
c/o Eversource Energy
800 Boylston Street, P1700
Boston, MA 02199-8003
Tel: (617) 424-2105
E-mail: mary.grover@eversource.com

*Persons designated for service[10]

II. EXPLANATION OF THE CHANGES ON COMPLIANCE

The August 4 Order largely accepted the Second Compliance Filing, identifying three outstanding compliance issues: (1) incorporating into the Tariff the parameters by which ISO-NE "will account for State of Charge and Duration Characteristics of electric storage resources in the day-ahead market";[11] (2) specifying in the Tariff when transmission charges will not be assessed to electric storage resources and when they will be;[12] and (3) ensuring that the Tariff cannot be read to create a barrier to entry for electric storage resources.[13]

The Commission directed that ISO-NE file the majority of the required compliance revisions within 90 days of the issuance of the August 4 Order.[14] With respect to the revisions to account for State of Charge in the day-ahead market, however, the Commission provided a one-year compliance window, in order to "allow ISO-NE sufficient time to develop a solution."[15]

---

[10] Due to the joint nature of this filing, the Filing Parties and PTO AC respectfully request a waiver of Section 385.203(b)(3) of the Commission's regulations to allow the inclusion of more than two persons on the service list in this proceeding.

[11] August 4 Order at P 36.

[12] *See* August 4 Order at P 52.

[13] *See* August 4 Order at P 67.

[14] *See* August 4 Order at P 15.

[15] August 4 Order at n. 64.

On August 31, 2020, ISO-NE and NEPOOL jointly filed a motion to request an extension of time of the 90-day compliance deadline.[16] ISO-NE and NEPOOL stated that the extension would permit ISO-NE to develop further revisions to address all the requirements set forth in the August 2020 Order in one comprehensive compliance filing, rather than two separate filings, while allowing for meaningful stakeholder consideration of the proposed compliance revisions through the complete stakeholder process.[17] On September 10, 2020, the Commission granted the motion for extension of time, establishing December 7, 2020 as the deadline for submission of the single compliance filing. Accordingly, the Tariff revisions filed herewith address the three outstanding compliance issues, including the revisions to account for State of Charge in the day-ahead market.

A. Accounting for State of Charge and Duration Characteristics in the Day-Ahead Energy Market

In the August 4 Order, the Commission wrote that the Second Compliance Filing partially complied with the Commission's directive "to modify ISO-NE's electric storage resource participation model to account for State of Charge and Duration Characteristics through bidding parameters or other means in its day-ahead market."[18] Specifically, the Commission found that "while ISO-NE's proposed revisions state that it will account for such characteristics in the day-ahead market through bidding parameters or other means, ISO-NE has failed to propose any bidding parameters or other means through which it will do so."[19] Accordingly, the Commission directed ISO-NE to file, "revisions to Tariff section III.1.10.6(d) to specify how ISO-NE will account for State of Charge and Duration Characteristics of electric storage resources in the day-ahead market."[20] The Commission continued: "if ISO-NE intends to rely on new bidding parameters, it must define those bidding parameters in its Tariff and explain in its transmittal how those bidding parameters will be incorporated into its day-ahead market engine."[21]

ISO-NE will rely on four new bidding parameters—Initial State of Charge, Maximum State of Charge, Minimum State of Charge, and Round-Trip Efficiency, as well as a State of Charge parameter derived from the four new bidding parameters—to account for State of Charge and Duration Characteristics of electric storage resources in the day-ahead market. These new parameters will be incorporated into the day-ahead market engine as follows.

---

[16] *See ISO New England Inc. and New England Power Pool*, Joint Motion Requesting Extension of Time, Docket No. ER19-470-004 (filed August 31, 2020) ("Motion for Extension of Time").

[17] See Motion for Extension of Time at 2.

[18] August 4 Order at P 36.

[19] August 4 Order at P 36.

[20] August 4 Order at P 36.

[21] August 4 Order at P 36.

The day-ahead clearing software will use an Electric Storage Facility's Initial State of Charge as the facility's State of Charge at the start of hour one of the Operating Day. For each subsequent hour, the day-ahead clearing software will calculate the Electric Storage Facility's State of Charge at the start of the hour based on the State of Charge of the previous hour taking into account the previous hour's scheduled MWs and the facility's Round-Trip Efficiency, which, as described below, is a percentage expressing the megawatt-hours of energy that an Electric Storage Facility injects onto the grid per megawatt-hour of energy it receives from the grid. In clearing the first hour and each subsequent hour of the day-ahead market, the clearing software will respect the Minimum State of Charge and Maximum State of Charge submitted by the Electric Storage Facility for that hour. The four new bidding parameters together with the derived State of Charge parameter will also account for the Duration Characteristics of electric storage resources because, in respecting these new parameters, the day-ahead software will ensure that an Electric Storage Facility will not be scheduled to charge or discharge for a duration that would exceed the Electric Storage Facility's Maximum State of Charge or Minimum State of Charge.[22]

To implement these changes in compliance with the August 4 Order, ISO-NE is revising section III.1.10.6(d) as follows:

> In clearing the Day-Ahead Energy Market, the ISO will respect Electric Storage Facility Initial State of Charge, Round Trip Efficiency, Maximum State of Charge, and Minimum State of Charge~~account for maximum run time, maximum charge time, state of charge, maximum state of charge, and minimum state of charge through bidding parameters or other means, as required by the Commission in Order No. 841~~.

ISO-NE is also adding the following definitions to Section I.2.2 of the tariff, also to implement the changes in compliance with the August 4 Order:

> **Initial State of Charge** is the State of Charge that an Electric Storage Facility offers at the start of hour one of the Day-Ahead Energy Market.
>
> **Maximum State of Charge** is the megawatt-hour value of stored energy, submitted by an Electric Storage Facility as part of its Offer Data for a given hour of the Day-Ahead Energy Market, above which the ISO shall not schedule the Electric Storage Facility to receive electricity from the grid.
>
> **Minimum State of Charge** is the megawatt-hour value of stored energy, submitted by an Electric Storage Facility as part of its Offer Data for a given hour

[22] The Commission has previously explained that respecting a storage resource's State of Charge at the start of each day-ahead market interval "would sufficiently account for both Maximum Charge Time and Maximum Run Time." *See ISO New England Inc.*, 171 FERC ¶ 61,043 (April 16, 2020) at P 19.

of the Day-Ahead Energy Market, below which the ISO shall not schedule the Electric Storage Facility to inject electricity to the grid.

Round-Trip Efficiency is a percentage expressing the megawatt-hours of energy that an Electric Storage Facility injects onto the grid per megawatt-hour of energy it receives from the grid.

State of Charge is the total quantity of megawatt-hours available to be injected by an Electric Storage Facility onto the grid.

B. Application of Transmission Charges

In the August 4 Order, the Commission found that "ISO-NE's proposal with respect to the application of transmission charges to electric storage resources partially complies with [the Commission's] directives."[23] Specifically, the Commission accepted "ISO-NE's proposal not to assess transmission charges to electric storage resources that are being dispatched by ISO-NE to provide voltage support and reactive control, operating reserves, and regulation."[24] The Commission also accepted "ISO-NE's proposal not to apply transmission charges to energy withdrawn by an electric storage resource pursuant to central dispatch, which according to ISO-NE includes energy withdrawn by an electric storage resource when it is dispatched to: (1) balance energy supply and demand on an economic basis or (2) address a reliability concern."[25]

However, the Commission "disagre[ed] with ISO-NE's statement that electric storage resources will always be providing a service when charging for later resale in the wholesale markets."[26] Specifically, the Commission found that "ISO-NE has failed to demonstrate that an electric storage resource that is self-scheduled to charge at a fixed MW quantity is providing a service that warrants exempting its full self-scheduled charging MW from transmission charges."[27] The Commission therefore directed ISO-NE to assess transmission charges on any "remaining self-scheduled charging MW [that] are not dispatched to provide a service to ISO-NE."[28]

---

[23] August 4 Order at P 49.

[24] August 4 Order at P 49.

[25] August 4 Order at P 49.

[26] August 4 Order at P 50.

[27] August 4 Order at P 50. By way of example, the Commission argued that "[w]hile ISO-NE states that a self-scheduled electric storage resource provides voltage support and reactive control, ISO-NE fails to acknowledge that only a portion of such resources' withdrawals may be associated with being dispatched to provide a service (i.e., voltage support and reactive control)." *Id.*

[28] August 4 Order at P 50. As directed by the Commission, the Filing Parties and the PTO AC are submitting Tariff revisions to address the Commission's concern (*see* final sentence of Revised

In the August 4 Order, the Commission directed ISO-NE to file Tariff revisions:

> (1) specifying that it will not apply transmission charges to electric storage resources when they are dispatched to withdraw energy to provide voltage support and reactive control, provide operating reserves, provide regulation, balance energy supply and demand on an economic basis, or address a reliability concern; and (2) applying transmission charges to electric storage resources when they are not being dispatched to provide one of those tariff-defined services.[29]

In compliance with this directive, the Filing Parties and the PTO AC are revising section II.21.3 of the OATT as follows:

> **II.21.3 Exception to Payment for Regional Network Service:** Regional Network Service charges associated with an Electric Storage Facility's charging load: The applicable Local Network RNS Rate shall be reduced to zero for monthly Regional Network Load associated with the charging load of an Electric Storage Facility. The reduction to zero of the applicable Local Network RNS Rate shall only apply to the Schedule 9 charges. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market. The applicable Local Network RNS Rate will be applied to Electric Storage Facility charging load unless it is reported as described in (a) above and is providing one or more services as described in (b) above.[30]

Section II.21.3). However, ISO-NE notes that the provision of voltage support and reactive control in New England is not affected by the self- or pool-scheduled status of a resource. ISO-NE's interconnection procedures require charging electric storage resources to provide reactive power voltage control at the MW value of dispatch, which includes any fixed MW portion of a self-schedule (*see, e.g.*, Section 1.8.1.2 of the Standard Small Generator Interconnection Agreement (Exhibit 1 to Schedule 23 of the OATT), requiring Generating Facilities, which include electric storage resources, to provide dynamic voltage support and reactive control at all times when injecting or consuming). In addition, self-scheduled Electric Storage Facility load, just like pool-scheduled Electric Storage Facility load, is subject at all times to central dispatch by ISO-NE pursuant to Section I.3.4 and therefore, just like pool-scheduled Electric Storage Facility load, provides real-time balancing of supply and demand on an economic basis and can be dispatched to cease charging at any time to address a reliability concern.

[29] August 4 Order at P 52.

[30] The sentence "Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market,"

In addition, the PTO AC is proposing conforming revisions to Section I.13 (Local Point-to-Point Service, Compensation for Local Point-to-Point Service) and Section II.9 (Local Network Service, Rates and Charges) of Schedule 21-Common of the OATT.

C. Ensuring the Tariff Cannot be Read to Create a Barrier to Entry

In the August 4 Order, the Commission found that "ISO-NE's revisions adequately ensure that electric storage resources do not pay both the wholesale and retail price for the same charging energy."[31] At the same time, however, the Commission also found that the "proposed Tariff section III.1.10.6(d)(ii) as written could effectively allow the host utility to decide whether an electric storage resource may participate in the ISO-NE markets."[32] The Commission explained that "[the] language may create a barrier to the wholesale participation of electric storage resources, and may therefore be inconsistent with Order Nos. 841 and 841-A."[33] The Commission therefore directed "a further compliance filing either modifying this language in proposed Tariff section III.1.10.6(d)(ii) or clarifying how it does not serve as a barrier to the participation of electric storage resources."[34]

Consistent with this directive, the Filing Parties are revising section III.1.10.6(d)(ii) to eliminate the language the Commission found "could effectively allow a host utility to decide whether an electric storage resource may participate in the ISO-NE markets,"[35] thereby creating a potential barrier to the wholesale participation of electric storage resources. The proposed revisions are as follows:

> A storage facility's charging energy ~~load~~ shall not qualify as, or be billed to, a Storage DARD if that facility's charging energy is included in another ~~the Host Participant is unwilling or unable to support the registration, metering, and accounting of the storage facility's load as a separate and distinct~~ Load Asset. A

---

while not directed by the Commission, is modeled on a sentence approved by the Commission in the Order 841 compliance proceeding of PJM Interconnection L.L.C ("PJM"). Specifically, in a December 16, 2019 compliance filing in Docket No. ER19-469-003, PJM included the sentence "Energy Storage Resource Model Participants shall be considered to be providing Energy Imbalance Service when they are dispatchable by PJM in real-time" in its revisions to comply with the Commission's directive to add language to its tariff describing the services that would result in the application of the transmission charge exemption. The revisions were accepted subject to a further (unrelated) compliance filing in *PJM Interconnection, L.L.C.*, 172 FERC ¶ 61,029 (July 16, 2020).

[31] August 4 Order at P 67.

[32] August 4 Order at P 67.

[33] August 4 Order at P 67.

[34] August 4 Order at P 67.

[35] August 4 Order at P 67.

storage facility registered as a DARD will be charged the nodal Locational Marginal Price by the ISO and the Market Participant will not pay twice for the same charging energy ~~load~~.

III. REQUESTED EFFECTIVE DATE

ISO-NE and, to the extent applicable, the PTO AC request an effective date of March 1, 2021 for the majority of the revisions filed herewith. For the revisions specific to the Day-Ahead Energy Market, described in Part II.A of this transmittal letter, ISO-NE requests an effective date of January 1, 2026.

IV. STAKEHOLDER PROCESS

The revisions filed herein were considered through the complete NEPOOL Participant Processes and received the unanimous support of NEPOOL. At its October 27, 2020 meeting, the NEPOOL Transmission Committee considered the changes concerning the transmission charge exemption that applies to charging electric storage resources, namely, revisions to Section II.21.3 and to Schedule 21-Common of the OATT. The Transmission Committee approved a resolution to recommend Participants Committee support for those revisions with no opposition and one abstention noted.[36] At its November 9–10, 2020 meeting, the NEPOOL Markets Committee considered the proposed revisions to Market Rule 1, namely, incorporating five new defined terms in Section I.2.2 and revising Sections III.1.10.6(d)(ii) and (d). The Markets Committee unanimously approved a resolution to recommend Participants Committee support for those revisions. Subsequently, the NEPOOL Participants Committee unanimously approved the revisions herein as part of the Consent Agenda for its December 3, 2020 meeting.[37]

Separately, the PTO AC voted to support the revisions to Section II.21 and Sections I.13 and II.9 to Schedule 21-Common of the OATT at its October 20, 2020 meeting.

[36] The abstention was registered by a member of NEPOOL's End Use Sector.

[37] The Consent Agenda for a Participants Committee meeting, similar to the Consent Agenda for a Commission open meeting, is a group of actions (each recommended by a Technical Committee or subgroup established by the Participants Committee) to be taken by the Participants Committee through approval of a single motion at a meeting. All recommendations voted on as part of the Consent Agenda are deemed to have been voted on individually and independently. In this case, the Participants Committee's unanimous approval (with one opposition recorded for reasons not related to the revisions herein, as well as one abstention recorded) of the Consent Agenda included its support for the rule changes filed herein.

V. ADDITIONAL SUPPORTING INFORMATION

Section 35.13 of the Commission's regulations generally requires public utilities to file certain cost and other information related to an examination of traditional cost-of-service rates. However, the Tariff revisions filed here do not modify a traditional "rate" and ISO-NE is not a traditional investor-owned utility. Therefore, to the extent necessary, the Filing Parties and the PTO AC request waiver of Section 35.13 of the Commission's regulations.[38] Notwithstanding its request for waiver, the Filing Parties and the PTO AC submit the following additional information in substantial compliance with relevant provisions of Section 35.13 of the Commission's regulations:

35.13(b)(1) – Materials included herewith are as follows:

- This transmittal letter;
- Blacklined Tariff sections effective March 1, 2021;
- Clean Tariff sections effective March 1, 2021;
- Blacklined Tariff sections effective January 1, 2026;
- Clean Tariff sections effective January 1, 2026;
- List of governors and utility regulatory agencies in Connecticut, Maine, Massachusetts, New Hampshire, Rhode Island, and Vermont to which a copy of this filing has been sent.

35.13(b)(2) – As set forth in Part III of this transmittal letter, ISO-NE and, to the extent applicable, the PTO AC request that the majority of the Tariff revisions filed herewith become effective on March 1, 2021, with the revisions to the day-ahead market, described in Part II.A of this transmittal letter, becoming effective on January 1, 2026.

35.13(b)(3) – Pursuant to Section 17.11(e) of the Participants Agreement, Governance Participants are being served electronically rather than by paper copy. The names and addresses of the Governance Participants are posted on the ISO-NE website at http://www.iso-ne.com/participate/participant-asset-listings. A copy of this transmittal letter and the accompanying materials have also been sent to the governors and electric utility regulatory agencies for the six New England states that comprise the New England Control Area, the New England Conference of Public Utility Commissioners, Inc., and to the New England States Committee on Electricity. Their names and addresses are shown in the attached listing. In accordance with Commission rules and practice, there is no need for the Governance Participants or the entities identified in the listing to be included

[38] 18 C.F.R. § 35.13 (2018).

on the Commission's official service list in the captioned proceeding unless such entities become intervenors in this proceeding.

35.13(b)(4) – A description of the materials submitted pursuant to this filing is contained in this Part V of this transmittal letter.

35.13(b)(5) – The reasons for this filing are discussed in Part II of this transmittal letter.

35.13(b)(6) – ISO-NE's approval of these changes is evidenced by this filing. These changes reflect the support of the Participants Committee and the PTO AC.

35.13(b)(7) – Neither ISO-NE, NEPOOL, nor the PTO AC has knowledge of any relevant expenses or costs of service that have been alleged or judged in any administrative or judicial proceeding to be illegal, duplicative, or unnecessary costs that are demonstrably the product of discriminatory employment practices.

35.13(c)(1) – The Tariff changes herein do not modify a traditional "rate," and the statement required under this Commission regulation is not applicable to the instant filing.

35.13(c)(2) – ISO-NE and the PTOs do not provide services under other rate schedules that are similar to the wholesale, resale and transmission services they provide under the Tariff.

35.13(c)(3) – No specifically assignable facilities have been or will be installed or modified in connection with the revisions filed herein.

VI. CONCLUSION

For the reasons stated above, the Filing Parties and the PTO AC request that the Commission accept the revisions submitted herewith as filed, the majority to become effective on March 1, 2021. ISO-NE requests an effective date of January 1, 2026 for the Tariff revisions specific to the day-ahead market, described in Part II.A of this transmittal letter.

Respectfully submitted,

/s/ Jennifer Wolfson

Jennifer Wolfson, Esq.
ISO New England Inc.
One Sullivan Road
Holyoke, MA 01040-2841
Tel: (413) 540-4663
E-mail: jwolfson@iso-ne.com

/s/ Sebastian M. Lombardi

Sebastian M. Lombardi, Esq.
Rosendo Garza, Jr., Esq.
Day Pitney LLP
242 Trumbull Street
Hartford, CT 06103
Tel: (860) 275-0663
E-mail: slombardi@daypitney.com
rgarza@daypitney.com

/s/ Mary E. Grover

Mary E. Grover, Esq.
Chair, PTO AC Legal Work Group
c/o Eversource Energy
800 Boylston Street, P1700
Boston, MA 02199-8003
Tel: (617) 424-2105
E-mail: mary.grover@eversource.com

CERTIFICATE OF SERVICE

I hereby certify that I have this day caused the foregoing document to be served upon the New England governors and electric utility regulatory agencies and upon each person designated on the official service list compiled by the Secretary in this proceeding.

Dated at Holyoke, Massachusetts, this 7th day of December, 2020.

/s/ Linda Morrison

Linda Morrison

II.21 Rates and Charges

II.21.1 Regional Network Service: Each Transmission Customer which has a load in the New England Control Area and takes Regional Network Service for a month shall be subject to the applicable provisions of Part II.B. of this OATT and shall pay to the ISO for such month an amount equal to its Monthly Regional Network Load for the month times the applicable Local Network RNS Rate (except as provided for in Section II.21.3), and shall pay in addition any amount which it is required to pay for the service pursuant to Section II.18.3 and Schedules 13 and 14 of this OATT. It shall also be obligated to pay for any Direct Assignment Facilities and its share of any new facilities or upgrades required to provide the requested service including applicable study costs to the extent they are consistent with Commission policy and Schedules 11 and 12, and any ancillary service charges and other charges and/or costs required to be paid pursuant to the Transmission, Markets and Services Tariff. The applicable Local Network RNS Rate shall be the rate, determined in accordance with Schedule 9 to this OATT, which is applicable to (i) a delivery to load in the particular Local Network in which the load served by the Transmission Customer is located, or (ii) to the extent that the ISO, after consultation with the affected PTOs, at the request of a PTO who owns the Local Network where the Regional Network Load is located, recognizes Regional Network Load to be the responsibility of another PTO, the applicable Local Network RNS Rate shall be the Local Network RNS Rate of the PTO responsible for such Regional Network Load. In the event the Transmission Customer serves Regional Network Load located on more than one Local Network, the amount to be paid by it shall be separately computed for the Regional Network Load located on each Local Network.

II.21.2 Determination of Network Customer's Monthly Regional Network Load: Network Customer's "Monthly Regional Network Load" is its hourly load (including its designated Regional Network Load not physically interconnected with the PTF under Section II.18.3 of this OATT) coincident with the coincident aggregate load of all Network Customers served in each Local Network in the hour in which the coincident load is at its maximum for the month ("Monthly Peak"). For Regional Network Load located within the New England Control Area, the Monthly Regional Network Load of all Network Customers within a Local Network shall be calculated by the associated PTO. For Regional Network Load located outside of the New England Control Area, the Monthly Regional Network Load of all Network Customers shall be calculated by the associated PTO (in consultation with the ISO and the associated Balancing Authority).

II.21.3 Exception to Payment for Regional Network Service: Regional Network Service charges associated with an Electric Storage Facility's charging load: The applicable Local Network RNS Rate shall be reduced to zero for monthly Regional Network Load associated with the charging load of an Electric Storage Facility. The reduction to zero of the applicable Local Network RNS Rate shall only apply to the Schedule 9 charges. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market. The applicable Local Network RNS Rate will be applied to Electric Storage Facility charging load unless it is reported as described in (a) above and is providing one or more services as described in (b) above.

SCHEDULE 21 - LOCAL SERVICE

This Schedule 21 contains the main substantive provisions applicable to Local Service. It includes common PTO rates, terms and conditions for Local Point-to-Point Service and Local Network Service and PTO-specific Local Service Schedules. Retail service is not subject to this Schedule 21 unless specifically provided for in the PTO's Local Service Schedule. The rates, terms and conditions for interconnection service to generators with total generating capacity of greater than 20 MW are set forth in Schedule 22. The rates, terms and conditions for interconnection service to generators with total generating capacity of 20 MW and less are set forth in Schedule 23. To the extent applicable, the rates, terms and conditions for load interconnections are set forth under the PTO-specific Local Service Schedules.

All Transmission Customers taking Local Service shall be subject to and comply with the rates, terms and conditions of this Schedule 21 as well as any applicable Local Service Schedule. In the event of a conflict between any rate, term or condition in the Tariff and any rate, term or condition in this Schedule 21 and/or an applicable Local Service Schedule, the rate, term or condition in this Schedule 21 and/or the applicable Local Service Schedule shall govern.

The following NAESB WEQ Standards are hereby incorporated by reference in this Schedule 21 to the extent that the requirements therein apply to the PTOs:

- WEQ-000, Abbreviations, Acronyms, and Definition of Terms, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Oct. 4, 2012, Nov. 28, 2012 and Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);

- WEQ-001, Open Access Same-Time Information System (OASIS), OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013) excluding Standards 001-9.5, 001-10.5, 001-14.1.3, 001-15.1.2 and 001-106.2.5;

- WEQ-002, Open Access Same-Time Information System (OASIS) Business Practice Standards and Communication Protocols (S&CP), OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Nov. 28, 2012 and Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);

- WEQ-003, Open Access Same-Time Information System (OASIS) Data Dictionary Business Practice Standards, OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);

- WEQ-004, Coordinate Interchange, WEQ Version 003, July 31, 2012 (as modified by NAESB final actions ratified on December 28, 2012);

- WEQ-005,Area Control Error (ACE) Equation Special Cases, WEQ Version 003, July 31, 2012);
- WEQ-006, Manual Time Error Correction, WEQ Version 003, July 31, 2012;
- WEQ-007,Inadvertent Interchange Payback, WEQ Version 003, July 31, 2012;
- WEQ-008,Transmission Loading Relief (TLR) – Eastern Interconnection, WEQ Version 003, July 31, 2012 (with minor corrections applied November 28, 2012);
- WEQ-011, Gas / Electric Coordination, WEQ Version 003, July 31, 2012;
- WEQ-012, Public Key Infrastructure (PKI) WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on October 4, 2012);
- WEQ-013, Open Access Same-Time Information System (OASIS) Implementation Guide, OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);
- WEQ-015, Measurement and Verification of Wholesale Electricity Demand Response, WEQ Version 003, July 31, 2012;
- WEQ-021, Measurement and Verification of Energy Efficiency Products, WEQ Version 003, July 31, 2012.

The PTOs will perform their functions under this Schedule 21 and the Local Service Schedules in a manner that is not inconsistent with the ISO's provision of regional service, administration of the regional markets, dispatch of resources, and operation of the New England Transmission System for purposes of reliability.

Pre-Confirmed Request: Is an OASIS transmission service request that commits the Transmission Customer to take and pay for the requested Local Point-to-Point Service upon acceptance on OASIS by the PTO that can provide the requested Local Point-to-Point Service.

Pre-RTO Local Service Agreements [1]: A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Firm or Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of their existing Local Service Agreement that was in effect prior to February 1, 2005

[1] LSAs as defined in Section II.1 of the OATT do not include Excepted Transaction Agreements under Attachments G-1, G-2 and G-3 of the OATT.

("Pre-RTO Local Service Agreement" as defined to Section II.1 of the OATT) shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21. Instead, the Transmission Customer shall contact the associated PTO to discuss and, if appropriate, modify its existing Pre-RTO Local Service Agreement.

A Transmission Customer who wishes to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of its existing Pre-RTO Local Service Agreement, shall contact the PTO to make arrangements to terminate the Transmission Customer's existing pre-RTO Local Service Agreement and shall complete (and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

RTO Local Service Agreements: For Local Service Agreements with an effective date on or after February 1, 2005 (an "RTO Local Service Agreement" as defined to Section II.1 of the OATT) a Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of its existing Local Service Agreement under this Schedule 21, shall not be required to execute a new Local Service Agreement under this Schedule 21, however, modifications to the Transmission Customer's existing Local Service Agreement may be required. Such modifications to an existing Local Service Agreement typically do not require an additional local or regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an application for Local Transmission Service that reflects the requested modifications to the Local Service Agreement to facilitate revision of its existing Schedule 21 Local Service Agreement. A Transmission Customer who wishes to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of its existing RTO Local Service Agreement, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing RTO Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) a new Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

Reservation Priority For Existing Firm Service Customers: Existing firm service customers (wholesale requirements and transmission only, with a contract term of five years or more), have the right to continue to take Local Service from the PTO when the contract expires, rolls over or is renewed. This transmission reservation priority is independent of whether the existing customer continues to purchase capacity and energy from the PTO or elects to purchase capacity and energy from another supplier. If at

the end of the contract term, the PTO's Local Network cannot accommodate all of the requests for Local Service, the existing firm service customer must agree to accept a contract term at least equal to a competing request by any new Eligible Customer and to pay the current just and reasonable rate, as approved by the Commission, for such service; provided that, the firm service customer shall have a right of first refusal at the end of such service only if the new contract is for five years or more. The existing firm service customer must provide notice to the PTO whether it will exercise its right of first refusal no less than one year prior to the expiration date of its Local Service Agreement. This transmission reservation priority for existing firm service customers is an ongoing right that may be exercised at the end of all firm contract terms of five years or longer. Local Service Agreements subject to a right of first refusal entered into prior to the date of the PTOs' filing adopting the reformed rollover language herein in compliance with Order No. 890 or associated with a transmission service request received prior to July 13, 2007, unless terminated, will become subject to the five year/one year requirement on the first rollover date after the date of the PTOs' filing adopting the reformed rollover language herein in compliance with Order No. 890; provided that, the one year notice requirement shall apply to such service agreements with five years or more left in their terms as of the date of the PTOs' filing adopting the reformed rollover language herein in compliance with Order No. 890.

FERC: The Federal Energy Regulatory Commission.

Force Majeure: Neither the ISO, a Transmission Owner nor a Customer will be considered in default as to any obligation under the Tariff if prevented from fulfilling the obligation due to an event of Force Majeure; provided that no event of Force Majeure affecting any entity shall excuse that entity from making any payment that it is obligated to make hereunder or under a Service Agreement. However, an entity whose performance under the Tariff is hindered by an event of Force Majeure shall make all reasonable efforts to perform its obligations under the Tariff, and shall promptly notify the ISO, the Transmission Owner or the Customer, whichever is appropriate, of the commencement and end of each event of Force Majeure.

Liability: The ISO shall not be liable for money damages or other compensation to the Customer for actions or omissions by the ISO in performing its obligations under the Tariff or any Service Agreement thereunder, except to the extent such act or omission by the ISO is found to result from its gross negligence or willful misconduct. A Transmission Owner shall not be liable for money damages or other compensation to the Customer for action or omissions by such Transmission Owner in performing its obligations under the Tariff or any Service Agreement thereunder, except to the extent such act or

omission by such Transmission Owner is found to result from it gross negligence or willful misconduct. To the extent the Customer has claims against the ISO or a Transmission Owner, the Customer may only look to the assets of the ISO or a Transmission Owner (as the case may be) for the enforcement of such claims and may not seek to enforce any claims against the directors, members, shareholders, officers, employees or agents of the ISO or a Transmission Owner or Affiliate of either who, the Customer acknowledges and agrees, have no personal or other liability for obligations of the ISO or a Transmission Owner by reason of their status as directors, members, shareholders, officers, employees or agents of the ISO or a Transmission Owner or Affiliate of either. In no event shall the ISO, a Transmission Owner or any Customer be liable for any incidental, consequential, multiple or punitive damages, loss of revenues or profits, attorneys fees or costs arising out of, or connected in any way with the performance or non-performance under the Tariff or any Service Agreement thereunder. Notwithstanding the foregoing, nothing in this section shall diminish a Customer's obligations under Section I.5.3 of the Tariff or under Schedule 21 of the OATT.

Indemnification: Each Customer shall at all times indemnify, defend, and save harmless the ISO and the Transmission Owners and their respective directors, officers, members, employees and agents from any and all damages, losses, claims and liabilities by or to third parties arising out of or resulting from the performance by the ISO or Transmission Owners under the Tariff or any Service Agreement thereunder, any bankruptcy filings made by a Customer, or the actions or omissions of the Customer in connection with the Tariff or any Service Agreement thereunder, except in case of the ISO, gross negligence or willful misconduct by the ISO or its directors, officers, members, employees or agents, and, in the case of a Transmission Owner, the gross negligence or willful misconduct by such Transmission Owner or its directors, officers, members, employees or agents. The amount of any indemnity payment hereunder shall be reduced (including, without limitation, retroactively) by any insurance proceeds or other amounts actually recovered by the indemnified party in respect of the indemnified action, claim, demand, cost, damage or liability. The obligations of each Customer to indemnify the ISO and Transmission Owners shall be several, and not joint or joint and several.

Interruption: A reduction in non-firm transmission service due to economic reasons pursuant to Section I. 2 g).

Local Network Upgrade: Modifications or additions to the Local Network of a PTO, made in accordance with this Schedule 21, that are not Direct Assignment Facilities.

I. LOCAL POINT-TO-POINT SERVICE

Preamble

Eligible Customers seeking Local Point-To-Point Service on a specific Local Network shall refer to the applicable Local Service Schedule to determine any PTO-specific rates, terms, and conditions applicable to such service. Except as otherwise provided in the Local Service Schedules, Firm and Non-Firm Local Point-To-Point Service will be provided pursuant to the rates, terms and conditions set forth below. Local Point-To-Point Service is for the receipt of capacity and/or energy at designated Point(s) of Receipt and the transfer of such capacity and energy to designated Point(s) of Delivery.

A Local Point-To-Point Service Customer is not excused from any requirements of state law, or any order or regulation issued pursuant to state law, to arrange for Local Delivery Service with the PTO and distribution company providing such service and to pay all applicable charges associated with such service, including charges for stranded costs.

1) Nature of Firm Local Point-To-Point Service

a) Term: The minimum term of Firm Local Point-To-Point Service shall be one day and the maximum term shall be specified in the Local Service Agreement.

b) Reservation Priority: Local Long-Term Firm Point-To-Point Service shall be available on a first-come, first-served basis, i.e., in the chronological sequence in which each Transmission Customer has reserved service. Reservations for Local Short-Term Firm Point-To-Point Service will be conditional based upon the length of the requested transaction. However, Pre-Confirmed Requests for Local Short-Term Point-to-Point Service will receive priority over earlier-submitted requests that are not pre-confirmed and that have equal or shorter duration. Among requests with the same duration and, as relevant, pre-confirmation status (pre-confirmed or not pre-confirmed), priority will be given to a Transmission Customer's request that offers the highest price, followed by the date and time of the request. If the Local Network becomes oversubscribed, requests for service may preempt competing reservations up to the following conditional reservation deadlines: one day before the commencement of daily service, one week before the commencement of weekly service, and one month before the commencement of monthly service. Before the conditional reservation deadline, if available transfer capability is insufficient to satisfy all requests and reservations, a Transmission Customer with a reservation for shorter term service or equal duration service and lower price has the right of first refusal

to match any longer term request or equal duration service with a higher price before losing its reservation priority. A longer term competing request for Local Short-Term Firm Point-To-Point Service will be granted if the Transmission Customer with the right of first refusal does not agree to match the competing request within 24 hours (or earlier if necessary to comply with the scheduling deadlines provided in Section I.1.h of this Schedule 21) from being notified by the PTO of a longer-term competing request for Local Short-Term Firm Point-To-Point Service. When a longer duration request preempts multiple shorter duration reservations, the shorter duration requests shall have simultaneous opportunities to exercise the right of first refusal. Duration, price and time of response will be used to determine the order by which the multiple shorter duration reservations will be able to exercise the right of first refusal. After the conditional reservation deadline, service will commence pursuant to the terms of this Schedule 21. Firm Local Point-To-Point Service will always have a reservation priority over Non-Firm Local Point-To-Point Service under the Tariff. All Local Long-Term Firm Point-To-Point Service will have equal reservation priority with Native Load Customers and Network Customers. Reservation priorities for existing firm service customers are provided in the Local Service Schedules of this Schedule 21.

c) Use of Firm Local Point-to-Point Service by the PTO: The PTO will be subject to the rates, terms and conditions of this Schedule 21 when making Third-Party Sales under agreements executed on or after the effective date of the Tariff. The PTO will maintain separate accounting for any use of the Local Point-To-Point Service to make Third-Party Sales.

d) Service Agreements: After consultation with the PTO, the ISO shall forward a standard form of Local Service Agreement (Attachment A to this Schedule 21) to an Eligible Customer after an Eligible Customer submits a Completed Application for Local Point-To-Point Service to the ISO. Local Service Agreements executed by the Eligible Customer that contain the information required under this Schedule 21 shall also be executed by the PTO and returned to the ISO for execution and filing and/or reporting by the ISO with the Commission in compliance with applicable Commission regulations. An Eligible Customer that uses Local Point-to-Point Service at a Point of Receipt or Point of Delivery that it has not reserved and that has not executed a Local Service Agreement will be deemed, for purposes of assessing any appropriate charges and penalties, to have executed the appropriate Local Service Agreement.

e) Transmission Customer Obligations for Facility Additions Costs: In cases where the PTO, in consultation with the ISO, determines that the Local Network is not capable of providing Firm Local Point-To-Point Service without (1) degrading or impairing the reliability of service to Native Load Customers, Network Customers and other Transmission Customers taking Firm Local Point-To-Point

Service, or (2) interfering with the PTO's ability to meet prior firm contractual commitments to others, the PTO will be obligated to expand or upgrade its Local Network pursuant to the terms of Section I.3.d of this Schedule 21. The Transmission Customer must agree to compensate the PTO for any necessary transmission facility additions pursuant to the terms of Section I.14 of this Schedule 21. Any Local Network Upgrade or Direct Assignment Facilities costs to be charged to the Transmission Customer on an incremental basis under the Tariff will be specified in the Local Service Agreement prior to initiating service.

f) Curtailment of Firm Local Point-To-Point Service: In the event that a Curtailment on the PTO's Local Network, or a portion thereof, is required to maintain reliable operation of such system, Curtailments will be made on a non-discriminatory basis to the transaction(s) that effectively relieve the constraint. If multiple transactions require Curtailment, to the extent practicable and consistent with Good Utility Practice, the PTO will curtail service to Network Customers and Transmission Customers taking Firm Local Point-To-Point Service on a basis comparable to the curtailment of service to the PTO's Native Load Customers. All Curtailments will be made on a non-discriminatory basis, however, Non-Firm Local Point-To-Point Service shall be subordinate to Firm Local Point-To-Point Service and Local Network Service. When the PTO determines that an electrical emergency exists on the Non-PTF and the PTO implements emergency procedures to Curtail Firm Local Service, the Transmission Customer shall make the required reductions upon request of the PTO. The PTO reserves the right to Curtail, in whole or in part, any Local Service when, in the PTO's sole discretion, an emergency or other unforeseen condition impairs or degrades the reliability of its Local Network. The PTO will notify all affected Transmission Customers in a timely manner of any scheduled Curtailments. Penalties for failure to Curtail shall be assessed pursuant to the applicable Local Service Schedule.

g) Classification of Firm Local Point-To-Point Service:

(i) The Transmission Customer taking Firm Local Point-To-Point Service may (1) change its Receipt and Delivery Points to obtain service on a non-firm basis consistent with the terms of Section I.10.a of this Schedule 21 or (2) request a modification of the Points of Receipt or Delivery on a firm basis pursuant to the terms of Section I.10.b of this Schedule 21.

(ii) The Transmission Customer may purchase transmission service to make sales of capacity and energy from multiple generating units that are on the PTO's Local Network. For such a purchase of transmission service, the resources will be designated as multiple Points of Receipt,

unless the multiple generating units are at the same generating plant in which case the units would be treated as a single Point of Receipt.

(iii) The PTO shall provide firm deliveries of capacity and energy from the Point(s) of Receipt to the Point(s) of Delivery. For Long-Term Firm Point-To-Point Service, each Point of Receipt at which firm transfer capability is reserved by the Transmission Customer shall be set forth in the Local Service Agreement along with a corresponding capacity reservation associated with each Point of Receipt. For Short-Term Firm Point-To-Point Service, Points of Receipt and corresponding capacity reservations shall be as mutually agreed upon by the Parties. For Long-Term Firm Point-To-Point Service, each Point of Delivery at which firm transfer capability is reserved by the Transmission Customer shall be set forth in the Service Agreement along with a corresponding capacity reservation associated with each Point of Delivery. For Short-Term Firm Point-To-Point Service, Points of Delivery and corresponding capacity reservations shall be as mutually agreed upon by the Parties. The greater of either (1) the sum of the capacity reservations at the Point(s) of Receipt, or (2) the sum of the capacity reservations at the Point(s) of Delivery shall be the Transmission Customer's Reserved Capacity. The Transmission Customer will be billed for its Reserved Capacity under the terms of the applicable Local Service Schedule. The Transmission Customer may not exceed its firm capacity reserved at each Point of Receipt and each Point of Delivery except as otherwise specified in the applicable Local Service Schedule. The Local Service Schedule shall specify the rate treatment and all related terms and conditions applicable in the event that a Transmission Customer (including Third-Party Sales by the PTO) exceeds its firm reserved capacity at any Point of Receipt or Point of Delivery or uses Local Point-to-Point Service at a Point of Receipt or Point of Delivery that it has not reserved.

h) Scheduling of Firm Local Point-To-Point Service: Schedules for the Transmission Customer's Firm Local Point-To-Point Service must be submitted to the PTO no later than 10:00 a.m. of the day prior to commencement of such service. Schedules submitted after 10:00 a.m. will be accommodated, if practicable. Hour-to-hour schedules of any capacity and energy that is to be delivered must be stated in increments of 10 kW per hour. Transmission Customers within the PTO's service area with multiple requests for Transmission Service at a Point of Receipt, each of which is under 10 kW per hour, may consolidate their service requests at a common point of receipt into units of 10 kW per hour for scheduling and billing purposes. Scheduling changes will be permitted up to twenty (20) minutes before the start of the next clock hour provided that the Delivering Party and Receiving Party also agree to the schedule modification. The PTO will furnish hour-to-hour schedules equal to those furnished by the

Receiving Party (unless reduced for losses) and shall deliver the capacity and energy provided by such schedules. Should the Transmission Customer, Delivering Party or Receiving Party revise or terminate any schedule, such party shall immediately notify the PTO, and the PTO shall have the right to adjust accordingly the schedule for capacity and energy to be received and to be delivered.

2) Nature of Non-Firm Local Point-To-Point Service

a) Term: Non-Firm Local Point-To-Point Service will be available for periods ranging from one (1) hour to one (1) month. However, a purchaser of Non-Firm Local Point-To-Point Service will be entitled to reserve a sequential term of service (such as a sequential monthly term without having to wait for the initial term to expire before requesting another monthly term) so that the total time period for which the reservation applies is greater than one month, subject to the requirements of Section I.6.c of this Schedule 21.

b) Reservation Priority: Non-Firm Local Point-To-Point Service shall be available from transfer capability in excess of that needed for reliable service to Native Load Customers, Network Customers, Excepted Transactions and other Transmission Customers taking Local Long-Term and Local Short-Term Firm Point-To-Point Service. Individual Local Service Schedules may contain other applicable services. A higher priority will be assigned first to requests or reservations with a longer duration of service and second to Pre-Confirmed Requests. In the event the Local Network is constrained, competing requests of the same pre-confirmation status and equal duration will be prioritized based on the highest price offered by the Transmission Customer for the Transmission Service, or in the event the price for all Transmission Customers is the same, will be prioritized on a first-come, first-served basis, i.e., in the chronological sequence in which each customer has requested service. Transmission Customers that have already reserved shorter term service have the right of first refusal to match any longer term request before being preempted. A longer term competing request for Non-Firm Local Point-To-Point Service will be granted if the Transmission Customer with the right of first refusal does not agree to match the competing request: (a) immediately for hourly Non-Firm Local Point-To-Point Service after notification by the PTO; and, (b) within 24 hours (or earlier if necessary to comply with the scheduling deadlines provided in Section I.2.f of this Schedule 21) for Non-Firm Local Point-To-Point Service other than hourly transactions after notification by the PTO. Non-Firm Local Point-To-Point Service over secondary Point(s) of Receipt and Point(s) of Delivery will have the lowest reservation priority under the OATT.

c) Use of Non-Firm Local Point-To-Point Service by the PTO: The PTO will be subject to the rates, terms and conditions of this Schedule 21 when making Third-Party Sales under (i) agreements executed on or after the effective date of the Tariff. The PTO will maintain separate accounting for any use of Non-Firm Local Point-To-Point Service to make Third-Party Sales.

d) Service Agreements: After consultation with the PTO, the ISO shall forward a standard form of Local Service Agreement (Attachment A to this Schedule 21) to an Eligible Customer after an Eligible Customer submits a Completed Application for Local Point-To-Point Service to the ISO. Local Service Agreements executed by the Eligible Customer that contain the information required under this Schedule 21 shall also be executed by the PTO and returned to the ISO for execution and filing and/or reporting by the ISO with the Commission in compliance with applicable Commission regulations. An Eligible Customer that uses Local Point-to-Point Service at a Point of Receipt or Point of Delivery that it has not reserved and that has not executed a Local Service Agreement will be deemed, for purposes of assessing any appropriate charges and penalties, to have executed the appropriate Local Service Agreement.

e) Classification of Non-Firm Local Point-To-Point Service: The PTO and the ISO undertake no obligation under the Tariff to plan the Local Network in order to have sufficient capacity for Non-Firm Local Point-To-Point Service. Parties requesting Non-Firm Local Point-To-Point Service for the transmission of firm power do so with the full realization that such service is subject to availability and to Curtailment or Interruption under the terms of the Tariff. The Local Service Schedules shall specify the rate treatment and all related terms and conditions applicable in the event that a Transmission Customer (including Third-Party Sales by the PTO) exceeds its non-firm capacity reservation. Non-Firm Local Point-To-Point Service shall include transmission of energy on an hourly basis and transmission of scheduled short-term capacity and energy on a daily, weekly or monthly basis, but not to exceed one month's reservation for any one Application.

f) Scheduling of Non-Firm Local Point-To-Point Service: Schedules for Non-Firm Local Point-To-Point Service must be submitted to the PTO no later than 2:00 p.m. of the day prior to commencement of such service. Schedules submitted after these times will be accommodated, if practicable. Hour-to-hour schedules of energy that is to be delivered must be stated in increments of 10 kW per hour. Transmission Customers within the PTO's service area with multiple requests for Transmission Service at a Point of Receipt, each of which is under 10 kW per hour, may consolidate their schedules at a common Point of Receipt into units of 10 kW per hour. Scheduling changes will be permitted up to twenty (20) minutes before the start of the next clock hour provided that the Delivering Party and Receiving Party

also agree to the schedule modification. The PTO will furnish hour-to-hour schedules equal to those furnished by the Receiving Party (unless reduced for losses) and shall deliver the capacity and energy provided by such schedules. Should the Transmission Customer, Delivering Party or Receiving Party revise or terminate any schedule, such party shall immediately notify the PTO and the PTO shall have the right to adjust accordingly the schedule for capacity and energy to be received and to be delivered.

g) Curtailment or Interruption of Service: The PTO reserves the right to Curtail, in whole or in part, Non-Firm Local Point-To-Point Service provided under the Tariff for reliability reasons when, an emergency or other unforeseen condition threatens to impair or degrade the reliability of the Local Network. The PTO reserves the right to Interrupt, in whole or in part, Non-Firm Local Point-To-Point Service provided under the Tariff for economic reasons in order to accommodate (1) a request for Firm Local Transmission Service, (2) a request for Non-Firm Local Point-To-Point Service of greater duration, (3) a request for Non-Firm Local Point-To-Point Service of equal duration with a higher price, or (4) transmission service for Network Customers from non-designated resources. The PTO also will discontinue or reduce service to the Transmission Customer to the extent that deliveries for transmission are discontinued or reduced at the Point(s) of Receipt. Where required, Curtailments or Interruptions will be made on a non-discriminatory basis to the transaction(s) that effectively relieve the constraint, however, Non-Firm Local Point-To-Point Service shall be subordinate to Firm Local Transmission Service. If multiple transactions require Curtailment or Interruption, to the extent practicable and consistent with Good Utility Practice, Curtailments or Interruptions will be made to transactions of the shortest term (e.g., hourly non-firm transactions will be Curtailed or Interrupted before daily non-firm transactions and daily non-firm transactions will be Curtailed or Interrupted before weekly non-firm transactions). Transmission service for Network Customers from resources other than designated Network Resources will have a higher priority than any Non-Firm Local Point-To-Point Service under the Tariff. Non-Firm Local Point-To-Point Service over secondary Point(s) of Receipt and Point(s) of Delivery will have a lower priority than any Non-Firm Local Point-To-Point Service under the Tariff. The PTO will provide advance notice of Curtailment or Interruption where such notice can be provided consistent with Good Utility Practice and in accordance with the applicable Local Service Schedule. Penalties for failure to Curtail or Interrupt shall be assessed pursuant to the applicable Local Service Schedule.

3) Service Availability

a) General Conditions: The PTO will provide Firm Local and Non-Firm Local Point-To-Point Service to any Transmission Customer that has met the requirements of Section I.4 of this Schedule 21.

b) Determination of Available Transfer Capability: The PTO shall determine available transfer capability in accordance with its respective Attachment setting forth its Methodology to Assess Available Transfer Capability.

c) Initiating Service in the Absence of an Executed Service Agreement: If the PTO and the Transmission Customer requesting Firm Local or Non-Firm Local Point-To-Point Service cannot agree on all of the terms and conditions of the Local Service Agreement, the ISO shall file with the Commission, within thirty (30) days after the date the Transmission Customer provides written notification to both the PTO and the ISO directing the ISO to file, an unexecuted Local Service Agreement containing terms and conditions deemed by the PTO (in consultation with the ISO) to be appropriate for such requested service. The PTO shall commence providing Transmission Service subject to the Transmission Customer agreeing to (i) compensate the PTO at whatever rate the Commission ultimately determines to be just and reasonable, and (ii) comply with the terms and conditions of the Tariff including posting appropriate security deposits in accordance with the terms of Section I.5.c of this Schedule 21.

d) Obligation to Provide Transmission Service that Requires Expansion or Modification of the Local Network: If the PTO, in consultation with the ISO, determines that a Completed Application for Firm Local Point-To-Point Service cannot be accommodated because of insufficient capability on the Local Network, the PTO will use due diligence to expand or modify its Local Network to provide the requested Firm Local Point-To-Point Service, consistent with its planning obligations in Attachment K, provided the Transmission Customer agrees to compensate the PTO for such costs. The PTO, in consultation with the ISO, will conform to Good Utility Practice and its planning obligations in Attachment K, in determining the need for new facilities and in the design and construction of such facilities. The obligation of the PTO to expand or modify its Local Network obligation to provide the requested Firm Local Point-To-Point Service applies only to those facilities that the PTO has the right to expand or modify.

e) Deferral of Service: The PTO may defer providing service until it completes construction of new transmission facilities or upgrades needed to provide Firm Local Point-To-Point Service whenever

the PTO determines that providing the requested service would, without such new facilities or upgrades, impair or degrade reliability to any existing firm services.

f) Other Transmission Service Schedules: Eligible Customers receiving transmission service under other agreements on file with the Commission may continue to receive transmission service under those agreements until such time as those agreements may be modified by the Commission.

g) Real Power Losses: "Real Power Losses" those losses associated with transmission service as determined in accordance with Section 15.3, Section 31.6 and Schedule 21 of the OATT. Neither the ISO nor the PTOs are obligated to provide Real Power Losses. Non-PTF Real Power Losses shall be calculated and charged for in accordance with the applicable Schedule 21 Local Service Schedule.

h) Load Shedding: Load Shedding shall occur in accordance with the applicable Local Service Schedule to the extent provided for in such Local Service Schedule.

4) Transmission Customer Responsibilities

a) Conditions Required of Transmission Customers: Firm Local and Non-Firm Local Point-To-Point Service shall be provided only if the following conditions are satisfied by the Transmission Customer:

(i) The Transmission Customer has pending a Completed Application for service;

(ii) The Transmission Customer meets the creditworthiness procedures in Attachment L to the applicable PTO's Local Service Schedule;

(iii) The Transmission Customer will have arrangements in place for any other transmission service necessary to effect the delivery from the generating source to the PTO prior to the time service commences;

(iv) The Transmission Customer agrees to pay for any facilities constructed and chargeable to such Transmission Customer, whether or not the Transmission Customer takes service for the full term of its reservation;

(v) The Transmission Customer provides the information required by the PTO's planning process established in Attachment K; and

(vi) The Transmission Customer has executed a Local Service Agreement or has requested the filing of an unexecuted Local Service Agreement pursuant to Section I.3.c of this Schedule 21.

b) Transmission Customer Responsibility for Third-Party Arrangements: Any scheduling arrangements that may be required by other electric systems shall be the responsibility of the Eligible Customer requesting service. The Transmission Customer shall provide, unless waived by the ISO and the PTO, notification to the ISO and the PTO identifying such systems and authorizing them to schedule the capacity and energy to be transmitted pursuant to this Schedule 21 on behalf of the Receiving Party at the Point of Delivery or the Delivering Party at the Point of Receipt. However, the ISO and the PTO will undertake reasonable efforts to assist the Transmission Customer in making such arrangements, including without limitation, providing any information or data required by such other electric system pursuant to Good Utility Practice.

5) Procedures for Arranging Firm Local Point-To-Point Service

a) Pre-RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, or make upgrades (i.e., increase MWs served) within the terms of its existing Firm Local Point-to-Point Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Firm Local Point-to-Point Service Agreement may be required. Instead, the Transmission Customer shall contact the associated PTO to discuss and, if appropriate, modify its existing Firm Local Point-to-Point Service Agreement.

(ii) A Transmission Customer who wishes to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of its existing Firm Local Point-to-Point Service Agreement, shall contact the PTO to make arrangements to terminate the Transmission Customer's existing Local Service Agreement and shall complete

(and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

b) RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, or make upgrades (i.e., increase MWs served) within the terms of the existing Firm Local Point-to-Point Service Agreement under this Schedule 21, shall not be required to execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Firm Local Point-to-Point Service Agreement under this Schedule 21 may be required. Such modifications to an existing Local Service Agreement typically do not require an additional local or regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an application for Local Transmission Service that reflects the requested modifications to the Local Service Agreement to facilitate revision of its existing Schedule 21 Local Service Agreement.

(ii) Transmission Customers who wish to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of the existing Firm Local Point-to-Point Service Agreement under this Schedule 21, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) an Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

c) Application: A request for Firm Local Point-To-Point Service for periods of one year or longer must be made in a completed Application submitted to the ISO at least sixty (60) days in advance of the calendar month in which service is to commence. The PTO will consider requests for such firm service on shorter notice when feasible. Requests for firm service for periods of less than one year shall be subject to expedited procedures that shall be negotiated between the PTO and the Eligible Customer within the time constraints provided in the applicable Local Service Schedule. A Completed Application may be submitted by transmitting the required information to the ISO by telefax. This method will provide a time-stamped record for establishing the priority of the Application.

d) Completed Application: A Completed Application shall provide all of the information included in 18 C.F.R. § 2.20 including but not limited to the following:

(i) The identity, address, telephone number and facsimile number of the entity requesting service;

(ii) A statement that the entity requesting service is, or will be upon commencement of service, an Eligible Customer under the Tariff;

(iii) The location of the Point(s) of Receipt and Point(s) of Delivery and the identities of the Delivering Parties and the Receiving Parties;

(iv) The location of the generating facility(ies) supplying the capacity and energy and the location of the load ultimately served by the capacity and energy transmitted. The ISO and the PTO will treat this information as confidential except to the extent that disclosure of this information is required by the Tariff, by regulatory or judicial order, for reliability purposes pursuant to Good Utility Practice or pursuant to the Information Policy;

(v) A description of the supply characteristics of the capacity and energy to be delivered;

(vi) An estimate of the capacity and energy expected to be delivered to the Receiving Party;

(vii) The Service Commencement Date and the term of the requested Transmission Service;

(viii) The transmission capacity requested for each Point of Receipt and each Point of Delivery on the PTO's Local Network; customers may combine their requests for service in order to satisfy the minimum transmission capacity requirement;

(ix) A statement indicating that if the Transmission Customer submits a Pre-Confirmed Request, then the Transmission Customer will take and pay for the requested Local Service upon acceptance on OASIS by the PTO that can provide the requested Local Service; and

(x) Any additional information required by the PTO’s planning process established in Attachment K.

The ISO and the PTO shall treat this information consistent with the standards of conduct contained in Part 37 of the Commission's regulations.

e) Deposit: Except as is otherwise provided in the Local Service Schedule, a Completed Application for Firm Local Point-To-Point Service also shall include a deposit of either one month's charge for Reserved Capacity or the full charge for Reserved Capacity for service requests of less than one month. If the Application is rejected because it does not meet the conditions for service as set forth herein, in the Local Service Schedule or, in the case of requests for service arising in connection with losing bidders, in a Request For Proposals (RFP), said deposit shall be returned with interest less any reasonable costs incurred by the PTO in connection with the review of the losing bidder's Application. The deposit also will be returned with interest less any reasonable costs incurred by the PTO if the PTO is unable to complete new facilities needed to provide the service. If an Application is withdrawn or the Eligible Customer decides not to enter into a Local Service Agreement for Firm Local Point-To-Point Service, the deposit shall be refunded in full, with interest, less reasonable costs incurred by the PTO to the extent such costs have not already been recovered by the PTO from the Eligible Customer. The PTO will provide to the Eligible Customer a complete accounting of all costs deducted from the refunded deposit, which the Eligible Customer may contest if there is a dispute concerning the deducted costs. Deposits associated with construction of new facilities are subject to the provisions of Section I.5.c of this Schedule 21. If a Local Service Agreement for Firm Local Point-To-Point Service is executed, the deposit, with interest, will be returned to the Transmission Customer upon expiration or termination of the Local Service Agreement. Applicable interest shall be computed in accordance with the Commission's regulations at 18 C.F.R. § 35.19a(a)(2)(iii), and shall be calculated from the day the deposit check is credited to the PTO's account.

f) Notice of Deficient Application: If an Application fails to meet the requirements of the Tariff, the PTO shall notify the ISO within ten (10) days of the Application’s receipt of the reasons for such failure, and the ISO shall, in turn, so notify the entity requesting service within five (5) days of the receipt of notice from the PTO of the reasons for such failure. The PTO will attempt to remedy minor deficiencies in the Application through informal communications with the Eligible Customer. If such efforts are unsuccessful, the ISO shall return the Application. The PTO shall return any deposit, with interest, to the Eligible Customer. Upon receipt of a new or revised Application that fully complies with the requirements of this Schedule 21, the Eligible Customer shall be assigned a new priority consistent with the date of the new or revised Application.

g) Response to a Completed Application: Following receipt of a Completed Application for Firm Local Point-To-Point Service, the PTO shall make a determination of available transfer capability as required in Section I.3.b of this Schedule 21. Within twenty-five (25) days after the date of receipt of a Completed Application, the PTO shall notify the ISO either (i) if it will be able to provide service without performing a System Impact Study or (ii) if such a study is needed to evaluate the impact of the Application. The ISO shall so notify the Eligible Customer within five (5) days of the ISO's receipt of such notice from the PTO. Responses by the PTO and the ISO must be made as soon as practicable to all Completed Applications and the timing of such responses must be made on a non-discriminatory basis.

h) Execution of Service Agreement: Whenever the PTO, in consultation with the ISO, determines that a System Impact Study is not required and that the service can be provided, it shall notify the Eligible Customer as soon as practicable but no later than thirty (30) days after receipt of the Completed Application. Where a System Impact Study is required, the provisions of Section I.7 of this Schedule 21 will govern the execution of a Local Service Agreement. Failure of an Eligible Customer to execute and return the Local Service Agreement or request the filing of an unexecuted service agreement pursuant to Section I.3.c of this Schedule 21 within fifteen (15) days after the Local Service Agreement is tendered will be deemed a withdrawal and termination of the Application and any deposit submitted shall be refunded with interest. Nothing herein limits the right of an Eligible Customer to file another Application after such withdrawal and termination.

i) Extensions for Commencement of Service: The Transmission Customer can obtain, subject to availability, up to five (5) one-year extensions for the commencement of service. The Transmission Customer may postpone service by paying to the PTO a non-refundable annual reservation fee equal to one-month's charge for Firm Local Point-To-Point Service for each year or fraction thereof within 15 days of notifying the PTO it intends to extend the commencement of service. If during any extension for the commencement of service an Eligible Customer submits a Completed Application for Firm Local Point-To-Point Service, and such request can be satisfied only by releasing all or part of the Transmission Customer's Reserved Capacity, the original Reserved Capacity will be released unless the following condition is satisfied. Within thirty (30) days, the original Transmission Customer agrees to pay the rate for its Reserved Capacity concurrent with the new Service Commencement Date. In the event the Transmission Customer elects to release the Reserved Capacity, the reservation fees or portions thereof previously paid will be forfeited.

6) Procedures for Arranging Non-Firm Local Point-To-Point Service

a) Pre-RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of their existing Non-Firm Local Point-to-Point Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Non-Firm Local Point-to-Point Service Agreement may be required. The Transmission Customer shall contact the associated PTO to discuss and, if appropriate, modify the existing Non-Firm Local Point-to-Point Service Agreement.

(ii) A Transmission Customer who wishes to make upgrades (i.e., increase MWs served) beyond the terms of its existing Non-Firm Local Point-to-Point Service Agreement that is in effect prior February 1, 2005 ("Pre-RTO Local Service Agreement"), shall contact the PTO to make arrangements to terminate the Transmission Customer's existing Local Service Agreement and shall complete (and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

b) RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of the existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21, shall not be required to execute a new Local Service Agreement under this Schedule 21, however, modifications to the existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21 may be required.

Such modifications to an existing Local Service Agreement typically do not require an additional local or regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an application for Local Transmission Service that reflects the

requested modifications to the Local Service Agreement to facilitate revision of its existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21.

(ii) A Transmission Customer who wishes to request an upgrade (i.e., increase MWs served) beyond the terms of the existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) a new Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

c) Application: Eligible Customers seeking Non-Firm Local Point-To-Point Service must submit a Completed Application to the ISO. A Completed Application may be submitted by transmitting the required information to the ISO by telefax. This method will provide a time-stamped record for establishing the service priority of the Application.

d) Completed Application: A Completed Application shall provide all of the information included in 18 C.F.R. § 2.20 including but not limited to the following:

(i) The identity, address, telephone number and facsimile number of the entity requesting service;

(ii) A statement that the entity requesting service is, or will be upon commencement of service, an Eligible Customer under the Tariff;

(iii) The Point(s) of Receipt and the Point(s) of Delivery;

(iv) The maximum amount of capacity requested at each Point of Receipt and Point of Delivery; and

(v) The proposed dates and hours for initiating and terminating transmission service hereunder.

In addition to the information specified above, when required to properly evaluate system conditions, the ISO and the PTO also may ask the Transmission Customer to provide the following:

(vi) The electrical location of the initial source of the power to be transmitted pursuant to the Transmission Customer's request for service;

(vii) The electrical location of the ultimate load; and

(viii) A statement indicating that if the Transmission Customer submits a Pre-Confirmed Request, then the Transmission Customer will take and pay for the requested Local Point-to-Point Service upon acceptance on OASIS by the PTO that can provide the requested Local Service.

The ISO and the PTO will treat this information in (vi) and (vii) as confidential at the request of the Transmission Customer except to the extent that disclosure of this information is required by the Tariff, by regulatory or judicial order, for reliability purposes pursuant to Good Utility Practice, or pursuant to the ISO New England Information Policy. The ISO and the PTO shall treat this information consistent with the standards of conduct contained in Part 37 of the Commission's regulations.

e) Reservation of Non-Firm Local Point-To-Point Service: Requests for monthly service shall be submitted no earlier than sixty (60) days before service is to commence; requests for weekly service shall be submitted no earlier than fourteen (14) days before service is to commence, requests for daily service shall be submitted no earlier than two (2) days before service is to commence, and requests for hourly service shall be submitted no earlier than noon the day before service is to commence. Requests for service received later than 2:00 p.m. prior to the day service is scheduled to commence will be accommodated if practicable.

f) Determination of Available Transfer Capability: The PTO shall determine available transfer capability in accordance with its respective Attachment setting forth its Methodology to Assess Available Transfer Capability.

7) Additional Study Procedures For Firm Local Point-To-Point Service Requests

a) Notice of Need for System Impact Study: After receiving a request for Firm Local Point-To-Point Service, a determination shall be made on a non-discriminatory basis as to whether a System Impact Study is needed. The ISO shall review the request to determine whether the provision of the requested service would have an impact on facilities other than Non-PTF, and if so, whether a System Impact Study

is necessary to accommodate the requested service. If so, the ISO shall so inform the Eligible Customer as soon as practicable and will (in consultation with the PTO) perform a System Impact Study, as necessary, with respect to the request. A description of the ISO's methodology for completing a System Impact Study is provided in OATT Attachment D. If the ISO determines that the service would not have an impact on facilities other than Non-PTF, the PTO shall determine whether a System Impact Study is necessary to accommodate the requested service and shall so inform the Eligible Customer as soon as practicable and will (in consultation with the ISO) perform a System Impact Study, as necessary, with respect to the application. In such cases, the ISO or the PTO, as applicable, shall within thirty (30) days of receipt of a Completed Application, tender a System Impact Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the ISO or the PTO, as applicable, for performing the required System Impact Study. For a service request to remain a Completed Application, the Eligible Customer shall execute the System Impact Study Agreement and return it to the ISO or the PTO, as applicable, within fifteen (15) days. If the Eligible Customer elects not to execute the System Impact Study Agreement, its Application shall be deemed withdrawn and its deposit, pursuant to Section I.5.c of this Schedule 21, shall be returned with interest. A description of the PTO's methodology for completing a System Impact Study is provided in its Local Service Schedules.

b) System Impact Study Agreement and Cost Reimbursement:

(i) The System Impact Study Agreement will clearly specify an estimate of the cost and time for completion of the System Impact Study. The charge shall not exceed the actual cost of the study. The System Impact Study shall rely on existing transmission planning studies to the extent reasonably practicable. The Eligible Customer will not be assessed a charge for such existing studies; however, the Eligible Customer will be responsible for charges associated with any modifications to existing planning studies that are reasonably necessary to evaluate the impact of the Eligible Customer's request for service on the Local Network.

(ii) If in response to multiple Eligible Customers requesting service in relation to the same competitive solicitation, a single System Impact Study is sufficient to accommodate the requests for service, the costs of that study shall be pro-rated among the Eligible Customers.

(iii) For System Impact Studies that the PTO conducts on its own behalf, the PTO shall record the cost of the System Impact Studies pursuant to Section II.8.5 of the Tariff.

(iv) In response to multiple Eligible Customers within the same geographical or electrically interconnected area requesting that a System Impact Study for Local Service be clustered, the PTO will cluster such multiple requests if it can reasonably do so. The costs of that study shall be divided equally among the Eligible Customers, unless otherwise agreed to by the PTO and the Eligible Customers.

(v) Once a clustered study is initiated by the PTO, as evidenced by an executed System Impact Study Agreement, Eligible Customers opting out of a clustered study regarding Non-PTF facilities shall be liable for their share of the study costs as set forth in Section 7(b)(iv) above, unless otherwise agreed to by the parties to such System Impact Study Agreement.

c) System Impact Study Procedures: Upon receipt of an executed System Impact Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required System Impact Study within a sixty (60) day period. The System Impact Study shall identify any system constraints identified with specificity by a transmission element or flowgate, and additional Direct Assignment Facilities or Local Network Upgrades required to provide the requested service. In the event that the ISO or the PTO, as applicable, is unable to complete the required System Impact Study within such time period, it shall so notify the Eligible Customer and provide an estimated completion date along with an explanation of the reasons why additional time is required to complete the required studies. A copy of the completed System Impact Study and related work papers shall be made available to the Eligible Customer as soon as the System Impact Study is complete. The PTO will use the same due diligence in completing the System Impact Study for an Eligible Customer as it uses when completing studies for itself. The ISO or the PTO, as applicable, shall notify the Eligible Customer immediately upon completion of the System Impact Study if the Local Network will be adequate to accommodate all or part of a request for service or that no costs are likely to be incurred for new transmission facilities or upgrades. In order for a request to remain a Completed Application, within fifteen (15) days of completion of the System Impact Study, the Eligible Customer must execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement pursuant to Section I.3.c of this Schedule 21 or the Application shall be deemed terminated and withdrawn.

d) Facilities Study Procedures: If a System Impact Study indicates that additions or upgrades to facilities other than Non-PTF are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on the MTF facilities, the ISO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the

Eligible Customer shall agree to reimburse the ISO for performing the required Facilities Study. If a System Impact Study indicates that additions or upgrades to Non-PTF facilities are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on facilities other than Non-PTF, the PTO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the PTO for performing the required Facilities Study. For clustered studies, the cost of such studies shall be divided equally among the Eligible Customers, unless otherwise agreed to by the PTO and the Eligible Customers. Once a clustered study is initiated by the PTO, as evidenced by an executed Facilities Study Agreement, Eligible Customers opting out of a clustered study regarding Non-PTF facilities shall be liable for their share of the study costs as set forth in this Section 7(d) above, unless otherwise agreed to by the parties to such Facilities Study Agreement. For a service request to remain a Completed Application, the Eligible Customer shall execute the Facilities Study Agreement and return it within fifteen (15) days. If the Eligible Customer elects not to execute the Facilities Study Agreement, its Application shall be deemed withdrawn and its deposit, pursuant to Section I.5.c of this Schedule 21, shall be returned with interest. Upon receipt of an executed Facilities Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required Facilities Study within a sixty (60) day period. If the Facilities Study cannot be completed in the allotted time period, the Transmission Customer shall be notified and provided an estimate of the time needed to reach a final determination along with an explanation of the reasons that additional time is required to complete the study. When completed, the Facilities Study will include a good faith estimate of (i) the cost of Direct Assignment Facilities to be charged to the Transmission Customer, (ii) the Transmission Customer's appropriate share of the cost of any required Local Network Upgrades, and (iii) the time required to complete such construction and initiate the requested service. The Transmission Customer shall provide a letter of credit or other reasonable form of security acceptable to the PTO equivalent to the costs of new facilities or upgrades consistent with commercial practices as established by the Uniform Commercial Code. The Transmission Customer shall have thirty (30) days to execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement and provide the required letter of credit or other form of security or the request will no longer be a Completed Application and shall be deemed terminated and withdrawn.

e) Facilities Study Modifications: Any change in design arising from the inability to site or construct facilities as proposed will require development of a revised good faith estimate. New good faith estimates also will be required in the event of new statutory or regulatory requirements that are effective before the completion of construction or other circumstances beyond the control of the ISO and/or the

PTO that significantly affect the final cost of new facilities or upgrades to be charged to the Transmission Customer.

f) Due Diligence in Completing New Facilities: The PTO shall use due diligence to add necessary facilities or upgrade its Local Network within a reasonable time. The PTO will not upgrade its existing or planned Local Network in order to provide the requested Firm Local Point-To-Point Service if doing so would impair system reliability or otherwise impair or degrade existing firm service.

g) Partial Interim Service: If the PTO determines that it will not have adequate transfer capability to satisfy the full amount of a Completed Application for Firm Local Point-To-Point Service, the PTO nonetheless shall be obligated to offer and provide the portion of the requested Firm Local Point-To-Point Service that can be accommodated without addition of any facilities. However, the PTO shall not be obligated to provide the incremental amount of requested Firm Local Point-To-Point Service that requires the addition of facilities or upgrades to the Local Network until such facilities or upgrades have been placed in service.

h) Expedited Procedures for New Facilities: In lieu of the procedures set forth above, the Eligible Customer shall have the option to expedite the process by requesting the ISO (in consultation with the PTO) to tender at one time, together with the results of required studies, an "Expedited Local Service Agreement" pursuant to which the Eligible Customer would agree to compensate the PTO for all costs incurred. In order to exercise this option, the Eligible Customer shall request in writing an expedited Local Service Agreement covering all of the above-specified items within thirty (30) days of receiving the results of the System Impact Study identifying needed facility additions or upgrades or costs incurred in providing the requested service. While the PTO agrees to provide the Eligible Customer with its best estimate of the new facility costs and other charges that may be incurred, such estimate shall not be binding and the Eligible Customer must agree in writing to compensate the PTO for all costs incurred. The Eligible Customer shall execute and return such an Expedited Local Service Agreement within fifteen (15) days of its receipt or the Eligible Customer's request for service will cease to be a Completed Application and will be deemed terminated and withdrawn.

i) Penalties for Failure to Meet Study Deadlines: Sections I.7.c and I.7.d of this Schedule 21 require a Transmission Provider to use due diligence to meet 60-day study completion deadlines for System Impact Studies and Facilities Studies.

(i) The PTO is required to file a notice with the Commission in the event that more than twenty (20) percent of non-Affiliates' System Impact Studies and Facilities Studies completed by the PTO in any two consecutive calendar quarters are not completed within the 60-day study completion deadlines. Such notice must be filed within thirty (30) days of the end of the calendar quarter triggering the notice requirement.

(ii) For the purposes of calculating the percent of non-Affiliates' System Impact Studies and Facilities Studies processed outside of the 60-day study completion deadlines, the PTO shall consider all System Impact Studies and Facilities Studies that it completes for non-Affiliates during the calendar quarter. The percentage should be calculated by dividing the number of those studies which are completed on time by the total number of completed studies. The PTO may provide an explanation in its notification filing to the Commission if it believes there are extenuating circumstances that prevented it from meeting the 60-day study completion deadlines.

(iii) The PTO is subject to an operational penalty if it completes ten (10) percent or more of non-Affiliates' System Impact Studies and Facilities Studies outside of the 60-day study completion deadlines for each of the two calendar quarters immediately following the quarter that triggered its notification filing to the Commission. The operational penalty will be assessed for each calendar quarter for which an operational penalty applies, starting with the calendar quarter immediately following the quarter that triggered the PTO's notification filing to the Commission. The operational penalty will continue to be assessed each quarter until the PTO completes at least ninety (90) percent of all non-Affiliates' System Impact Studies and Facilities Studies within the 60-day deadline.

(iv) For penalties assessed in accordance with subsection (iii) above, the penalty amount for each System Impact Study or Facilities Study shall be equal to $500 for each day the PTO takes to complete that study beyond the 60-day deadline.

j) Claims or Disputes: Any claim or dispute between the PTO and the Transmission Customer with respect to a System Impact Study or Facilities Study shall be governed by the provisions of Section I.6 of the Tariff.

8) Procedures if The PTO is Unable to Complete New Transmission Facilities for Firm Local Point-To-Point Service

a) Delays in Construction of New Facilities: If any event occurs that will materially affect the time for completion of new facilities, or the ability to complete them, the PTO shall promptly notify the Transmission Customer. In such circumstances, the PTO shall within, thirty (30) days of notifying the Transmission Customer of such delays, convene a technical meeting with the Transmission Customer to evaluate the alternatives available to the Transmission Customer. The PTO also shall make available to the Transmission Customer studies and work papers related to the delay, including all information that is in the possession of the PTO that is reasonably needed by the Transmission Customer to evaluate any alternatives.

b) Alternatives to the Original Facility Additions: When the review process of Section I.8.a of this Schedule 21 determines that one or more alternatives exist to the originally planned construction project, the PTO shall present such alternatives for consideration by the Transmission Customer. If, upon review of any alternatives, the Transmission Customer desires to maintain its Completed Application subject to construction of the alternative facilities, it may request that the ISO file a revised Local Service Agreement for Firm Local Point-To-Point Service. If the alternative approach solely involves Non-Firm Local Point-To-Point Service, the PTO shall so inform the ISO, and the ISO (in consultation with the PTO) shall thereafter promptly tender to the Transmission Customer a Local Service Agreement for Non-Firm Local Point-To-Point Service providing for the service. In the event the PTO concludes that no reasonable alternative exists and the Transmission Customer disagrees, the Transmission Customer may seek relief under the dispute resolution procedures of Section I.6 of the Tariff.

c) Refund Obligation for Unfinished Facility Additions: If the PTO and the Transmission Customer mutually agree that no other reasonable alternatives exist and the requested Firm Local Point-To-Point Service cannot be provided out of existing capability, the obligation to provide the requested service shall terminate and any deposit made by the Transmission Customer shall be returned with interest pursuant to Commission regulations 35.19a(a)(2)(iii). However, the Transmission Customer shall be responsible for all prudently incurred costs by the ISO and the PTO through the time construction was suspended, including costs for removal of unfinished facilities and any ongoing operating expenses of the unfinished facilities until they are removed.

9) Provisions Relating to Transmission Construction and Services on the Systems of Other Utilities

a) Responsibility for Third-Party System Additions: The PTO shall not be responsible for making arrangements for any necessary engineering, permitting, and construction of transmission or distribution facilities on the system(s) of any other entity or for obtaining any regulatory approval for such facilities. The PTO will undertake reasonable efforts to assist the Transmission Customer in obtaining such arrangements, including without limitation, providing any information or data required by such other electric system pursuant to Good Utility Practice.

b) Coordination of Third-Party System Additions: In circumstances where the need for transmission facilities or upgrades is identified, and if such upgrades further require the addition of transmission facilities on other systems, the PTO shall have the right to coordinate construction on its own system with the construction required by others. The PTO, after consultation with the Transmission Customer and representatives of such other systems, may defer construction of its new transmission facilities, if the new transmission facilities on another system cannot be completed in a timely manner. The PTO shall notify the Transmission Customer in writing of the basis for any decision to defer construction and the specific problems which must be resolved before it will initiate or resume construction of new facilities. Within sixty (60) days of receiving written notification by the PTO of its intent to defer construction, the Transmission Customer may challenge the decision in accordance with Section I.6 of the Tariff.

10) Changes in Service Specifications

a) Modifications On a Non-Firm Basis: The Transmission Customer taking Firm Local Point-To-Point Service from a PTO may request transmission service on a non-firm basis over Receipt and Delivery Points of the same PTO other than those specified in the Local Service Agreement ("Secondary Receipt and Delivery Points") in amounts not to exceed its firm capacity reservation, without incurring an additional Non-Firm Local Point-To-Point Service charge or executing a new Local Service Agreement, subject to the following conditions. A Transmission Customer may request a modification to its Non-Firm Local Point-to-Point Service by making such a request to the PTO and the ISO, which must be made pursuant to Sections I.6. (a) and (b), as appropriate.

(a) Service provided over Secondary Receipt and Delivery Points will be non-firm only, on an as-available basis and will not displace any firm or non-firm service reserved or scheduled by third-parties under the Tariff or by the PTO on behalf of its Native Load Customers.

(b) The sum of all Firm Local and Non-Firm Local Point-To-Point Service provided to the Transmission Customer at any time pursuant to this section shall not exceed the Reserved Capacity in the relevant Local Service Agreement under which such services are provided.

(c) The Transmission Customer shall retain its right to schedule Firm Local Point-To-Point Service at the Receipt and Delivery Points specified in the relevant Local Service Agreement in the amount of its original capacity reservation.

(d) Service over Secondary Receipt and Delivery Points on a non-firm basis shall not require the filing of an Application for Non-Firm Local Point-To-Point Service under the Tariff. However, all other requirements of this Schedule 21 (except as to transmission rates) shall apply to transmission service on a non-firm basis over Secondary Receipt and Delivery Points.

b) Modification On a Firm Basis: Any request by a Transmission Customer to modify the Firm Local Point-to-Point Service it receives from a PTO to obtain service between different Receipt and Delivery Points on the Local Network of the same PTO on a firm basis shall be treated as a new request for service, except that such Transmission Customer shall not be obligated to pay any additional deposit if the capacity reservation does not exceed the amount reserved in the existing Local Service Agreement. While such new request is pending, the Transmission Customer shall retain its priority for service at the existing firm Receipt and Delivery Points specified in its Local Service Agreement. A Transmission Customer may request a modification to its Firm Local Point-to-Point Service by making such a request to the PTO and the ISO, which must be made pursuant to Sections I.5. (a) and (b), as appropriate.

11) Sale or Assignment of Transmission Service

a) Procedures for Assignment or Transfer of Service: A Transmission Customer may sell, assign, or transfer all or a portion of its rights under its Local Service Agreement, but only to another Eligible Customer (the Assignee). The Transmission Customer that sells, assigns or transfers its rights under its Local Service Agreement is hereafter referred to as the "Reseller" as the term used throughout this Schedule 21. Compensation to Resellers shall be at rates established by agreement between the Reseller and the Assignee. The Assignee must execute a service agreement with the PTO governing reassignments of transmission service prior to the date on which the reassigned service commences. The PTO shall charge the Reseller, as appropriate, at the rate stated in the Reseller's Local Service Agreement with the PTO or the associated OASIS schedule and credit the Reseller with the price reflected in the

Assignee's Service Agreement with the PTO or the associated OASIS schedule; provided that, such credit shall be reversed in the event of non-payment by the Assignee. If the Assignee does not request any change in the Point(s) of Receipt or the Point(s) of Delivery, or a change in any other term or condition set forth in the original Local Service Agreement, the Assignee will receive the same services as did the Reseller and the priority of service for the Assignee will be the same as that of the Reseller. The Assignee will be subject to all terms and conditions of the Tariff. If the Assignee requests a change in service, the reservation priority of service will be determined by the PTO pursuant to Section I.1.b of this Schedule 21. A Transmission Customer may request a modification to its Firm Local Point-to-Point Service by making such a request to the PTO and the ISO must be made pursuant to sections I.5. (a) and (b) and I.6. (a) and (b), as appropriate.

b) Limitations on Assignment or Transfer of Service: If the Assignee requests a change in the Point(s) of Receipt or Point(s) of Delivery, or a change in any other specifications set forth in the original Local Service Agreement, the PTO will consent to such change subject to the provisions of the Tariff, provided that the change will not impair the operation and reliability of the New England Transmission System or the PTO's distribution system, as applicable. The Assignee shall compensate the ISO and/or the PTO, as applicable, for performing any System Impact Study needed to accommodate the proposed change and any additional costs resulting from such change. The Reseller shall remain liable for the performance of all obligations under the Local Service Agreement, except as specifically agreed to by the PTO and Reseller through an amendment to the Local Service Agreement

c) Information on Assignment or Transfer of Service: In accordance with Section I.11 of this Schedule 21 and applicable provisions of the Local Service Schedules, all sales or assignments of capacity must be conducted through or otherwise posted on the PTO's OASIS on or before the date the reassigned Local Point-to-Point Service commences and are subject to Section I.11.a of this Schedule 21. Resellers may also use the OASIS to post transmission capacity available for resale.

12) Metering and Power Factor Correction at Receipt and Delivery Points(s)

a) Transmission Customer Obligations: Unless otherwise provided in the applicable Local Service Schedule, the Transmission Customer shall be responsible for installing and maintaining compatible metering and communications equipment to accurately account for the capacity and energy being transmitted through Local Point-To-Point Service and to communicate the information to the PTO,

Local Control Centers and the ISO. Such equipment shall remain the property of the Transmission Customer.

b) PTO Access to Metering Data: The PTO shall have access to metering data, which may reasonably be required to facilitate measurements and billing under the Local Service Agreement.

c) Power Factor: In accordance with Good Utility Practice and any applicable Local Service Schedule, the Transmission Customer is required to maintain a power factor within the same range as the PTO. The power factor requirements are specified in the Local Service Agreement where applicable.

13) Compensation for Local Point-To-Point Service:

Rates for Firm Local and Non-Firm Local Point-To-Point Service are set forth in the Local Service Schedules. The applicable rates for Firm Local and Non-Firm Local Point-to-Point Service set forth in the Local Service Schedules shall be reduced to zero for the charging load of an Electric Storage Facility when the Regional Network Service charges are reduced to zero pursuant to Section II.21.3 of the OATT. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market.

14) Compensation for New Facilities Costs:

Whenever a System Impact Study performed in connection with the provision of Firm Local Point-To-Point Service identifies the need for new facilities, the Transmission Customer shall be responsible for the costs of the new facilities to the extent consistent with Commission policy.

II. LOCAL NETWORK SERVICE

Preamble

Eligible Customers seeking Local Network Service on a specific Local Network shall refer to the applicable Local Service Schedule to determine any PTO-specific rates, terms, and conditions applicable

to such service. Except as otherwise provided in the Local Service Schedules, Local Network Service will be provided pursuant to the applicable rates, terms and conditions set forth below.

1) Nature of Local Network Service

Local Network Service is provided to Network Customers to serve their loads. It includes transmission service for the delivery to a Network Customer of its energy and capacity from Network Resources and delivery to or by Network Customers of energy and capacity from New England Markets transactions.

2) Availability of Local Network Service

a) Eligibility to Receive Local Network Service: Transmission Customers taking Regional Network Service must also take Local Service.

b) Compliance With State Law: A Network Customer is not excused from any requirements of state law, or any order or regulation issued pursuant to state law, to arrange for Local Delivery Service with the PTO and distribution company providing such service and to pay all applicable charges associated with such service, including charges for stranded costs.

c) Scope of Service: Local Network Service allows Network Customers to efficiently and economically utilize their resources and Interchange Transactions to serve their Local and Regional Network Load and any additional load that may be designated pursuant to the Tariff. The Network Customer taking Local Network Service must obtain or provide Ancillary Services.

d) PTO Responsibilities: The PTO in accordance with the TOA will plan, construct, operate and maintain its Local Network in accordance with Good Utility Practice and its planning obligations in Attachment K in order to provide the Network Customer with Local Network Service. Each PTO, on behalf of its Native Load Customers, shall be required to designate resources and loads in the same manner as any Network Customer. This information must be consistent with the information used by the PTO to calculate available transfer capability. The PTO in accordance with the TOA shall include the Network Customer's Local Network Load in Local Network planning and shall, consistent with Good Utility Practice and Attachment K, endeavor to construct and place into service sufficient transfer capability to deliver Network Resources to serve the Network Customer's Local and Regional Network Load on a basis comparable to the PTO's delivery of its own generating and purchased resources to its Native Load Customers.

e) **Comparability of Service**: Local Network Service will be provided to the Network Customer for the delivery of energy and/or capacity from its resources to serve its Local and Regional Network Loads on a basis that is comparable to the PTO's use of its Local Network to reliably serve Native Load Customers.

f) **Real Power Losses**: "Real Power Losses" those losses associated with transmission service as determined in accordance with Section 15.3, Section 31.6 and Schedule 21 of the OATT. The PTOs are not obligated to provide Real Power Losses. Non-PTF Real Power Losses shall be calculated and charged for in accordance with the applicable Schedule 21 Local Service Schedule.

g) **Secondary Service**: The Network Customer may use the Local Network to deliver energy to its Local Network Loads from resources that have not been designated as Network Resources. Such energy shall be transmitted, on an as available basis, at no additional charge. Secondary service shall not require the filing of an Application for Local Network Service under Section II of this Schedule 21. However, all other requirements of Section II of this Schedule 21 (except for transmission rates) shall apply to secondary service. Deliveries from resources other than Network Resources will have a higher priority than any Non Firm Local Point To Point Service.

h) **Restrictions on Use of Service**: The Network Customer shall not use Local Network Service for (i) sales of capacity and energy to non designated loads, or (ii) direct or indirect provision of transmission service by the Network Customer to third parties. All Network Customers taking Local Network Service shall use Local Point To Point Service for any Third Party Sale, which requires use of the Local Network. The PTO shall specify any appropriate charges and penalties and all related terms and conditions applicable in the event that a Network Customer uses Local Network Service or secondary service pursuant to Section II.2.g of this Schedule 21 to facilitate a wholesale sale that does not serve Local Network Load.

3) **Initiating Service**

a) **Condition Precedent for Receiving Service**: Local Network Service shall be provided only if the following conditions are satisfied by the Eligible Customer: (i) the Eligible Customer completes an Application to the ISO for service, (ii) the Eligible Customer and the PTO complete the technical arrangements, and (iii) the Eligible Customer executes a Local Service Agreement with the PTO and the

ISO or requests in writing that the ISO file an unexecuted Local Service Agreement containing terms and conditions deemed by the PTO (in consultation with the ISO) to be appropriate for such requested service with the Commission.

4) Procedures for Arranging Local Network Service

a) Pre-RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of their existing Local Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Local Service Agreement may be required. The Transmission Customer shall contact the PTO to discuss and, if appropriate, modify the existing Local Service Agreement.

(ii) A Transmission Customer who wishes to make upgrades (i.e., increase MWs served) beyond the terms of its existing Local Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall contact the PTO to make arrangements to terminate the Transmission Customer's existing Local Service Agreement and shall complete (and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

b) RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternative Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of the existing Local Service Agreement under this Schedule 21, shall not be required execute a new Local Service Agreement under this Schedule 21, however, modifications to the existing Local Service Agreement under this Schedule 21 may be required. Such modifications to an existing Local Service Agreement typically do not require an additional Local or Regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an

application for Local Transmission Service that reflects the requested modifications to the Local Service Agreement to facilitate revision of its existing Schedule 21 Local Service Agreement.

(ii) A Transmission Customer who wishes to make upgrades (i.e., increase MWs served) beyond the terms of the existing Local Service Agreement under this Schedule 21, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) a new Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

c) Application Procedures: An Eligible Customer requesting Local Network Service must submit an Application, with a deposit equal to the charge for one month of service, unless another charge is specified in the applicable Local Service Schedule, to the ISO as far as possible in advance of the month in which service is to commence. Completed Applications for Local Network Service will be assigned a reservation priority according to the date and time the Application is received, with the earliest Application receiving the highest priority. A Completed Application shall provide all of the information included in 18 C.F.R. §2.20 including but not limited to the following:

(i) The identity, address, telephone number and facsimile number of the party requesting service;

(ii) A statement that the party requesting service is, or will be upon commencement of service, an Eligible Customer;

(iii) A description of the Local Network Load at each delivery point. This description should separately identify and provide the Eligible Customer's best estimate of the total loads to be served at each transmission voltage level, and the loads to be served from each substation at the same transmission voltage level. The description should include a ten-year forecast of summer and winter load resource requirements beginning with the first year after the service is scheduled to commence;

(iv) The amount and location of any interruptible loads included in the Local Network Load. This shall include the summer and winter capacity requirements for each interruptible load (had such load not been interruptible), that portion of the load subject to interruption, the conditions under which an interruption can be implemented and any limitations on the amount and frequency

of interruptions. An Eligible Customer should identify the amount of interruptible customer load (if any) included in the ten-year load forecast provided in response to (iii) above;

(v) A description of Network Resources (current and ten-year projection), which shall include, for each Network Resource, if the description is not otherwise available to the ISO and the PTOs:

- Unit size and amount of capacity from that unit to be designated as Network Resource
- VAR capability (both leading and lagging) of all generators
- Operating restrictions
- Any periods of restricted operations throughout the year
- Maintenance schedules
- Minimum loading level of unit
- Normal operating level of unit
- Any must-run unit designations required for system reliability or contract reasons
- Approximate variable dispatch price ($/MWH), consistent with Market Rule 1, for redispatch computations
- Arrangements governing sale and delivery of power to third parties from generating facilities located in the New England Control Area, where only a portion of unit output is designated as a Network Resource
- Description of external purchased power designated as a Network Resource including source of supply, control area location, transmission arrangements and delivery point(s);

(vi) Description of Eligible Customer's transmission system:

- Load flow and stability data, such as real and reactive parts of the load, lines, transformers, reactive devices and load type, including normal and emergency ratings of all transmission equipment in a load flow format compatible with that used by the ISO and the PTOs
- Operating restrictions needed for reliability
- Operating guides employed by system operators
- Contractual restrictions or committed uses of the Eligible Customer's transmission system, other than the Eligible Customer's Local Network Loads and Resources
- Location of Network Resources described in subsection (v) above

- ten-year projection of system expansions or upgrades
- transmission system maps that include any proposed expansions or upgrades
- Thermal ratings of Eligible Customer's Control Area ties with other Control Areas;

(vii) Service Commencement Date and the term of the requested service. The minimum term for service is one year; and

(viii) Any additional information required of the Transmission Customer as specified in the PTO's planning process established in Attachment K.

Unless the Eligible Customer and the ISO agree to a different time frame, the ISO must acknowledge the request within ten (10) days of receipt. The acknowledgment must include a date by which a response, including a Local Service Agreement, will be sent to the Eligible Customer. If an Application fails to meet the requirements of this Section, the PTO shall notify the ISO within ten (10) days of the Application's receipt of the reasons for such failure, and the ISO shall, in turn, so notify the entity requesting service within five (5) days of the receipt of notice from the PTO of the reasons for such failure. Wherever possible, the ISO and the PTO will attempt to remedy deficiencies in the Application through informal communications with the Eligible Customer. If such efforts are unsuccessful, the ISO shall return the Application without prejudice to the Eligible Customer, who may thereafter file a new or revised Application that fully complies with the requirements of this Section. The Eligible Customer will be assigned a new reservation priority consistent with the date of the new or revised Application. The ISO and the PTO shall treat this information consistent with the standards of conduct contained in Part 37 of the Commission's regulations.

d) Technical Arrangements to be Completed Prior to Commencement of Service: Local Network Service shall not commence until the PTO and the Network Customer, or a third party, have completed installation of all equipment specified under the Local Service Agreement consistent with Good Utility Practice and any additional requirements reasonably and consistently imposed to ensure the reliable operation of the Non-PTF. The PTO shall exercise reasonable efforts, in coordination with the Network Customer, to complete such arrangements as soon as practicable taking into consideration the Service Commencement Date.

e) Network Customer Facilities: The provision of Local Network Service shall be conditioned upon the Network Customer's constructing, maintaining and operating the facilities on its side of each

delivery point or interconnection necessary to reliably deliver capacity and energy from the Non-PTF to the Network Customer. The Network Customer shall be solely responsible for constructing or installing and operating and maintaining all facilities on the Network Customer's side of each such delivery point or interconnection.

f) Filing of Service Agreement: The ISO shall file Local Service Agreements with the Commission in compliance with applicable Commission regulations.

5) Network Resources

a) Designation of Network Resources: The Network Customer shall designate those Network Resources which are owned, purchased or leased by it. The Network Resources so designated may not include resources, or any portion thereof, that are committed for sale to non-designated third party load or otherwise cannot be called upon to meet the Network Customer's Local Network Load on a non-interruptible basis. Any owned, purchased or leased resources that were serving the Network Customer's loads under firm agreements entered into on or before the Compliance Effective Date shall be deemed to continue to be so owned, purchased or leased by it until the Network Customer informs the ISO and the PTO of a change.

b) Designation of New Network Resources: The Network Customer shall identify any new Network Resources which are owned, purchased or leased by it with as much advance notice as practicable. A designation of any new Network Resource as owned, purchased or leased by the Customer must be made by a notice to the ISO and the PTO.

c) Termination of Network Resources: The Network Customer may terminate the designation of all or part of a Network Resource as owned, purchased or leased by it at any time but shall provide notification to the ISO and the PTO as soon as reasonably practicable.

d) Network Customer Redispatch Obligation: As a condition to receiving Local Network Service, the Network Customer agrees to redispatch its Network Resources as requested by the ISO and the PTO. The ISO will redispatch all Resources subject to its control, pursuant to Market Rule 1, in order to meet load and to accommodate External Transactions. The Network Customers will be charged for the Congestion Costs and any other costs associated with such redispatch in accordance with Market Rule 1.

e) Transmission Arrangements for Network Resources Not Physically Interconnected with the PTO's Non-PTF: The Network Customer shall be responsible for any arrangements necessary to deliver capacity and energy from a Network Resource not physically interconnected with the PTO's Non-PTF. The applicable PTO will undertake reasonable efforts to assist the Network Customer in obtaining such arrangements, including without limitation, providing any information or data required by such other entity pursuant to Good Utility Practice.

f) Limitation on Designation of Network Resources: The Network Customer must demonstrate that it owns or has committed to purchase generation pursuant to an executed contract in order to designate a generating resource as a Network Resource. Alternatively, the Network Customer may establish that execution of a contract is contingent upon the availability of transmission service under this Schedule 21.

g) Network Customer Owned Transmission Facilities: The Network Customer that owns existing transmission facilities that are integrated with the PTO's Local Network may be eligible to receive consideration either through a billing credit or some other mechanism. In order to receive such consideration, the Network Customer must demonstrate that its transmission facilities are integrated into the planning and operations of the PTO to serve all of its power and transmission customers. For facilities added by the Network Customer subsequent to the effective date of a Final Rule in RM05-25-000, the Network Customer shall receive credit for such transmission facilities added if such facilities are integrated into the operations of the PTO's facilities; provided however, the Local Network Customer's transmission facilities shall be presumed to be integrated if such transmission facilities, if owned by the PTO, would be eligible for inclusion in the PTO's annual transmission revenue requirement as specified in the PTO's respective Local Service Schedule. Calculation of any credit under this subsection shall be addressed in either the Network Customer's Service Agreement or any other agreement between the Parties.

6) Designation of Local Network Load

a) Local Network Load: The Network Customer must designate the individual Local Network Loads which it expects to have served through Local Network Service. The Local Network Loads shall be specified in the Local Service Agreement.

b) New Local Network Loads Within the New England Control Area: The Network Customer shall provide the ISO and the PTO with as much advance notice as reasonably practicable of the designation of new Local Network Load that will be added to the Non-PTF. A designation of new Local Network Load must be made through a modification of service pursuant to a new Application. The PTO will use due diligence to install or cause to be installed any transmission facilities required to interconnect a new Local Network Load designated by the Network Customer. The costs of new facilities required to interconnect a new Local Network Load shall be determined in accordance with the procedures provided in this Schedule 21 and shall be charged to the Network Customer in accordance with Commission policy and this Schedule 21.

c) Local Network Load Not Physically Interconnected with the PTO: This Section applies to both initial designation and the subsequent addition of new Local Network Load not physically interconnected with the PTO's Non-PTF. To the extent that the Network Customer desires to obtain transmission service for a load outside the Local Network, the Network Customer shall have the option of (1) electing to include the entire load as Local Network Load for all purposes under this Schedule 21 and designating Network Resources in connection with such additional Local Network Load, or (2) excluding that entire load from its Local Network Load and purchasing Local Point To Point Service under this Schedule 21. To the extent that the Network Customer gives notice of its intent to add a new Local Network Load as part of its Local Network Load pursuant to this Section the request must be made through a modification of service pursuant to a new Application.

d) New Interconnection Points: To the extent the Network Customer desires to add a new Delivery Point or interconnection point between the Non-PTF and a Local Network Load, the Network Customer shall provide the ISO and the PTO with as much advance notice as reasonably practicable.

e) Changes in Service Requests: Under no circumstances shall the Network Customer's decision to cancel or delay a requested change in Local Network Service (the addition of a new Network Resource, if any, or designation of a new Local Network Load) in any way relieve the Network Customer of its obligation to pay the costs of transmission facilities constructed by the PTOs and charged to the Network Customer as reflected in the applicable Local Service Agreement or other appropriate agreement. However, the PTO must treat any requested change in Local Network Service in a non-discriminatory manner.

f) Annual Load and Resource Information Updates: The Network Customer shall provide the ISO and the PTO with annual updates of Local Network Load and Network Resource forecasts consistent with those included in its Application including, but not limited to, any information provided under Section II.3.b of this Schedule 21 pursuant to the PTO's planning process in Attachment K. The Network Customer also shall provide the ISO and the PTO with timely written notice of material changes in any other information provided in its Application relating to the Network Customer's Local Network Load, Network Resources, its transmission system or other aspects of its facilities or operations affecting the ability of the PTO to provide reliable service.

7) Additional Study Procedures For Local Network Service Requests

a) Notice of Need for System Impact Study: After receiving a request for Local Network Service, a determination shall be made on a non-discriminatory basis as to whether a System Impact Study is needed. The ISO shall review the request to determine whether the provision of the requested service would have an impact on facilities other than Non-PTF, and if so, whether a System Impact Study is necessary to accommodate the requested service. If so, the ISO shall so inform the Eligible Customer as soon as practicable and will (in consultation with the PTO) perform a System Impact Study, as necessary, with respect to the request. A description of the ISO's methodology for completing a System Impact Study is provided in OATT Attachment D. If the ISO determines that the service would not have an impact on facilities other than Non-PTF, the PTO shall determine whether a System Impact Study is necessary to accommodate the requested service and shall so inform the Eligible Customer as soon as practicable and will (in consultation with the ISO) perform a System Impact Study, as necessary, with respect to the application. In such cases, the ISO or the PTO, as applicable, shall within thirty (30) days of receipt of a Completed Application, tender a System Impact Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the ISO or the PTO, as applicable, for performing the required System Impact Study. For a service request to remain a Completed Application, the Eligible Customer shall execute the System Impact Study Agreement and return it to the ISO or the PTO, as applicable, within fifteen (15) days. If the Eligible Customer elects not to execute the System Impact Study Agreement, its Application shall be deemed withdrawn and its deposit shall be returned with interest. A description of the PTO's methodology for completing a System Impact Study is provided in its Local Service Schedule.

b) System Impact Study Agreement and Cost Reimbursement:

(i) The System Impact Study Agreement will clearly specify an estimate of the cost and time for completion of the System Impact Study. The charge shall not exceed the actual cost of the study. The System Impact Study shall rely on existing transmission planning studies to the extent reasonably practicable. The Eligible Customer will not be assessed a charge for such existing studies; however, the Eligible Customer will be responsible for charges associated with any modifications to existing planning studies that are reasonably necessary to evaluate the impact of the Eligible Customer's request for service on the Local Network.

(ii) If in response to multiple Eligible Customers requesting service in relation to the same competitive solicitation, a single System Impact Study is sufficient to accommodate the requests for service, the costs of that study shall be pro-rated among the Eligible Customers.

(iii) For System Impact Studies that the PTO conducts on its own behalf, the PTO shall record the cost of the System Impact Studies pursuant to Section II.8.5 of the Tariff.

(iv) In response to multiple Eligible Customers within the same electrically interconnected area requesting clustering of system Impact Study analysis for Local Service, the PTO will accommodate such multiple requests if it can reasonable do so. The costs of such studies shall be pro-rated among the Eligible Customers on an agreed upon basis.

c) System Impact Study Procedures: Upon receipt of an executed System Impact Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required System Impact Study within a sixty (60) day period. The System Impact Study shall identify any system constraints, additional Direct Assignment Facilities or Local Network Upgrades required to provide the requested service. In the event that the ISO or the PTO, as applicable, is unable to complete the required System Impact Study within such time period, it shall so notify the Eligible Customer and provide an estimated completion date along with an explanation of the reasons why additional time is required to complete the required studies. A copy of the completed System Impact Study and related work papers shall be made available to the Eligible Customer as soon as the System Impact Study is complete. The PTO will use the same due diligence in completing the System Impact Study for an Eligible Customer as it uses when completing studies for itself. The ISO or the PTO, as applicable, shall notify the Eligible Customer immediately upon completion of the System Impact Study if the Local Network will be adequate to accommodate all or part of a request for service or that no costs are likely to be incurred for new transmission facilities or upgrades. In order for a request to remain a Completed Application, within

fifteen (15) days of completion of the System Impact Study, the Eligible Customer must execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement pursuant to Section II.3.a of this Schedule 21 or the Application shall be deemed terminated and withdrawn.

d) Facilities Study Procedures: If a System Impact Study indicates that additions or upgrades to facilities other than Non-PTF are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on the MTF facilities, the ISO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the ISO for performing the required Facilities Study. If a System Impact Study indicates that additions or upgrades to Non-PTF facilities are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on the MTF facilities, the PTO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the PTO for performing the required Facilities Study. For clustered studies, the cost of such studies shall be pro-rated among the Eligible Customers on an agreed upon basis. For a service request to remain a Completed Application, the Eligible Customer shall execute the Facilities Study Agreement and return it within fifteen (15) days. If the Eligible Customer elects not to execute the Facilities Study Agreement, its Application shall be deemed withdrawn and its deposit shall be returned with interest. Upon receipt of an executed Facilities Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required Facilities Study within a sixty (60) day period. If the Facilities Study cannot be completed in the allotted time period, the Eligible Customer shall be notified and provided an estimate of the time needed to reach a final determination along with an explanation of the reasons that additional time is required to complete the study. When completed, the Facilities Study will include a good faith estimate of (i) the cost of Direct Assignment Facilities to be charged to the Eligible Customer, (ii) the Eligible Customer's appropriate share of the cost of any required Local Network Upgrades, and (iii) the time required to complete such construction and initiate the requested service. The Eligible Customer shall provide a letter of credit or other reasonable form of security acceptable to the PTO equivalent to the costs of new facilities or upgrades consistent with commercial practices as established by the Uniform Commercial Code. The Eligible Customer shall have thirty (30) days to execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement and provide the required letter of credit or other form of security or the request will no longer be a Completed Application and shall be deemed terminated and withdrawn.

In addition to the foregoing, each Facilities Study shall, if requested by the Eligible Customer, contain a non-binding estimate from the ISO of the Incremental ARRs, if any, resulting from the construction of the new facilities. After completion of the transmission upgrade or expansion, the ISO shall determine the Incremental ARRs, if any, resulting from the upgrade or expansion.

e) Facilities Study Modifications: Any change in design arising from the inability to site or construct facilities as proposed will require development of a revised good faith estimate. New good faith estimates also will be required in the event of new statutory or regulatory requirements that are effective before the completion of construction or other circumstances beyond the control of the ISO and/or the PTO that significantly affect the final cost of new facilities or upgrades to be charged to the Transmission Customer.

f) Due Diligence in Completing New Facilities: The PTO shall use due diligence to add necessary facilities or upgrade its Local Network within a reasonable time. The PTO will not upgrade its existing or planned Local Network in order to provide the requested Local Network Service if doing so would impair system reliability or otherwise impair or degrade existing firm service.

g) Claims or Disputes: Any claim or dispute between the PTO and the Transmission Customer with respect to a System Impact Study or Facilities Study shall be governed by the provisions of Section I.6 of the Tariff.

h) Penalties for Failure to Meet Study Deadlines: Section I.7.i of this Schedule 21 defines penalties that apply for failure to meet the 60-day study completion due diligence deadlines for System Impact Studies and Facilities Studies under Section I of this Schedule 21. These same requirements and penalties apply to service under Section II of this Schedule 21.

8) Load Shedding and Curtailments

a) Procedures: The PTO shall establish Load Shedding and Curtailment procedures (consistent with those of the ISO and the Local Control Center) with the objective of responding to contingencies on the Non-PTF. The PTO will notify all affected Local Network Service Customers in a timely manner of any scheduled Curtailment.

b) Transmission Constraints: During any period when a PTO or the Local Control Center determines that a transmission constraint exists on the Non-PTF, and such constraint may impair the reliability of the New England Transmission System, the PTO or the Local Control Center will so inform the ISO. The ISO will take whatever actions, consistent with Good Utility Practice, that are reasonably necessary to maintain the reliability of the system. To the extent the ISO determines that the reliability of the New England Transmission System can be maintained by redispatching resources, The ISO will initiate procedures to redispatch all resources on a least-cost basis without regard to the ownership of such resources.

c) Cost Responsibility for Relieving Transmission Constraints: Whenever the ISO implements least-cost redispatch procedures in response to a transmission constraint, the Transmission Customer will bear the costs of such redispatch in accordance with Market Rule 1.

d) Curtailments of Scheduled Deliveries: If a transmission constraint on the Non-PTF cannot be relieved through the implementation of least-cost redispatch procedures and the PTO determines that it is necessary to effect a Curtailment of scheduled deliveries, such schedule shall be curtailed in accordance with the terms of the Tariff.

e) Allocation of Curtailments: The ISO, the Transmission Owner or the Local Control Center shall on a non-discriminatory basis, effect a Curtailment of the transaction(s) that effectively relieves the constraint. However, to the extent practicable and consistent with Good Utility Practice, any Curtailment will be shared by the customers taking MTF Service and OTF Service and/or Through or Out Service and Network Customers on a non-discriminatory basis. Notwithstanding the preceding provisions of this Section, External Transactions shall be scheduled and curtailed in accordance with Section II.44 of the OATT.

f) Load Shedding: Load Shedding also may occur in accordance with the applicable Local Service Schedule to the extent provided for in such Local Service Schedule.

g) System Reliability: Notwithstanding any other provisions of this Schedule, The ISO, the PTO and the Local Control Centers reserve the right, consistent with Good Utility Practice and on a not unduly discriminatory basis, to effect a Curtailment of service without liability on the part of the ISO, the PTO or the Local Control Centers for the purpose of making necessary adjustments to, changes in, or repairs on the PTO's lines, substations and facilities, and in cases where the continuance of service would endanger

persons or property. In the event of any adverse condition(s) or disturbance(s) on the Non-PTF or on any other system(s) directly or indirectly interconnected with the Non-PTF, the ISO, the PTO and the Local Control Centers, consistent with Good Utility Practice, also may effect a Curtailment of service in order to (i) limit the extent or damage of the adverse condition(s) or disturbance(s), (ii) prevent damage to generating or transmission facilities, or (iii) expedite restoration of service. The ISO, the PTO or the Local Control Centers will give the Network Customer as much advance notice as is practicable in the event of such Curtailment. Any Curtailment of Local Network Service will be not unduly discriminatory relative to the PTO's use of the New England Transmission System on behalf of their Native Load Customers. The Local Service Schedules shall specify the rate treatment and all related terms and conditions applicable in the event that the Network Customer fails to respond to established Load Shedding and Curtailment procedures.

9) Rates and Charges

Except as provided below, the Network Customer shall pay all applicable charges for Local Network Service set forth in this Schedule 21, including the Local Service Schedules, and for any Direct Assignment Facilities and its share of the cost of any required Local Network Upgrades and applicable study costs consistent with Commission policy, along with any additional charges imposed under the Tariff. In the event the Network Customer serves Local Network Load located on more than one Local Network, the amount to be paid by it shall be separately computed for each Local Network.

The applicable charges for Local Network Service set forth in this Schedule 21, including the Local Service Schedules, shall be reduced to zero for the charging load of an Electric Storage Facility when the Regional Network Service charges are reduced to zero pursuant to Section II.21.3 of the OATT. The reduction to zero of the applicable charges shall not apply to any Direct Assignment Facilities nor the Network Customer's share of the cost of any required Local Network Upgrades and applicable study costs consistent with Commission policy, along with any additional charges imposed under the Tariff. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market.

10) Determination of Network Customer's Monthly Network Load

For purposes of Local Network Service, the Network Customer's "Monthly Network Load" shall be determined in accordance with the applicable Local Service Schedule.

11) Operating Arrangements

The Network Customer shall plan, construct, operate and maintain its facilities in accordance with Good Utility Practice and in conformance with the terms of the Tariff. The terms and conditions under which the Network Customer taking Local Network Service shall operate its facilities and the technical and operational matters associated with the implementation of Local Network Service shall be specified in Section II.22 of the Tariff and/or the Local Service Schedules.

SCHEDULE 21

ATTACHMENT A

FORM OF LOCAL SERVICE AGREEMENT

This LOCAL SERVICE AGREEMENT, dated as of _____, is entered into, by and between _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Transmission Owner"), _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Transmission Customer") and ISO New England, Inc., a non-stock corporation organized and existing under the laws of the State of Delaware ("ISO"). Under this Agreement the Transmission Owner, Transmission Customer, and the ISO each may be referred to as a "Party" or collectively as the "Parties."

PART I – General Terms and Conditions

1. Service Provided (Check applicable):

__ Local Network Service

__ Local Point-To-Point Service

__ Firm

__ Non-Firm

Regional Network Service customers must take either Local Network Service or Local Point-To-Point Service.

2. The Transmission Customer is an Eligible Customer under the Tariff and is a party to either a Market Participant Service Agreement or a Transmission Service Agreement.

3. The Transmission Customer has submitted a Completed Application and the required deposit, if applicable, for service under this Local Service Agreement and the Tariff.

4. The Transmission Customer agrees to supply information to the Transmission Owner that the Transmission Owner deems reasonably necessary in accordance with Schedule 21 and Good Utility Practice in order for it to receive the requested service.

5. The Transmission Owner agrees to provide and the Transmission Customer agrees to take and pay for service in accordance with the provisions of the Tariff and this Local Service Agreement.

6. Service may be subject to some combination of the charges detailed in Schedule 21 of the OATT. The appropriate charges will be determined in accordance with the terms and conditions of Schedule 21.

7. Any notice or request made to or by either party regarding this Local Service Agreement shall be made to the representative of the other party as indicated below.
Transmission Customer:

_____
_____
_____

Transmission Owner:

_____
_____
_____

The ISO:

_____
_____
_____

8. The ISO New England Inc. Transmission, Markets and Services Tariff (the "Tariff") is incorporated herein and made a part hereof. Capitalized terms used in this Local Service Agreement shall have the meanings ascribed in the Tariff.

9. Nothing contained in this Local Service Agreement shall be construed as affecting in any way the right of the Transmission Owner to file with the Commission under Section 205 of the Federal Power Act and pursuant to the Commission's rules and regulations promulgated thereunder for a change in any rates, terms and conditions of this Local Service Agreement. Nothing contained in this Local Service Agreement shall be construed as affecting in any way the ability of the Transmission Customer to file with the Commission under Section 206 of the Federal Power Act

and pursuant to the Commission's rules and regulations promulgated thereunder for a change in any rates, terms and conditions of this Local Service Agreement.

10. Nothing contained in this Local Service Agreement shall be construed as affecting or enlarging, in whole or in part, the limited responsibility of the ISO under the Transmission Operating Agreement ("TOA") to coordinate the Transmission Owner's provision of Local Service and to determine whether the provision of Local Service would have an impact on facilities used for the provision of Regional Transmission Service.

PART II – Local Network Service

1. The Transmission Customer has been determined by the Transmission Owner and the ISO to have a Completed Application for Local Network Service under the Tariff.

2. Service shall commence on the later of: (l) _____, or (2) the date on which construction of all interconnection equipment, any Direct Assignment Facilities and/or facility or Local Network Upgrades are completed, or (3) such other date as it is permitted to become effective by the Commission. Service shall terminate on _____.

3. Specifications for Local Network Service.

    a. Term of Service:

    b. List of Network Resources and Point(s) of Receipt:

    c. Description of capacity and energy to be transmitted:

    d. Description of Local Network Load:

    e. List of Point(s) of Delivery and metering point(s) when they differ from Point(s) of Delivery:

    f. List of non-Network Resource(s), to the extent known:

g. Ancillary Services requested or proof of satisfactory arrangements for Ancillary Services:

h. Identity of Designated Agent:

Authority of Designated Agent:

Term of Designated Agent's authority:

Division of responsibilities and obligations between Transmission Customer and Designated Agent:

i. Interconnection facilities and associated equipment:

j. Project name:

k. Interconnecting Transmission Customer:

l. Location:

m. Transformer nameplate rating:

n. Interconnection point:

o. Additional facilities and/or associated equipment:

p. Service under this Local Service Agreement shall be subject to the following charges:

q. Additional terms and conditions:

4. Planned work schedule.

Milestone (Activity)	Estimated Time Period For Completion (# of months)

5. Payment schedule and costs.

(Study grade estimate, +___% accuracy, year $s)

Milestone Amount ($)

6. Policy and practices for protection requirements for new or modified load interconnections.

7. Insurance requirements.

PART III – Local Point-To-Point Service

1. The Transmission Customer has been determined by the Transmission Owner and the ISO to have a Completed Application for Local Point-To-Point Service under the Tariff.

2. Service shall commence on the later of: (l) _____, or (2) the date on which construction of any Direct Assignment Facilities and/or Local Network Upgrades are completed, or (3) such other date as it is permitted to become effective by the Commission. Service shall terminate on _____.

3. Non-firm Local Point-To-Point Service shall be provided by the Transmission Owner upon request by an authorized representative of the Transmission Customer.

4. Specifications for Local Point-To-Point Service.

a. Term of Transaction:

b. Description of capacity and energy to be transmitted by the Transmission Owner including the electric Control Area in which the transaction originates:

c. Point(s) of Receipt:

d. Delivering Party:

e. Point(s) of Delivery:

f. Receiving Party:

g. Maximum amount of capacity and energy to be transmitted (Reserved Capacity):

h. Designation of party(ies) subject to reciprocal service obligation:

i. Name(s) of any intervening Control Areas providing transmission service:

j. Service under this Local Service Agreement shall be subject to the following charges:

k Interconnection facilities and associated equipment:

l. Project name:

m. Interconnecting Transmission Customer:

n. Location:

o. Transformer nameplate rating:

p. Interconnection point:

q. Additional facilities and/or associated equipment:

r. Additional terms and conditions:

5. Planned work schedule.

Milestone (Activity)	Estimated Time Period For Completion (# of months)

6. Payment schedule and costs.

(Study grade estimate, +___% accuracy, year $s)

Milestone	Amount ($)

7. Policy and practices for protection requirements for new or modified load interconnections.

8. Insurance requirements.

IN WITNESS WHEREOF, the Parties have caused this Local Service Agreement to be executed by their respective authorized officials.

Transmission Customer:

By:_____ _____ _____

Name Title Date

_____

Print Name

Transmission Owner:

By:_____ _____ _____

Name Title Date

_____

Print Name

The ISO:

By:_____ _____ _____

Name Title Date

_____Print Name

SCHEDULE 21

ATTACHMENT A-1

Form of Local Service Agreement For The Resale, Reassignment or Transfer of Point-To-Point Transmission Service

1.0 This LOCAL SERVICE AGREEMENT, dated as of _____, is entered into, by and between _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Transmission Owner"), _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Assignee") and ISO New England, Inc., a non-stock corporation organized and existing under the laws of the State of Delaware ("ISO"). Under this Agreement the Transmission Owner, Assignee, and the ISO each may be referred to as a "Party" or collectively as the "Parties."

2.0 The Assignee has been determined by the Transmission Owner to be an Eligible Customer under the Tariff pursuant to which the transmission service rights to be transferred were originally obtained.

3.0 The terms and conditions for the transaction entered into under this Local Service Agreement shall be subject to the terms and conditions of Part I of Schedule 21 and the Transmission Owner's Local Service Schedule of Tariff, except for those terms and conditions negotiated by the Reseller of the reassigned transmission capacity (pursuant to Section I.11.a of this Tariff) and the Assignee, to include: contract effective and termination dates, the amount of reassigned capacity or energy, point(s) of receipt and delivery. Changes by the Assignee to the Reseller's Points of Receipt and Points of Delivery will be subject to the provisions of Section I.11.b of this Tariff.

4.0 The Transmission Owner shall credit the Reseller for the price reflected in the Assignee's Local Service Agreement or the associated OASIS schedule.

5.0 Any notice or request made to or by either Party regarding this Local Service Agreement shall be made to the representative of the other Party as indicated below.

Transmission Owner:

_____

_____

_____

The ISO:

_____

_____

_____

Assignee:

_____

_____

_____

6.0 The Tariff is incorporated herein and made a part hereof.

IN WITNESS WHEREOF, the Parties have caused this Local Service Agreement to be executed by their respective authorized officials.

Transmission Owner:

By:_____ _____ _____

Print Name: Title: Date:

The ISO:

By:_____ _____ _____

Print Name: Title: Date:

Assignee:

By:_____ _____ _____

Print Name: Title: Date:

Specifications For The Resale, Reassignment Or Transfer of Long-Term Firm Point-To-Point Transmission Service

1.0 Term of Transaction: _____

Start Date: _____

Termination Date: _____

2.0 Description of capacity and energy to be transmitted by Transmission Owner including the electric Control Area in which the transaction originates.

_____

3.0 Point(s) of Receipt:_____

Delivering Party:_____

4.0 Point(s) of Delivery:_____

Receiving Party:_____

5.0 Maximum amount of reassigned capacity: _____

6.0 Designation of party(ies) subject to reciprocal service obligation:_____

_____

_____

_____

7.0 Name(s) of any Intervening Systems providing transmission service:_____

_____

(Name of Transmission Owner) Open Access Transmission Tariff

8.0 Service under this Agreement may be subject to some combination of the charges detailed below. (The appropriate charges for individual transactions will be determined in accordance with the terms and conditions of the Tariff.)

8.1 Transmission Charge:_____

_____

8.2 System Impact and/or Facilities Study Charge(s):

_____

_____

8.3 Direct Assignment Facilities Charge:_____

_____

8.4 Ancillary Services Charges: _____

_____

_____

_____

_____

_____

_____

9.0 Name of Reseller of the reassigned transmission capacity:

_____

STANDARD MARKET DESIGN

III.1 Market Operations

III.1.1 Introduction.

This Market Rule 1 sets forth the scheduling, other procedures, and certain general provisions applicable to the operation of the New England Markets within the New England Control Area. The ISO shall operate the New England Markets in compliance with NERC, NPCC and ISO reliability criteria. The ISO is the Counterparty for agreements and transactions with its Customers (including assignments involving Customers), including bilateral transactions described in Market Rule 1, and sales to the ISO and/or purchases from the ISO of energy, reserves, Ancillary Services, capacity, demand/load response, FTRs and other products, paying or charging (if and as applicable) its Customers the amounts produced by the pertinent market clearing process or through the other pricing mechanisms described in Market Rule 1. The bilateral transactions to which the ISO is the Counterparty (subject to compliance with the requirements of Section III.1.4) include, but are not limited to, Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). Notwithstanding the foregoing, the ISO will not act as Counterparty for the import into the New England Control Area, for the use of Publicly Owned Entities, of: (1) energy, capacity, and ancillary products associated therewith, to which the Publicly Owned Entities are given preference under Articles 407 and 408 of the project license for the New York Power Authority's Niagara Project; and (2) energy, capacity, and ancillary products associated therewith, to which Publicly Owned Entities are entitled under Article 419 of the project license for the New York Power Authority's Franklin D. Roosevelt – St. Lawrence Project. This Market Rule 1 addresses each of the three time frames pertinent to the daily operation of the New England Markets: "Pre-scheduling" as specified in Section III.1.9, "Scheduling" as specified in III.1.10, and "Dispatch" as specified in III.1.11. This Market Rule 1 became effective on February 1, 2005.

III.1.2 [Reserved.]

III.1.3 Definitions.

Whenever used in Market Rule 1, in either the singular or plural number, capitalized terms shall have the meanings specified in Section I of the Tariff. Terms used in Market Rule 1 that are not defined in Section

I shall have the meanings customarily attributed to such terms by the electric utility industry in New England or as defined elsewhere in the ISO New England Filed Documents. Terms used in Market Rule 1 that are defined in Section I are subject to the 60% Participant Vote threshold specified in Section 11.1.2 of the Participants Agreement.

III.1.3.1 [Reserved.]

III.1.3.2 [Reserved.]

III.1.3.3 [Reserved.]

III.1.4 Requirements for Certain Transactions.

III.1.4.1 ISO Settlement of Certain Transactions.

The ISO will settle, and act as Counterparty to, the transactions described in Section III.1.4.2 if the transactions (and their related transactions) conform to, and the transacting Market Participants comply with, the requirements specified in Section III.1.4.3.

III.1.4.2 Transactions Subject to Requirements of Section III.1.4.

Transactions that must conform to the requirements of Section III.1.4 include: Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). The foregoing are referred to collectively as "Section III.1.4 Transactions," and individually as a "Section III.1.4 Transaction." Transactions that conform to the standards are referred to collectively as "Section III.1.4 Conforming Transactions," and individually as a "Section III.1.4 Conforming Transaction."

III.1.4.3 Requirements for Section III.1.4 Conforming Transactions.

(a) To qualify as a Section III.1.4 Conforming Transaction, a Section III.1.4 Transaction must constitute an exchange for an off-market transaction (a "Related Transaction"), where the Related Transaction:

(i) is not cleared or settled by the ISO as Counterparty;

(ii) is a spot, forward or derivatives contract that contemplates the transfer of energy or a MW obligation to or from a Market Participant;

(iii) involves commercially appropriate obligations that impose a duty to transfer electricity or a MW obligation from the seller to the buyer, or from the buyer to the seller, with performance taking place within a reasonable time in accordance with prevailing cash market practices; and

(iv) is not contingent on either party to carry out the Section III.1.4 Transaction.

(b) In addition, to qualify as a Section III.1.4 Conforming Transaction:

(i) the Section III.1.4 Transaction must be executed between separate beneficial owners or separate parties trading for independently controlled accounts;

(ii) the Section III.1.4 Transaction and the Related Transaction must be separately identified in the records of the parties to the transactions; and

(iii) the Section III.1.4 Transaction must be separately identified in the records of the ISO.

(c) As further requirements:

(i) each party to the Section III.1.4 Transaction and Related Transaction must maintain, and produce upon request of the ISO, records demonstrating compliance with the requirements of Sections III.1.4.3(a) and (b) for the Section III.1.4 Transaction, the Related Transaction and any other transaction that is directly related to, or integrated in any way with, the Related Transaction, including the identity of the counterparties and the material economic terms of the transactions including their price, tenor, quantity and execution date; and

(ii) each party to the Section III.1.4 Transaction must be a Market Participant that meets all requirements of the ISO New England Financial Assurance Policy.

III.1.5 Resource Auditing.

III.1.5.1 Claimed Capability Audits.

III.1.5.1.1 General Audit Requirements.

(a) The following types of Claimed Capability Audits may be performed:

(i) An Establish Claimed Capability Audit establishes the Generator Asset's ability to respond to ISO Dispatch Instructions and to maintain performance at a specified output level for a specified duration.

(ii) A Seasonal Claimed Capability Audit determines a Generator Asset's capability to perform under specified summer and winter conditions for a specified duration.

(iii) A Seasonal DR Audit determines the ability of a Demand Response Resource to perform during specified months for a specified duration.

(iv) An ISO-Initiated Claimed Capability Audit is conducted by the ISO to verify the Generator Asset's Establish Claimed Capability Audit value or the Demand Response Resource's Seasonal DR Audit value.

(b) The Claimed Capability Audit value of a Generator Asset shall reflect any limitations based upon the interdependence of common elements between two or more Generator Assets such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(c) The Claimed Capability Audit value of gas turbine, combined cycle, and pseudo-combined cycle assets shall be normalized to standard 90° (summer) and 20° (winter) temperatures.

(d) The Claimed Capability Audit value for steam turbine assets with steam exports, combined cycle, or pseudo-combined cycle assets with steam exports where steam is exported for uses external to the electric power facility, shall be normalized to the facility's Seasonal Claimed Capability steam demand.

(e) A Claimed Capability Audit may be denied or rescheduled by the ISO if its performance will jeopardize the reliable operation of the electrical system.

III.1.5.1.2 Establish Claimed Capability Audit.

(a) An Establish Claimed Capability Audit may be performed only by a Generator Asset.

(b) The time and date of an Establish Claimed Capability Audit shall be unannounced.

(c) For a newly commercial Generator Asset:

(i) An Establish Claimed Capability Audit will be scheduled by the ISO within five Business Days of the commercial operation date for all Generator Assets except:

1. Non-intermittent daily cycle hydro;
2. Non-intermittent net-metered, or special qualifying facilities that do not elect to audit as described in Section III.1.5.1.3; and
3. Intermittent Generator Assets

(ii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iii) The Establish Claimed Capability Audit values shall be effective as of the commercial operation date of the Generator Asset.

(d) For Generator Assets with an Establish Claimed Capability Audit value:

(i) An Establish Claimed Capability Audit may be performed at the request of a Market Participant in order to support a change in the summer and winter Establish Claimed Capability Audit values for a Generator Asset.

(ii) An Establish Claimed Capability Audit shall be performed within five Business Days of the date of the request.

(iii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iv) The Establish Claimed Capability Audit values become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(e) An Establish Claimed Capability Audit value may not exceed the maximum interconnected flow specified in the Network Resource Capability for the resource associated with the Generator Asset.

(f) Establish Claimed Capability Audits shall be performed on non-NERC holiday weekdays between 0800 and 2200.

(g) To conduct an Establish Claimed Capability Audit, the ISO shall:

(i) Initiate an Establish Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset's net output to increase from the current operating level to its Real-Time High Operating Limit.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) Begin the audit with the first full clock hour after sufficient time has been allowed for the asset to ramp, based on its offered ramp rate from its current operating point to reach its Real-Time High Operating Limit.

(h) An Establish Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an Establish Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4
Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4

Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(i) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.2(h).

III.1.5.1.3. Seasonal Claimed Capability Audits.

(a) A Seasonal Claimed Capability Audit may be performed only by a Generator Asset.

(b) A Seasonal Claimed Capability Audit must be conducted by all Generator Assets except:

(i) Non-intermittent daily hydro; and

(ii) Intermittent, net-metered, and special qualifying facilities. Non-intermittent net-metered and special qualifying facilities may elect to perform Seasonal Claimed Capability Audits pursuant to Section III.1.7.11(c)(iv).

(c) An Establish Claimed Capability Audit or ISO-Initiated Claimed Capability Audit that meets the requirements of a Seasonal Claimed Capability Audit in this Section III.1.5.1.3 may be used to fulfill a Generator Asset's Seasonal Claimed Capability Audit obligation.

(d) Except as provided in Section III.1.5.1.3(n) below, a summer Seasonal Claimed Capability Audit must be conducted:

(i) At least once every Capability Demonstration Year;

(ii) Either (1) at a mean ambient temperature during the audit that is greater than or equal to 80 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced summer Seasonal Claimed Capability Audit window.

(e) A winter Seasonal Claimed Capability Audit must be conducted:

(i) At least once in the previous three Capability Demonstration Years, except that a newly commercial Generator Asset which becomes commercial on or after:

(1) September 1 and prior to December 31 shall perform a winter Seasonal Claimed Capability Audit prior to the end of that Capability Demonstration Year.

(2) January 1 shall perform a winter Seasonal Claimed Capability Audit prior to the end of the next Capability Demonstration Year.

(ii) Either (1) at a mean ambient temperature during the audit that is less than or equal to 32 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced winter Seasonal Claimed Capability Audit window.

(f) A Seasonal Claimed Capability Audit shall be performed by operating the Generator Asset for the audit time period and submitting to the ISO operational data that meets the following requirements:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal Claimed Capability Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal Claimed Capability Audit and other relevant operating data.

(g) The Seasonal Claimed Capability Audit value (summer or winter) will be the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(h) The Seasonal Claimed Capability Audit value (summer or winter) shall be the most recent audit data submitted to the ISO meeting the requirements of this Section III.1.5.1.3. In the event that a Market Participant fails to submit Seasonal Claimed Capability Audit data to meet the timing requirements in Section III.1.5.1.3(d) and (e), the Seasonal Claimed Capability Audit value for the season shall be set to zero.

(i) The Seasonal Claimed Capability Audit value shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(j) A Seasonal Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for a Seasonal Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	2
Combined Cycle	2

Integrated Coal Gasification Combustion Cycle	2
Pressurized Fluidized Bed Combustion	2
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine-Reversible (Electric Storage) Hydraulic Turbine-Other	2
Hydro-Conventional Weekly	2
Fuel Cell	1
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(k) A Generator Asset that is on a planned outage that was approved in the ISO's annual maintenance scheduling process during all hours that meet the temperature requirements for a Seasonal Claimed Capability Audit that is to be performed by the asset during that Capability Demonstration Year shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these auditing requirements;

(ii) Have its Seasonal Claimed Capability Audit value for the season set to zero; and

(iii) Perform the required Seasonal Claimed Capability Audit on the next available day that meets the Seasonal Claimed Capability Audit temperature requirements.

(l) A Generator Asset that does not meet the auditing requirements of this Section III.1.5.1.3 because (1) every time the temperature requirements were met at the Generator Asset's location the ISO denied the request to operate to full capability, or (2) the temperature requirements were not met at the Generator Asset's location during the Capability Demonstration Year during which the asset was required to perform a Seasonal Claimed Capability Audit during the hours 0700 to 2300 for each weekday excluding those weekdays that are defined as NERC holidays, shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these temperature requirements, including verifiable temperature data;

(ii) Retain the current Seasonal Claimed Capability Audit value for the season; and

(iii) Perform the required Seasonal Claimed Capability Audit during the next Capability Demonstration Year.

(m) The ISO may issue notice of a summer or winter Seasonal Claimed Capability Audit window for some or all of the New England Control Area if the ISO determines that weather forecasts indicate that temperatures during the audit window will meet the summer or winter Seasonal

Claimed Capability Audit temperature requirements. A notice shall be issued at least 48 hours prior to the opening of the audit window. Any audit performed during the announced audit window shall be deemed to meet the temperature requirement for the summer or winter audit. In the event that five or more audit windows for the summer Seasonal Claimed Capability Audit temperature requirement, each of at least a four hour duration between 0700 and 2300 and occurring on a weekday excluding those weekdays that are defined as NERC holidays, are not opened for a Generator Asset prior to August 15 during a Capability Demonstration Year, a two-week audit window shall be opened for that Generator Asset to perform a summer Seasonal Claimed Capability Audit, and any audit performed by that Generator Asset during the open audit window shall be deemed to meet the temperature requirement for the summer Seasonal Claimed Capability Audit. The open audit window shall be between 0700 and 2300 each day during August 15 through August 31.

(n) A Market Participant that is required to perform testing on a Generator Asset that is in addition to a summer Seasonal Claimed Capability Audit may notify the ISO that the summer Seasonal Claimed Capability Audit was performed in conjunction with this additional testing, provided that:

(i) The notification shall be provided at the time the Seasonal Claimed Capability Audit data is submitted under Section III.1.5.1.3(f).

(ii) The notification explains the nature of the additional testing and that the summer Seasonal Claimed Capability Audit was performed while the Generator Asset was online to perform this additional testing.

(iii) The summer Seasonal Claimed Capability Audit and additional testing are performed during the months of June, July or August between the hours of 0700 and 2300.

(iv) In the event that the summer Seasonal Claimed Capability Audit does not meet the temperature requirements of Section III.1.5.1.3(d)(ii), the summer Seasonal Claimed Capability Audit value may not exceed the summer Seasonal Claimed Capability Audit value from the prior Capability Demonstration Year.

(v) This Section III.1.5.1.3(n) may be utilized no more frequently than once every three Capability Demonstration Years for a Generator Asset.

(o) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.3(j).

III.1.5.1.3.1 Seasonal DR Audits.

(a) A Seasonal DR Audit may be performed only by a Demand Response Resource.

(b) A Seasonal DR Audit shall be performed for 12 contiguous five-minute intervals.

(c) A summer Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of April through November;

(d) A winter Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of December through March.

(e) A Seasonal DR Audit may be performed either:

(i) At the request of a Market Participant as described in subsection (f) below; or

(ii) By the Market Participant designating a period of dispatch after the fact as described in subsection (g) below.

(f) If a Market Participant requests a Seasonal DR Audit:

(i) The ISO shall perform the Seasonal DR Audit at an unannounced time between 0800 and 2200 on non-NERC holiday weekdays within five Business Days of the date of the request.

(ii) The ISO shall initiate the Seasonal DR Audit by issuing a Dispatch Instruction ordering the Demand Response Resource to its Maximum Reduction.

(iii) The ISO shall indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iv) The ISO shall begin the audit with the start of the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(g) If the Seasonal DR Audit is performed by the designation of a period of dispatch after the fact, the designated period must meet all of the requirements in this Section III.1.5.1.3.1 and:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal DR Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal DR Audit.

(iii) The demonstration period may begin with the start of any five-minute interval after the completion of the Demand Response Resource Notification Time.

(iv) A CLAIM10 audit or CLAIM30 audit that meets the requirements of a Seasonal DR Audit as provided in this Section III.1.5.1.3.1 may be used to fulfill the Seasonal DR Audit obligation of a Demand Response Resource.

(h) An ISO-Initiated Claimed Capability Audit fulfils the Seasonal DR Audit obligation of a Demand Response Resource.

(i) Each Demand Response Asset associated with a Demand Response Resource is evaluated during the Seasonal DR Audit of the Demand Response Resource.

(j) Any Demand Response Asset on a forced or scheduled curtailment as defined in Section III.8.3 is assessed a zero audit value.

(k) The Seasonal DR Audit value (summer or winter) of a Demand Response Resource resulting from the Seasonal DR Audit shall be the sum of the average demand reductions demonstrated during the audit by each of the Demand Response Resource's constituent Demand Response Assets.

(l) If a Demand Response Asset is added to or removed from a Demand Response Resource between audits, the Demand Response Resource's capability shall be updated to reflect the inclusion or exclusion of the audit value of the Demand Response Asset, such that at any point in time the summer or winter Seasonal DR Audit value of a Demand Response Resource shall equal the sum of the most recent valid like-season audit values of its constituent Demand Response Assets.

(m) The Seasonal DR Audit value shall become effective one calendar day following notification of the audit results to the Market Participant by the ISO.

(n) The summer or winter audit value of a Demand Response Asset shall be set to zero at the end of the Capability Demonstration Year if the Demand Response Asset did not perform a Seasonal DR Audit for that season as part of a Demand Response Resource during that Capability Demonstration Year.

(o) For a Demand Response Asset that was associated with a "Real-Time Demand Response Resource" or a "Real-Time Emergency Generation Resource," as those terms were defined prior to June 1, 2018, any valid result from an audit conducted prior to June 1, 2018 shall continue to be valid on June 1, 2018, and shall retain the same expiration date.

III.1.5.1.4. ISO-Initiated Claimed Capability Audits.

(a) An ISO-Initiated Claimed Capability Audit may be performed by the ISO at any time.

(b) An ISO-Initiated Claimed Capability Audit value shall replace either the summer or winter Seasonal DR Audit value for a Demand Response Resource and shall replace both the winter and summer Establish Claimed Capability Audit values for a Generator Asset, normalized for temperature and steam exports, except:

(i) The Establish Claimed Capability Audit values for a Generator Asset may not exceed the maximum interconnected flow specified in the Network Resource Capability for that resource.

(ii) An ISO-Initiated Claimed Capability Audit value for a Generator Asset shall not set the winter Establish Claimed Capability Audit value unless the ISO-Initiated Claimed Capability Audit was performed at a mean ambient temperature that is less than or equal to 32 degrees Fahrenheit at the Generator Asset location.

(c) If for a Generator Asset a Market Participant submits pressure and relative humidity data for the previous Establish Claimed Capability Audit and the current ISO-Initiated Claimed Capability Audit, the Establish Claimed Capability Audit values derived from the ISO-Initiated Claimed Capability Audit will be normalized to the pressure of the previous Establish Claimed Capability Audit and a relative humidity of 64%.

(d) The audit values derived from the ISO-Initiated Claimed Capability Audit shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(e) To conduct an ISO-Initiated Claimed Capability Audit, the ISO shall:

(i) Initiate an ISO-Initiated Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset to its Real-Time High Operating Limit or the Demand Response Resource to its Maximum Reduction.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) For Generator Assets, begin the audit with the first full clock hour after sufficient time has been allowed for the Generator Asset to ramp, based on its offered ramp rate, from its current operating point to its Real-Time High Operating Limit.

(iv) For Demand Response Resources, begin the audit with the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(f) An ISO-Initiated Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an ISO-Initiated Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4

Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine – Reversible)	2
Demand Response Resource	1

(g) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for an Asset or Resource type not listed in Section III.1.5.1.4(f).

III.1.5.2 ISO-Initiated Parameter Auditing.

(a) The ISO may perform an audit of any Supply Offer, Demand Reduction Offer or other operating parameter that impacts the ability of a Generator Asset or Demand Response Resource to provide real-time energy or reserves.

(b) Generator audits shall be performed using the following methods for the relevant parameter:

(i) **Economic Maximum Limit**. The Generator Asset shall be evaluated based upon its ability to achieve the current offered Economic Maximum Limit value, through a review of historical dispatch data or based on a response to a current ISO-issued Dispatch Instruction.

(ii) **Manual Response Rate**. The Generator Asset shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Manual Response Rate, including hold points and changes in Manual Response Rates.

(iii) **Start-Up Time**. The Generator Asset shall be evaluated based upon its ability to achieve the offered Start-Up Time.

(iv) **Notification Time**. The Generator Asset shall be evaluated based upon its ability to close its output breaker within its offered Notification Time.

(v) **CLAIM10**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(vii) **Automatic Response Rate**. The Generator Asset shall be analyzed, based upon a review of historical performance data, for its ability to respond to four-second electronic Dispatch Instructions.

(viii) **Dual Fuel Capability**. A Generator Asset that is capable of operating on multiple fuels may be required to audit on a specific fuel, as set out in Section III.1.5.2(f).

(c) Demand Response Resource audits shall be performed using the following methods:

(i) **Maximum Reduction**. The Demand Response Resource shall be evaluated based upon its ability to achieve the current offered Maximum Reduction value, through a review of historical dispatch data or based on a response to a current Dispatch Instruction.

(ii) **Demand Response Resource Ramp Rate**. The Demand Response Resource shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Demand Response Resource Ramp Rate.

(iii) **Demand Response Resource Start-Up Time**. The Demand Response Resource shall be evaluated based upon its ability to achieve its Minimum Reduction within the offered Demand Response Resource Start-Up Time, in response to a Dispatch Instruction and after completing its Demand Response Resource Notification Time.

(iv) **Demand Response Resource Notification Time**. The Demand Response Resource shall be evaluated based upon its ability to start reducing demand within its offered Demand Response Resource Notification Time, from the receipt of a Dispatch Instruction when the Demand Response Resource was not previously reducing demand.

(v) **CLAIM10**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(d) To conduct an audit based upon historical data, the ISO shall:

(i) Obtain data through random sampling of generator or Demand Response Resource performance in response to Dispatch Instructions; or

(ii) Obtain data through continual monitoring of generator or Demand Response Resource performance in response to Dispatch Instructions.

(e) To conduct an unannounced audit, the ISO shall initiate the audit by issuing a Dispatch Instruction ordering the Generator Asset or Demand Response Resource to change from the current operating level to a level that permits the ISO to evaluate the performance of the Generator Asset or Demand Response Resource for the parameters being audited.

(f) To conduct an audit of the capability of a Generator Asset described in Section III.1.5.2(b)(viii) to run on a specific fuel:

(i) The ISO shall notify the Lead Market Participant if a Generator Asset is required to undergo an audit on a specific fuel. The ISO, in consultation with the Lead Market Participant, shall develop a plan for the audit.

(ii) The Lead Market Participant will have the ability to propose the time and date of the audit within the ISO's prescribed time frame and must notify the ISO at least five Business Days in advance of the audit, unless otherwise agreed to by the ISO and the Lead Market Participant.

(g) To the extent that the audit results indicate a Market Participant is providing Supply Offer, Demand Reduction Offer or other operating parameter values that are not representative of the actual capability of the Generator Asset or Demand Response Resource, the values for the Generator Asset or Demand Response Resource shall be restricted to those values that are supported by the audit.

(h) In the event that a Generator Asset or Demand Response Resource has had a parameter value restricted:

(i) The Market Participant may submit a restoration plan to the ISO to restore that parameter. The restoration plan shall:

1. Provide an explanation of the discrepancy;
2. Indicate the steps that the Market Participant will take to re-establish the parameter's value;
3. Indicate the timeline for completing the restoration; and
4. Explain the testing that the Market Participant will undertake to verify restoration of the parameter value upon completion.

(ii) The ISO shall:

1. Accept the restoration plan if implementation of the plan, including the testing plan, is reasonably likely to support the proposed change in the parameter value restriction;
2. Coordinate with the Market Participant to perform required testing upon completion of the restoration; and
3. Modify the parameter value restriction following completion of the restoration plan, based upon tested values.

III.1.5.3 Reactive Capability Audits.

(a) Two types of Reactive Capability Audits may be performed:

(i) A lagging Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to provide reactive power to the transmission system at a specified real power output or consumption.

(ii) A leading Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to absorb reactive power from the transmission system at a specified real power output or consumption.

(b) The ISO shall develop a list of Reactive Resources that must conduct Reactive Capability Audits. The list shall include Reactive Resources that: (i) have a gross individual nameplate rating greater than 20 MVA; (ii) are directly connected, or are connected through equipment designed primarily for delivering real or reactive power to an interconnection point, to the transmission system at a voltage of 100 kV or above; and (iii) are not exempted from providing voltage control by the ISO. Additional criteria to be used in adding a Reactive Resource to the list includes, but is not limited to, the effect of the Reactive Resource on System Operating Limits, Interconnection Reliability Operating Limits, and local area voltage limits during the following operating states: normal, emergency, and system restoration.

(c) Unless otherwise directed by the ISO, Reactive Resources that are required to perform Reactive Capability Audits shall perform both a lagging Reactive Capability Audit and a leading Reactive Capability Audit.

(d) All Reactive Capability Audits shall meet the testing conditions specified in the ISO New England Operating Documents.

(e) The Reactive Capability Audit value of a Reactive Resource shall reflect any limitations based upon the interdependence of common elements between two or more Reactive Resources such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(f) A Reactive Capability Audit may be denied or rescheduled by the ISO if conducting the Reactive Capability Audit could jeopardize the reliable operation of the electrical system.

(g) Reactive Capability Audits shall be conducted at least every five years, unless otherwise required by the ISO. The ISO may require a Reactive Resource to conduct Reactive Capability Audits more often than every five years if:

(i) there is a change in the Reactive Resource that may affect the reactive power capability of the Reactive Resource;

(ii) there is a change in electrical system conditions that may affect the achievable reactive power output or absorption of the Reactive Resource; or

(iii) historical data shows that the amount of reactive power that the Reactive Resource can provide to or absorb from the transmission system is higher or lower than the latest audit data.

(h) A Lead Market Participant or Transmission Owner may request a waiver of the requirement to conduct a Reactive Capability Audit for its Reactive Resource. The ISO, at its sole discretion, shall determine whether and for how long a waiver may be granted.

III.1.6 [Reserved.]

III.1.6.1 [Reserved.]

III.1.6.2 [Reserved.]

III.1.6.3 [Reserved.]

III.1.6.4 ISO New England Manuals and ISO New England Administrative Procedures.

The ISO shall prepare, maintain and update the ISO New England Manuals and ISO New England Administrative Procedures consistent with the ISO New England Filed Documents. The ISO New England Manuals and ISO New England Administrative Procedures shall be available for inspection by the Market Participants, regulatory authorities with jurisdiction over the ISO or any Market Participant, and the public.

III.1.7 General.

III.1.7.1 Provision of Market Data to the Commission.

The ISO will electronically deliver to the Commission, on an ongoing basis and in a form and manner consistent with its collection of data and in a form and manner acceptable to the Commission, data related to the markets that it administers, in accordance with the Commission's regulations.

III.1.7.2 [Reserved.]

III.1.7.3 Agents.

A Market Participant may participate in the New England Markets through an agent, provided that such Market Participant informs the ISO in advance in writing of the appointment of such agent. A Market Participant using an agent shall be bound by all of the acts or representations of such agent with respect to transactions in the New England Markets, and shall ensure that any such agent complies with the

requirements of the ISO New England Manuals and ISO New England Administrative Procedures and the ISO New England Filed Documents.

III.1.7.4 [Reserved.]

III.1.7.5 Transmission Constraint Penalty Factors.

In the Day-Ahead Energy Market, the Transmission Constraint Penalty Factor for an interface constraint is $10,000/MWh and the Transmission Constraint Penalty Factor for all other transmission constraints is $30,000/MWh. In the Real-Time Energy Market, the Transmission Constraint Penalty Factor for any transmission constraint is $30,000/MWh. Transmission Constraint Penalty Factors are not used in calculating Locational Marginal Prices.

III.1.7.6 Scheduling and Dispatching.

(a) The ISO shall schedule Day-Ahead and schedule and dispatch in Real-Time Resources economically on the basis of least-cost, security-constrained dispatch and the prices and operating characteristics offered by Market Participants. The ISO shall schedule and dispatch sufficient Resources of the Market Participants to serve the New England Markets energy purchase requirements under normal system conditions of the Market Participants and meet the requirements of the New England Control Area for ancillary services provided by such Resources. The ISO shall use a joint optimization process to serve Real-Time Energy Market energy requirements and meet Real-Time Operating Reserve requirements based on a least-cost, security-constrained economic dispatch.

(b) In the event that one or more Resources cannot be scheduled in the Day-Ahead Energy Market on the basis of a least-cost, security-constrained dispatch as a result of one or more Self-Schedule offers contributing to a transmission limit violation, the following scheduling protocols will apply:

(i) When a single Self-Schedule offer contributes to a transmission limit violation, the Self-Schedule offer will not be scheduled for the entire Self-Schedule period in development of Day-Ahead schedules.

(ii) When two Self-Schedule offers contribute to a transmission limit violation, parallel clearing solutions will be executed such that, for each solution, one of the Self-Schedule offers

will be omitted for its entire Self-Schedule period. The least cost solution will be used for purposes of determining which Resources are scheduled in the Day-Ahead Energy Market.

(iii) When three or more Self-Schedule offers contribute to a transmission limit violation, the ISO will determine the total daily MWh for each Self-Schedule offer and will omit Self-Schedule offers in their entirety, in sequence from the offer with the least total daily MWh to the offer with the greatest total MWh, stopping when the transmission limit violation is resolved.

(c) Scheduling and dispatch shall be conducted in accordance with the ISO New England Filed Documents.

(d) The ISO shall undertake, together with Market Participants, to identify any conflict or incompatibility between the scheduling or other deadlines or specifications applicable to the New England Markets, and any relevant procedures of another Control Area, or any tariff (including the Transmission, Markets and Services Tariff). Upon determining that any such conflict or incompatibility exists, the ISO shall propose tariff or procedural changes, or undertake such other efforts as may be appropriate, to resolve any such conflict or incompatibility.

III.1.7.7 Energy Pricing.

The price paid for energy, including demand reductions, bought and sold by the ISO in the New England Markets will reflect the Locational Marginal Price at each Location, determined by the ISO in accordance with the ISO New England Filed Documents. Congestion Costs, which shall be determined by differences in the Congestion Component of Locational Marginal Prices caused by constraints, shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1. Loss costs associated with Pool Transmission Facilities, which shall be determined by the differences in Loss Components of the Locational Marginal Prices shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1.

III.1.7.8 Market Participant Resources.

A Market Participant may elect to Self-Schedule its Resources in accordance with and subject to the limitations and procedures specified in this Market Rule 1 and the ISO New England Manuals.

III.1.7.9 Real-Time Reserve Prices.

The price paid by the ISO for the provision of Real-Time Operating Reserve in the New England Markets will reflect Real-Time Reserve Clearing Prices determined by the ISO in accordance with the ISO New England Filed Documents for the system and each Reserve Zone.

III.1.7.10 Other Transactions.

Market Participants may enter into internal bilateral transactions and External Transactions for the purchase or sale of energy or other products to or from each other or any other entity, subject to the obligations of Market Participants to make resources with a Capacity Supply Obligation available for dispatch by the ISO. External Transactions that contemplate the physical transfer of energy or obligations to or from a Market Participant shall be reported to and coordinated with the ISO in accordance with this Market Rule 1 and the ISO New England Manuals.

III.1.7.11 Seasonal Claimed Capability of a Generating Capacity Resource.

(a) A Seasonal Claimed Capability value must be established and maintained for all Generating Capacity Resources. A summer Seasonal Claimed Capability is established for use from June 1 through September 30 and a winter Seasonal Claimed Capability is established for use from October 1 through May 31.

(b) The Seasonal Claimed Capability of a Generating Capacity Resource is the sum of the Seasonal Claimed Capabilities of the Generator Assets that are associated with the Generating Capacity Resource.

(c) The Seasonal Claimed Capability of a Generator Asset is:

(i) Based upon review of historical data for non-intermittent daily cycle hydro.

(ii) The median net real power output during reliability hours, as described in Section III.13.1.2.2.2, for (1) intermittent facilities, and (2) net-metered and special qualifying facilities that do not elect to audit, as reflected in hourly revenue metering data.

(iii) For non-intermittent net-metered and special qualifying facilities that elect to audit, the minimum of (1) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3; (2) the Generator Asset's current Establish Claimed Capability Audit value; and (3) the median hourly availability during hours ending 2:00 p.m. through 6:00 p.m. each day of the preceding June through September for Summer and hours ending 6:00 p.m. and 7:00 p.m. each day of the preceding October through May for Winter. The hourly availability:

a. For a Generator Asset that is available for commitment and following Dispatch Instructions, shall be the asset's Economic Maximum Limit, as submitted or redeclared.

b. For a Generator Asset that is off-line and not available for commitment shall be zero.

c. For a Generator Asset that is on-line but not able to follow Dispatch Instructions, shall be the asset's metered output.

(iv) For all other Generator Assets, the minimum of: (1) the Generator Asset's current Establish Claimed Capability Audit value and (2) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3.

III.1.7.12 Seasonal DR Audit Value of an Active Demand Capacity Resource.

(a) A Seasonal DR Audit value must be established and maintained for all Active Demand Capacity Resources. A summer Seasonal DR Audit value is established for use from April 1 through November 30 and a winter Seasonal DR Audit value is established for use from December 1 through March 31.

(b) The Seasonal DR Audit value of an Active Demand Capacity Resource is the sum of the Seasonal DR Audit values of the Demand Response Resources that are associated with the Active Demand Capacity Resource.

III.1.7.13 [Reserved.]

III.1.7.14 [Reserved.]

III.1.7.15 [Reserved.]

III.1.7.16 [Reserved.]

III.1.7.17 Operating Reserve.

The ISO shall endeavor to procure and maintain an amount of Operating Reserve in Real-Time equal to the system and zonal Operating Reserve requirements as specified in the ISO New England Manuals and ISO New England Administrative Procedures. Reserve requirements for the Forward Reserve Market are determined in accordance with the methodology specified in Section III.9.2 of Market Rule 1. Operating Reserve requirements for Real-Time dispatch within an Operating Day are determined in accordance with Market Rule 1 and ISO New England Operating Procedure No. 8, Operating Reserve and Regulation.

III.1.7.18 Ramping.

A Generator Asset, Dispatchable Asset Related Demand, or Demand Response Resource dispatched by the ISO pursuant to a control signal appropriate to increase or decrease the Resource's megawatt output, consumption, or demand reduction level shall be able to change output, consumption, or demand

reduction at the ramping rate specified in the Offer Data submitted to the ISO for that Resource and shall be subject to sanctions for failure to comply as described in **Appendix B**.

III.1.7.19 Real-Time Reserve Designation.

The ISO shall determine the Real-Time Reserve Designation for each eligible Resource in accordance with this Section III.1.7.19. The Real-Time Reserve Designation shall consist of a MW value, in no case less than zero, for each Operating Reserve product: Ten-Minute Spinning Reserve, Ten-Minute Non-Spinning Reserve, and Thirty-Minute Operating Reserve.

III.1.7.19.1 Eligibility.

To be eligible to receive a Real-Time Reserve Designation, a Resource must meet all of the criteria enumerated in this Section III.1.7.19.1. A Resource that does not meet all of these criteria is not eligible to provide Operating Reserve and will not receive a Real-Time Reserve Designation.

(1) The Resource must be a Dispatchable Resource located within the metered boundaries of the New England Control Area and capable of receiving and responding to electronic Dispatch Instructions.

(2) The Resource must not be part of the first contingency supply loss.

(3) The Resource must not be designated as constrained by transmission limitations.

(4) The Resource's Operating Reserve, if activated, must be sustainable for at least one hour from the time of activation. (This eligibility requirement does not affect a Resource's obligation to follow Dispatch Instructions, even after one hour from the time of activation.)

(5) The Resource must comply with the applicable standards and requirements for provision and dispatch of Operating Reserve as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

III.1.7.19.2 Calculation of Real-Time Reserve Designation.

III.1.7.19.2.1 Generator Assets.

III.1.7.19.2.1.1 On-line Generator Assets.

The Manual Response Rate used in calculations in this section shall be the lesser of the Generator Asset's offered Manual Response Rate and its audited Manual Response Rate as described in Section III.1.5.2.

(a) **Ten-Minute Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit). For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Non-Spinning Reserve shall be zero. For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit).

(c) **Thirty-Minute Operating Reserve.** For an on-line Generator Asset, Thirty-Minute Operating Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within thirty minutes given its Manual Response Rate (and in no case greater than its Economic Maximum Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (b) above.

III.1.7.19.2.1.2 Off-line Generator Assets.

For an off-line Generator Asset that is not a Fast Start Generator, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Fast Start Generator's Offered CLAIM10, its CLAIM10, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Ten-Minute Non-Spinning Reserve shall be zero, except during the last ten minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Ten-Minute Non-Spinning Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires).

(c) **Thirty-Minute Operating Reserve.** For an off-line Fast Start Generator, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Fast Start Generator's Offered CLAIM30, its CLAIM30, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Thirty-Minute Operating Reserve shall be zero, except during the last thirty minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Thirty-Minute Operating Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires), minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Fast Start Generator pursuant to subsection (b) above.

III.1.7.19.2.2 Dispatchable Asset Related Demand.

III.1.7.19.2.2.1 Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Storage DARD, Ten-Minute Spinning Reserve shall be calculated as the absolute value of the amount of current telemetered consumption.

(b) **Ten-Minute Non-Spinning Reserve.** For a Storage DARD, Ten-Minute Non-Spinning Reserve shall be zero.

(c) **Thirty-Minute Operating Reserve.** For a Storage DARD, Thirty-Minute Operating Reserve shall be zero.

III.1.7.19.2.2.2 Dispatchable Asset Related Demand Other Than Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit). For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit).

(c) **Thirty-Minute Operating Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (a) above. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Non-Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (b) above.

III.1.7.19.2.3 Demand Response Resources.

For a Demand Response Resource that does not provide one-minute telemetry to the ISO, notwithstanding any provision in this Section III.1.7.19.2.3 to the contrary, the Ten-Minute Spinning Reserve and Ten-Minute Non-Spinning Reserve components of the Real-Time Reserve Designation shall

be zero. The Demand Response Resource Ramp Rate used in calculations in this section shall be the lesser of the Resource's offered Demand Response Resource Ramp Rate and its audited Demand Response Resource Ramp Rate as described in Section III.1.5.2.

III.1.7.19.2.3.1 Dispatched.

(a) **Ten-Minute Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction). For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction).

(c) **Thirty-Minute Operating Reserve.** For a Demand Response Resource that is being dispatched, Thirty-Minute Operating Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within thirty minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction) minus the Ten-Minute Spinning Reserve quantity calculated for the Resource pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Resource pursuant to subsection (b) above.

III.1.7.19.2.3.2 Non-Dispatched.

For a Demand Response Resource that is not being dispatched that is not a Fast Start Demand Response Resource, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Demand Response Resource's Offered CLAIM10, its CLAIM10, and its Maximum Reduction.

(c) **Thirty-Minute Operating Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Demand Response Resource's Offered CLAIM30, its CLAIM30, and its Maximum Reduction, minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Demand Response Resource pursuant to subsection (b) above.

III.1.7.20 Information and Operating Requirements.

(a) [Reserved.]

(b) Market Participants selling from Resources within the New England Control Area shall: supply to the ISO all applicable Offer Data; report to the ISO Resources that are Self-Scheduled; report to the ISO External Transaction sales; confirm to the ISO bilateral sales to Market Participants within the New England Control Area; respond to the ISO's directives to start, shutdown or change output, consumption, or demand reduction levels of Generator Assets, DARDs, or Demand Response Resources, change scheduled voltages or reactive output levels; continuously maintain all Offer Data concurrent with on-line operating information; and ensure that, where so equipped, equipment is operated with control equipment functioning as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

(c) Market Participants selling from Resources outside the New England Control Area shall: provide to the ISO all applicable Offer Data, including offers specifying amounts of energy available, hours of availability and prices of energy and other services; respond to ISO directives to schedule delivery or change delivery schedules; and communicate delivery schedules to the source Control Area and any intermediary Control Areas.

(d) Market Participants, as applicable, shall: respond or ensure a response to ISO directives for load management steps; report to the ISO all bilateral purchase transactions including External Transaction

purchases; and respond or ensure a response to other ISO directives such as those required during Emergency operation.

(e) Market Participant, as applicable, shall provide to the ISO requests to purchase specified amounts of energy for each hour of the Operating Day during which it intends to purchase from the Day-Ahead Energy Market.

(f) Market Participants are responsible for reporting to the ISO anticipated availability and other information concerning Generator Assets, Demand Response Resources and Dispatchable Asset Related Demands required by the ISO New England Operating Documents, including but not limited to the Market Participant's ability to procure fuel and physical limitations that could reduce Resource output or demand reduction capability for the pertinent Operating Day.

III.1.8 [Reserved.]

III.1.9 Pre-scheduling.

III.1.9.1 Offer and Bid Caps and Cost Verification for Offers and Bids.

III.1.9.1.1 Cost Verification of Resource Offers.

The incremental energy values of Supply Offers and Demand Response Resources above $1,000/MWh for any Resource other than an External Resource are subject to the following cost verification requirements. Unless expressly stated otherwise, cost verification is utilized in all pricing, commitment, dispatch and settlement determinations. For purposes of the following requirements, Reference Levels are calculated using the procedures in Section III.A.7.5 for calculating cost-based Reference Levels.

(a) If the incremental energy value of a Resource's offer is greater than the incremental energy Reference Level value of the Resource, then the incremental energy value in the offer is replaced with the greater of the Reference Level for incremental energy or $1,000/MWh.

(b) For purposes of the price calculations in Sections III.2.5 and III.2.7A, if the adjusted offer calculated under Section III.2.4 for a Rapid Response Pricing Asset is greater than $1,000/MWh (after the incremental energy value is evaluated under Section III.1.9.1.1(a) above), then verification will be performed as follows using a Reference Level value calculated with the adjusted offer formulas specified in Section III.2.4.

(i) If the Reference Level value is less than or equal to $1,000/MWh, then the adjusted offer for the Resource is set at $1,000/MWh;

(ii) If the Reference Level value is greater than $1,000/MWh, then the adjusted offer for the Resource is set at the lower of the Reference Level value and the adjusted offer.

III.1.9.1.2 Offer and Bid Caps.

(a) For purposes of the price calculations described in Section III.2 and for purposes of scheduling a Resource in the Day-Ahead Energy Market in accordance with Section III.1.7.6 following the commitment of the Resource, the incremental energy value of an offer is capped at $2,000/MWh.

(b) Demand Bids shall not specify a bid price below the Energy Offer Floor or above the Demand Bid Cap.

(c) Supply Offers and Demand Reduction Offers shall not specify an offer price (for incremental energy) below the Energy Offer Floor.

(d) External Transactions shall not specify a price below the External Transaction Floor or above the External Transaction Cap.

(e) Increment Offers and Decrement Bids shall not specify an offer or bid price below the Energy Offer Floor or above the Virtual Cap.

III.1.9.2 [Reserved.]

III.1.9.3 [Reserved.]

III.1.9.4 [Reserved.]

III.1.9.5 [Reserved.]

III.1.9.6 [Reserved.]

III.1.9.7 Market Participant Responsibilities.

Market Participants authorized and intending to request market-based Start-Up Fees and No-Load Fee in their Offer Data shall submit a specification of such fees to the ISO for each Generator Asset as to which the Market Participant intends to request such fees. Any such specification shall identify the applicable period and be submitted on or before the applicable deadline and shall remain in effect unless otherwise modified in accordance with Section III.1.10.9. The ISO shall reject any request for Start-Up Fees and No-Load Fee in a Market Participant's Offer Data that does not conform to the Market Participant's specification on file with the ISO.

III.1.9.8 [Reserved.]

III.1.10 Scheduling.

III.1.10.1 General.

(a) The ISO shall administer scheduling processes to implement a Day-Ahead Energy Market and a Real-Time Energy Market.

(b) The Day-Ahead Energy Market shall enable Market Participants to purchase and sell energy through the New England Markets at Day-Ahead Prices and enable Market Participants to submit External Transactions conditioned upon Congestion Costs not exceeding a specified level. Market Participants whose purchases and sales and External Transactions are scheduled in the Day-Ahead Energy Market shall be obligated to purchase or sell energy or pay Congestion Costs and costs for losses, at the applicable Day-Ahead Prices for the amounts scheduled.

(c) In the Real-Time Energy Market,

(i) Market Participants that deviate from the amount of energy purchases or sales scheduled in the Day-Ahead Energy Market shall replace the energy not delivered with energy from the Real-Time Energy Market or an internal bilateral transaction and shall pay for such energy not delivered, net of any internal bilateral transactions, at the applicable Real-Time Price, unless otherwise specified by this Market Rule 1, and

(ii) Non-Market Participant Transmission Customers shall be obligated to pay Congestion Costs and costs for losses for the amount of the scheduled transmission uses in the Real-Time Energy Market at the applicable Real-Time Congestion Component and Loss Component price differences, unless otherwise specified by this Market Rule 1.

(d) The following scheduling procedures and principles shall govern the commitment of Resources to the Day-Ahead Energy Market and the Real-Time Energy Market over a period extending from one week to one hour prior to the Real-Time dispatch. Scheduling encompasses the Day-Ahead and hourly scheduling process, through which the ISO determines the Day-Ahead Energy Market schedule and determines, based on changing forecasts of conditions and actions by Market Participants and system constraints, a plan to serve the hourly energy and reserve requirements of the New England Control Area in the least costly manner, subject to maintaining the reliability of the New England Control Area.

Scheduling of External Transactions in the Real-Time Energy Market is subject to Section II.44 of the OATT.

(e) If the ISO's forecast for the next seven days projects a likelihood of Emergency Condition, the ISO may commit, for all or part of such seven day period, to the use of Generator Assets or Demand Response Resources with Notification Time greater than 24 hours as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Participants' binding Supply Offers or Demand Reduction Offers.

III.1.10.1A Energy Market Scheduling.

Market Participants may submit offers and bids in the Day-Ahead Energy Market until 10:30 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the ISO in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Market Rule 1.

(a) **Locational Demand Bids –** Each Market Participant may submit to the ISO specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-Ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures. Each Market Participant shall inform the ISO of (i) the prices, if any, at which it desires not to include its load in the Day-Ahead Energy Market rather than pay the Day-Ahead Price, (ii) hourly schedules for Resources Self-Scheduled by the Market Participant; and (iii) the Decrement Bid at which each such Self-Scheduled Resource will disconnect or reduce output, or confirmation of the Market Participant's intent not to reduce output. Price-sensitive Demand Bids and Decrement Bids must be greater than zero MW and shall not exceed the Demand Bid Cap and Virtual Cap.

(b) **External Transactions –** All Market Participants shall submit to the ISO schedules for any External Transactions involving use of Generator Assets or the New England Transmission System as specified below, and shall inform the ISO whether the transaction is to be included in the Day-Ahead Energy Market. Any Market Participant that elects to include an External Transaction in the Day-Ahead Energy Market may specify the price (such price not to exceed the maximum price that may be specified in the ISO New England Manuals and ISO New England Administrative Procedures), if any, at which it will be curtailed rather than pay Congestion Costs. The foregoing price specification shall apply to the price difference between the Locational Marginal Prices for specified External Transaction source and

sink points in the Day-Ahead scheduling process only. Any Market Participant that deviates from its Day-Ahead External Transaction schedule or elects not to include its External Transaction in the Day-Ahead Energy Market shall be subject to Congestion Costs in the Real-Time Energy Market in order to complete any such scheduled External Transaction. Scheduling of External Transactions shall be conducted in accordance with the specifications in the ISO New England Manuals and ISO New England Administrative Procedures and the following requirements:

(i) Market Participants shall submit schedules for all External Transaction purchases for delivery within the New England Control Area from Resources outside the New England Control Area;

(ii) Market Participants shall submit schedules for External Transaction sales to entities outside the New England Control Area from Resources within the New England Control Area;

(iii) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction purchases less External Transaction sales exceeds the import capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction purchases at the applicable External Node shall be set equal to the Energy Offer Floor;

(iv) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction sales less External Transaction purchases exceeds the export capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction sales at the applicable External Node shall be set equal to the External Transaction Cap;

(v) The ISO shall not consider Start-Up Fees, No-Load Fees, Notification Times or any other inter-temporal parameters in scheduling or dispatching External Transactions.

(c) **Generator Asset Supply Offers –** Market Participants selling into the New England Markets from Generator Assets may submit Supply Offers for the supply of energy for the following Operating Day.

Such Supply Offers:

(i) Shall specify the Resource and Blocks (price and quantity of Energy) for each hour of the Operating Day for each Resource offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) If based on energy from a Generator Asset internal to the New England Control Area, may specify, for Supply Offers, a Start-Up Fee and No-Load Fee for each hour of the Operating Day. Start-Up Fee and No-Load Fee may vary on an hourly basis;

(iii) Shall specify, for Supply Offers from a dual-fuel Generator Asset, the fuel type. The fuel type may vary on an hourly basis. A Market Participant that submits a Supply Offer using the higher cost fuel type must satisfy the consultation requirements for dual-fuel Generator Assets in Section III.A.3 of Appendix A;

(iv) Shall specify a Minimum Run Time to be used for commitment purposes that does not exceed 24 hours;

(v) Supply Offers shall constitute an offer to submit the Generator Asset to the ISO for commitment and dispatch in accordance with the terms of the Supply Offer, where such Supply Offer, with regard to operating limits, shall specify changes, including to the Economic Maximum Limit, Economic Minimum Limit and Emergency Minimum Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource (except that for a Limited Energy Resource, the Economic Maximum Limit may be revised to reflect an energy (MWh) limitation), which offer shall remain open through the Operating Day for which the Supply Offer is submitted; and

(vi) Shall, in the case of a Supply Offer from a Generator Asset associated with an Electric Storage Facility, also meet the requirements specified in Section III.1.10.6.

(d) DARD Demand Bids – Market Participants participating in the New England Markets with Dispatchable Asset Related Demands may submit Demand Bids for the consumption of energy for the following Operating Day.

Such Demand Bids:

(i) Shall specify the Dispatchable Asset Related Demand and Blocks (price and Energy quantity pairs) for each hour of the Operating Day for each Dispatchable Asset Related Demand offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) Shall constitute an offer to submit the Dispatchable Asset Related Demand to the ISO for commitment and dispatch in accordance with the terms of the Demand Bid, where such Demand Bid, with regard to operating limits, shall specify changes, including to the Maximum Consumption Limit and Minimum Consumption Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource;

(iii) Shall specify a Minimum Consumption Limit that is less than or equal to its Nominated Consumption Limit; and

(iv) Shall, in the case of a Demand Bid from a Storage DARD, also meet the requirements specified in Section III.1.10.6.

(e) **Demand Response Resource Demand Reduction Offers –** Market Participants selling into the New England Markets from Demand Response Resources may submit Demand Reduction Offers for the supply of energy for the following Operating Day. A Demand Reduction Offer shall constitute an offer to submit the Demand Response Resource to the ISO for commitment and dispatch in accordance with the terms of the Demand Reduction Offer. Demand Reduction Offers:

(i) Shall specify the Demand Response Resource and Blocks (price and demand reduction quantity pairs) for each hour of the Operating Day. The prices and demand reduction quantities may vary on an hourly basis.

(ii) Shall not specify a price that is below the Demand Reduction Threshold Price in effect for the Operating Day. For purposes of clearing the Day-Ahead and Real-Time Energy Markets and calculating Day-Ahead and Real-Time Locational Marginal Prices and Real-Time Reserve Clearing Prices, any price specified below the Demand Reduction Threshold price in effect for the Operating Day will be considered to be equal to the Demand Reduction Threshold Price for the Operating Day.

(iii) Shall not include average avoided peak transmission or distribution losses in the demand reduction quantity.

(iv) May specify an Interruption Cost for each hour of the Operating Day, which may vary on an hourly basis.

(v) Shall specify a Minimum Reduction Time to be used for scheduling purposes that does not exceed 24 hours.

(vi) Shall specify a Maximum Reduction amount no greater than the sum of the Maximum Interruptible Capacities of the Demand Response Resource's operational Demand Response Assets.

(vii) Shall specify changes to the Maximum Reduction and Minimum Reduction from those submitted as part of the Demand Response Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Demand Response Resource.

(f) **Demand Reduction Threshold Price –** The Demand Reduction Threshold Price for each month shall be determined through an analysis of a smoothed, historic supply curve for the month. The historic supply curve shall be derived from Real-Time generator and import Offer Data (excluding Coordinated External Transactions) for the same month of the previous year. The ISO may adjust the Offer Data to account for significant changes in generator and import availability or other significant changes to the historic supply curve. The historic supply curve shall be calculated as follows:

(a) Each generator and import offer Block (i.e., each price-quantity pair offered in the Real-Time Energy Market) for each day of the month shall be compiled and sorted in ascending order of price to create an unsmoothed supply curve.

(b) An unsmoothed supply curve for the month shall be formed from the price and cumulative quantity of each offer Block.

(c) A non-linear regression shall be performed on a sampled portion of the unsmoothed supply curve to produce an increasing, convex, smooth approximation of the supply curve.

(d) A historic threshold price P_{th} shall be determined as the point on the smoothed supply curve beyond which the benefit to load from the reduced LMP resulting from the demand reduction of Demand Response Resources exceeds the cost to load associated with compensating Demand Response Resources for demand reduction.

(e) The Demand Reduction Threshold Price for the upcoming month shall be determined by the following formula:

$$DRTP = P_{th} X — \frac{FPI_c}{FPI_h}$$

where FPI_h is the historic fuel price index for the same month of the previous year, and FPI_c is the fuel price index for the current month.

The historic and current fuel price indices used to establish the Demand Reduction Threshold Price for a month shall be based on the lesser of the monthly natural gas or heating oil fuel indices applicable to the New England Control Area, as calculated three business days before the start of the month preceding the Demand Reduction Threshold Price's effective date.

The ISO will post the Demand Reduction Threshold Price, along with the index-based fuel price values used in establishing the Demand Reduction Threshold Price, on its website by the 15th day of the month preceding the Demand Reduction Threshold Price's effective date.

(g) **Subsequent Operating Days** – Each Supply Offer, Demand Reduction Offer, or Demand Bid by a Market Participant of a Resource shall remain in effect for subsequent Operating Days until superseded or canceled except in the case of an External Transaction purchase, in which case, the Supply Offer shall remain in effect for the applicable Operating Day and shall not remain in effect for subsequent Operating Days. Hourly overrides of a Supply Offer, a Demand Reduction Offer, or a Demand Bid shall remain in effect only for the applicable Operating Day.

(h) **Load Estimate** – The ISO shall post on the internet the total hourly loads including Decrement Bids scheduled in the Day-Ahead Energy Market, as well as the ISO's estimate of the Control Area hourly load for the next Operating Day.

(i) **Prorated Supply** – In determining Day-Ahead schedules, in the event of multiple marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases at a pricing location, the ISO shall clear the marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases proportional to the amount of energy (MW) from each marginal offer and/or External Transaction at the pricing location. The Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions are not used in determining the amount of energy (MW) in each marginal Supply Offer or Demand Reduction Offer to be cleared on a pro-rated basis. However, the Day-Ahead schedules resulting from the pro-ration process will reflect Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions.

(j) **Prorated Demand** – In determining Day-Ahead schedules, in the event of multiple marginal Demand Bids, Decrement Bids and/or External Transaction sales at a pricing location, the ISO shall clear the marginal Demand Bids, Decrement Bids and/or External Transaction sales proportional to the amount of energy (MW) from each marginal bid and/or External Transaction at the pricing location.

(k) **Virtuals** – All Market Participants may submit Increment Offers and/or Decrement Bids that apply to the Day-Ahead Energy Market only. Such offers and bids must comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-Ahead Energy Market.

III.1.10.2 Pool-Scheduled Resources.

Pool-Scheduled Resources are those Resources for which Market Participants submitted Supply Offers, Demand Reduction Offers, or Demand Bids in the Day-Ahead Energy Market and which the ISO scheduled in the Day-Ahead Energy Market as well as Generator Assets, DARDs or Demand Response Resources committed by the ISO subsequent to the Day-Ahead Energy Market. Such Resources shall be committed to provide or consume energy in the Real-Time dispatch unless the schedules for such Resources are revised pursuant to Sections III.1.10.9 or III.1.11. Pool-Scheduled Resources shall be governed by the following principles and procedures.

(a) Pool-Scheduled Resources shall be selected by the ISO on the basis of the prices offered for energy supply or consumption and related services, Start-Up Fees, No-Load Fees, Interruption Cost and the specified operating characteristics, offered by Market Participants.

(b) The ISO shall optimize the dispatch of energyfrom Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources in the Day-Ahead Energy Market consistent with the Supply Offers and Demand Reduction Offers of other Resources, the submitted Demand Bids and Decrement Bids and Operating Reserve and Replacement Reserve requirements.

(c) Market Participants offering energy from facilities with fuel or environmental limitations may submit data to the ISO that is sufficient to enable the ISO to determine the available operating hours of such facilities.

(d) Market Participants shall make available their Pool-Scheduled Resources to the ISO for coordinated operation to supply the needs of the New England Control Area for energy and ancillary services.

III.1.10.3 Self-Scheduled Resources.

A Resource that is Self-Scheduled shall be governed by the following principles and procedures. The minimum duration of a Self-Schedule for a Generator Asset or DARD shall not result in the Generator Asset or DARD operating for less than its Minimum Run Time. A Generator Asset that is online as a result of a Self-Schedule will be dispatched above its Economic Minimum Limit based on the economic merit of its Supply Offer. A DARD that is consuming as a result of a Self-Schedule may be dispatched above its Minimum Consumption Limit based on the economic merit of its Demand Bid. A Demand Response Resource shall not be Self-Scheduled.

III.1.10.4 External Resources.

Market Participants with External Resources may submit External Transactions as detailed in Section III.1.10.7 and Section III.1.10.7.A of this Market Rule 1.

III.1.10.5 Dispatchable Asset Related Demand.

(a) External Transactions that are sales to an external Control Area are not eligible to be Dispatchable Asset Related Demands.

(b) A Market Participant with a Dispatchable Asset Related Demand in the New England Control Area must:

(i) notify the ISO of any outage (including partial outages) that may reduce the Dispatchable Asset Related Demand's ability to respond to Dispatch Instructions and the expected return date from the outage;

(ii) in accordance with the ISO New England Manuals and Operating Procedures, perform audit tests and submit the results to the ISO or provide to the ISO appropriate historical production data;

(iii) abide by the ISO maintenance coordination procedures; and

(iv) provide information reasonably requested by the ISO, including the name and location of the Dispatchable Asset Related Demand.

III.1.10.6 Electric Storage

A storage facility is a facility that is capable of receiving electricity from the grid and storing the energy for later injection of electricity back to the grid. A storage facility may participate in the New England Markets as described below.

(a) A storage facility that satisfies the requirements of this subsection (a) may participate in the New England Markets as an Electric Storage Facility. An Electric Storage Facility shall:

(i) comprise one or more storage facilities at the same point of interconnection;

(ii) have the ability to inject at least 0.1 MW and consume at least 0.1 MW;

(iii) be directly metered;

(iv) be registered as, and subject to all rules applicable to, a dispatchable Generator Asset;

(v) be registered as, and subject to all rules applicable to, a DARD that represents the same equipment as the Generator Asset;

(vi) settle its injection of electricity to the grid as a Generator Asset and its receipt of electricity from the grid as a DARD;

(vii) not be precluded from providing retail services so long as it is able to fulfill its wholesale Energy Market and Forward Capacity Market obligations including, but not limited to, satisfying meter data reporting requirements and notifying the ISO of any changes to operational capabilities; and

(viii) meet the requirements of either a Binary Storage Facility or a Continuous Storage Facility, as described in subsections (b) and (c) below.

(b) A storage facility that satisfies the requirements of this subsection (b) may participate in the New England Markets as a Binary Storage Facility. A Binary Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility; and

(ii) offer its Generator Asset and DARD into the Energy Market as Rapid Response Pricing Assets; and

(iii) be issued Dispatch Instructions in a manner that ensures the facility is not required to consume and inject simultaneously.

(c) A storage facility that satisfies the requirements of this subsection (c) may participate in the New England Markets as a Continuous Storage Facility. A Continuous Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility;

(ii) be registered as, may provide Regulation as, and is subject to all rules applicable to, an ATRR that represents the same equipment as the Generator Asset and DARD;

(iii) be capable of transitioning between the facility's maximum output and maximum consumption (and vice versa) in ten minutes or less;

(iv) not utilize storage capability that is shared with another Generator Asset, DARD or ATRR;

(v) specify in Supply Offers a zero MW value for Economic Minimum Limit and Emergency Minimum Limit (except for Generator Assets undergoing Facility and Equipment Testing or auditing); a zero time value for Minimum Run Time, Minimum Down Time, Notification Time, and Start-Up Time; and a zero cost value for Start-Up Fee and No-Load Fee;

(vi) specify in Demand Bids a zero MW value for Minimum Consumption Limit (except for DARDs undergoing Facility and Equipment Testing or auditing) and a zero time value for Minimum Run Time and Minimum Down Time;

(vii) be Self-Scheduled in the Day-Ahead Energy Market and Real-Time Energy Market, and operate in an on-line state, unless the facility is declared unavailable by the Market Participant; and

(viii) be issued a combined dispatch control signal equal to the Desired Dispatch Point (of the Generator Asset) minus the Desired Dispatch Point (of the DARD) plus the AGC SetPoint (of the ATRR).

(d) A storage facility shall comply with all applicable registration, metering, and accounting rules including, but not limited to, the following:

(i) A Market Participant wishing to purchase energy from the ISO-administered wholesale markets must first, jointly with its Host Participant, register one or more wholesale Load Assets with the ISO as described in ISO New England Manual M-28 and ISO New England Manual M-RPA; where the Market Participant wishes to register an Electric Storage Facility, the registered Load Asset must be a DARD.

(ii) A storage facility's charging energy ~~load~~ shall not qualify as, or be billed to, a Storage DARD if that facility's charging energy is included in another ~~the Host Participant is unwilling or unable to support the registration, metering, and accounting of the storage facility's load as a separate and distinct~~ Load Asset. A storage facility registered as a DARD will be charged the nodal Locational Marginal Price by the ISO and the Market Participant will not pay twice for the same charging energy~~load~~.

(iii) The registration and metering of all Assets must comply with ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18, including with the requirement that an Asset's revenue metering must comply with the accuracy requirements found in ISO New England Operating Procedure No. 18.

(iv) Pursuant to ISO New England Manual M-28, the Assigned Meter Reader, the Host Participant, and the ISO provide the data for use in the daily settlement process within the timelines described in the manual. The data may be five-minute interval data, and may be no more than hourly data, as described in Section III.3.2 and in ISO New England Manual M-28.

(v) Based on the Metered Quantity For Settlement and the Locational Marginal Price in the settlement interval, the ISO shall conduct all Energy Market accounting pursuant to Section III.3.2.1.

(e) A facility registered as a dispatchable Generator Asset, an ATRR, and a DARD that each represent the same equipment must participate as a Continuous Storage Facility.

(f) A storage facility not participating as an Electric Storage Facility may, if it satisfies the associated requirements, be registered as a Generator Asset (including a Settlement Only Resource) for settlement of its injection of electricity to the grid and as an Asset Related Demand for settlement of its wholesale load.

(g) A storage facility may, if it satisfies the associated requirements, be registered as a Demand Response Asset. (As described in Section III.8.1.1, a Demand Response Asset and a Generator Asset may not

be registered at the same end-use customer facility unless the Generator Asset is separately metered and reported and its output does not reduce the load reported at the Retail Delivery Point of the Demand Response Asset.)

(h) A storage device may, if it satisfies the associated requirements, be registered as a component of either an On-Peak Demand Resource or a Seasonal Peak Demand Resource.

(i) A storage facility may, if it satisfies the associated requirements, provide Regulation pursuant to Section III.14.

III.1.10.7 External Transactions.

The provisions of this Section III.1.10.7 do not apply to Coordinated External Transactions.

(a) Market Participants that submit an External Transaction in the Day-Ahead Energy Market must also submit a corresponding External Transaction in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market. Priced External Transactions for the Real-Time Energy Market must be submitted by the offer submission deadline for the Day-Ahead Energy Market.

(b) Priced External Transactions submitted in both the Day-Ahead Energy Market and the Real-Time Energy Market will be treated as Self-Scheduled External Transactions in the Real-Time Energy Market for the associated megawatt amounts that cleared the Day-Ahead Energy Market, unless the Market Participant modifies the price component of its Real-Time offer during the Re-Offer Period.

(c) Any External Transaction, or portion thereof, submitted to the Real-Time Energy Market that did not clear in the Day-Ahead Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency. External Transactions cleared in the Day-Ahead Energy Market and associated with a Real-Time Energy Market submission will continue to be scheduled in Real-Time prior to and during an Emergency, until the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, require a change in schedule.

(d) External Transactions submitted to the Real-Time Energy Market must contain the associated e-Tag ID and transmission reservation, if required, at the time the transaction is submitted to the Real-Time Energy Market.

(e) [Reserved.]

(f) External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below receive priority in the scheduling and curtailment of transactions as set forth in Section II.44 of the OATT. External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below are referred to herein and in the OATT as being supported in Real-Time.

(i) Capacity Export Through Import Constrained Zone Transactions:

(1) The External Transaction is exporting across an external interface located in an import-constrained Capacity Zone that cleared in the Forward Capacity Auction with price separation, as determined in accordance with Section III.12.4 and Section III.13.2.3.4 of Market Rule 1;

(2) The External Transaction is directly associated with an Export Bid or Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The External Node associated with the cleared Export Bid or Administrative Export De-List Bid is connected to the import-constrained Capacity Zone, and is not connected to a Capacity Zone that is not import-constrained;

(4) The Resource, or portion thereof, that is associated with the cleared Export Bid or Administrative Export De-List Bid is not located in the import-constrained Capacity Zone;

(5) The External Transaction has been submitted and cleared in the Day-Ahead Energy Market;

(6) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(ii) FCA Cleared Export Transactions:

(1) The External Transaction sale is exporting to an External Node that is connected only to an import-constrained Reserve Zone;

(2) The External Transaction sale is directly associated with an Export Bid or an Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation associated with the Export Bid or Administrative Export De-List Bid is located outside the import-constrained Reserve Zone;

(4) The External Transaction sale is submitted and cleared in the Day-Ahead Energy Market;

(5) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(iii) Same Reserve Zone Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is connected only to the same Reserve Zone in which the associated Resource, or portion thereof, without a Capacity Supply Obligation is located;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(4) Neither the External Transaction sale nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(iv) Unconstrained Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is not connected only to an import-constrained Reserve Zone;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is not separated from the External Node by a transmission interface constraint as determined in Sections III.12.2.1(b) and III.12.2.2(b) of Market Rule 1 that was binding in the Forward Capacity Auction in the direction of the export;

(4) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(5) Neither the External Transaction sale, nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(g) Treatment of External Transaction sales in ISO commitment for local second contingency protection.

(i) Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: The transaction's export demand that clears in the Day-Ahead Energy Market will be explicitly considered as load in the exporting Reserve Zone by the ISO when committing Resources to provide local second contingency protection for the associated Operating Day.

(ii) The export demand of External Transaction sales not meeting the criteria in (i) above is not considered by the ISO when planning and committing Resources to provide local second contingency protection, and is assumed to be zero.

(iii) Same Reserve Zone Export Transactions and Unconstrained Export Transactions: If a Resource, or portion thereof, without a Capacity Supply Obligation is committed to be online during the Operating Day either through clearing in the Day-Ahead Energy Market or through Self-Scheduling subsequent to the Day-Ahead Energy Market and a Same Reserve Zone Export Transaction or Unconstrained Export Transaction is submitted before the end of the Re-Offer Period designating that Resource as supporting the transaction, the ISO will not utilize the portion of the Resource without a Capacity Supply Obligation supporting the export transaction to meet local second contingency protection requirements. The eligibility of Resources not meeting the foregoing criteria to be used to meet local second contingency protection requirements shall be in accordance with the relevant provisions of the ISO New England System Rules.

(h) Allocation of costs to Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: Market Participants with Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions shall incur a proportional share of the charges described below, which are allocated to Market Participants based on Day-Ahead Load Obligation or Real-Time Load Obligation. The share shall be determined by including the Day-Ahead Load Obligation or Real-Time Load Obligation associated with the External Transaction, as applicable, in the total Day-Ahead Load Obligation or Real-Time Load Obligation for the appropriate Reliability Region, Reserve Zone, or Load Zone used in each cost allocation calculation:

(i) NCPC for Local Second Contingency Protection Resources allocated within the exporting Reliability Region, pursuant to Section III.F.3.3.

(ii) Forward Reserve Market charges allocated within the exporting Load Zone, pursuant to Section III.9.9.

(iii) Real-Time Reserve Charges allocated within the exporting Load Zone, pursuant to Section III.10.3.

(i) When action is taken by the ISO to reduce External Transaction sales due to a system wide capacity deficient condition or the forecast of such a condition, and an External Transaction sale designates a Resource, or portion of a Resource, without a Capacity Supply Obligation, to support the transaction, the ISO will review the status of the designated Resource. If the designated Resource is Self-Scheduled and online at a megawatt level greater than or equal to the External Transaction sale, that External Transaction sale will not be reduced until such time as Regional Network Load within the New England Control Area is also being reduced. When reductions to such transactions are required, the affected transactions shall be reduced pro-rata.

(j) Market Participants shall submit External Transactions as megawatt blocks with intervals of one hour at the relevant External Node. External Transactions will be scheduled in the Day-Ahead Energy Market as megawatt blocks for hourly durations. The ISO may dispatch External Transactions in the Real-Time Energy Market as megawatt blocks for periods of less than one hour, to the extent allowed pursuant to inter-Control Area operating protocols.

III.1.10.7.A Coordinated Transaction Scheduling.

The provisions of this Section III.1.10.7.A apply to Coordinated External Transactions, which are implemented at the New York Northern AC external Location.

(a) Market Participants that submit a Coordinated External Transaction in the Day-Ahead Energy Market must also submit a corresponding Coordinated External Transaction, in the form of an Interface Bid, in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market.

(b) An Interface Bid submitted in the Real-Time Energy Market shall specify a duration consisting of one or more consecutive 15-minute increments. An Interface Bid shall include a bid price, a bid quantity, and a bid direction for each 15-minute increment. The bid price may be positive or negative. An Interface Bid may not be submitted or modified later than 75 minutes before the start of the clock hour for which it is offered.

(c) Interface Bids are cleared in economic merit order for each 15-minute increment, based upon the forecasted real-time price difference across the external interface. The total quantity of Interface Bids cleared shall determine the external interface schedule between New England and the adjacent Control Area. The total quantity of Interface Bids cleared shall depend upon, among other factors, bid production

costs of resources in both Control Areas, the Interface Bids of all Market Participants, transmission system conditions, and any real-time operating limits necessary to ensure reliable operation of the transmission system.

(d) All Coordinated External Transactions submitted either to the Day-Ahead Energy Market or the Real-Time Energy Market must contain the associated e-Tag ID at the time the transaction is submitted.

(e) Any Coordinated External Transaction, or portion thereof, submitted to the Real-Time Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency, unless the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, permit the transaction to be scheduled.

III.1.10.8 ISO Responsibilities.

(a) The ISO shall use its best efforts to determine (i) the least-cost means of satisfying hourly purchase requests for energy, the projected hourly requirements for Operating Reserve, Replacement Reserve and other ancillary services of the Market Participants, including the reliability requirements of the New England Control Area, of the Day-Ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve, Replacement Reserve and other ancillary service requirements for any portion of the load forecast of the ISO for the Operating Day in excess of that scheduled in the Day-Ahead Energy Market. In making these determinations, the ISO shall take into account: (i) the ISO's forecasts of New England Markets and New England Control Area energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Participants for the Day-Ahead Energy Market; (ii) the offers and bids submitted by Market Participants; (iii) the availability of Limited Energy Resources; (iv) the capacity, location, and other relevant characteristics of Self-Scheduled Resources; (v) the requirements of the New England Control Area for Operating Reserve and Replacement Reserve, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vi) the requirements of the New England Control Area for Regulation and other ancillary services, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; and (viii) such other factors as the ISO reasonably concludes are relevant to the foregoing determination. The ISO shall develop a Day-Ahead Energy schedule based on the applicable portions of the foregoing determination, and shall determine the Day-Ahead Prices resulting from such schedule. (b)

Not later than 1:30 p.m. of the day before each Operating Day, or such earlier deadline as may be

specified by the ISO in the ISO New England Manuals and ISO New England Administrative Procedures or such later deadline as necessary to account for software failures or other events, the ISO shall: (i) post the aggregate Day-Ahead Energy schedule; (ii) post the Day-Ahead Prices; and (iii) inform the Market Participants of their scheduled injections and withdrawals. In the event of an Emergency, the ISO will notify Market Participants as soon as practicable if the Day-Ahead Energy Market can not be operated.

(c) Following posting of the information specified in Section III.1.10.8(b), the ISO shall revise its schedule of Resources to reflect updated projections of load, conditions affecting electric system operations in the New England Control Area, the availability of and constraints on limited energy and other Resources, transmission constraints, and other relevant factors.

(d) Market Participants shall pay and be paid for the quantities of energy scheduled in the Day-Ahead Energy Market at the Day-Ahead Prices.

III.1.10.9 Hourly Scheduling.

(a) Following the initial posting by the ISO of the Locational Marginal Prices resulting from the Day-Ahead Energy Market, and subject to the right of the ISO to schedule and dispatch Resources and to direct that schedules be changed to address an actual or potential Emergency, a Resource Re-Offer Period shall exist from the time of the posting specified in Section III.1.10.8(b) until 2:00 p.m. on the day before each Operating Day or such other Re-Offer Period as necessary to account for software failures or other events. During the Re-Offer Period, Market Participants may submit revisions to Supply Offers, revisions to Demand Reduction Offers, and revisions to Demand Bids for any Dispatchable Asset Related Demand. Resources scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices.

(b) During the Re-Offer Period, Market Participants may submit revisions to the price of priced External Transactions. External Transactions scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices. A submission during the Re-Offer Period for any portion of a transaction that was cleared in the Day-Ahead Energy Market is subject to the provisions in Section III.1.10.7. A Market Participant may request to Self-Schedule an External Transaction and adjust the schedule on an hour-to-hour basis or request to reduce the quantity of a priced External Transaction. The ISO must be notified of the request not later than 60 minutes prior to the hour in which the adjustment is to take effect. The External

Transaction re-offer provisions of this Section III.1.10.9(b) shall not apply to Coordinated External Transactions, which are submitted pursuant to Section III.1.10.7.A.

(c) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may modify certain Supply Offer or Demand Bid parameters for a Generator Asset or a Dispatchable Asset Related Demand on an hour-to-hour basis, provided that the modification is made no later than 30 minutes prior to the beginning of the hour for which the modification is to take effect:

(i) For a Generator Asset, the Start-Up Fee, the No-Load Fee, the fuel type (for dual-fuel Generator Assets), and the quantity and price pairs of its Blocks may be modified.

(ii) For a Dispatchable Asset Related Demand, the quantity and price pairs of its Blocks may be modified.

(d) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may not modify any of the following Demand Reduction Offer parameters: price and demand reduction quantity pairs, Interruption Cost, Demand Response Resource Start-Up Time, Demand Response Resource Notification Time, Minimum Reduction Time, and Minimum Time Between Reductions.

(e) During the Operating Day, a Market Participant may request to Self-Schedule a Generator Asset or Dispatchable Asset Related Demand or may request to cancel a Self-Schedule for a Generator Asset or Dispatchable Asset Related Demand. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor a Self-Schedule request, a Generator Asset will be permitted to come online at its Economic Minimum Limit and a Dispatchable Asset Related Demand will be dispatched to its Minimum Consumption Limit. A Market Participant may not request to Self-Schedule a Demand Response Resource. A Market Participant may cancel the Self-Schedule of a Continuous Storage Generator Asset or a Continuous Storage DARD only by declaring the facility unavailable.

(f) During the Operating Day, in the event that in a given hour a Market Participant seeks to modify a Supply Offer or Demand Bid after the deadline for modifications specified in Section III.1.10.9(c), then:

(i) the Market Participant may request that a Generator Asset be dispatched above its Economic Minimum Limit at a specified output. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the

request, the Generator Asset will be dispatched as though it had offered the specified output for the hour in question at the Energy Offer Floor.

(ii) the Market Participant may request that a Dispatchable Asset Related Demand be dispatched above its Minimum Consumption Limit at a specified value. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the request, the Dispatchable Asset Related Demand will be dispatched at or above the requested amount for the hour in question.

(g) During the Operating Day, in any interval in which a Generator Asset is providing Regulation, the upper limit of its energy dispatch range shall be reduced by the amount of Regulation Capacity, and the lower limit of its energy dispatch range shall be increased by the amount of Regulation Capacity. Any such adjustment shall not affect the Real-Time Reserve Designation.

(h) During the Operating Day, in any interval in which a Continuous Storage ATRR is providing Regulation, the upper limit of the associated Generator Asset's energy dispatch range shall be reduced by the Regulation High Limit, and the associated DARD's consumption dispatch range shall be reduced by the Regulation Low Limit. Any such adjustment shall not affect the Real-Time Reserve Designation.

(i) For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this Section III.1.10, the ISO shall provide Market Participants and parties to External Transactions with any revisions to their schedules for the hour.

III.1.11 Dispatch.

The following procedures and principles shall govern the dispatch of the Resources available to the ISO.

III.1.11.1 Resource Output or Consumption and Demand Reduction.

The ISO shall have the authority to direct any Market Participant to adjust the output, consumption or demand reduction of any Dispatchable Resource within the operating characteristics specified in the Market Participant's Offer Data, Supply Offer, Demand Reduction Offer or Demand Bid. The ISO may cancel its selection of, or otherwise release, Pool-Scheduled Resources. The ISO shall adjust the output, consumption or demand reduction of Resources as necessary: (a) for both Dispatchable Resources and Non-Dispatchable Resources, to maintain reliability, and subject to that constraint, for Dispatchable Resources, (b) to minimize the cost of supplying the energy, reserves, and other services required by the

Market Participants and the operation of the New England Control Area; (c) to balance supply and demand, maintain scheduled tie flows, and provide frequency support within the New England Control Area; and (d) to minimize unscheduled interchange that is not frequency related between the New England Control Area and other Control Areas.

III.1.11.2 Operating Basis.

In carrying out the foregoing objectives, the ISO shall conduct the operation of the New England Control Area and shall, in accordance with the ISO New England Manuals and ISO New England Administrative Procedures, (i) utilize available Operating Reserve and replace such Operating Reserve when utilized; and (ii) monitor the availability of adequate Operating Reserve.

III.1.11.3 Dispatchable Resources.

With the exception of Settlement Only Resources, Generator Assets that meet the size criteria to be Settlement Only Resources, External Transactions, nuclear-powered Resources and photovoltaic Resources, all Resources must be Dispatchable Resources in the Energy Market and meet the technical specifications in ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18 for dispatchability.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market because the Resource is not connected to a remote terminal unit meeting the requirements of ISO New England Operating Procedure No. 18 shall take the following steps:

1. By January 15, 2017, the Market Participant shall submit to the ISO a circuit order form for the primary and secondary communication paths for the remote terminal unit.
2. The Market Participant shall work diligently with the ISO to ensure the Resource is able to receive and respond to electronic Dispatch Instructions within twelve months of the circuit order form submission.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market by the deadline set forth above shall provide the ISO with a written plan for remedying the deficiencies, and shall identify in the plan the specific actions to be taken and a reasonable timeline for rendering the Resource dispatchable. The Market Participant shall complete the remediation in accordance with and under the timeline set forth in the written plan. Until a Resource is dispatchable, it may only be Self-Scheduled in the Real-Time Energy Market and shall otherwise be treated as a Non-Dispatchable Resource.

Dispatchable Resources in the Energy Market are subject to the following requirements:

(a) The ISO shall optimize the dispatch of energy from Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources consistent with the dynamic load-following requirements of the New England Control Area and the availability of other Resources to the ISO.

(b) The ISO shall implement the dispatch of energy from Dispatchable Resources and the designation of Real-Time Operating Reserve to Dispatchable Resources, including the dispatchable portion of Resources which are otherwise Self-Scheduled, by sending appropriate signals and instructions to the entity controlling such Resources. Each Market Participant shall ensure that the entity controlling a Dispatchable Resource offered or made available by that Market Participant complies with the energy dispatch signals and instructions transmitted by the ISO.

(c) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed, and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(d) Market Participants shall exert all reasonable efforts to operate, or ensure the operation of, their Dispatchable Resources in the New England Control Area as close to dispatched output, consumption or demand reduction levels as practical, consistent with Good Utility Practice.

(e) Settlement Only Resources are not eligible to be DNE Dispatchable Generators.

Wind and hydro Intermittent Power Resources that are not Settlement Only Resources are required to receive and respond to Do Not Exceed Dispatch Points, except as follows:

(i) A wind or hydro Intermittent Power Resource not capable of receiving and responding to electronic Dispatch Instructions will be manually dispatched.

(ii) A Market Participant may elect, but is not required, to have a wind or hydro Intermittent Power Resource that is less than 5 MW and is connected through transmission facilities rated at less than 115 kV be dispatched as a DNE Dispatchable Generator.

(iii) A Market Participant with a hydro Intermittent Power Resource that is able to operate within a dispatchable range and is capable of responding to Dispatch Instructions to increase or decrease output within its dispatchable range may elect to have that resource dispatched as a DDP Dispatchable Resource.

(f) The ISO may request that dual-fuel Generator Assets that normally burn natural gas voluntarily take all necessary steps (within the limitations imposed by the operating limitations of their installed equipment and their environmental and operating permits) to prepare to switch to secondary fuel in anticipation of natural gas supply shortages. The ISO may request that Market Participants with dual-fuel Generator Assets that normally burn natural gas voluntarily switch to a secondary fuel in anticipation of natural gas supply shortages. The ISO may communicate with Market Participants with dual-fuel Generator Assets that normally burn natural gas to verify whether the Market Participants have switched or are planning to switch to an alternate fuel.

III.1.11.4 Emergency Condition.

If the ISO anticipates or declares an Emergency Condition, all External Transaction sales out of the New England Control Area that are not backed by a Resource may be interrupted, in accordance with the ISO New England Manuals, in order to serve load and Operating Reserve in the New England Control Area.

III.1.11.5 Dispatchability Requirements for Intermittent Power Resources.

(a) Intermittent Power Resources that are Dispatchable Resources with Supply Offers that do not clear in the Day-Ahead Energy Market and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market at the Resource's Economic Minimum Limit in order to operate in Real-Time.

(b) Intermittent Power Resources that are not Settlement Only Resources, are not Dispatchable Resources, and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market with the Resource's Economic Maximum Limit and Economic Minimum Limit redeclared to the same value in order to operate in Real-Time. Redeclarations must be updated throughout the Operating Day to reflect actual operating capabilities.

III.1.11.6 Non-Dispatchable Resources.

Non-Dispatchable Resources are subject to the following requirements:

(a) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Non-Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(b) Market Participants with Non-Dispatchable Resources shall exert all reasonable efforts to operate or ensure the operation of their Resources in the New England Control Area as close to dispatched levels as practical when dispatched by the ISO for reliability, consistent with Good Utility Practice.

II.21 Rates and Charges

II.21.1 Regional Network Service: Each Transmission Customer which has a load in the New England Control Area and takes Regional Network Service for a month shall be subject to the applicable provisions of Part II.B. of this OATT and shall pay to the ISO for such month an amount equal to its Monthly Regional Network Load for the month times the applicable Local Network RNS Rate (except as provided for in Section II.21.3), and shall pay in addition any amount which it is required to pay for the service pursuant to Section II.18.3 and Schedules 13 and 14 of this OATT. It shall also be obligated to pay for any Direct Assignment Facilities and its share of any new facilities or upgrades required to provide the requested service including applicable study costs to the extent they are consistent with Commission policy and Schedules 11 and 12, and any ancillary service charges and other charges and/or costs required to be paid pursuant to the Transmission, Markets and Services Tariff. The applicable Local Network RNS Rate shall be the rate, determined in accordance with Schedule 9 to this OATT, which is applicable to (i) a delivery to load in the particular Local Network in which the load served by the Transmission Customer is located, or (ii) to the extent that the ISO, after consultation with the affected PTOs, at the request of a PTO who owns the Local Network where the Regional Network Load is located, recognizes Regional Network Load to be the responsibility of another PTO, the applicable Local Network RNS Rate shall be the Local Network RNS Rate of the PTO responsible for such Regional Network Load. In the event the Transmission Customer serves Regional Network Load located on more than one Local Network, the amount to be paid by it shall be separately computed for the Regional Network Load located on each Local Network.

II.21.2 Determination of Network Customer's Monthly Regional Network Load: Network Customer's "Monthly Regional Network Load" is its hourly load (including its designated Regional Network Load not physically interconnected with the PTF under Section II.18.3 of this OATT) coincident with the coincident aggregate load of all Network Customers served in each Local Network in the hour in which the coincident load is at its maximum for the month ("Monthly Peak"). For Regional Network Load located within the New England Control Area, the Monthly Regional Network Load of all Network Customers within a Local Network shall be calculated by the associated PTO. For Regional Network Load located outside of the New England Control Area, the Monthly Regional Network Load of all Network Customers shall be calculated by the associated PTO (in consultation with the ISO and the associated Balancing Authority).

II.21.3 Exception to Payment for Regional Network Service: Regional Network Service charges associated with an Electric Storage Facility's charging load: The applicable Local Network RNS Rate shall be reduced to zero for monthly Regional Network Load associated with the charging load of an Electric Storage Facility. The reduction to zero of the applicable Local Network RNS Rate shall only apply to the Schedule 9 charges. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market. The applicable Local Network RNS Rate will be applied to Electric Storage Facility charging load unless it is reported as described in (a) above and is providing one or more services as described in (b) above.

SCHEDULE 21 - LOCAL SERVICE

This Schedule 21 contains the main substantive provisions applicable to Local Service. It includes common PTO rates, terms and conditions for Local Point-to-Point Service and Local Network Service and PTO-specific Local Service Schedules. Retail service is not subject to this Schedule 21 unless specifically provided for in the PTO's Local Service Schedule. The rates, terms and conditions for interconnection service to generators with total generating capacity of greater than 20 MW are set forth in Schedule 22. The rates, terms and conditions for interconnection service to generators with total generating capacity of 20 MW and less are set forth in Schedule 23. To the extent applicable, the rates, terms and conditions for load interconnections are set forth under the PTO-specific Local Service Schedules.

All Transmission Customers taking Local Service shall be subject to and comply with the rates, terms and conditions of this Schedule 21 as well as any applicable Local Service Schedule. In the event of a conflict between any rate, term or condition in the Tariff and any rate, term or condition in this Schedule 21 and/or an applicable Local Service Schedule, the rate, term or condition in this Schedule 21 and/or the applicable Local Service Schedule shall govern.

The following NAESB WEQ Standards are hereby incorporated by reference in this Schedule 21 to the extent that the requirements therein apply to the PTOs:

- WEQ-000, Abbreviations, Acronyms, and Definition of Terms, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Oct. 4, 2012, Nov. 28, 2012 and Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);

- WEQ-001, Open Access Same-Time Information System (OASIS), OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013) excluding Standards 001-9.5, 001-10.5, 001-14.1.3, 001-15.1.2 and 001-106.2.5;

- WEQ-002, Open Access Same-Time Information System (OASIS) Business Practice Standards and Communication Protocols (S&CP), OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Nov. 28, 2012 and Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);

- WEQ-003, Open Access Same-Time Information System (OASIS) Data Dictionary Business Practice Standards, OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);

- WEQ-004, Coordinate Interchange, WEQ Version 003, July 31, 2012 (as modified by NAESB final actions ratified on December 28, 2012);

- WEQ-005,Area Control Error (ACE) Equation Special Cases, WEQ Version 003, July 31, 2012);
- WEQ-006, Manual Time Error Correction, WEQ Version 003, July 31, 2012;
- WEQ-007,Inadvertent Interchange Payback, WEQ Version 003, July 31, 2012;
- WEQ-008,Transmission Loading Relief (TLR) – Eastern Interconnection, WEQ Version 003, July 31, 2012 (with minor corrections applied November 28, 2012);
- WEQ-011, Gas / Electric Coordination, WEQ Version 003, July 31, 2012;
- WEQ-012, Public Key Infrastructure (PKI) WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on October 4, 2012);
- WEQ-013, Open Access Same-Time Information System (OASIS) Implementation Guide, OASIS Version 2.0, WEQ Version 003, July 31, 2012, as modified by NAESB final actions ratified on Dec. 28, 2012 (with minor corrections applied Nov. 26, 2013);
- WEQ-015, Measurement and Verification of Wholesale Electricity Demand Response, WEQ Version 003, July 31, 2012;
- WEQ-021, Measurement and Verification of Energy Efficiency Products, WEQ Version 003, July 31, 2012.

The PTOs will perform their functions under this Schedule 21 and the Local Service Schedules in a manner that is not inconsistent with the ISO's provision of regional service, administration of the regional markets, dispatch of resources, and operation of the New England Transmission System for purposes of reliability.

Pre-Confirmed Request: Is an OASIS transmission service request that commits the Transmission Customer to take and pay for the requested Local Point-to-Point Service upon acceptance on OASIS by the PTO that can provide the requested Local Point-to-Point Service.

Pre-RTO Local Service Agreements [1]: A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Firm or Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of their existing Local Service Agreement that was in effect prior to February 1, 2005

[1] LSAs as defined in Section II.1 of the OATT do not include Excepted Transaction Agreements under Attachments G-1, G-2 and G-3 of the OATT.

("Pre-RTO Local Service Agreement" as defined to Section II.1 of the OATT) shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21. Instead, the Transmission Customer shall contact the associated PTO to discuss and, if appropriate, modify its existing Pre-RTO Local Service Agreement.

A Transmission Customer who wishes to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of its existing Pre-RTO Local Service Agreement, shall contact the PTO to make arrangements to terminate the Transmission Customer's existing pre-RTO Local Service Agreement and shall complete (and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

RTO Local Service Agreements: For Local Service Agreements with an effective date on or after February 1, 2005 (an "RTO Local Service Agreement" as defined to Section II.1 of the OATT) a Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of its existing Local Service Agreement under this Schedule 21, shall not be required to execute a new Local Service Agreement under this Schedule 21, however, modifications to the Transmission Customer's existing Local Service Agreement may be required. Such modifications to an existing Local Service Agreement typically do not require an additional local or regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an application for Local Transmission Service that reflects the requested modifications to the Local Service Agreement to facilitate revision of its existing Schedule 21 Local Service Agreement. A Transmission Customer who wishes to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of its existing RTO Local Service Agreement, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing RTO Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) a new Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

Reservation Priority For Existing Firm Service Customers: Existing firm service customers (wholesale requirements and transmission only, with a contract term of five years or more), have the right to continue to take Local Service from the PTO when the contract expires, rolls over or is renewed. This transmission reservation priority is independent of whether the existing customer continues to purchase capacity and energy from the PTO or elects to purchase capacity and energy from another supplier. If at

the end of the contract term, the PTO's Local Network cannot accommodate all of the requests for Local Service, the existing firm service customer must agree to accept a contract term at least equal to a competing request by any new Eligible Customer and to pay the current just and reasonable rate, as approved by the Commission, for such service; provided that, the firm service customer shall have a right of first refusal at the end of such service only if the new contract is for five years or more. The existing firm service customer must provide notice to the PTO whether it will exercise its right of first refusal no less than one year prior to the expiration date of its Local Service Agreement. This transmission reservation priority for existing firm service customers is an ongoing right that may be exercised at the end of all firm contract terms of five years or longer. Local Service Agreements subject to a right of first refusal entered into prior to the date of the PTOs' filing adopting the reformed rollover language herein in compliance with Order No. 890 or associated with a transmission service request received prior to July 13, 2007, unless terminated, will become subject to the five year/one year requirement on the first rollover date after the date of the PTOs' filing adopting the reformed rollover language herein in compliance with Order No. 890; provided that, the one year notice requirement shall apply to such service agreements with five years or more left in their terms as of the date of the PTOs' filing adopting the reformed rollover language herein in compliance with Order No. 890.

FERC: The Federal Energy Regulatory Commission.

Force Majeure: Neither the ISO, a Transmission Owner nor a Customer will be considered in default as to any obligation under the Tariff if prevented from fulfilling the obligation due to an event of Force Majeure; provided that no event of Force Majeure affecting any entity shall excuse that entity from making any payment that it is obligated to make hereunder or under a Service Agreement. However, an entity whose performance under the Tariff is hindered by an event of Force Majeure shall make all reasonable efforts to perform its obligations under the Tariff, and shall promptly notify the ISO, the Transmission Owner or the Customer, whichever is appropriate, of the commencement and end of each event of Force Majeure.

Liability: The ISO shall not be liable for money damages or other compensation to the Customer for actions or omissions by the ISO in performing its obligations under the Tariff or any Service Agreement thereunder, except to the extent such act or omission by the ISO is found to result from its gross negligence or willful misconduct. A Transmission Owner shall not be liable for money damages or other compensation to the Customer for action or omissions by such Transmission Owner in performing its obligations under the Tariff or any Service Agreement thereunder, except to the extent such act or

omission by such Transmission Owner is found to result from it gross negligence or willful misconduct. To the extent the Customer has claims against the ISO or a Transmission Owner, the Customer may only look to the assets of the ISO or a Transmission Owner (as the case may be) for the enforcement of such claims and may not seek to enforce any claims against the directors, members, shareholders, officers, employees or agents of the ISO or a Transmission Owner or Affiliate of either who, the Customer acknowledges and agrees, have no personal or other liability for obligations of the ISO or a Transmission Owner by reason of their status as directors, members, shareholders, officers, employees or agents of the ISO or a Transmission Owner or Affiliate of either. In no event shall the ISO, a Transmission Owner or any Customer be liable for any incidental, consequential, multiple or punitive damages, loss of revenues or profits, attorneys fees or costs arising out of, or connected in any way with the performance or non-performance under the Tariff or any Service Agreement thereunder. Notwithstanding the foregoing, nothing in this section shall diminish a Customer's obligations under Section I.5.3 of the Tariff or under Schedule 21 of the OATT.

Indemnification: Each Customer shall at all times indemnify, defend, and save harmless the ISO and the Transmission Owners and their respective directors, officers, members, employees and agents from any and all damages, losses, claims and liabilities by or to third parties arising out of or resulting from the performance by the ISO or Transmission Owners under the Tariff or any Service Agreement thereunder, any bankruptcy filings made by a Customer, or the actions or omissions of the Customer in connection with the Tariff or any Service Agreement thereunder, except in case of the ISO, gross negligence or willful misconduct by the ISO or its directors, officers, members, employees or agents, and, in the case of a Transmission Owner, the gross negligence or willful misconduct by such Transmission Owner or its directors, officers, members, employees or agents. The amount of any indemnity payment hereunder shall be reduced (including, without limitation, retroactively) by any insurance proceeds or other amounts actually recovered by the indemnified party in respect of the indemnified action, claim, demand, cost, damage or liability. The obligations of each Customer to indemnify the ISO and Transmission Owners shall be several, and not joint or joint and several.

Interruption: A reduction in non-firm transmission service due to economic reasons pursuant to Section I. 2 g).

Local Network Upgrade: Modifications or additions to the Local Network of a PTO, made in accordance with this Schedule 21, that are not Direct Assignment Facilities.

I. LOCAL POINT-TO-POINT SERVICE

Preamble

Eligible Customers seeking Local Point-To-Point Service on a specific Local Network shall refer to the applicable Local Service Schedule to determine any PTO-specific rates, terms, and conditions applicable to such service. Except as otherwise provided in the Local Service Schedules, Firm and Non-Firm Local Point-To-Point Service will be provided pursuant to the rates, terms and conditions set forth below. Local Point-To-Point Service is for the receipt of capacity and/or energy at designated Point(s) of Receipt and the transfer of such capacity and energy to designated Point(s) of Delivery.

A Local Point-To-Point Service Customer is not excused from any requirements of state law, or any order or regulation issued pursuant to state law, to arrange for Local Delivery Service with the PTO and distribution company providing such service and to pay all applicable charges associated with such service, including charges for stranded costs.

1) Nature of Firm Local Point-To-Point Service

a) Term: The minimum term of Firm Local Point-To-Point Service shall be one day and the maximum term shall be specified in the Local Service Agreement.

b) Reservation Priority: Local Long-Term Firm Point-To-Point Service shall be available on a first-come, first-served basis, i.e., in the chronological sequence in which each Transmission Customer has reserved service. Reservations for Local Short-Term Firm Point-To-Point Service will be conditional based upon the length of the requested transaction. However, Pre-Confirmed Requests for Local Short-Term Point-to-Point Service will receive priority over earlier-submitted requests that are not pre-confirmed and that have equal or shorter duration. Among requests with the same duration and, as relevant, pre-confirmation status (pre-confirmed or not pre-confirmed), priority will be given to a Transmission Customer's request that offers the highest price, followed by the date and time of the request. If the Local Network becomes oversubscribed, requests for service may preempt competing reservations up to the following conditional reservation deadlines: one day before the commencement of daily service, one week before the commencement of weekly service, and one month before the commencement of monthly service. Before the conditional reservation deadline, if available transfer capability is insufficient to satisfy all requests and reservations, a Transmission Customer with a reservation for shorter term service or equal duration service and lower price has the right of first refusal

to match any longer term request or equal duration service with a higher price before losing its reservation priority. A longer term competing request for Local Short-Term Firm Point-To-Point Service will be granted if the Transmission Customer with the right of first refusal does not agree to match the competing request within 24 hours (or earlier if necessary to comply with the scheduling deadlines provided in Section I.1.h of this Schedule 21) from being notified by the PTO of a longer-term competing request for Local Short-Term Firm Point-To-Point Service. When a longer duration request preempts multiple shorter duration reservations, the shorter duration requests shall have simultaneous opportunities to exercise the right of first refusal. Duration, price and time of response will be used to determine the order by which the multiple shorter duration reservations will be able to exercise the right of first refusal. After the conditional reservation deadline, service will commence pursuant to the terms of this Schedule 21. Firm Local Point-To-Point Service will always have a reservation priority over Non-Firm Local Point-To-Point Service under the Tariff. All Local Long-Term Firm Point-To-Point Service will have equal reservation priority with Native Load Customers and Network Customers. Reservation priorities for existing firm service customers are provided in the Local Service Schedules of this Schedule 21.

c) Use of Firm Local Point-to-Point Service by the PTO: The PTO will be subject to the rates, terms and conditions of this Schedule 21 when making Third-Party Sales under agreements executed on or after the effective date of the Tariff. The PTO will maintain separate accounting for any use of the Local Point-To-Point Service to make Third-Party Sales.

d) Service Agreements: After consultation with the PTO, the ISO shall forward a standard form of Local Service Agreement (Attachment A to this Schedule 21) to an Eligible Customer after an Eligible Customer submits a Completed Application for Local Point-To-Point Service to the ISO. Local Service Agreements executed by the Eligible Customer that contain the information required under this Schedule 21 shall also be executed by the PTO and returned to the ISO for execution and filing and/or reporting by the ISO with the Commission in compliance with applicable Commission regulations. An Eligible Customer that uses Local Point-to-Point Service at a Point of Receipt or Point of Delivery that it has not reserved and that has not executed a Local Service Agreement will be deemed, for purposes of assessing any appropriate charges and penalties, to have executed the appropriate Local Service Agreement.

e) Transmission Customer Obligations for Facility Additions Costs: In cases where the PTO, in consultation with the ISO, determines that the Local Network is not capable of providing Firm Local Point-To-Point Service without (1) degrading or impairing the reliability of service to Native Load Customers, Network Customers and other Transmission Customers taking Firm Local Point-To-Point

Service, or (2) interfering with the PTO's ability to meet prior firm contractual commitments to others, the PTO will be obligated to expand or upgrade its Local Network pursuant to the terms of Section I.3.d of this Schedule 21. The Transmission Customer must agree to compensate the PTO for any necessary transmission facility additions pursuant to the terms of Section I.14 of this Schedule 21. Any Local Network Upgrade or Direct Assignment Facilities costs to be charged to the Transmission Customer on an incremental basis under the Tariff will be specified in the Local Service Agreement prior to initiating service.

f) Curtailment of Firm Local Point-To-Point Service: In the event that a Curtailment on the PTO's Local Network, or a portion thereof, is required to maintain reliable operation of such system, Curtailments will be made on a non-discriminatory basis to the transaction(s) that effectively relieve the constraint. If multiple transactions require Curtailment, to the extent practicable and consistent with Good Utility Practice, the PTO will curtail service to Network Customers and Transmission Customers taking Firm Local Point-To-Point Service on a basis comparable to the curtailment of service to the PTO's Native Load Customers. All Curtailments will be made on a non-discriminatory basis, however, Non-Firm Local Point-To-Point Service shall be subordinate to Firm Local Point-To-Point Service and Local Network Service. When the PTO determines that an electrical emergency exists on the Non-PTF and the PTO implements emergency procedures to Curtail Firm Local Service, the Transmission Customer shall make the required reductions upon request of the PTO. The PTO reserves the right to Curtail, in whole or in part, any Local Service when, in the PTO's sole discretion, an emergency or other unforeseen condition impairs or degrades the reliability of its Local Network. The PTO will notify all affected Transmission Customers in a timely manner of any scheduled Curtailments. Penalties for failure to Curtail shall be assessed pursuant to the applicable Local Service Schedule.

g) Classification of Firm Local Point-To-Point Service:

(i) The Transmission Customer taking Firm Local Point-To-Point Service may (1) change its Receipt and Delivery Points to obtain service on a non-firm basis consistent with the terms of Section I.10.a of this Schedule 21 or (2) request a modification of the Points of Receipt or Delivery on a firm basis pursuant to the terms of Section I.10.b of this Schedule 21.

(ii) The Transmission Customer may purchase transmission service to make sales of capacity and energy from multiple generating units that are on the PTO's Local Network. For such a purchase of transmission service, the resources will be designated as multiple Points of Receipt,

unless the multiple generating units are at the same generating plant in which case the units would be treated as a single Point of Receipt.

(iii) The PTO shall provide firm deliveries of capacity and energy from the Point(s) of Receipt to the Point(s) of Delivery. For Long-Term Firm Point-To-Point Service, each Point of Receipt at which firm transfer capability is reserved by the Transmission Customer shall be set forth in the Local Service Agreement along with a corresponding capacity reservation associated with each Point of Receipt. For Short-Term Firm Point-To-Point Service, Points of Receipt and corresponding capacity reservations shall be as mutually agreed upon by the Parties. For Long-Term Firm Point-To-Point Service, each Point of Delivery at which firm transfer capability is reserved by the Transmission Customer shall be set forth in the Service Agreement along with a corresponding capacity reservation associated with each Point of Delivery. For Short-Term Firm Point-To-Point Service, Points of Delivery and corresponding capacity reservations shall be as mutually agreed upon by the Parties. The greater of either (1) the sum of the capacity reservations at the Point(s) of Receipt, or (2) the sum of the capacity reservations at the Point(s) of Delivery shall be the Transmission Customer's Reserved Capacity. The Transmission Customer will be billed for its Reserved Capacity under the terms of the applicable Local Service Schedule. The Transmission Customer may not exceed its firm capacity reserved at each Point of Receipt and each Point of Delivery except as otherwise specified in the applicable Local Service Schedule. The Local Service Schedule shall specify the rate treatment and all related terms and conditions applicable in the event that a Transmission Customer (including Third-Party Sales by the PTO) exceeds its firm reserved capacity at any Point of Receipt or Point of Delivery or uses Local Point-to-Point Service at a Point of Receipt or Point of Delivery that it has not reserved.

h) Scheduling of Firm Local Point-To-Point Service: Schedules for the Transmission Customer's Firm Local Point-To-Point Service must be submitted to the PTO no later than 10:00 a.m. of the day prior to commencement of such service. Schedules submitted after 10:00 a.m. will be accommodated, if practicable. Hour-to-hour schedules of any capacity and energy that is to be delivered must be stated in increments of 10 kW per hour. Transmission Customers within the PTO's service area with multiple requests for Transmission Service at a Point of Receipt, each of which is under 10 kW per hour, may consolidate their service requests at a common point of receipt into units of 10 kW per hour for scheduling and billing purposes. Scheduling changes will be permitted up to twenty (20) minutes before the start of the next clock hour provided that the Delivering Party and Receiving Party also agree to the schedule modification. The PTO will furnish hour-to-hour schedules equal to those furnished by the

Receiving Party (unless reduced for losses) and shall deliver the capacity and energy provided by such schedules. Should the Transmission Customer, Delivering Party or Receiving Party revise or terminate any schedule, such party shall immediately notify the PTO, and the PTO shall have the right to adjust accordingly the schedule for capacity and energy to be received and to be delivered.

2) Nature of Non-Firm Local Point-To-Point Service

a) Term: Non-Firm Local Point-To-Point Service will be available for periods ranging from one (1) hour to one (1) month. However, a purchaser of Non-Firm Local Point-To-Point Service will be entitled to reserve a sequential term of service (such as a sequential monthly term without having to wait for the initial term to expire before requesting another monthly term) so that the total time period for which the reservation applies is greater than one month, subject to the requirements of Section I.6.c of this Schedule 21.

b) Reservation Priority: Non-Firm Local Point-To-Point Service shall be available from transfer capability in excess of that needed for reliable service to Native Load Customers, Network Customers, Excepted Transactions and other Transmission Customers taking Local Long-Term and Local Short-Term Firm Point-To-Point Service. Individual Local Service Schedules may contain other applicable services. A higher priority will be assigned first to requests or reservations with a longer duration of service and second to Pre-Confirmed Requests. In the event the Local Network is constrained, competing requests of the same pre-confirmation status and equal duration will be prioritized based on the highest price offered by the Transmission Customer for the Transmission Service, or in the event the price for all Transmission Customers is the same, will be prioritized on a first-come, first-served basis, i.e., in the chronological sequence in which each customer has requested service. Transmission Customers that have already reserved shorter term service have the right of first refusal to match any longer term request before being preempted. A longer term competing request for Non-Firm Local Point-To-Point Service will be granted if the Transmission Customer with the right of first refusal does not agree to match the competing request: (a) immediately for hourly Non-Firm Local Point-To-Point Service after notification by the PTO; and, (b) within 24 hours (or earlier if necessary to comply with the scheduling deadlines provided in Section I.2.f of this Schedule 21) for Non-Firm Local Point-To-Point Service other than hourly transactions after notification by the PTO. Non-Firm Local Point-To-Point Service over secondary Point(s) of Receipt and Point(s) of Delivery will have the lowest reservation priority under the OATT.

c) Use of Non-Firm Local Point-To-Point Service by the PTO: The PTO will be subject to the rates, terms and conditions of this Schedule 21 when making Third-Party Sales under (i) agreements executed on or after the effective date of the Tariff. The PTO will maintain separate accounting for any use of Non-Firm Local Point-To-Point Service to make Third-Party Sales.

d) Service Agreements: After consultation with the PTO, the ISO shall forward a standard form of Local Service Agreement (Attachment A to this Schedule 21) to an Eligible Customer after an Eligible Customer submits a Completed Application for Local Point-To-Point Service to the ISO. Local Service Agreements executed by the Eligible Customer that contain the information required under this Schedule 21 shall also be executed by the PTO and returned to the ISO for execution and filing and/or reporting by the ISO with the Commission in compliance with applicable Commission regulations. An Eligible Customer that uses Local Point-to-Point Service at a Point of Receipt or Point of Delivery that it has not reserved and that has not executed a Local Service Agreement will be deemed, for purposes of assessing any appropriate charges and penalties, to have executed the appropriate Local Service Agreement.

e) Classification of Non-Firm Local Point-To-Point Service: The PTO and the ISO undertake no obligation under the Tariff to plan the Local Network in order to have sufficient capacity for Non-Firm Local Point-To-Point Service. Parties requesting Non-Firm Local Point-To-Point Service for the transmission of firm power do so with the full realization that such service is subject to availability and to Curtailment or Interruption under the terms of the Tariff. The Local Service Schedules shall specify the rate treatment and all related terms and conditions applicable in the event that a Transmission Customer (including Third-Party Sales by the PTO) exceeds its non-firm capacity reservation. Non-Firm Local Point-To-Point Service shall include transmission of energy on an hourly basis and transmission of scheduled short-term capacity and energy on a daily, weekly or monthly basis, but not to exceed one month's reservation for any one Application.

f) Scheduling of Non-Firm Local Point-To-Point Service: Schedules for Non-Firm Local Point-To-Point Service must be submitted to the PTO no later than 2:00 p.m. of the day prior to commencement of such service. Schedules submitted after these times will be accommodated, if practicable. Hour-to-hour schedules of energy that is to be delivered must be stated in increments of 10 kW per hour. Transmission Customers within the PTO's service area with multiple requests for Transmission Service at a Point of Receipt, each of which is under 10 kW per hour, may consolidate their schedules at a common Point of Receipt into units of 10 kW per hour. Scheduling changes will be permitted up to twenty (20) minutes before the start of the next clock hour provided that the Delivering Party and Receiving Party

also agree to the schedule modification. The PTO will furnish hour-to-hour schedules equal to those furnished by the Receiving Party (unless reduced for losses) and shall deliver the capacity and energy provided by such schedules. Should the Transmission Customer, Delivering Party or Receiving Party revise or terminate any schedule, such party shall immediately notify the PTO and the PTO shall have the right to adjust accordingly the schedule for capacity and energy to be received and to be delivered.

g) Curtailment or Interruption of Service: The PTO reserves the right to Curtail, in whole or in part, Non-Firm Local Point-To-Point Service provided under the Tariff for reliability reasons when, an emergency or other unforeseen condition threatens to impair or degrade the reliability of the Local Network. The PTO reserves the right to Interrupt, in whole or in part, Non-Firm Local Point-To-Point Service provided under the Tariff for economic reasons in order to accommodate (1) a request for Firm Local Transmission Service, (2) a request for Non-Firm Local Point-To-Point Service of greater duration, (3) a request for Non-Firm Local Point-To-Point Service of equal duration with a higher price, or (4) transmission service for Network Customers from non-designated resources. The PTO also will discontinue or reduce service to the Transmission Customer to the extent that deliveries for transmission are discontinued or reduced at the Point(s) of Receipt. Where required, Curtailments or Interruptions will be made on a non-discriminatory basis to the transaction(s) that effectively relieve the constraint, however, Non-Firm Local Point-To-Point Service shall be subordinate to Firm Local Transmission Service. If multiple transactions require Curtailment or Interruption, to the extent practicable and consistent with Good Utility Practice, Curtailments or Interruptions will be made to transactions of the shortest term (e.g., hourly non-firm transactions will be Curtailed or Interrupted before daily non-firm transactions and daily non-firm transactions will be Curtailed or Interrupted before weekly non-firm transactions). Transmission service for Network Customers from resources other than designated Network Resources will have a higher priority than any Non-Firm Local Point-To-Point Service under the Tariff. Non-Firm Local Point-To-Point Service over secondary Point(s) of Receipt and Point(s) of Delivery will have a lower priority than any Non-Firm Local Point-To-Point Service under the Tariff. The PTO will provide advance notice of Curtailment or Interruption where such notice can be provided consistent with Good Utility Practice and in accordance with the applicable Local Service Schedule. Penalties for failure to Curtail or Interrupt shall be assessed pursuant to the applicable Local Service Schedule.

3) Service Availability

a) General Conditions: The PTO will provide Firm Local and Non-Firm Local Point-To-Point Service to any Transmission Customer that has met the requirements of Section I.4 of this Schedule 21.

b) Determination of Available Transfer Capability: The PTO shall determine available transfer capability in accordance with its respective Attachment setting forth its Methodology to Assess Available Transfer Capability.

c) Initiating Service in the Absence of an Executed Service Agreement: If the PTO and the Transmission Customer requesting Firm Local or Non-Firm Local Point-To-Point Service cannot agree on all of the terms and conditions of the Local Service Agreement, the ISO shall file with the Commission, within thirty (30) days after the date the Transmission Customer provides written notification to both the PTO and the ISO directing the ISO to file, an unexecuted Local Service Agreement containing terms and conditions deemed by the PTO (in consultation with the ISO) to be appropriate for such requested service. The PTO shall commence providing Transmission Service subject to the Transmission Customer agreeing to (i) compensate the PTO at whatever rate the Commission ultimately determines to be just and reasonable, and (ii) comply with the terms and conditions of the Tariff including posting appropriate security deposits in accordance with the terms of Section I.5.c of this Schedule 21.

d) Obligation to Provide Transmission Service that Requires Expansion or Modification of the Local Network: If the PTO, in consultation with the ISO, determines that a Completed Application for Firm Local Point-To-Point Service cannot be accommodated because of insufficient capability on the Local Network, the PTO will use due diligence to expand or modify its Local Network to provide the requested Firm Local Point-To-Point Service, consistent with its planning obligations in Attachment K, provided the Transmission Customer agrees to compensate the PTO for such costs. The PTO, in consultation with the ISO, will conform to Good Utility Practice and its planning obligations in Attachment K, in determining the need for new facilities and in the design and construction of such facilities. The obligation of the PTO to expand or modify its Local Network obligation to provide the requested Firm Local Point-To-Point Service applies only to those facilities that the PTO has the right to expand or modify.

e) Deferral of Service: The PTO may defer providing service until it completes construction of new transmission facilities or upgrades needed to provide Firm Local Point-To-Point Service whenever

the PTO determines that providing the requested service would, without such new facilities or upgrades, impair or degrade reliability to any existing firm services.

f) Other Transmission Service Schedules: Eligible Customers receiving transmission service under other agreements on file with the Commission may continue to receive transmission service under those agreements until such time as those agreements may be modified by the Commission.

g) Real Power Losses: "Real Power Losses" those losses associated with transmission service as determined in accordance with Section 15.3, Section 31.6 and Schedule 21 of the OATT. Neither the ISO nor the PTOs are obligated to provide Real Power Losses. Non-PTF Real Power Losses shall be calculated and charged for in accordance with the applicable Schedule 21 Local Service Schedule.

h) Load Shedding: Load Shedding shall occur in accordance with the applicable Local Service Schedule to the extent provided for in such Local Service Schedule.

4) Transmission Customer Responsibilities

a) Conditions Required of Transmission Customers: Firm Local and Non-Firm Local Point-To-Point Service shall be provided only if the following conditions are satisfied by the Transmission Customer:

(i) The Transmission Customer has pending a Completed Application for service;

(ii) The Transmission Customer meets the creditworthiness procedures in Attachment L to the applicable PTO's Local Service Schedule;

(iii) The Transmission Customer will have arrangements in place for any other transmission service necessary to effect the delivery from the generating source to the PTO prior to the time service commences;

(iv) The Transmission Customer agrees to pay for any facilities constructed and chargeable to such Transmission Customer, whether or not the Transmission Customer takes service for the full term of its reservation;

(v) The Transmission Customer provides the information required by the PTO's planning process established in Attachment K; and

(vi) The Transmission Customer has executed a Local Service Agreement or has requested the filing of an unexecuted Local Service Agreement pursuant to Section I.3.c of this Schedule 21.

b) Transmission Customer Responsibility for Third-Party Arrangements: Any scheduling arrangements that may be required by other electric systems shall be the responsibility of the Eligible Customer requesting service. The Transmission Customer shall provide, unless waived by the ISO and the PTO, notification to the ISO and the PTO identifying such systems and authorizing them to schedule the capacity and energy to be transmitted pursuant to this Schedule 21 on behalf of the Receiving Party at the Point of Delivery or the Delivering Party at the Point of Receipt. However, the ISO and the PTO will undertake reasonable efforts to assist the Transmission Customer in making such arrangements, including without limitation, providing any information or data required by such other electric system pursuant to Good Utility Practice.

5) Procedures for Arranging Firm Local Point-To-Point Service

a) Pre-RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, or make upgrades (i.e., increase MWs served) within the terms of its existing Firm Local Point-to-Point Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Firm Local Point-to-Point Service Agreement may be required. Instead, the Transmission Customer shall contact the associated PTO to discuss and, if appropriate, modify its existing Firm Local Point-to-Point Service Agreement.

(ii) A Transmission Customer who wishes to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of its existing Firm Local Point-to-Point Service Agreement, shall contact the PTO to make arrangements to terminate the Transmission Customer's existing Local Service Agreement and shall complete

(and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

b) RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, or make upgrades (i.e., increase MWs served) within the terms of the existing Firm Local Point-to-Point Service Agreement under this Schedule 21, shall not be required to execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Firm Local Point-to-Point Service Agreement under this Schedule 21 may be required. Such modifications to an existing Local Service Agreement typically do not require an additional local or regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an application for Local Transmission Service that reflects the requested modifications to the Local Service Agreement to facilitate revision of its existing Schedule 21 Local Service Agreement.

(ii) Transmission Customers who wish to request an alternate Firm Point of Receipt or Point of Delivery or make upgrades (i.e., increase MWs served) beyond the terms of the existing Firm Local Point-to-Point Service Agreement under this Schedule 21, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) an Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

c) Application: A request for Firm Local Point-To-Point Service for periods of one year or longer must be made in a completed Application submitted to the ISO at least sixty (60) days in advance of the calendar month in which service is to commence. The PTO will consider requests for such firm service on shorter notice when feasible. Requests for firm service for periods of less than one year shall be subject to expedited procedures that shall be negotiated between the PTO and the Eligible Customer within the time constraints provided in the applicable Local Service Schedule. A Completed Application may be submitted by transmitting the required information to the ISO by telefax. This method will provide a time-stamped record for establishing the priority of the Application.

d) Completed Application: A Completed Application shall provide all of the information included in 18 C.F.R. § 2.20 including but not limited to the following:

(i) The identity, address, telephone number and facsimile number of the entity requesting service;

(ii) A statement that the entity requesting service is, or will be upon commencement of service, an Eligible Customer under the Tariff;

(iii) The location of the Point(s) of Receipt and Point(s) of Delivery and the identities of the Delivering Parties and the Receiving Parties;

(iv) The location of the generating facility(ies) supplying the capacity and energy and the location of the load ultimately served by the capacity and energy transmitted. The ISO and the PTO will treat this information as confidential except to the extent that disclosure of this information is required by the Tariff, by regulatory or judicial order, for reliability purposes pursuant to Good Utility Practice or pursuant to the Information Policy;

(v) A description of the supply characteristics of the capacity and energy to be delivered;

(vi) An estimate of the capacity and energy expected to be delivered to the Receiving Party;

(vii) The Service Commencement Date and the term of the requested Transmission Service;

(viii) The transmission capacity requested for each Point of Receipt and each Point of Delivery on the PTO's Local Network; customers may combine their requests for service in order to satisfy the minimum transmission capacity requirement;

(ix) A statement indicating that if the Transmission Customer submits a Pre-Confirmed Request, then the Transmission Customer will take and pay for the requested Local Service upon acceptance on OASIS by the PTO that can provide the requested Local Service; and

(x) Any additional information required by the PTO’s planning process established in Attachment K.

The ISO and the PTO shall treat this information consistent with the standards of conduct contained in Part 37 of the Commission's regulations.

e) Deposit: Except as is otherwise provided in the Local Service Schedule, a Completed Application for Firm Local Point-To-Point Service also shall include a deposit of either one month's charge for Reserved Capacity or the full charge for Reserved Capacity for service requests of less than one month. If the Application is rejected because it does not meet the conditions for service as set forth herein, in the Local Service Schedule or, in the case of requests for service arising in connection with losing bidders, in a Request For Proposals (RFP), said deposit shall be returned with interest less any reasonable costs incurred by the PTO in connection with the review of the losing bidder's Application. The deposit also will be returned with interest less any reasonable costs incurred by the PTO if the PTO is unable to complete new facilities needed to provide the service. If an Application is withdrawn or the Eligible Customer decides not to enter into a Local Service Agreement for Firm Local Point-To-Point Service, the deposit shall be refunded in full, with interest, less reasonable costs incurred by the PTO to the extent such costs have not already been recovered by the PTO from the Eligible Customer. The PTO will provide to the Eligible Customer a complete accounting of all costs deducted from the refunded deposit, which the Eligible Customer may contest if there is a dispute concerning the deducted costs. Deposits associated with construction of new facilities are subject to the provisions of Section I.5.c of this Schedule 21. If a Local Service Agreement for Firm Local Point-To-Point Service is executed, the deposit, with interest, will be returned to the Transmission Customer upon expiration or termination of the Local Service Agreement. Applicable interest shall be computed in accordance with the Commission's regulations at 18 C.F.R. § 35.19a(a)(2)(iii), and shall be calculated from the day the deposit check is credited to the PTO's account.

f) Notice of Deficient Application: If an Application fails to meet the requirements of the Tariff, the PTO shall notify the ISO within ten (10) days of the Application’s receipt of the reasons for such failure, and the ISO shall, in turn, so notify the entity requesting service within five (5) days of the receipt of notice from the PTO of the reasons for such failure. The PTO will attempt to remedy minor deficiencies in the Application through informal communications with the Eligible Customer. If such efforts are unsuccessful, the ISO shall return the Application. The PTO shall return any deposit, with interest, to the Eligible Customer. Upon receipt of a new or revised Application that fully complies with the requirements of this Schedule 21, the Eligible Customer shall be assigned a new priority consistent with the date of the new or revised Application.

g) Response to a Completed Application: Following receipt of a Completed Application for Firm Local Point-To-Point Service, the PTO shall make a determination of available transfer capability as required in Section I.3.b of this Schedule 21. Within twenty-five (25) days after the date of receipt of a Completed Application, the PTO shall notify the ISO either (i) if it will be able to provide service without performing a System Impact Study or (ii) if such a study is needed to evaluate the impact of the Application. The ISO shall so notify the Eligible Customer within five (5) days of the ISO's receipt of such notice from the PTO. Responses by the PTO and the ISO must be made as soon as practicable to all Completed Applications and the timing of such responses must be made on a non-discriminatory basis.

h) Execution of Service Agreement: Whenever the PTO, in consultation with the ISO, determines that a System Impact Study is not required and that the service can be provided, it shall notify the Eligible Customer as soon as practicable but no later than thirty (30) days after receipt of the Completed Application. Where a System Impact Study is required, the provisions of Section I.7 of this Schedule 21 will govern the execution of a Local Service Agreement. Failure of an Eligible Customer to execute and return the Local Service Agreement or request the filing of an unexecuted service agreement pursuant to Section I.3.c of this Schedule 21 within fifteen (15) days after the Local Service Agreement is tendered will be deemed a withdrawal and termination of the Application and any deposit submitted shall be refunded with interest. Nothing herein limits the right of an Eligible Customer to file another Application after such withdrawal and termination.

i) Extensions for Commencement of Service: The Transmission Customer can obtain, subject to availability, up to five (5) one-year extensions for the commencement of service. The Transmission Customer may postpone service by paying to the PTO a non-refundable annual reservation fee equal to one-month's charge for Firm Local Point-To-Point Service for each year or fraction thereof within 15 days of notifying the PTO it intends to extend the commencement of service. If during any extension for the commencement of service an Eligible Customer submits a Completed Application for Firm Local Point-To-Point Service, and such request can be satisfied only by releasing all or part of the Transmission Customer's Reserved Capacity, the original Reserved Capacity will be released unless the following condition is satisfied. Within thirty (30) days, the original Transmission Customer agrees to pay the rate for its Reserved Capacity concurrent with the new Service Commencement Date. In the event the Transmission Customer elects to release the Reserved Capacity, the reservation fees or portions thereof previously paid will be forfeited.

6) Procedures for Arranging Non-Firm Local Point-To-Point Service

a) Pre-RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of their existing Non-Firm Local Point-to-Point Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Non-Firm Local Point-to-Point Service Agreement may be required. The Transmission Customer shall contact the associated PTO to discuss and, if appropriate, modify the existing Non-Firm Local Point-to-Point Service Agreement.

(ii) A Transmission Customer who wishes to make upgrades (i.e., increase MWs served) beyond the terms of its existing Non-Firm Local Point-to-Point Service Agreement that is in effect prior February 1, 2005 ("Pre-RTO Local Service Agreement"), shall contact the PTO to make arrangements to terminate the Transmission Customer's existing Local Service Agreement and shall complete (and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

b) RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Non-Firm Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of the existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21, shall not be required to execute a new Local Service Agreement under this Schedule 21, however, modifications to the existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21 may be required.

Such modifications to an existing Local Service Agreement typically do not require an additional local or regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an application for Local Transmission Service that reflects the

requested modifications to the Local Service Agreement to facilitate revision of its existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21.

(ii) A Transmission Customer who wishes to request an upgrade (i.e., increase MWs served) beyond the terms of the existing Non-Firm Local Point-to-Point Service Agreement under this Schedule 21, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) a new Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

c) Application: Eligible Customers seeking Non-Firm Local Point-To-Point Service must submit a Completed Application to the ISO. A Completed Application may be submitted by transmitting the required information to the ISO by telefax. This method will provide a time-stamped record for establishing the service priority of the Application.

d) Completed Application: A Completed Application shall provide all of the information included in 18 C.F.R. § 2.20 including but not limited to the following:

(i) The identity, address, telephone number and facsimile number of the entity requesting service;

(ii) A statement that the entity requesting service is, or will be upon commencement of service, an Eligible Customer under the Tariff;

(iii) The Point(s) of Receipt and the Point(s) of Delivery;

(iv) The maximum amount of capacity requested at each Point of Receipt and Point of Delivery; and

(v) The proposed dates and hours for initiating and terminating transmission service hereunder.

In addition to the information specified above, when required to properly evaluate system conditions, the ISO and the PTO also may ask the Transmission Customer to provide the following:

(vi) The electrical location of the initial source of the power to be transmitted pursuant to the Transmission Customer's request for service;

(vii) The electrical location of the ultimate load; and

(viii) A statement indicating that if the Transmission Customer submits a Pre-Confirmed Request, then the Transmission Customer will take and pay for the requested Local Point-to-Point Service upon acceptance on OASIS by the PTO that can provide the requested Local Service.

The ISO and the PTO will treat this information in (vi) and (vii) as confidential at the request of the Transmission Customer except to the extent that disclosure of this information is required by the Tariff, by regulatory or judicial order, for reliability purposes pursuant to Good Utility Practice, or pursuant to the ISO New England Information Policy. The ISO and the PTO shall treat this information consistent with the standards of conduct contained in Part 37 of the Commission's regulations.

e) Reservation of Non-Firm Local Point-To-Point Service: Requests for monthly service shall be submitted no earlier than sixty (60) days before service is to commence; requests for weekly service shall be submitted no earlier than fourteen (14) days before service is to commence, requests for daily service shall be submitted no earlier than two (2) days before service is to commence, and requests for hourly service shall be submitted no earlier than noon the day before service is to commence. Requests for service received later than 2:00 p.m. prior to the day service is scheduled to commence will be accommodated if practicable.

f) Determination of Available Transfer Capability: The PTO shall determine available transfer capability in accordance with its respective Attachment setting forth its Methodology to Assess Available Transfer Capability.

7) Additional Study Procedures For Firm Local Point-To-Point Service Requests

a) Notice of Need for System Impact Study: After receiving a request for Firm Local Point-To-Point Service, a determination shall be made on a non-discriminatory basis as to whether a System Impact Study is needed. The ISO shall review the request to determine whether the provision of the requested service would have an impact on facilities other than Non-PTF, and if so, whether a System Impact Study

is necessary to accommodate the requested service. If so, the ISO shall so inform the Eligible Customer as soon as practicable and will (in consultation with the PTO) perform a System Impact Study, as necessary, with respect to the request. A description of the ISO's methodology for completing a System Impact Study is provided in OATT Attachment D. If the ISO determines that the service would not have an impact on facilities other than Non-PTF, the PTO shall determine whether a System Impact Study is necessary to accommodate the requested service and shall so inform the Eligible Customer as soon as practicable and will (in consultation with the ISO) perform a System Impact Study, as necessary, with respect to the application. In such cases, the ISO or the PTO, as applicable, shall within thirty (30) days of receipt of a Completed Application, tender a System Impact Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the ISO or the PTO, as applicable, for performing the required System Impact Study. For a service request to remain a Completed Application, the Eligible Customer shall execute the System Impact Study Agreement and return it to the ISO or the PTO, as applicable, within fifteen (15) days. If the Eligible Customer elects not to execute the System Impact Study Agreement, its Application shall be deemed withdrawn and its deposit, pursuant to Section I.5.c of this Schedule 21, shall be returned with interest. A description of the PTO's methodology for completing a System Impact Study is provided in its Local Service Schedules.

b) System Impact Study Agreement and Cost Reimbursement:

(i) The System Impact Study Agreement will clearly specify an estimate of the cost and time for completion of the System Impact Study. The charge shall not exceed the actual cost of the study. The System Impact Study shall rely on existing transmission planning studies to the extent reasonably practicable. The Eligible Customer will not be assessed a charge for such existing studies; however, the Eligible Customer will be responsible for charges associated with any modifications to existing planning studies that are reasonably necessary to evaluate the impact of the Eligible Customer's request for service on the Local Network.

(ii) If in response to multiple Eligible Customers requesting service in relation to the same competitive solicitation, a single System Impact Study is sufficient to accommodate the requests for service, the costs of that study shall be pro-rated among the Eligible Customers.

(iii) For System Impact Studies that the PTO conducts on its own behalf, the PTO shall record the cost of the System Impact Studies pursuant to Section II.8.5 of the Tariff.

(iv) In response to multiple Eligible Customers within the same geographical or electrically interconnected area requesting that a System Impact Study for Local Service be clustered, the PTO will cluster such multiple requests if it can reasonably do so. The costs of that study shall be divided equally among the Eligible Customers, unless otherwise agreed to by the PTO and the Eligible Customers.

(v) Once a clustered study is initiated by the PTO, as evidenced by an executed System Impact Study Agreement, Eligible Customers opting out of a clustered study regarding Non-PTF facilities shall be liable for their share of the study costs as set forth in Section 7(b)(iv) above, unless otherwise agreed to by the parties to such System Impact Study Agreement.

c) System Impact Study Procedures: Upon receipt of an executed System Impact Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required System Impact Study within a sixty (60) day period. The System Impact Study shall identify any system constraints identified with specificity by a transmission element or flowgate, and additional Direct Assignment Facilities or Local Network Upgrades required to provide the requested service. In the event that the ISO or the PTO, as applicable, is unable to complete the required System Impact Study within such time period, it shall so notify the Eligible Customer and provide an estimated completion date along with an explanation of the reasons why additional time is required to complete the required studies. A copy of the completed System Impact Study and related work papers shall be made available to the Eligible Customer as soon as the System Impact Study is complete. The PTO will use the same due diligence in completing the System Impact Study for an Eligible Customer as it uses when completing studies for itself. The ISO or the PTO, as applicable, shall notify the Eligible Customer immediately upon completion of the System Impact Study if the Local Network will be adequate to accommodate all or part of a request for service or that no costs are likely to be incurred for new transmission facilities or upgrades. In order for a request to remain a Completed Application, within fifteen (15) days of completion of the System Impact Study, the Eligible Customer must execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement pursuant to Section I.3.c of this Schedule 21 or the Application shall be deemed terminated and withdrawn.

d) Facilities Study Procedures: If a System Impact Study indicates that additions or upgrades to facilities other than Non-PTF are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on the MTF facilities, the ISO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the

Eligible Customer shall agree to reimburse the ISO for performing the required Facilities Study. If a System Impact Study indicates that additions or upgrades to Non-PTF facilities are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on facilities other than Non-PTF, the PTO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the PTO for performing the required Facilities Study. For clustered studies, the cost of such studies shall be divided equally among the Eligible Customers, unless otherwise agreed to by the PTO and the Eligible Customers. Once a clustered study is initiated by the PTO, as evidenced by an executed Facilities Study Agreement, Eligible Customers opting out of a clustered study regarding Non-PTF facilities shall be liable for their share of the study costs as set forth in this Section 7(d) above, unless otherwise agreed to by the parties to such Facilities Study Agreement. For a service request to remain a Completed Application, the Eligible Customer shall execute the Facilities Study Agreement and return it within fifteen (15) days. If the Eligible Customer elects not to execute the Facilities Study Agreement, its Application shall be deemed withdrawn and its deposit, pursuant to Section I.5.c of this Schedule 21, shall be returned with interest. Upon receipt of an executed Facilities Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required Facilities Study within a sixty (60) day period. If the Facilities Study cannot be completed in the allotted time period, the Transmission Customer shall be notified and provided an estimate of the time needed to reach a final determination along with an explanation of the reasons that additional time is required to complete the study. When completed, the Facilities Study will include a good faith estimate of (i) the cost of Direct Assignment Facilities to be charged to the Transmission Customer, (ii) the Transmission Customer's appropriate share of the cost of any required Local Network Upgrades, and (iii) the time required to complete such construction and initiate the requested service. The Transmission Customer shall provide a letter of credit or other reasonable form of security acceptable to the PTO equivalent to the costs of new facilities or upgrades consistent with commercial practices as established by the Uniform Commercial Code. The Transmission Customer shall have thirty (30) days to execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement and provide the required letter of credit or other form of security or the request will no longer be a Completed Application and shall be deemed terminated and withdrawn.

e) Facilities Study Modifications: Any change in design arising from the inability to site or construct facilities as proposed will require development of a revised good faith estimate. New good faith estimates also will be required in the event of new statutory or regulatory requirements that are effective before the completion of construction or other circumstances beyond the control of the ISO and/or the

PTO that significantly affect the final cost of new facilities or upgrades to be charged to the Transmission Customer.

f) Due Diligence in Completing New Facilities: The PTO shall use due diligence to add necessary facilities or upgrade its Local Network within a reasonable time. The PTO will not upgrade its existing or planned Local Network in order to provide the requested Firm Local Point-To-Point Service if doing so would impair system reliability or otherwise impair or degrade existing firm service.

g) Partial Interim Service: If the PTO determines that it will not have adequate transfer capability to satisfy the full amount of a Completed Application for Firm Local Point-To-Point Service, the PTO nonetheless shall be obligated to offer and provide the portion of the requested Firm Local Point-To-Point Service that can be accommodated without addition of any facilities. However, the PTO shall not be obligated to provide the incremental amount of requested Firm Local Point-To-Point Service that requires the addition of facilities or upgrades to the Local Network until such facilities or upgrades have been placed in service.

h) Expedited Procedures for New Facilities: In lieu of the procedures set forth above, the Eligible Customer shall have the option to expedite the process by requesting the ISO (in consultation with the PTO) to tender at one time, together with the results of required studies, an "Expedited Local Service Agreement" pursuant to which the Eligible Customer would agree to compensate the PTO for all costs incurred. In order to exercise this option, the Eligible Customer shall request in writing an expedited Local Service Agreement covering all of the above-specified items within thirty (30) days of receiving the results of the System Impact Study identifying needed facility additions or upgrades or costs incurred in providing the requested service. While the PTO agrees to provide the Eligible Customer with its best estimate of the new facility costs and other charges that may be incurred, such estimate shall not be binding and the Eligible Customer must agree in writing to compensate the PTO for all costs incurred. The Eligible Customer shall execute and return such an Expedited Local Service Agreement within fifteen (15) days of its receipt or the Eligible Customer's request for service will cease to be a Completed Application and will be deemed terminated and withdrawn.

i) Penalties for Failure to Meet Study Deadlines: Sections I.7.c and I.7.d of this Schedule 21 require a Transmission Provider to use due diligence to meet 60-day study completion deadlines for System Impact Studies and Facilities Studies.

(i) The PTO is required to file a notice with the Commission in the event that more than twenty (20) percent of non-Affiliates' System Impact Studies and Facilities Studies completed by the PTO in any two consecutive calendar quarters are not completed within the 60-day study completion deadlines. Such notice must be filed within thirty (30) days of the end of the calendar quarter triggering the notice requirement.

(ii) For the purposes of calculating the percent of non-Affiliates' System Impact Studies and Facilities Studies processed outside of the 60-day study completion deadlines, the PTO shall consider all System Impact Studies and Facilities Studies that it completes for non-Affiliates during the calendar quarter. The percentage should be calculated by dividing the number of those studies which are completed on time by the total number of completed studies. The PTO may provide an explanation in its notification filing to the Commission if it believes there are extenuating circumstances that prevented it from meeting the 60-day study completion deadlines.

(iii) The PTO is subject to an operational penalty if it completes ten (10) percent or more of non-Affiliates' System Impact Studies and Facilities Studies outside of the 60-day study completion deadlines for each of the two calendar quarters immediately following the quarter that triggered its notification filing to the Commission. The operational penalty will be assessed for each calendar quarter for which an operational penalty applies, starting with the calendar quarter immediately following the quarter that triggered the PTO's notification filing to the Commission. The operational penalty will continue to be assessed each quarter until the PTO completes at least ninety (90) percent of all non-Affiliates' System Impact Studies and Facilities Studies within the 60-day deadline.

(iv) For penalties assessed in accordance with subsection (iii) above, the penalty amount for each System Impact Study or Facilities Study shall be equal to $500 for each day the PTO takes to complete that study beyond the 60-day deadline.

j) Claims or Disputes: Any claim or dispute between the PTO and the Transmission Customer with respect to a System Impact Study or Facilities Study shall be governed by the provisions of Section I.6 of the Tariff.

8) Procedures if The PTO is Unable to Complete New Transmission Facilities for Firm Local Point-To-Point Service

a) Delays in Construction of New Facilities: If any event occurs that will materially affect the time for completion of new facilities, or the ability to complete them, the PTO shall promptly notify the Transmission Customer. In such circumstances, the PTO shall within, thirty (30) days of notifying the Transmission Customer of such delays, convene a technical meeting with the Transmission Customer to evaluate the alternatives available to the Transmission Customer. The PTO also shall make available to the Transmission Customer studies and work papers related to the delay, including all information that is in the possession of the PTO that is reasonably needed by the Transmission Customer to evaluate any alternatives.

b) Alternatives to the Original Facility Additions: When the review process of Section I.8.a of this Schedule 21 determines that one or more alternatives exist to the originally planned construction project, the PTO shall present such alternatives for consideration by the Transmission Customer. If, upon review of any alternatives, the Transmission Customer desires to maintain its Completed Application subject to construction of the alternative facilities, it may request that the ISO file a revised Local Service Agreement for Firm Local Point-To-Point Service. If the alternative approach solely involves Non-Firm Local Point-To-Point Service, the PTO shall so inform the ISO, and the ISO (in consultation with the PTO) shall thereafter promptly tender to the Transmission Customer a Local Service Agreement for Non-Firm Local Point-To-Point Service providing for the service. In the event the PTO concludes that no reasonable alternative exists and the Transmission Customer disagrees, the Transmission Customer may seek relief under the dispute resolution procedures of Section I.6 of the Tariff.

c) Refund Obligation for Unfinished Facility Additions: If the PTO and the Transmission Customer mutually agree that no other reasonable alternatives exist and the requested Firm Local Point-To-Point Service cannot be provided out of existing capability, the obligation to provide the requested service shall terminate and any deposit made by the Transmission Customer shall be returned with interest pursuant to Commission regulations 35.19a(a)(2)(iii). However, the Transmission Customer shall be responsible for all prudently incurred costs by the ISO and the PTO through the time construction was suspended, including costs for removal of unfinished facilities and any ongoing operating expenses of the unfinished facilities until they are removed.

9) Provisions Relating to Transmission Construction and Services on the Systems of Other Utilities

a) Responsibility for Third-Party System Additions: The PTO shall not be responsible for making arrangements for any necessary engineering, permitting, and construction of transmission or distribution facilities on the system(s) of any other entity or for obtaining any regulatory approval for such facilities. The PTO will undertake reasonable efforts to assist the Transmission Customer in obtaining such arrangements, including without limitation, providing any information or data required by such other electric system pursuant to Good Utility Practice.

b) Coordination of Third-Party System Additions: In circumstances where the need for transmission facilities or upgrades is identified, and if such upgrades further require the addition of transmission facilities on other systems, the PTO shall have the right to coordinate construction on its own system with the construction required by others. The PTO, after consultation with the Transmission Customer and representatives of such other systems, may defer construction of its new transmission facilities, if the new transmission facilities on another system cannot be completed in a timely manner. The PTO shall notify the Transmission Customer in writing of the basis for any decision to defer construction and the specific problems which must be resolved before it will initiate or resume construction of new facilities. Within sixty (60) days of receiving written notification by the PTO of its intent to defer construction, the Transmission Customer may challenge the decision in accordance with Section I.6 of the Tariff.

10) Changes in Service Specifications

a) Modifications On a Non-Firm Basis: The Transmission Customer taking Firm Local Point-To-Point Service from a PTO may request transmission service on a non-firm basis over Receipt and Delivery Points of the same PTO other than those specified in the Local Service Agreement ("Secondary Receipt and Delivery Points") in amounts not to exceed its firm capacity reservation, without incurring an additional Non-Firm Local Point-To-Point Service charge or executing a new Local Service Agreement, subject to the following conditions. A Transmission Customer may request a modification to its Non-Firm Local Point-to-Point Service by making such a request to the PTO and the ISO, which must be made pursuant to Sections I.6. (a) and (b), as appropriate.

(a) Service provided over Secondary Receipt and Delivery Points will be non-firm only, on an as-available basis and will not displace any firm or non-firm service reserved or scheduled by third-parties under the Tariff or by the PTO on behalf of its Native Load Customers.

(b) The sum of all Firm Local and Non-Firm Local Point-To-Point Service provided to the Transmission Customer at any time pursuant to this section shall not exceed the Reserved Capacity in the relevant Local Service Agreement under which such services are provided.

(c) The Transmission Customer shall retain its right to schedule Firm Local Point-To-Point Service at the Receipt and Delivery Points specified in the relevant Local Service Agreement in the amount of its original capacity reservation.

(d) Service over Secondary Receipt and Delivery Points on a non-firm basis shall not require the filing of an Application for Non-Firm Local Point-To-Point Service under the Tariff. However, all other requirements of this Schedule 21 (except as to transmission rates) shall apply to transmission service on a non-firm basis over Secondary Receipt and Delivery Points.

b) Modification On a Firm Basis: Any request by a Transmission Customer to modify the Firm Local Point-to-Point Service it receives from a PTO to obtain service between different Receipt and Delivery Points on the Local Network of the same PTO on a firm basis shall be treated as a new request for service, except that such Transmission Customer shall not be obligated to pay any additional deposit if the capacity reservation does not exceed the amount reserved in the existing Local Service Agreement. While such new request is pending, the Transmission Customer shall retain its priority for service at the existing firm Receipt and Delivery Points specified in its Local Service Agreement. A Transmission Customer may request a modification to its Firm Local Point-to-Point Service by making such a request to the PTO and the ISO, which must be made pursuant to Sections I.5. (a) and (b), as appropriate.

11) Sale or Assignment of Transmission Service

a) Procedures for Assignment or Transfer of Service: A Transmission Customer may sell, assign, or transfer all or a portion of its rights under its Local Service Agreement, but only to another Eligible Customer (the Assignee). The Transmission Customer that sells, assigns or transfers its rights under its Local Service Agreement is hereafter referred to as the "Reseller" as the term used throughout this Schedule 21. Compensation to Resellers shall be at rates established by agreement between the Reseller and the Assignee. The Assignee must execute a service agreement with the PTO governing reassignments of transmission service prior to the date on which the reassigned service commences. The PTO shall charge the Reseller, as appropriate, at the rate stated in the Reseller's Local Service Agreement with the PTO or the associated OASIS schedule and credit the Reseller with the price reflected in the

Assignee's Service Agreement with the PTO or the associated OASIS schedule; provided that, such credit shall be reversed in the event of non-payment by the Assignee. If the Assignee does not request any change in the Point(s) of Receipt or the Point(s) of Delivery, or a change in any other term or condition set forth in the original Local Service Agreement, the Assignee will receive the same services as did the Reseller and the priority of service for the Assignee will be the same as that of the Reseller. The Assignee will be subject to all terms and conditions of the Tariff. If the Assignee requests a change in service, the reservation priority of service will be determined by the PTO pursuant to Section I.1.b of this Schedule 21. A Transmission Customer may request a modification to its Firm Local Point-to-Point Service by making such a request to the PTO and the ISO must be made pursuant to sections I.5. (a) and (b) and I.6. (a) and (b), as appropriate.

b) Limitations on Assignment or Transfer of Service: If the Assignee requests a change in the Point(s) of Receipt or Point(s) of Delivery, or a change in any other specifications set forth in the original Local Service Agreement, the PTO will consent to such change subject to the provisions of the Tariff, provided that the change will not impair the operation and reliability of the New England Transmission System or the PTO's distribution system, as applicable. The Assignee shall compensate the ISO and/or the PTO, as applicable, for performing any System Impact Study needed to accommodate the proposed change and any additional costs resulting from such change. The Reseller shall remain liable for the performance of all obligations under the Local Service Agreement, except as specifically agreed to by the PTO and Reseller through an amendment to the Local Service Agreement

c) Information on Assignment or Transfer of Service: In accordance with Section I.11 of this Schedule 21 and applicable provisions of the Local Service Schedules, all sales or assignments of capacity must be conducted through or otherwise posted on the PTO's OASIS on or before the date the reassigned Local Point-to-Point Service commences and are subject to Section I.11.a of this Schedule 21. Resellers may also use the OASIS to post transmission capacity available for resale.

12) Metering and Power Factor Correction at Receipt and Delivery Points(s)

a) Transmission Customer Obligations: Unless otherwise provided in the applicable Local Service Schedule, the Transmission Customer shall be responsible for installing and maintaining compatible metering and communications equipment to accurately account for the capacity and energy being transmitted through Local Point-To-Point Service and to communicate the information to the PTO,

Local Control Centers and the ISO. Such equipment shall remain the property of the Transmission Customer.

b) PTO Access to Metering Data: The PTO shall have access to metering data, which may reasonably be required to facilitate measurements and billing under the Local Service Agreement.

c) Power Factor: In accordance with Good Utility Practice and any applicable Local Service Schedule, the Transmission Customer is required to maintain a power factor within the same range as the PTO. The power factor requirements are specified in the Local Service Agreement where applicable.

13) Compensation for Local Point-To-Point Service:

Rates for Firm Local and Non-Firm Local Point-To-Point Service are set forth in the Local Service Schedules. The applicable rates for Firm Local and Non-Firm Local Point-to-Point Service set forth in the Local Service Schedules shall be reduced to zero for the charging load of an Electric Storage Facility when the Regional Network Service charges are reduced to zero pursuant to Section II.21.3 of the OATT. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market.

14) Compensation for New Facilities Costs:

Whenever a System Impact Study performed in connection with the provision of Firm Local Point-To-Point Service identifies the need for new facilities, the Transmission Customer shall be responsible for the costs of the new facilities to the extent consistent with Commission policy.

II. LOCAL NETWORK SERVICE

Preamble

Eligible Customers seeking Local Network Service on a specific Local Network shall refer to the applicable Local Service Schedule to determine any PTO-specific rates, terms, and conditions applicable

to such service. Except as otherwise provided in the Local Service Schedules, Local Network Service will be provided pursuant to the applicable rates, terms and conditions set forth below.

1) Nature of Local Network Service

Local Network Service is provided to Network Customers to serve their loads. It includes transmission service for the delivery to a Network Customer of its energy and capacity from Network Resources and delivery to or by Network Customers of energy and capacity from New England Markets transactions.

2) Availability of Local Network Service

a) Eligibility to Receive Local Network Service: Transmission Customers taking Regional Network Service must also take Local Service.

b) Compliance With State Law: A Network Customer is not excused from any requirements of state law, or any order or regulation issued pursuant to state law, to arrange for Local Delivery Service with the PTO and distribution company providing such service and to pay all applicable charges associated with such service, including charges for stranded costs.

c) Scope of Service: Local Network Service allows Network Customers to efficiently and economically utilize their resources and Interchange Transactions to serve their Local and Regional Network Load and any additional load that may be designated pursuant to the Tariff. The Network Customer taking Local Network Service must obtain or provide Ancillary Services.

d) PTO Responsibilities: The PTO in accordance with the TOA will plan, construct, operate and maintain its Local Network in accordance with Good Utility Practice and its planning obligations in Attachment K in order to provide the Network Customer with Local Network Service. Each PTO, on behalf of its Native Load Customers, shall be required to designate resources and loads in the same manner as any Network Customer. This information must be consistent with the information used by the PTO to calculate available transfer capability. The PTO in accordance with the TOA shall include the Network Customer's Local Network Load in Local Network planning and shall, consistent with Good Utility Practice and Attachment K, endeavor to construct and place into service sufficient transfer capability to deliver Network Resources to serve the Network Customer's Local and Regional Network Load on a basis comparable to the PTO's delivery of its own generating and purchased resources to its Native Load Customers.

e) Comparability of Service: Local Network Service will be provided to the Network Customer for the delivery of energy and/or capacity from its resources to serve its Local and Regional Network Loads on a basis that is comparable to the PTO's use of its Local Network to reliably serve Native Load Customers.

f) Real Power Losses: "Real Power Losses" those losses associated with transmission service as determined in accordance with Section 15.3, Section 31.6 and Schedule 21 of the OATT. The PTOs are not obligated to provide Real Power Losses. Non-PTF Real Power Losses shall be calculated and charged for in accordance with the applicable Schedule 21 Local Service Schedule.

g) Secondary Service: The Network Customer may use the Local Network to deliver energy to its Local Network Loads from resources that have not been designated as Network Resources. Such energy shall be transmitted, on an as available basis, at no additional charge. Secondary service shall not require the filing of an Application for Local Network Service under Section II of this Schedule 21. However, all other requirements of Section II of this Schedule 21 (except for transmission rates) shall apply to secondary service. Deliveries from resources other than Network Resources will have a higher priority than any Non Firm Local Point To Point Service.

h) Restrictions on Use of Service: The Network Customer shall not use Local Network Service for (i) sales of capacity and energy to non designated loads, or (ii) direct or indirect provision of transmission service by the Network Customer to third parties. All Network Customers taking Local Network Service shall use Local Point To Point Service for any Third Party Sale, which requires use of the Local Network. The PTO shall specify any appropriate charges and penalties and all related terms and conditions applicable in the event that a Network Customer uses Local Network Service or secondary service pursuant to Section II.2.g of this Schedule 21 to facilitate a wholesale sale that does not serve Local Network Load.

3) Initiating Service

a) Condition Precedent for Receiving Service: Local Network Service shall be provided only if the following conditions are satisfied by the Eligible Customer: (i) the Eligible Customer completes an Application to the ISO for service, (ii) the Eligible Customer and the PTO complete the technical arrangements, and (iii) the Eligible Customer executes a Local Service Agreement with the PTO and the

ISO or requests in writing that the ISO file an unexecuted Local Service Agreement containing terms and conditions deemed by the PTO (in consultation with the ISO) to be appropriate for such requested service with the Commission.

4) Procedures for Arranging Local Network Service

a) Pre-RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternate Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of their existing Local Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall not be required to complete an Application or execute a Local Service Agreement under this Schedule 21, however, modifications to the existing Local Service Agreement may be required. The Transmission Customer shall contact the PTO to discuss and, if appropriate, modify the existing Local Service Agreement.

(ii) A Transmission Customer who wishes to make upgrades (i.e., increase MWs served) beyond the terms of its existing Local Service Agreement that is in effect prior to February 1, 2005 ("Pre-RTO Local Service Agreement"), shall contact the PTO to make arrangements to terminate the Transmission Customer's existing Local Service Agreement and shall complete (and submit to the ISO) an Application for Local Service and then execute a Local Service Agreement under this Schedule 21.

b) RTO Local Service Agreements

(i) A Transmission Customer who wishes to revise the Local Service Agreement termination date, transfer Local Service Agreement ownership, request an alternative Point of Receipt or Point of Delivery, or make upgrades (i.e., increase MWs served) within the terms of the existing Local Service Agreement under this Schedule 21, shall not be required execute a new Local Service Agreement under this Schedule 21, however, modifications to the existing Local Service Agreement under this Schedule 21 may be required. Such modifications to an existing Local Service Agreement typically do not require an additional Local or Regional System Impact Study to be completed. The Transmission Customer shall complete (and submit to the ISO) an

application for Local Transmission Service that reflects the requested modifications to the Local Service Agreement to facilitate revision of its existing Schedule 21 Local Service Agreement.

(ii) A Transmission Customer who wishes to make upgrades (i.e., increase MWs served) beyond the terms of the existing Local Service Agreement under this Schedule 21, shall contact the ISO to discuss and, if appropriate, terminate the Transmission Customer's existing Local Service Agreement under this Schedule 21 and shall complete (and submit to the ISO) a new Application for Local Service and then execute a new Local Service Agreement under this Schedule 21.

c) Application Procedures: An Eligible Customer requesting Local Network Service must submit an Application, with a deposit equal to the charge for one month of service, unless another charge is specified in the applicable Local Service Schedule, to the ISO as far as possible in advance of the month in which service is to commence. Completed Applications for Local Network Service will be assigned a reservation priority according to the date and time the Application is received, with the earliest Application receiving the highest priority. A Completed Application shall provide all of the information included in 18 C.F.R. §2.20 including but not limited to the following:

(i) The identity, address, telephone number and facsimile number of the party requesting service;

(ii) A statement that the party requesting service is, or will be upon commencement of service, an Eligible Customer;

(iii) A description of the Local Network Load at each delivery point. This description should separately identify and provide the Eligible Customer's best estimate of the total loads to be served at each transmission voltage level, and the loads to be served from each substation at the same transmission voltage level. The description should include a ten-year forecast of summer and winter load resource requirements beginning with the first year after the service is scheduled to commence;

(iv) The amount and location of any interruptible loads included in the Local Network Load. This shall include the summer and winter capacity requirements for each interruptible load (had such load not been interruptible), that portion of the load subject to interruption, the conditions under which an interruption can be implemented and any limitations on the amount and frequency

of interruptions. An Eligible Customer should identify the amount of interruptible customer load (if any) included in the ten-year load forecast provided in response to (iii) above;

(v) A description of Network Resources (current and ten-year projection), which shall include, for each Network Resource, if the description is not otherwise available to the ISO and the PTOs:

- Unit size and amount of capacity from that unit to be designated as Network Resource
- VAR capability (both leading and lagging) of all generators
- Operating restrictions
- Any periods of restricted operations throughout the year
- Maintenance schedules
- Minimum loading level of unit
- Normal operating level of unit
- Any must-run unit designations required for system reliability or contract reasons
- Approximate variable dispatch price ($/MWH), consistent with Market Rule 1, for redispatch computations
- Arrangements governing sale and delivery of power to third parties from generating facilities located in the New England Control Area, where only a portion of unit output is designated as a Network Resource
- Description of external purchased power designated as a Network Resource including source of supply, control area location, transmission arrangements and delivery point(s);

(vi) Description of Eligible Customer's transmission system:

- Load flow and stability data, such as real and reactive parts of the load, lines, transformers, reactive devices and load type, including normal and emergency ratings of all transmission equipment in a load flow format compatible with that used by the ISO and the PTOs
- Operating restrictions needed for reliability
- Operating guides employed by system operators
- Contractual restrictions or committed uses of the Eligible Customer's transmission system, other than the Eligible Customer's Local Network Loads and Resources
- Location of Network Resources described in subsection (v) above

- ten-year projection of system expansions or upgrades
- transmission system maps that include any proposed expansions or upgrades
- Thermal ratings of Eligible Customer's Control Area ties with other Control Areas;

(vii) Service Commencement Date and the term of the requested service. The minimum term for service is one year; and

(viii) Any additional information required of the Transmission Customer as specified in the PTO's planning process established in Attachment K.

Unless the Eligible Customer and the ISO agree to a different time frame, the ISO must acknowledge the request within ten (10) days of receipt. The acknowledgment must include a date by which a response, including a Local Service Agreement, will be sent to the Eligible Customer. If an Application fails to meet the requirements of this Section, the PTO shall notify the ISO within ten (10) days of the Application's receipt of the reasons for such failure, and the ISO shall, in turn, so notify the entity requesting service within five (5) days of the receipt of notice from the PTO of the reasons for such failure. Wherever possible, the ISO and the PTO will attempt to remedy deficiencies in the Application through informal communications with the Eligible Customer. If such efforts are unsuccessful, the ISO shall return the Application without prejudice to the Eligible Customer, who may thereafter file a new or revised Application that fully complies with the requirements of this Section. The Eligible Customer will be assigned a new reservation priority consistent with the date of the new or revised Application. The ISO and the PTO shall treat this information consistent with the standards of conduct contained in Part 37 of the Commission's regulations.

d) Technical Arrangements to be Completed Prior to Commencement of Service: Local Network Service shall not commence until the PTO and the Network Customer, or a third party, have completed installation of all equipment specified under the Local Service Agreement consistent with Good Utility Practice and any additional requirements reasonably and consistently imposed to ensure the reliable operation of the Non-PTF. The PTO shall exercise reasonable efforts, in coordination with the Network Customer, to complete such arrangements as soon as practicable taking into consideration the Service Commencement Date.

e) Network Customer Facilities: The provision of Local Network Service shall be conditioned upon the Network Customer's constructing, maintaining and operating the facilities on its side of each

delivery point or interconnection necessary to reliably deliver capacity and energy from the Non-PTF to the Network Customer. The Network Customer shall be solely responsible for constructing or installing and operating and maintaining all facilities on the Network Customer's side of each such delivery point or interconnection.

f) Filing of Service Agreement: The ISO shall file Local Service Agreements with the Commission in compliance with applicable Commission regulations.

5) Network Resources

a) Designation of Network Resources: The Network Customer shall designate those Network Resources which are owned, purchased or leased by it. The Network Resources so designated may not include resources, or any portion thereof, that are committed for sale to non-designated third party load or otherwise cannot be called upon to meet the Network Customer's Local Network Load on a non-interruptible basis. Any owned, purchased or leased resources that were serving the Network Customer's loads under firm agreements entered into on or before the Compliance Effective Date shall be deemed to continue to be so owned, purchased or leased by it until the Network Customer informs the ISO and the PTO of a change.

b) Designation of New Network Resources: The Network Customer shall identify any new Network Resources which are owned, purchased or leased by it with as much advance notice as practicable. A designation of any new Network Resource as owned, purchased or leased by the Customer must be made by a notice to the ISO and the PTO.

c) Termination of Network Resources: The Network Customer may terminate the designation of all or part of a Network Resource as owned, purchased or leased by it at any time but shall provide notification to the ISO and the PTO as soon as reasonably practicable.

d) Network Customer Redispatch Obligation: As a condition to receiving Local Network Service, the Network Customer agrees to redispatch its Network Resources as requested by the ISO and the PTO. The ISO will redispatch all Resources subject to its control, pursuant to Market Rule 1, in order to meet load and to accommodate External Transactions. The Network Customers will be charged for the Congestion Costs and any other costs associated with such redispatch in accordance with Market Rule 1.

e) Transmission Arrangements for Network Resources Not Physically Interconnected with the PTO's Non-PTF: The Network Customer shall be responsible for any arrangements necessary to deliver capacity and energy from a Network Resource not physically interconnected with the PTO's Non-PTF. The applicable PTO will undertake reasonable efforts to assist the Network Customer in obtaining such arrangements, including without limitation, providing any information or data required by such other entity pursuant to Good Utility Practice.

f) Limitation on Designation of Network Resources: The Network Customer must demonstrate that it owns or has committed to purchase generation pursuant to an executed contract in order to designate a generating resource as a Network Resource. Alternatively, the Network Customer may establish that execution of a contract is contingent upon the availability of transmission service under this Schedule 21.

g) Network Customer Owned Transmission Facilities: The Network Customer that owns existing transmission facilities that are integrated with the PTO's Local Network may be eligible to receive consideration either through a billing credit or some other mechanism. In order to receive such consideration, the Network Customer must demonstrate that its transmission facilities are integrated into the planning and operations of the PTO to serve all of its power and transmission customers. For facilities added by the Network Customer subsequent to the effective date of a Final Rule in RM05-25-000, the Network Customer shall receive credit for such transmission facilities added if such facilities are integrated into the operations of the PTO's facilities; provided however, the Local Network Customer's transmission facilities shall be presumed to be integrated if such transmission facilities, if owned by the PTO, would be eligible for inclusion in the PTO's annual transmission revenue requirement as specified in the PTO's respective Local Service Schedule. Calculation of any credit under this subsection shall be addressed in either the Network Customer's Service Agreement or any other agreement between the Parties.

6) Designation of Local Network Load

a) Local Network Load: The Network Customer must designate the individual Local Network Loads which it expects to have served through Local Network Service. The Local Network Loads shall be specified in the Local Service Agreement.

b) New Local Network Loads Within the New England Control Area: The Network Customer shall provide the ISO and the PTO with as much advance notice as reasonably practicable of the designation of new Local Network Load that will be added to the Non-PTF. A designation of new Local Network Load must be made through a modification of service pursuant to a new Application. The PTO will use due diligence to install or cause to be installed any transmission facilities required to interconnect a new Local Network Load designated by the Network Customer. The costs of new facilities required to interconnect a new Local Network Load shall be determined in accordance with the procedures provided in this Schedule 21 and shall be charged to the Network Customer in accordance with Commission policy and this Schedule 21.

c) Local Network Load Not Physically Interconnected with the PTO: This Section applies to both initial designation and the subsequent addition of new Local Network Load not physically interconnected with the PTO's Non-PTF. To the extent that the Network Customer desires to obtain transmission service for a load outside the Local Network, the Network Customer shall have the option of (1) electing to include the entire load as Local Network Load for all purposes under this Schedule 21 and designating Network Resources in connection with such additional Local Network Load, or (2) excluding that entire load from its Local Network Load and purchasing Local Point To Point Service under this Schedule 21. To the extent that the Network Customer gives notice of its intent to add a new Local Network Load as part of its Local Network Load pursuant to this Section the request must be made through a modification of service pursuant to a new Application.

d) New Interconnection Points: To the extent the Network Customer desires to add a new Delivery Point or interconnection point between the Non-PTF and a Local Network Load, the Network Customer shall provide the ISO and the PTO with as much advance notice as reasonably practicable.

e) Changes in Service Requests: Under no circumstances shall the Network Customer's decision to cancel or delay a requested change in Local Network Service (the addition of a new Network Resource, if any, or designation of a new Local Network Load) in any way relieve the Network Customer of its obligation to pay the costs of transmission facilities constructed by the PTOs and charged to the Network Customer as reflected in the applicable Local Service Agreement or other appropriate agreement. However, the PTO must treat any requested change in Local Network Service in a non-discriminatory manner.

f) Annual Load and Resource Information Updates: The Network Customer shall provide the ISO and the PTO with annual updates of Local Network Load and Network Resource forecasts consistent with those included in its Application including, but not limited to, any information provided under Section II.3.b of this Schedule 21 pursuant to the PTO's planning process in Attachment K. The Network Customer also shall provide the ISO and the PTO with timely written notice of material changes in any other information provided in its Application relating to the Network Customer's Local Network Load, Network Resources, its transmission system or other aspects of its facilities or operations affecting the ability of the PTO to provide reliable service.

7) Additional Study Procedures For Local Network Service Requests

a) Notice of Need for System Impact Study: After receiving a request for Local Network Service, a determination shall be made on a non-discriminatory basis as to whether a System Impact Study is needed. The ISO shall review the request to determine whether the provision of the requested service would have an impact on facilities other than Non-PTF, and if so, whether a System Impact Study is necessary to accommodate the requested service. If so, the ISO shall so inform the Eligible Customer as soon as practicable and will (in consultation with the PTO) perform a System Impact Study, as necessary, with respect to the request. A description of the ISO's methodology for completing a System Impact Study is provided in OATT Attachment D. If the ISO determines that the service would not have an impact on facilities other than Non-PTF, the PTO shall determine whether a System Impact Study is necessary to accommodate the requested service and shall so inform the Eligible Customer as soon as practicable and will (in consultation with the ISO) perform a System Impact Study, as necessary, with respect to the application. In such cases, the ISO or the PTO, as applicable, shall within thirty (30) days of receipt of a Completed Application, tender a System Impact Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the ISO or the PTO, as applicable, for performing the required System Impact Study. For a service request to remain a Completed Application, the Eligible Customer shall execute the System Impact Study Agreement and return it to the ISO or the PTO, as applicable, within fifteen (15) days. If the Eligible Customer elects not to execute the System Impact Study Agreement, its Application shall be deemed withdrawn and its deposit shall be returned with interest. A description of the PTO's methodology for completing a System Impact Study is provided in its Local Service Schedule.

b) System Impact Study Agreement and Cost Reimbursement:

(i) The System Impact Study Agreement will clearly specify an estimate of the cost and time for completion of the System Impact Study. The charge shall not exceed the actual cost of the study. The System Impact Study shall rely on existing transmission planning studies to the extent reasonably practicable. The Eligible Customer will not be assessed a charge for such existing studies; however, the Eligible Customer will be responsible for charges associated with any modifications to existing planning studies that are reasonably necessary to evaluate the impact of the Eligible Customer's request for service on the Local Network.

(ii) If in response to multiple Eligible Customers requesting service in relation to the same competitive solicitation, a single System Impact Study is sufficient to accommodate the requests for service, the costs of that study shall be pro-rated among the Eligible Customers.

(iii) For System Impact Studies that the PTO conducts on its own behalf, the PTO shall record the cost of the System Impact Studies pursuant to Section II.8.5 of the Tariff.

(iv) In response to multiple Eligible Customers within the same electrically interconnected area requesting clustering of system Impact Study analysis for Local Service, the PTO will accommodate such multiple requests if it can reasonable do so. The costs of such studies shall be pro-rated among the Eligible Customers on an agreed upon basis.

c) System Impact Study Procedures: Upon receipt of an executed System Impact Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required System Impact Study within a sixty (60) day period. The System Impact Study shall identify any system constraints, additional Direct Assignment Facilities or Local Network Upgrades required to provide the requested service. In the event that the ISO or the PTO, as applicable, is unable to complete the required System Impact Study within such time period, it shall so notify the Eligible Customer and provide an estimated completion date along with an explanation of the reasons why additional time is required to complete the required studies. A copy of the completed System Impact Study and related work papers shall be made available to the Eligible Customer as soon as the System Impact Study is complete. The PTO will use the same due diligence in completing the System Impact Study for an Eligible Customer as it uses when completing studies for itself. The ISO or the PTO, as applicable, shall notify the Eligible Customer immediately upon completion of the System Impact Study if the Local Network will be adequate to accommodate all or part of a request for service or that no costs are likely to be incurred for new transmission facilities or upgrades. In order for a request to remain a Completed Application, within

fifteen (15) days of completion of the System Impact Study, the Eligible Customer must execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement pursuant to Section II.3.a of this Schedule 21 or the Application shall be deemed terminated and withdrawn.

d) Facilities Study Procedures: If a System Impact Study indicates that additions or upgrades to facilities other than Non-PTF are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on the MTF facilities, the ISO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the ISO for performing the required Facilities Study. If a System Impact Study indicates that additions or upgrades to Non-PTF facilities are needed to supply the Eligible Customer's service request or to mitigate indirect impacts on the MTF facilities, the PTO, within thirty (30) days of the completion of the System Impact Study, shall tender to the Eligible Customer a Facilities Study Agreement pursuant to which the Eligible Customer shall agree to reimburse the PTO for performing the required Facilities Study. For clustered studies, the cost of such studies shall be pro-rated among the Eligible Customers on an agreed upon basis. For a service request to remain a Completed Application, the Eligible Customer shall execute the Facilities Study Agreement and return it within fifteen (15) days. If the Eligible Customer elects not to execute the Facilities Study Agreement, its Application shall be deemed withdrawn and its deposit shall be returned with interest. Upon receipt of an executed Facilities Study Agreement, the ISO or the PTO, as applicable, will use due diligence to complete the required Facilities Study within a sixty (60) day period. If the Facilities Study cannot be completed in the allotted time period, the Eligible Customer shall be notified and provided an estimate of the time needed to reach a final determination along with an explanation of the reasons that additional time is required to complete the study. When completed, the Facilities Study will include a good faith estimate of (i) the cost of Direct Assignment Facilities to be charged to the Eligible Customer, (ii) the Eligible Customer's appropriate share of the cost of any required Local Network Upgrades, and (iii) the time required to complete such construction and initiate the requested service. The Eligible Customer shall provide a letter of credit or other reasonable form of security acceptable to the PTO equivalent to the costs of new facilities or upgrades consistent with commercial practices as established by the Uniform Commercial Code. The Eligible Customer shall have thirty (30) days to execute a Local Service Agreement or request the filing of an unexecuted Local Service Agreement and provide the required letter of credit or other form of security or the request will no longer be a Completed Application and shall be deemed terminated and withdrawn.

In addition to the foregoing, each Facilities Study shall, if requested by the Eligible Customer, contain a non-binding estimate from the ISO of the Incremental ARRs, if any, resulting from the construction of the new facilities. After completion of the transmission upgrade or expansion, the ISO shall determine the Incremental ARRs, if any, resulting from the upgrade or expansion.

e) Facilities Study Modifications: Any change in design arising from the inability to site or construct facilities as proposed will require development of a revised good faith estimate. New good faith estimates also will be required in the event of new statutory or regulatory requirements that are effective before the completion of construction or other circumstances beyond the control of the ISO and/or the PTO that significantly affect the final cost of new facilities or upgrades to be charged to the Transmission Customer.

f) Due Diligence in Completing New Facilities: The PTO shall use due diligence to add necessary facilities or upgrade its Local Network within a reasonable time. The PTO will not upgrade its existing or planned Local Network in order to provide the requested Local Network Service if doing so would impair system reliability or otherwise impair or degrade existing firm service.

g) Claims or Disputes: Any claim or dispute between the PTO and the Transmission Customer with respect to a System Impact Study or Facilities Study shall be governed by the provisions of Section I.6 of the Tariff.

h) Penalties for Failure to Meet Study Deadlines: Section I.7.i of this Schedule 21 defines penalties that apply for failure to meet the 60-day study completion due diligence deadlines for System Impact Studies and Facilities Studies under Section I of this Schedule 21. These same requirements and penalties apply to service under Section II of this Schedule 21.

8) Load Shedding and Curtailments

a) Procedures: The PTO shall establish Load Shedding and Curtailment procedures (consistent with those of the ISO and the Local Control Center) with the objective of responding to contingencies on the Non-PTF. The PTO will notify all affected Local Network Service Customers in a timely manner of any scheduled Curtailment.

b) Transmission Constraints: During any period when a PTO or the Local Control Center determines that a transmission constraint exists on the Non-PTF, and such constraint may impair the reliability of the New England Transmission System, the PTO or the Local Control Center will so inform the ISO. The ISO will take whatever actions, consistent with Good Utility Practice, that are reasonably necessary to maintain the reliability of the system. To the extent the ISO determines that the reliability of the New England Transmission System can be maintained by redispatching resources, The ISO will initiate procedures to redispatch all resources on a least-cost basis without regard to the ownership of such resources.

c) Cost Responsibility for Relieving Transmission Constraints: Whenever the ISO implements least-cost redispatch procedures in response to a transmission constraint, the Transmission Customer will bear the costs of such redispatch in accordance with Market Rule 1.

d) Curtailments of Scheduled Deliveries: If a transmission constraint on the Non-PTF cannot be relieved through the implementation of least-cost redispatch procedures and the PTO determines that it is necessary to effect a Curtailment of scheduled deliveries, such schedule shall be curtailed in accordance with the terms of the Tariff.

e) Allocation of Curtailments: The ISO, the Transmission Owner or the Local Control Center shall on a non-discriminatory basis, effect a Curtailment of the transaction(s) that effectively relieves the constraint. However, to the extent practicable and consistent with Good Utility Practice, any Curtailment will be shared by the customers taking MTF Service and OTF Service and/or Through or Out Service and Network Customers on a non-discriminatory basis. Notwithstanding the preceding provisions of this Section, External Transactions shall be scheduled and curtailed in accordance with Section II.44 of the OATT.

f) Load Shedding: Load Shedding also may occur in accordance with the applicable Local Service Schedule to the extent provided for in such Local Service Schedule.

g) System Reliability: Notwithstanding any other provisions of this Schedule, The ISO, the PTO and the Local Control Centers reserve the right, consistent with Good Utility Practice and on a not unduly discriminatory basis, to effect a Curtailment of service without liability on the part of the ISO, the PTO or the Local Control Centers for the purpose of making necessary adjustments to, changes in, or repairs on the PTO's lines, substations and facilities, and in cases where the continuance of service would endanger

persons or property. In the event of any adverse condition(s) or disturbance(s) on the Non-PTF or on any other system(s) directly or indirectly interconnected with the Non-PTF, the ISO, the PTO and the Local Control Centers, consistent with Good Utility Practice, also may effect a Curtailment of service in order to (i) limit the extent or damage of the adverse condition(s) or disturbance(s), (ii) prevent damage to generating or transmission facilities, or (iii) expedite restoration of service. The ISO, the PTO or the Local Control Centers will give the Network Customer as much advance notice as is practicable in the event of such Curtailment. Any Curtailment of Local Network Service will be not unduly discriminatory relative to the PTO's use of the New England Transmission System on behalf of their Native Load Customers. The Local Service Schedules shall specify the rate treatment and all related terms and conditions applicable in the event that the Network Customer fails to respond to established Load Shedding and Curtailment procedures.

9) Rates and Charges

Except as provided below, the Network Customer shall pay all applicable charges for Local Network Service set forth in this Schedule 21, including the Local Service Schedules, and for any Direct Assignment Facilities and its share of the cost of any required Local Network Upgrades and applicable study costs consistent with Commission policy, along with any additional charges imposed under the Tariff. In the event the Network Customer serves Local Network Load located on more than one Local Network, the amount to be paid by it shall be separately computed for each Local Network.

The applicable charges for Local Network Service set forth in this Schedule 21, including the Local Service Schedules, shall be reduced to zero for the charging load of an Electric Storage Facility when the Regional Network Service charges are reduced to zero pursuant to Section II.21.3 of the OATT. The reduction to zero of the applicable charges shall not apply to any Direct Assignment Facilities nor the Network Customer's share of the cost of any required Local Network Upgrades and applicable study costs consistent with Commission policy, along with any additional charges imposed under the Tariff. This discount will only be applied to Electric Storage Facility charging load that (a) is reported under a separately identified Regional Network Load that does not include station service load or any other load and (b) is providing one or more of the following services to the ISO: reactive power voltage support, operating reserves, regulation and frequency response, balancing energy supply and demand, or addressing a reliability concern. Electric Storage Facilities shall be considered to be balancing energy supply and demand when they are responding to ISO dispatch instructions in the Real-Time Energy Market.

10) Determination of Network Customer's Monthly Network Load

For purposes of Local Network Service, the Network Customer's "Monthly Network Load" shall be determined in accordance with the applicable Local Service Schedule.

11) Operating Arrangements

The Network Customer shall plan, construct, operate and maintain its facilities in accordance with Good Utility Practice and in conformance with the terms of the Tariff. The terms and conditions under which the Network Customer taking Local Network Service shall operate its facilities and the technical and operational matters associated with the implementation of Local Network Service shall be specified in Section II.22 of the Tariff and/or the Local Service Schedules.

SCHEDULE 21

ATTACHMENT A

FORM OF LOCAL SERVICE AGREEMENT

This LOCAL SERVICE AGREEMENT, dated as of _____, is entered into, by and between _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Transmission Owner"), _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Transmission Customer") and ISO New England, Inc., a non-stock corporation organized and existing under the laws of the State of Delaware ("ISO"). Under this Agreement the Transmission Owner, Transmission Customer, and the ISO each may be referred to as a "Party" or collectively as the "Parties."

PART I – General Terms and Conditions

1. Service Provided (Check applicable):

__ Local Network Service

__ Local Point-To-Point Service

__ Firm

__ Non-Firm

Regional Network Service customers must take either Local Network Service or Local Point-To-Point Service.

2. The Transmission Customer is an Eligible Customer under the Tariff and is a party to either a Market Participant Service Agreement or a Transmission Service Agreement.

3. The Transmission Customer has submitted a Completed Application and the required deposit, if applicable, for service under this Local Service Agreement and the Tariff.

4. The Transmission Customer agrees to supply information to the Transmission Owner that the Transmission Owner deems reasonably necessary in accordance with Schedule 21 and Good Utility Practice in order for it to receive the requested service.

5. The Transmission Owner agrees to provide and the Transmission Customer agrees to take and pay for service in accordance with the provisions of the Tariff and this Local Service Agreement.

6. Service may be subject to some combination of the charges detailed in Schedule 21 of the OATT. The appropriate charges will be determined in accordance with the terms and conditions of Schedule 21.

7. Any notice or request made to or by either party regarding this Local Service Agreement shall be made to the representative of the other party as indicated below.
Transmission Customer:

_____
_____
_____

Transmission Owner:

_____
_____
_____

The ISO:

_____
_____
_____

8. The ISO New England Inc. Transmission, Markets and Services Tariff (the "Tariff") is incorporated herein and made a part hereof. Capitalized terms used in this Local Service Agreement shall have the meanings ascribed in the Tariff.

9. Nothing contained in this Local Service Agreement shall be construed as affecting in any way the right of the Transmission Owner to file with the Commission under Section 205 of the Federal Power Act and pursuant to the Commission's rules and regulations promulgated thereunder for a change in any rates, terms and conditions of this Local Service Agreement. Nothing contained in this Local Service Agreement shall be construed as affecting in any way the ability of the Transmission Customer to file with the Commission under Section 206 of the Federal Power Act

and pursuant to the Commission's rules and regulations promulgated thereunder for a change in any rates, terms and conditions of this Local Service Agreement.

10. Nothing contained in this Local Service Agreement shall be construed as affecting or enlarging, in whole or in part, the limited responsibility of the ISO under the Transmission Operating Agreement ("TOA") to coordinate the Transmission Owner's provision of Local Service and to determine whether the provision of Local Service would have an impact on facilities used for the provision of Regional Transmission Service.

PART II – Local Network Service

1. The Transmission Customer has been determined by the Transmission Owner and the ISO to have a Completed Application for Local Network Service under the Tariff.

2. Service shall commence on the later of: (l) _____, or (2) the date on which construction of all interconnection equipment, any Direct Assignment Facilities and/or facility or Local Network Upgrades are completed, or (3) such other date as it is permitted to become effective by the Commission. Service shall terminate on _____.

3. Specifications for Local Network Service.

    a. Term of Service:

    b. List of Network Resources and Point(s) of Receipt:

    c. Description of capacity and energy to be transmitted:

    d. Description of Local Network Load:

    e. List of Point(s) of Delivery and metering point(s) when they differ from Point(s) of Delivery:

    f. List of non-Network Resource(s), to the extent known:

g. Ancillary Services requested or proof of satisfactory arrangements for Ancillary Services:

h. Identity of Designated Agent:

Authority of Designated Agent:

Term of Designated Agent's authority:

Division of responsibilities and obligations between Transmission Customer and Designated Agent:

i. Interconnection facilities and associated equipment:

j. Project name:

k. Interconnecting Transmission Customer:

l. Location:

m. Transformer nameplate rating:

n. Interconnection point:

o. Additional facilities and/or associated equipment:

p. Service under this Local Service Agreement shall be subject to the following charges:

q. Additional terms and conditions:

4. Planned work schedule.

Milestone (Activity)	Estimated Time Period For Completion (# of months)

5. Payment schedule and costs.

(Study grade estimate, +___% accuracy, year $s)

Milestone Amount ($)

6. Policy and practices for protection requirements for new or modified load interconnections.

7. Insurance requirements.

PART III – Local Point-To-Point Service

1. The Transmission Customer has been determined by the Transmission Owner and the ISO to have a Completed Application for Local Point-To-Point Service under the Tariff.

2. Service shall commence on the later of: (l) _____, or (2) the date on which construction of any Direct Assignment Facilities and/or Local Network Upgrades are completed, or (3) such other date as it is permitted to become effective by the Commission. Service shall terminate on _____.

3. Non-firm Local Point-To-Point Service shall be provided by the Transmission Owner upon request by an authorized representative of the Transmission Customer.

4. Specifications for Local Point-To-Point Service.

a. Term of Transaction:

b. Description of capacity and energy to be transmitted by the Transmission Owner including the electric Control Area in which the transaction originates:

c. Point(s) of Receipt:

d. Delivering Party:

e. Point(s) of Delivery:

f. Receiving Party:

g. Maximum amount of capacity and energy to be transmitted (Reserved Capacity):

h. Designation of party(ies) subject to reciprocal service obligation:

i. Name(s) of any intervening Control Areas providing transmission service:

j. Service under this Local Service Agreement shall be subject to the following charges:

k Interconnection facilities and associated equipment:

l. Project name:

m. Interconnecting Transmission Customer:

n. Location:

o. Transformer nameplate rating:

p. Interconnection point:

q. Additional facilities and/or associated equipment:

r. Additional terms and conditions:

5. Planned work schedule.

Milestone (Activity)	Estimated Time Period For Completion (# of months)

6. Payment schedule and costs.

(Study grade estimate, +___% accuracy, year $s)

Milestone	Amount ($)

7. Policy and practices for protection requirements for new or modified load interconnections.

8. Insurance requirements.

IN WITNESS WHEREOF, the Parties have caused this Local Service Agreement to be executed by their respective authorized officials.

Transmission Customer:

By:_____ _____ _____

Name Title Date

_____

Print Name

Transmission Owner:

By:_____ _____ _____

Name Title Date

_____

Print Name

The ISO:

By:_____ _____ _____

Name Title Date

_____Print Name

SCHEDULE 21

ATTACHMENT A-1

Form of Local Service Agreement For The Resale, Reassignment or Transfer of Point-To-Point Transmission Service

1.0 This LOCAL SERVICE AGREEMENT, dated as of _____, is entered into, by and between _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Transmission Owner"), _____ , a _____organized and existing under the laws of the State/Commonwealth of _____ ("Assignee") and ISO New England, Inc., a non-stock corporation organized and existing under the laws of the State of Delaware ("ISO"). Under this Agreement the Transmission Owner, Assignee, and the ISO each may be referred to as a "Party" or collectively as the "Parties."

2.0 The Assignee has been determined by the Transmission Owner to be an Eligible Customer under the Tariff pursuant to which the transmission service rights to be transferred were originally obtained.

3.0 The terms and conditions for the transaction entered into under this Local Service Agreement shall be subject to the terms and conditions of Part I of Schedule 21 and the Transmission Owner's Local Service Schedule of Tariff, except for those terms and conditions negotiated by the Reseller of the reassigned transmission capacity (pursuant to Section I.11.a of this Tariff) and the Assignee, to include: contract effective and termination dates, the amount of reassigned capacity or energy, point(s) of receipt and delivery. Changes by the Assignee to the Reseller's Points of Receipt and Points of Delivery will be subject to the provisions of Section I.11.b of this Tariff.

4.0 The Transmission Owner shall credit the Reseller for the price reflected in the Assignee's Local Service Agreement or the associated OASIS schedule.

5.0 Any notice or request made to or by either Party regarding this Local Service Agreement shall be made to the representative of the other Party as indicated below.

Transmission Owner:

_____

_____

_____

The ISO:

_____

_____

_____

Assignee:

_____

_____

_____

6.0 The Tariff is incorporated herein and made a part hereof.

IN WITNESS WHEREOF, the Parties have caused this Local Service Agreement to be executed by their respective authorized officials.

Transmission Owner:

By:_____ _____ _____

Print Name: Title: Date:

The ISO:

By:_____ _____ _____

Print Name: Title: Date:

Assignee:

By:_____ _____ _____

Print Name: Title: Date:

Specifications For The Resale, Reassignment Or Transfer of Long-Term Firm Point-To-Point Transmission Service

1.0 Term of Transaction: _____

Start Date: _____

Termination Date: _____

2.0 Description of capacity and energy to be transmitted by Transmission Owner including the electric Control Area in which the transaction originates.

_____

3.0 Point(s) of Receipt:_____

Delivering Party:_____

4.0 Point(s) of Delivery:_____

Receiving Party:_____

5.0 Maximum amount of reassigned capacity: _____

6.0 Designation of party(ies) subject to reciprocal service obligation:_____

_____

_____

_____

7.0 Name(s) of any Intervening Systems providing transmission service:_____

_____

(Name of Transmission Owner) Open Access Transmission Tariff

8.0 Service under this Agreement may be subject to some combination of the charges detailed below. (The appropriate charges for individual transactions will be determined in accordance with the terms and conditions of the Tariff.)

8.1 Transmission Charge:_____

_____

8.2 System Impact and/or Facilities Study Charge(s):

_____

_____

8.3 Direct Assignment Facilities Charge:_____

_____

8.4 Ancillary Services Charges: _____

_____

_____

_____

_____

_____

_____

9.0 Name of Reseller of the reassigned transmission capacity:

_____

STANDARD MARKET DESIGN

III.1 Market Operations

III.1.1 Introduction.

This Market Rule 1 sets forth the scheduling, other procedures, and certain general provisions applicable to the operation of the New England Markets within the New England Control Area. The ISO shall operate the New England Markets in compliance with NERC, NPCC and ISO reliability criteria. The ISO is the Counterparty for agreements and transactions with its Customers (including assignments involving Customers), including bilateral transactions described in Market Rule 1, and sales to the ISO and/or purchases from the ISO of energy, reserves, Ancillary Services, capacity, demand/load response, FTRs and other products, paying or charging (if and as applicable) its Customers the amounts produced by the pertinent market clearing process or through the other pricing mechanisms described in Market Rule 1. The bilateral transactions to which the ISO is the Counterparty (subject to compliance with the requirements of Section III.1.4) include, but are not limited to, Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). Notwithstanding the foregoing, the ISO will not act as Counterparty for the import into the New England Control Area, for the use of Publicly Owned Entities, of: (1) energy, capacity, and ancillary products associated therewith, to which the Publicly Owned Entities are given preference under Articles 407 and 408 of the project license for the New York Power Authority's Niagara Project; and (2) energy, capacity, and ancillary products associated therewith, to which Publicly Owned Entities are entitled under Article 419 of the project license for the New York Power Authority's Franklin D. Roosevelt – St. Lawrence Project. This Market Rule 1 addresses each of the three time frames pertinent to the daily operation of the New England Markets: "Pre-scheduling" as specified in Section III.1.9, "Scheduling" as specified in III.1.10, and "Dispatch" as specified in III.1.11. This Market Rule 1 became effective on February 1, 2005.

III.1.2 [Reserved.]

III.1.3 Definitions.

Whenever used in Market Rule 1, in either the singular or plural number, capitalized terms shall have the meanings specified in Section I of the Tariff. Terms used in Market Rule 1 that are not defined in Section

I shall have the meanings customarily attributed to such terms by the electric utility industry in New England or as defined elsewhere in the ISO New England Filed Documents. Terms used in Market Rule 1 that are defined in Section I are subject to the 60% Participant Vote threshold specified in Section 11.1.2 of the Participants Agreement.

III.1.3.1 [Reserved.]

III.1.3.2 [Reserved.]

III.1.3.3 [Reserved.]

III.1.4 Requirements for Certain Transactions.

III.1.4.1 ISO Settlement of Certain Transactions.

The ISO will settle, and act as Counterparty to, the transactions described in Section III.1.4.2 if the transactions (and their related transactions) conform to, and the transacting Market Participants comply with, the requirements specified in Section III.1.4.3.

III.1.4.2 Transactions Subject to Requirements of Section III.1.4.

Transactions that must conform to the requirements of Section III.1.4 include: Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). The foregoing are referred to collectively as "Section III.1.4 Transactions," and individually as a "Section III.1.4 Transaction." Transactions that conform to the standards are referred to collectively as "Section III.1.4 Conforming Transactions," and individually as a "Section III.1.4 Conforming Transaction."

III.1.4.3 Requirements for Section III.1.4 Conforming Transactions.

(a) To qualify as a Section III.1.4 Conforming Transaction, a Section III.1.4 Transaction must constitute an exchange for an off-market transaction (a "Related Transaction"), where the Related Transaction:

(i) is not cleared or settled by the ISO as Counterparty;

(ii) is a spot, forward or derivatives contract that contemplates the transfer of energy or a MW obligation to or from a Market Participant;

(iii) involves commercially appropriate obligations that impose a duty to transfer electricity or a MW obligation from the seller to the buyer, or from the buyer to the seller, with performance taking place within a reasonable time in accordance with prevailing cash market practices; and

(iv) is not contingent on either party to carry out the Section III.1.4 Transaction.

(b) In addition, to qualify as a Section III.1.4 Conforming Transaction:

(i) the Section III.1.4 Transaction must be executed between separate beneficial owners or separate parties trading for independently controlled accounts;

(ii) the Section III.1.4 Transaction and the Related Transaction must be separately identified in the records of the parties to the transactions; and

(iii) the Section III.1.4 Transaction must be separately identified in the records of the ISO.

(c) As further requirements:

(i) each party to the Section III.1.4 Transaction and Related Transaction must maintain, and produce upon request of the ISO, records demonstrating compliance with the requirements of Sections III.1.4.3(a) and (b) for the Section III.1.4 Transaction, the Related Transaction and any other transaction that is directly related to, or integrated in any way with, the Related Transaction, including the identity of the counterparties and the material economic terms of the transactions including their price, tenor, quantity and execution date; and

(ii) each party to the Section III.1.4 Transaction must be a Market Participant that meets all requirements of the ISO New England Financial Assurance Policy.

III.1.5 Resource Auditing.

III.1.5.1 Claimed Capability Audits.

III.1.5.1.1 General Audit Requirements.

(a) The following types of Claimed Capability Audits may be performed:

(i) An Establish Claimed Capability Audit establishes the Generator Asset's ability to respond to ISO Dispatch Instructions and to maintain performance at a specified output level for a specified duration.

(ii) A Seasonal Claimed Capability Audit determines a Generator Asset's capability to perform under specified summer and winter conditions for a specified duration.

(iii) A Seasonal DR Audit determines the ability of a Demand Response Resource to perform during specified months for a specified duration.

(iv) An ISO-Initiated Claimed Capability Audit is conducted by the ISO to verify the Generator Asset's Establish Claimed Capability Audit value or the Demand Response Resource's Seasonal DR Audit value.

(b) The Claimed Capability Audit value of a Generator Asset shall reflect any limitations based upon the interdependence of common elements between two or more Generator Assets such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(c) The Claimed Capability Audit value of gas turbine, combined cycle, and pseudo-combined cycle assets shall be normalized to standard 90° (summer) and 20° (winter) temperatures.

(d) The Claimed Capability Audit value for steam turbine assets with steam exports, combined cycle, or pseudo-combined cycle assets with steam exports where steam is exported for uses external to the electric power facility, shall be normalized to the facility's Seasonal Claimed Capability steam demand.

(e) A Claimed Capability Audit may be denied or rescheduled by the ISO if its performance will jeopardize the reliable operation of the electrical system.

III.1.5.1.2 Establish Claimed Capability Audit.

(a) An Establish Claimed Capability Audit may be performed only by a Generator Asset.

(b) The time and date of an Establish Claimed Capability Audit shall be unannounced.

(c) For a newly commercial Generator Asset:

(i) An Establish Claimed Capability Audit will be scheduled by the ISO within five Business Days of the commercial operation date for all Generator Assets except:

1. Non-intermittent daily cycle hydro;
2. Non-intermittent net-metered, or special qualifying facilities that do not elect to audit as described in Section III.1.5.1.3; and
3. Intermittent Generator Assets

(ii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iii) The Establish Claimed Capability Audit values shall be effective as of the commercial operation date of the Generator Asset.

(d) For Generator Assets with an Establish Claimed Capability Audit value:

(i) An Establish Claimed Capability Audit may be performed at the request of a Market Participant in order to support a change in the summer and winter Establish Claimed Capability Audit values for a Generator Asset.

(ii) An Establish Claimed Capability Audit shall be performed within five Business Days of the date of the request.

(iii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iv) The Establish Claimed Capability Audit values become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(e) An Establish Claimed Capability Audit value may not exceed the maximum interconnected flow specified in the Network Resource Capability for the resource associated with the Generator Asset.

(f) Establish Claimed Capability Audits shall be performed on non-NERC holiday weekdays between 0800 and 2200.

(g) To conduct an Establish Claimed Capability Audit, the ISO shall:

(i) Initiate an Establish Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset's net output to increase from the current operating level to its Real-Time High Operating Limit.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) Begin the audit with the first full clock hour after sufficient time has been allowed for the asset to ramp, based on its offered ramp rate from its current operating point to reach its Real-Time High Operating Limit.

(h) An Establish Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an Establish Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4
Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4

Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(i) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.2(h).

III.1.5.1.3. Seasonal Claimed Capability Audits.

(a) A Seasonal Claimed Capability Audit may be performed only by a Generator Asset.

(b) A Seasonal Claimed Capability Audit must be conducted by all Generator Assets except:

(i) Non-intermittent daily hydro; and

(ii) Intermittent, net-metered, and special qualifying facilities. Non-intermittent net-metered and special qualifying facilities may elect to perform Seasonal Claimed Capability Audits pursuant to Section III.1.7.11(c)(iv).

(c) An Establish Claimed Capability Audit or ISO-Initiated Claimed Capability Audit that meets the requirements of a Seasonal Claimed Capability Audit in this Section III.1.5.1.3 may be used to fulfill a Generator Asset's Seasonal Claimed Capability Audit obligation.

(d) Except as provided in Section III.1.5.1.3(n) below, a summer Seasonal Claimed Capability Audit must be conducted:

(i) At least once every Capability Demonstration Year;

(ii) Either (1) at a mean ambient temperature during the audit that is greater than or equal to 80 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced summer Seasonal Claimed Capability Audit window.

(e) A winter Seasonal Claimed Capability Audit must be conducted:

(i) At least once in the previous three Capability Demonstration Years, except that a newly commercial Generator Asset which becomes commercial on or after:

(1) September 1 and prior to December 31 shall perform a winter Seasonal Claimed Capability Audit prior to the end of that Capability Demonstration Year.

(2) January 1 shall perform a winter Seasonal Claimed Capability Audit prior to the end of the next Capability Demonstration Year.

(ii) Either (1) at a mean ambient temperature during the audit that is less than or equal to 32 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced winter Seasonal Claimed Capability Audit window.

(f) A Seasonal Claimed Capability Audit shall be performed by operating the Generator Asset for the audit time period and submitting to the ISO operational data that meets the following requirements:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal Claimed Capability Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal Claimed Capability Audit and other relevant operating data.

(g) The Seasonal Claimed Capability Audit value (summer or winter) will be the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(h) The Seasonal Claimed Capability Audit value (summer or winter) shall be the most recent audit data submitted to the ISO meeting the requirements of this Section III.1.5.1.3. In the event that a Market Participant fails to submit Seasonal Claimed Capability Audit data to meet the timing requirements in Section III.1.5.1.3(d) and (e), the Seasonal Claimed Capability Audit value for the season shall be set to zero.

(i) The Seasonal Claimed Capability Audit value shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(j) A Seasonal Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for a Seasonal Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	2
Combined Cycle	2

Integrated Coal Gasification Combustion Cycle	2
Pressurized Fluidized Bed Combustion	2
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine-Reversible (Electric Storage) Hydraulic Turbine-Other	2
Hydro-Conventional Weekly	2
Fuel Cell	1
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(k) A Generator Asset that is on a planned outage that was approved in the ISO's annual maintenance scheduling process during all hours that meet the temperature requirements for a Seasonal Claimed Capability Audit that is to be performed by the asset during that Capability Demonstration Year shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these auditing requirements;

(ii) Have its Seasonal Claimed Capability Audit value for the season set to zero; and

(iii) Perform the required Seasonal Claimed Capability Audit on the next available day that meets the Seasonal Claimed Capability Audit temperature requirements.

(l) A Generator Asset that does not meet the auditing requirements of this Section III.1.5.1.3 because (1) every time the temperature requirements were met at the Generator Asset's location the ISO denied the request to operate to full capability, or (2) the temperature requirements were not met at the Generator Asset's location during the Capability Demonstration Year during which the asset was required to perform a Seasonal Claimed Capability Audit during the hours 0700 to 2300 for each weekday excluding those weekdays that are defined as NERC holidays, shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these temperature requirements, including verifiable temperature data;

(ii) Retain the current Seasonal Claimed Capability Audit value for the season; and

(iii) Perform the required Seasonal Claimed Capability Audit during the next Capability Demonstration Year.

(m) The ISO may issue notice of a summer or winter Seasonal Claimed Capability Audit window for some or all of the New England Control Area if the ISO determines that weather forecasts indicate that temperatures during the audit window will meet the summer or winter Seasonal

Claimed Capability Audit temperature requirements. A notice shall be issued at least 48 hours prior to the opening of the audit window. Any audit performed during the announced audit window shall be deemed to meet the temperature requirement for the summer or winter audit. In the event that five or more audit windows for the summer Seasonal Claimed Capability Audit temperature requirement, each of at least a four hour duration between 0700 and 2300 and occurring on a weekday excluding those weekdays that are defined as NERC holidays, are not opened for a Generator Asset prior to August 15 during a Capability Demonstration Year, a two-week audit window shall be opened for that Generator Asset to perform a summer Seasonal Claimed Capability Audit, and any audit performed by that Generator Asset during the open audit window shall be deemed to meet the temperature requirement for the summer Seasonal Claimed Capability Audit. The open audit window shall be between 0700 and 2300 each day during August 15 through August 31.

(n) A Market Participant that is required to perform testing on a Generator Asset that is in addition to a summer Seasonal Claimed Capability Audit may notify the ISO that the summer Seasonal Claimed Capability Audit was performed in conjunction with this additional testing, provided that:

(i) The notification shall be provided at the time the Seasonal Claimed Capability Audit data is submitted under Section III.1.5.1.3(f).

(ii) The notification explains the nature of the additional testing and that the summer Seasonal Claimed Capability Audit was performed while the Generator Asset was online to perform this additional testing.

(iii) The summer Seasonal Claimed Capability Audit and additional testing are performed during the months of June, July or August between the hours of 0700 and 2300.

(iv) In the event that the summer Seasonal Claimed Capability Audit does not meet the temperature requirements of Section III.1.5.1.3(d)(ii), the summer Seasonal Claimed Capability Audit value may not exceed the summer Seasonal Claimed Capability Audit value from the prior Capability Demonstration Year.

(v) This Section III.1.5.1.3(n) may be utilized no more frequently than once every three Capability Demonstration Years for a Generator Asset.

(o) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.3(j).

III.1.5.1.3.1 Seasonal DR Audits.

(a) A Seasonal DR Audit may be performed only by a Demand Response Resource.

(b) A Seasonal DR Audit shall be performed for 12 contiguous five-minute intervals.

(c) A summer Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of April through November;

(d) A winter Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of December through March.

(e) A Seasonal DR Audit may be performed either:

(i) At the request of a Market Participant as described in subsection (f) below; or

(ii) By the Market Participant designating a period of dispatch after the fact as described in subsection (g) below.

(f) If a Market Participant requests a Seasonal DR Audit:

(i) The ISO shall perform the Seasonal DR Audit at an unannounced time between 0800 and 2200 on non-NERC holiday weekdays within five Business Days of the date of the request.

(ii) The ISO shall initiate the Seasonal DR Audit by issuing a Dispatch Instruction ordering the Demand Response Resource to its Maximum Reduction.

(iii) The ISO shall indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iv) The ISO shall begin the audit with the start of the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(g) If the Seasonal DR Audit is performed by the designation of a period of dispatch after the fact, the designated period must meet all of the requirements in this Section III.1.5.1.3.1 and:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal DR Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal DR Audit.

(iii) The demonstration period may begin with the start of any five-minute interval after the completion of the Demand Response Resource Notification Time.

(iv) A CLAIM10 audit or CLAIM30 audit that meets the requirements of a Seasonal DR Audit as provided in this Section III.1.5.1.3.1 may be used to fulfill the Seasonal DR Audit obligation of a Demand Response Resource.

(h) An ISO-Initiated Claimed Capability Audit fulfils the Seasonal DR Audit obligation of a Demand Response Resource.

(i) Each Demand Response Asset associated with a Demand Response Resource is evaluated during the Seasonal DR Audit of the Demand Response Resource.

(j) Any Demand Response Asset on a forced or scheduled curtailment as defined in Section III.8.3 is assessed a zero audit value.

(k) The Seasonal DR Audit value (summer or winter) of a Demand Response Resource resulting from the Seasonal DR Audit shall be the sum of the average demand reductions demonstrated during the audit by each of the Demand Response Resource's constituent Demand Response Assets.

(l) If a Demand Response Asset is added to or removed from a Demand Response Resource between audits, the Demand Response Resource's capability shall be updated to reflect the inclusion or exclusion of the audit value of the Demand Response Asset, such that at any point in time the summer or winter Seasonal DR Audit value of a Demand Response Resource shall equal the sum of the most recent valid like-season audit values of its constituent Demand Response Assets.

(m) The Seasonal DR Audit value shall become effective one calendar day following notification of the audit results to the Market Participant by the ISO.

(n) The summer or winter audit value of a Demand Response Asset shall be set to zero at the end of the Capability Demonstration Year if the Demand Response Asset did not perform a Seasonal DR Audit for that season as part of a Demand Response Resource during that Capability Demonstration Year.

(o) For a Demand Response Asset that was associated with a "Real-Time Demand Response Resource" or a "Real-Time Emergency Generation Resource," as those terms were defined prior to June 1, 2018, any valid result from an audit conducted prior to June 1, 2018 shall continue to be valid on June 1, 2018, and shall retain the same expiration date.

III.1.5.1.4. ISO-Initiated Claimed Capability Audits.

(a) An ISO-Initiated Claimed Capability Audit may be performed by the ISO at any time.

(b) An ISO-Initiated Claimed Capability Audit value shall replace either the summer or winter Seasonal DR Audit value for a Demand Response Resource and shall replace both the winter and summer Establish Claimed Capability Audit values for a Generator Asset, normalized for temperature and steam exports, except:

(i) The Establish Claimed Capability Audit values for a Generator Asset may not exceed the maximum interconnected flow specified in the Network Resource Capability for that resource.

(ii) An ISO-Initiated Claimed Capability Audit value for a Generator Asset shall not set the winter Establish Claimed Capability Audit value unless the ISO-Initiated Claimed Capability Audit was performed at a mean ambient temperature that is less than or equal to 32 degrees Fahrenheit at the Generator Asset location.

(c) If for a Generator Asset a Market Participant submits pressure and relative humidity data for the previous Establish Claimed Capability Audit and the current ISO-Initiated Claimed Capability Audit, the Establish Claimed Capability Audit values derived from the ISO-Initiated Claimed Capability Audit will be normalized to the pressure of the previous Establish Claimed Capability Audit and a relative humidity of 64%.

(d) The audit values derived from the ISO-Initiated Claimed Capability Audit shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(e) To conduct an ISO-Initiated Claimed Capability Audit, the ISO shall:

(i) Initiate an ISO-Initiated Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset to its Real-Time High Operating Limit or the Demand Response Resource to its Maximum Reduction.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) For Generator Assets, begin the audit with the first full clock hour after sufficient time has been allowed for the Generator Asset to ramp, based on its offered ramp rate, from its current operating point to its Real-Time High Operating Limit.

(iv) For Demand Response Resources, begin the audit with the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(f) An ISO-Initiated Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an ISO-Initiated Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4

Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine – Reversible)	2
Demand Response Resource	1

(g) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for an Asset or Resource type not listed in Section III.1.5.1.4(f).

III.1.5.2 ISO-Initiated Parameter Auditing.

(a) The ISO may perform an audit of any Supply Offer, Demand Reduction Offer or other operating parameter that impacts the ability of a Generator Asset or Demand Response Resource to provide real-time energy or reserves.

(b) Generator audits shall be performed using the following methods for the relevant parameter:

(i) **Economic Maximum Limit**. The Generator Asset shall be evaluated based upon its ability to achieve the current offered Economic Maximum Limit value, through a review of historical dispatch data or based on a response to a current ISO-issued Dispatch Instruction.

(ii) **Manual Response Rate**. The Generator Asset shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Manual Response Rate, including hold points and changes in Manual Response Rates.

(iii) **Start-Up Time**. The Generator Asset shall be evaluated based upon its ability to achieve the offered Start-Up Time.

(iv) **Notification Time**. The Generator Asset shall be evaluated based upon its ability to close its output breaker within its offered Notification Time.

(v) **CLAIM10**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(vii) **Automatic Response Rate**. The Generator Asset shall be analyzed, based upon a review of historical performance data, for its ability to respond to four-second electronic Dispatch Instructions.

(viii) **Dual Fuel Capability**. A Generator Asset that is capable of operating on multiple fuels may be required to audit on a specific fuel, as set out in Section III.1.5.2(f).

(c) Demand Response Resource audits shall be performed using the following methods:

(i) **Maximum Reduction**. The Demand Response Resource shall be evaluated based upon its ability to achieve the current offered Maximum Reduction value, through a review of historical dispatch data or based on a response to a current Dispatch Instruction.

(ii) **Demand Response Resource Ramp Rate**. The Demand Response Resource shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Demand Response Resource Ramp Rate.

(iii) **Demand Response Resource Start-Up Time**. The Demand Response Resource shall be evaluated based upon its ability to achieve its Minimum Reduction within the offered Demand Response Resource Start-Up Time, in response to a Dispatch Instruction and after completing its Demand Response Resource Notification Time.

(iv) **Demand Response Resource Notification Time**. The Demand Response Resource shall be evaluated based upon its ability to start reducing demand within its offered Demand Response Resource Notification Time, from the receipt of a Dispatch Instruction when the Demand Response Resource was not previously reducing demand.

(v) **CLAIM10**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(d) To conduct an audit based upon historical data, the ISO shall:

(i) Obtain data through random sampling of generator or Demand Response Resource performance in response to Dispatch Instructions; or

(ii) Obtain data through continual monitoring of generator or Demand Response Resource performance in response to Dispatch Instructions.

(e) To conduct an unannounced audit, the ISO shall initiate the audit by issuing a Dispatch Instruction ordering the Generator Asset or Demand Response Resource to change from the current operating level to a level that permits the ISO to evaluate the performance of the Generator Asset or Demand Response Resource for the parameters being audited.

(f) To conduct an audit of the capability of a Generator Asset described in Section III.1.5.2(b)(viii) to run on a specific fuel:

(i) The ISO shall notify the Lead Market Participant if a Generator Asset is required to undergo an audit on a specific fuel. The ISO, in consultation with the Lead Market Participant, shall develop a plan for the audit.

(ii) The Lead Market Participant will have the ability to propose the time and date of the audit within the ISO's prescribed time frame and must notify the ISO at least five Business Days in advance of the audit, unless otherwise agreed to by the ISO and the Lead Market Participant.

(g) To the extent that the audit results indicate a Market Participant is providing Supply Offer, Demand Reduction Offer or other operating parameter values that are not representative of the actual capability of the Generator Asset or Demand Response Resource, the values for the Generator Asset or Demand Response Resource shall be restricted to those values that are supported by the audit.

(h) In the event that a Generator Asset or Demand Response Resource has had a parameter value restricted:

(i) The Market Participant may submit a restoration plan to the ISO to restore that parameter. The restoration plan shall:

1. Provide an explanation of the discrepancy;
2. Indicate the steps that the Market Participant will take to re-establish the parameter's value;
3. Indicate the timeline for completing the restoration; and
4. Explain the testing that the Market Participant will undertake to verify restoration of the parameter value upon completion.

(ii) The ISO shall:

1. Accept the restoration plan if implementation of the plan, including the testing plan, is reasonably likely to support the proposed change in the parameter value restriction;
2. Coordinate with the Market Participant to perform required testing upon completion of the restoration; and
3. Modify the parameter value restriction following completion of the restoration plan, based upon tested values.

III.1.5.3 Reactive Capability Audits.

(a) Two types of Reactive Capability Audits may be performed:

(i) A lagging Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to provide reactive power to the transmission system at a specified real power output or consumption.

(ii) A leading Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to absorb reactive power from the transmission system at a specified real power output or consumption.

(b) The ISO shall develop a list of Reactive Resources that must conduct Reactive Capability Audits. The list shall include Reactive Resources that: (i) have a gross individual nameplate rating greater than 20 MVA; (ii) are directly connected, or are connected through equipment designed primarily for delivering real or reactive power to an interconnection point, to the transmission system at a voltage of 100 kV or above; and (iii) are not exempted from providing voltage control by the ISO. Additional criteria to be used in adding a Reactive Resource to the list includes, but is not limited to, the effect of the Reactive Resource on System Operating Limits, Interconnection Reliability Operating Limits, and local area voltage limits during the following operating states: normal, emergency, and system restoration.

(c) Unless otherwise directed by the ISO, Reactive Resources that are required to perform Reactive Capability Audits shall perform both a lagging Reactive Capability Audit and a leading Reactive Capability Audit.

(d) All Reactive Capability Audits shall meet the testing conditions specified in the ISO New England Operating Documents.

(e) The Reactive Capability Audit value of a Reactive Resource shall reflect any limitations based upon the interdependence of common elements between two or more Reactive Resources such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(f) A Reactive Capability Audit may be denied or rescheduled by the ISO if conducting the Reactive Capability Audit could jeopardize the reliable operation of the electrical system.

(g) Reactive Capability Audits shall be conducted at least every five years, unless otherwise required by the ISO. The ISO may require a Reactive Resource to conduct Reactive Capability Audits more often than every five years if:

(i) there is a change in the Reactive Resource that may affect the reactive power capability of the Reactive Resource;

(ii) there is a change in electrical system conditions that may affect the achievable reactive power output or absorption of the Reactive Resource; or

(iii) historical data shows that the amount of reactive power that the Reactive Resource can provide to or absorb from the transmission system is higher or lower than the latest audit data.

(h) A Lead Market Participant or Transmission Owner may request a waiver of the requirement to conduct a Reactive Capability Audit for its Reactive Resource. The ISO, at its sole discretion, shall determine whether and for how long a waiver may be granted.

III.1.6 [Reserved.]

III.1.6.1 [Reserved.]

III.1.6.2 [Reserved.]

III.1.6.3 [Reserved.]

III.1.6.4 ISO New England Manuals and ISO New England Administrative Procedures.

The ISO shall prepare, maintain and update the ISO New England Manuals and ISO New England Administrative Procedures consistent with the ISO New England Filed Documents. The ISO New England Manuals and ISO New England Administrative Procedures shall be available for inspection by the Market Participants, regulatory authorities with jurisdiction over the ISO or any Market Participant, and the public.

III.1.7 General.

III.1.7.1 Provision of Market Data to the Commission.

The ISO will electronically deliver to the Commission, on an ongoing basis and in a form and manner consistent with its collection of data and in a form and manner acceptable to the Commission, data related to the markets that it administers, in accordance with the Commission's regulations.

III.1.7.2 [Reserved.]

III.1.7.3 Agents.

A Market Participant may participate in the New England Markets through an agent, provided that such Market Participant informs the ISO in advance in writing of the appointment of such agent. A Market Participant using an agent shall be bound by all of the acts or representations of such agent with respect to transactions in the New England Markets, and shall ensure that any such agent complies with the

requirements of the ISO New England Manuals and ISO New England Administrative Procedures and the ISO New England Filed Documents.

III.1.7.4 [Reserved.]

III.1.7.5 Transmission Constraint Penalty Factors.

In the Day-Ahead Energy Market, the Transmission Constraint Penalty Factor for an interface constraint is $10,000/MWh and the Transmission Constraint Penalty Factor for all other transmission constraints is $30,000/MWh. In the Real-Time Energy Market, the Transmission Constraint Penalty Factor for any transmission constraint is $30,000/MWh. Transmission Constraint Penalty Factors are not used in calculating Locational Marginal Prices.

III.1.7.6 Scheduling and Dispatching.

(a) The ISO shall schedule Day-Ahead and schedule and dispatch in Real-Time Resources economically on the basis of least-cost, security-constrained dispatch and the prices and operating characteristics offered by Market Participants. The ISO shall schedule and dispatch sufficient Resources of the Market Participants to serve the New England Markets energy purchase requirements under normal system conditions of the Market Participants and meet the requirements of the New England Control Area for ancillary services provided by such Resources. The ISO shall use a joint optimization process to serve Real-Time Energy Market energy requirements and meet Real-Time Operating Reserve requirements based on a least-cost, security-constrained economic dispatch.

(b) In the event that one or more Resources cannot be scheduled in the Day-Ahead Energy Market on the basis of a least-cost, security-constrained dispatch as a result of one or more Self-Schedule offers contributing to a transmission limit violation, the following scheduling protocols will apply:

(i) When a single Self-Schedule offer contributes to a transmission limit violation, the Self-Schedule offer will not be scheduled for the entire Self-Schedule period in development of Day-Ahead schedules.

(ii) When two Self-Schedule offers contribute to a transmission limit violation, parallel clearing solutions will be executed such that, for each solution, one of the Self-Schedule offers

will be omitted for its entire Self-Schedule period. The least cost solution will be used for purposes of determining which Resources are scheduled in the Day-Ahead Energy Market.

(iii) When three or more Self-Schedule offers contribute to a transmission limit violation, the ISO will determine the total daily MWh for each Self-Schedule offer and will omit Self-Schedule offers in their entirety, in sequence from the offer with the least total daily MWh to the offer with the greatest total MWh, stopping when the transmission limit violation is resolved.

(c) Scheduling and dispatch shall be conducted in accordance with the ISO New England Filed Documents.

(d) The ISO shall undertake, together with Market Participants, to identify any conflict or incompatibility between the scheduling or other deadlines or specifications applicable to the New England Markets, and any relevant procedures of another Control Area, or any tariff (including the Transmission, Markets and Services Tariff). Upon determining that any such conflict or incompatibility exists, the ISO shall propose tariff or procedural changes, or undertake such other efforts as may be appropriate, to resolve any such conflict or incompatibility.

III.1.7.7 Energy Pricing.

The price paid for energy, including demand reductions, bought and sold by the ISO in the New England Markets will reflect the Locational Marginal Price at each Location, determined by the ISO in accordance with the ISO New England Filed Documents. Congestion Costs, which shall be determined by differences in the Congestion Component of Locational Marginal Prices caused by constraints, shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1. Loss costs associated with Pool Transmission Facilities, which shall be determined by the differences in Loss Components of the Locational Marginal Prices shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1.

III.1.7.8 Market Participant Resources.

A Market Participant may elect to Self-Schedule its Resources in accordance with and subject to the limitations and procedures specified in this Market Rule 1 and the ISO New England Manuals.

III.1.7.9 Real-Time Reserve Prices.

The price paid by the ISO for the provision of Real-Time Operating Reserve in the New England Markets will reflect Real-Time Reserve Clearing Prices determined by the ISO in accordance with the ISO New England Filed Documents for the system and each Reserve Zone.

III.1.7.10 Other Transactions.

Market Participants may enter into internal bilateral transactions and External Transactions for the purchase or sale of energy or other products to or from each other or any other entity, subject to the obligations of Market Participants to make resources with a Capacity Supply Obligation available for dispatch by the ISO. External Transactions that contemplate the physical transfer of energy or obligations to or from a Market Participant shall be reported to and coordinated with the ISO in accordance with this Market Rule 1 and the ISO New England Manuals.

III.1.7.11 Seasonal Claimed Capability of a Generating Capacity Resource.

(a) A Seasonal Claimed Capability value must be established and maintained for all Generating Capacity Resources. A summer Seasonal Claimed Capability is established for use from June 1 through September 30 and a winter Seasonal Claimed Capability is established for use from October 1 through May 31.

(b) The Seasonal Claimed Capability of a Generating Capacity Resource is the sum of the Seasonal Claimed Capabilities of the Generator Assets that are associated with the Generating Capacity Resource.

(c) The Seasonal Claimed Capability of a Generator Asset is:

(i) Based upon review of historical data for non-intermittent daily cycle hydro.

(ii) The median net real power output during reliability hours, as described in Section III.13.1.2.2.2, for (1) intermittent facilities, and (2) net-metered and special qualifying facilities that do not elect to audit, as reflected in hourly revenue metering data.

(iii) For non-intermittent net-metered and special qualifying facilities that elect to audit, the minimum of (1) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3; (2) the Generator Asset's current Establish Claimed Capability Audit value; and (3) the median hourly availability during hours ending 2:00 p.m. through 6:00 p.m. each day of the preceding June through September for Summer and hours ending 6:00 p.m. and 7:00 p.m. each day of the preceding October through May for Winter. The hourly availability:

a. For a Generator Asset that is available for commitment and following Dispatch Instructions, shall be the asset's Economic Maximum Limit, as submitted or redeclared.

b. For a Generator Asset that is off-line and not available for commitment shall be zero.

c. For a Generator Asset that is on-line but not able to follow Dispatch Instructions, shall be the asset's metered output.

(iv) For all other Generator Assets, the minimum of: (1) the Generator Asset's current Establish Claimed Capability Audit value and (2) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3.

III.1.7.12 Seasonal DR Audit Value of an Active Demand Capacity Resource.

(a) A Seasonal DR Audit value must be established and maintained for all Active Demand Capacity Resources. A summer Seasonal DR Audit value is established for use from April 1 through November 30 and a winter Seasonal DR Audit value is established for use from December 1 through March 31.

(b) The Seasonal DR Audit value of an Active Demand Capacity Resource is the sum of the Seasonal DR Audit values of the Demand Response Resources that are associated with the Active Demand Capacity Resource.

III.1.7.13 [Reserved.]

III.1.7.14 [Reserved.]

III.1.7.15 [Reserved.]

III.1.7.16 [Reserved.]

III.1.7.17 Operating Reserve.

The ISO shall endeavor to procure and maintain an amount of Operating Reserve in Real-Time equal to the system and zonal Operating Reserve requirements as specified in the ISO New England Manuals and ISO New England Administrative Procedures. Reserve requirements for the Forward Reserve Market are determined in accordance with the methodology specified in Section III.9.2 of Market Rule 1. Operating Reserve requirements for Real-Time dispatch within an Operating Day are determined in accordance with Market Rule 1 and ISO New England Operating Procedure No. 8, Operating Reserve and Regulation.

III.1.7.18 Ramping.

A Generator Asset, Dispatchable Asset Related Demand, or Demand Response Resource dispatched by the ISO pursuant to a control signal appropriate to increase or decrease the Resource's megawatt output, consumption, or demand reduction level shall be able to change output, consumption, or demand

reduction at the ramping rate specified in the Offer Data submitted to the ISO for that Resource and shall be subject to sanctions for failure to comply as described in **Appendix B**.

III.1.7.19 Real-Time Reserve Designation.

The ISO shall determine the Real-Time Reserve Designation for each eligible Resource in accordance with this Section III.1.7.19. The Real-Time Reserve Designation shall consist of a MW value, in no case less than zero, for each Operating Reserve product: Ten-Minute Spinning Reserve, Ten-Minute Non-Spinning Reserve, and Thirty-Minute Operating Reserve.

III.1.7.19.1 Eligibility.

To be eligible to receive a Real-Time Reserve Designation, a Resource must meet all of the criteria enumerated in this Section III.1.7.19.1. A Resource that does not meet all of these criteria is not eligible to provide Operating Reserve and will not receive a Real-Time Reserve Designation.

(1) The Resource must be a Dispatchable Resource located within the metered boundaries of the New England Control Area and capable of receiving and responding to electronic Dispatch Instructions.

(2) The Resource must not be part of the first contingency supply loss.

(3) The Resource must not be designated as constrained by transmission limitations.

(4) The Resource's Operating Reserve, if activated, must be sustainable for at least one hour from the time of activation. (This eligibility requirement does not affect a Resource's obligation to follow Dispatch Instructions, even after one hour from the time of activation.)

(5) The Resource must comply with the applicable standards and requirements for provision and dispatch of Operating Reserve as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

III.1.7.19.2 Calculation of Real-Time Reserve Designation.

III.1.7.19.2.1 Generator Assets.

III.1.7.19.2.1.1 On-line Generator Assets.

The Manual Response Rate used in calculations in this section shall be the lesser of the Generator Asset's offered Manual Response Rate and its audited Manual Response Rate as described in Section III.1.5.2.

(a) **Ten-Minute Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit). For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Non-Spinning Reserve shall be zero. For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit).

(c) **Thirty-Minute Operating Reserve.** For an on-line Generator Asset, Thirty-Minute Operating Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within thirty minutes given its Manual Response Rate (and in no case greater than its Economic Maximum Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (b) above.

III.1.7.19.2.1.2 Off-line Generator Assets.

For an off-line Generator Asset that is not a Fast Start Generator, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Fast Start Generator's Offered CLAIM10, its CLAIM10, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Ten-Minute Non-Spinning Reserve shall be zero, except during the last ten minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Ten-Minute Non-Spinning Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires).

(c) **Thirty-Minute Operating Reserve.** For an off-line Fast Start Generator, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Fast Start Generator's Offered CLAIM30, its CLAIM30, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Thirty-Minute Operating Reserve shall be zero, except during the last thirty minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Thirty-Minute Operating Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires), minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Fast Start Generator pursuant to subsection (b) above.

III.1.7.19.2.2 Dispatchable Asset Related Demand.

III.1.7.19.2.2.1 Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Storage DARD, Ten-Minute Spinning Reserve shall be calculated as the absolute value of the amount of current telemetered consumption.

(b) **Ten-Minute Non-Spinning Reserve.** For a Storage DARD, Ten-Minute Non-Spinning Reserve shall be zero.

(c) **Thirty-Minute Operating Reserve.** For a Storage DARD, Thirty-Minute Operating Reserve shall be zero.

III.1.7.19.2.2.2 Dispatchable Asset Related Demand Other Than Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit). For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit).

(c) **Thirty-Minute Operating Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (a) above. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Non-Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (b) above.

III.1.7.19.2.3 Demand Response Resources.

For a Demand Response Resource that does not provide one-minute telemetry to the ISO, notwithstanding any provision in this Section III.1.7.19.2.3 to the contrary, the Ten-Minute Spinning Reserve and Ten-Minute Non-Spinning Reserve components of the Real-Time Reserve Designation shall

be zero. The Demand Response Resource Ramp Rate used in calculations in this section shall be the lesser of the Resource's offered Demand Response Resource Ramp Rate and its audited Demand Response Resource Ramp Rate as described in Section III.1.5.2.

III.1.7.19.2.3.1 Dispatched.

(a) **Ten-Minute Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction). For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction).

(c) **Thirty-Minute Operating Reserve.** For a Demand Response Resource that is being dispatched, Thirty-Minute Operating Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within thirty minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction) minus the Ten-Minute Spinning Reserve quantity calculated for the Resource pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Resource pursuant to subsection (b) above.

III.1.7.19.2.3.2 Non-Dispatched.

For a Demand Response Resource that is not being dispatched that is not a Fast Start Demand Response Resource, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Demand Response Resource's Offered CLAIM10, its CLAIM10, and its Maximum Reduction.

(c) **Thirty-Minute Operating Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Demand Response Resource's Offered CLAIM30, its CLAIM30, and its Maximum Reduction, minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Demand Response Resource pursuant to subsection (b) above.

III.1.7.20 Information and Operating Requirements.

(a) [Reserved.]

(b) Market Participants selling from Resources within the New England Control Area shall: supply to the ISO all applicable Offer Data; report to the ISO Resources that are Self-Scheduled; report to the ISO External Transaction sales; confirm to the ISO bilateral sales to Market Participants within the New England Control Area; respond to the ISO's directives to start, shutdown or change output, consumption, or demand reduction levels of Generator Assets, DARDs, or Demand Response Resources, change scheduled voltages or reactive output levels; continuously maintain all Offer Data concurrent with on-line operating information; and ensure that, where so equipped, equipment is operated with control equipment functioning as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

(c) Market Participants selling from Resources outside the New England Control Area shall: provide to the ISO all applicable Offer Data, including offers specifying amounts of energy available, hours of availability and prices of energy and other services; respond to ISO directives to schedule delivery or change delivery schedules; and communicate delivery schedules to the source Control Area and any intermediary Control Areas.

(d) Market Participants, as applicable, shall: respond or ensure a response to ISO directives for load management steps; report to the ISO all bilateral purchase transactions including External Transaction

purchases; and respond or ensure a response to other ISO directives such as those required during Emergency operation.

(e) Market Participant, as applicable, shall provide to the ISO requests to purchase specified amounts of energy for each hour of the Operating Day during which it intends to purchase from the Day-Ahead Energy Market.

(f) Market Participants are responsible for reporting to the ISO anticipated availability and other information concerning Generator Assets, Demand Response Resources and Dispatchable Asset Related Demands required by the ISO New England Operating Documents, including but not limited to the Market Participant's ability to procure fuel and physical limitations that could reduce Resource output or demand reduction capability for the pertinent Operating Day.

III.1.8 [Reserved.]

III.1.9 Pre-scheduling.

III.1.9.1 Offer and Bid Caps and Cost Verification for Offers and Bids.

III.1.9.1.1 Cost Verification of Resource Offers.

The incremental energy values of Supply Offers and Demand Response Resources above $1,000/MWh for any Resource other than an External Resource are subject to the following cost verification requirements. Unless expressly stated otherwise, cost verification is utilized in all pricing, commitment, dispatch and settlement determinations. For purposes of the following requirements, Reference Levels are calculated using the procedures in Section III.A.7.5 for calculating cost-based Reference Levels.

(a) If the incremental energy value of a Resource's offer is greater than the incremental energy Reference Level value of the Resource, then the incremental energy value in the offer is replaced with the greater of the Reference Level for incremental energy or $1,000/MWh.

(b) For purposes of the price calculations in Sections III.2.5 and III.2.7A, if the adjusted offer calculated under Section III.2.4 for a Rapid Response Pricing Asset is greater than $1,000/MWh (after the incremental energy value is evaluated under Section III.1.9.1.1(a) above), then verification will be performed as follows using a Reference Level value calculated with the adjusted offer formulas specified in Section III.2.4.

(i) If the Reference Level value is less than or equal to $1,000/MWh, then the adjusted offer for the Resource is set at $1,000/MWh;

(ii) If the Reference Level value is greater than $1,000/MWh, then the adjusted offer for the Resource is set at the lower of the Reference Level value and the adjusted offer.

III.1.9.1.2 Offer and Bid Caps.

(a) For purposes of the price calculations described in Section III.2 and for purposes of scheduling a Resource in the Day-Ahead Energy Market in accordance with Section III.1.7.6 following the commitment of the Resource, the incremental energy value of an offer is capped at $2,000/MWh.

(b) Demand Bids shall not specify a bid price below the Energy Offer Floor or above the Demand Bid Cap.

(c) Supply Offers and Demand Reduction Offers shall not specify an offer price (for incremental energy) below the Energy Offer Floor.

(d) External Transactions shall not specify a price below the External Transaction Floor or above the External Transaction Cap.

(e) Increment Offers and Decrement Bids shall not specify an offer or bid price below the Energy Offer Floor or above the Virtual Cap.

III.1.9.2 [Reserved.]

III.1.9.3 [Reserved.]

III.1.9.4 [Reserved.]

III.1.9.5 [Reserved.]

III.1.9.6 [Reserved.]

III.1.9.7 Market Participant Responsibilities.

Market Participants authorized and intending to request market-based Start-Up Fees and No-Load Fee in their Offer Data shall submit a specification of such fees to the ISO for each Generator Asset as to which the Market Participant intends to request such fees. Any such specification shall identify the applicable period and be submitted on or before the applicable deadline and shall remain in effect unless otherwise modified in accordance with Section III.1.10.9. The ISO shall reject any request for Start-Up Fees and No-Load Fee in a Market Participant's Offer Data that does not conform to the Market Participant's specification on file with the ISO.

III.1.9.8 [Reserved.]

III.1.10 Scheduling.

III.1.10.1 General.

(a) The ISO shall administer scheduling processes to implement a Day-Ahead Energy Market and a Real-Time Energy Market.

(b) The Day-Ahead Energy Market shall enable Market Participants to purchase and sell energy through the New England Markets at Day-Ahead Prices and enable Market Participants to submit External Transactions conditioned upon Congestion Costs not exceeding a specified level. Market Participants whose purchases and sales and External Transactions are scheduled in the Day-Ahead Energy Market shall be obligated to purchase or sell energy or pay Congestion Costs and costs for losses, at the applicable Day-Ahead Prices for the amounts scheduled.

(c) In the Real-Time Energy Market,

(i) Market Participants that deviate from the amount of energy purchases or sales scheduled in the Day-Ahead Energy Market shall replace the energy not delivered with energy from the Real-Time Energy Market or an internal bilateral transaction and shall pay for such energy not delivered, net of any internal bilateral transactions, at the applicable Real-Time Price, unless otherwise specified by this Market Rule 1, and

(ii) Non-Market Participant Transmission Customers shall be obligated to pay Congestion Costs and costs for losses for the amount of the scheduled transmission uses in the Real-Time Energy Market at the applicable Real-Time Congestion Component and Loss Component price differences, unless otherwise specified by this Market Rule 1.

(d) The following scheduling procedures and principles shall govern the commitment of Resources to the Day-Ahead Energy Market and the Real-Time Energy Market over a period extending from one week to one hour prior to the Real-Time dispatch. Scheduling encompasses the Day-Ahead and hourly scheduling process, through which the ISO determines the Day-Ahead Energy Market schedule and determines, based on changing forecasts of conditions and actions by Market Participants and system constraints, a plan to serve the hourly energy and reserve requirements of the New England Control Area in the least costly manner, subject to maintaining the reliability of the New England Control Area.

Scheduling of External Transactions in the Real-Time Energy Market is subject to Section II.44 of the OATT.

(e) If the ISO's forecast for the next seven days projects a likelihood of Emergency Condition, the ISO may commit, for all or part of such seven day period, to the use of Generator Assets or Demand Response Resources with Notification Time greater than 24 hours as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Participants' binding Supply Offers or Demand Reduction Offers.

III.1.10.1A Energy Market Scheduling.

Market Participants may submit offers and bids in the Day-Ahead Energy Market until 10:30 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the ISO in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Market Rule 1.

(a) **Locational Demand Bids –** Each Market Participant may submit to the ISO specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-Ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures. Each Market Participant shall inform the ISO of (i) the prices, if any, at which it desires not to include its load in the Day-Ahead Energy Market rather than pay the Day-Ahead Price, (ii) hourly schedules for Resources Self-Scheduled by the Market Participant; and (iii) the Decrement Bid at which each such Self-Scheduled Resource will disconnect or reduce output, or confirmation of the Market Participant's intent not to reduce output. Price-sensitive Demand Bids and Decrement Bids must be greater than zero MW and shall not exceed the Demand Bid Cap and Virtual Cap.

(b) **External Transactions –** All Market Participants shall submit to the ISO schedules for any External Transactions involving use of Generator Assets or the New England Transmission System as specified below, and shall inform the ISO whether the transaction is to be included in the Day-Ahead Energy Market. Any Market Participant that elects to include an External Transaction in the Day-Ahead Energy Market may specify the price (such price not to exceed the maximum price that may be specified in the ISO New England Manuals and ISO New England Administrative Procedures), if any, at which it will be curtailed rather than pay Congestion Costs. The foregoing price specification shall apply to the price difference between the Locational Marginal Prices for specified External Transaction source and

sink points in the Day-Ahead scheduling process only. Any Market Participant that deviates from its Day-Ahead External Transaction schedule or elects not to include its External Transaction in the Day-Ahead Energy Market shall be subject to Congestion Costs in the Real-Time Energy Market in order to complete any such scheduled External Transaction. Scheduling of External Transactions shall be conducted in accordance with the specifications in the ISO New England Manuals and ISO New England Administrative Procedures and the following requirements:

(i) Market Participants shall submit schedules for all External Transaction purchases for delivery within the New England Control Area from Resources outside the New England Control Area;

(ii) Market Participants shall submit schedules for External Transaction sales to entities outside the New England Control Area from Resources within the New England Control Area;

(iii) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction purchases less External Transaction sales exceeds the import capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction purchases at the applicable External Node shall be set equal to the Energy Offer Floor;

(iv) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction sales less External Transaction purchases exceeds the export capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction sales at the applicable External Node shall be set equal to the External Transaction Cap;

(v) The ISO shall not consider Start-Up Fees, No-Load Fees, Notification Times or any other inter-temporal parameters in scheduling or dispatching External Transactions.

(c) **Generator Asset Supply Offers –** Market Participants selling into the New England Markets from Generator Assets may submit Supply Offers for the supply of energy for the following Operating Day.

Such Supply Offers:

(i) Shall specify the Resource and Blocks (price and quantity of Energy) for each hour of the Operating Day for each Resource offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) If based on energy from a Generator Asset internal to the New England Control Area, may specify, for Supply Offers, a Start-Up Fee and No-Load Fee for each hour of the Operating Day. Start-Up Fee and No-Load Fee may vary on an hourly basis;

(iii) Shall specify, for Supply Offers from a dual-fuel Generator Asset, the fuel type. The fuel type may vary on an hourly basis. A Market Participant that submits a Supply Offer using the higher cost fuel type must satisfy the consultation requirements for dual-fuel Generator Assets in Section III.A.3 of Appendix A;

(iv) Shall specify a Minimum Run Time to be used for commitment purposes that does not exceed 24 hours;

(v) Supply Offers shall constitute an offer to submit the Generator Asset to the ISO for commitment and dispatch in accordance with the terms of the Supply Offer, where such Supply Offer, with regard to operating limits, shall specify changes, including to the Economic Maximum Limit, Economic Minimum Limit and Emergency Minimum Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource (except that for a Limited Energy Resource, the Economic Maximum Limit may be revised to reflect an energy (MWh) limitation), which offer shall remain open through the Operating Day for which the Supply Offer is submitted; and

(vi) Shall, in the case of a Supply Offer from a Generator Asset associated with an Electric Storage Facility, also meet the requirements specified in Section III.1.10.6.

(d) DARD Demand Bids – Market Participants participating in the New England Markets with Dispatchable Asset Related Demands may submit Demand Bids for the consumption of energy for the following Operating Day.

Such Demand Bids:

(i) Shall specify the Dispatchable Asset Related Demand and Blocks (price and Energy quantity pairs) for each hour of the Operating Day for each Dispatchable Asset Related Demand offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) Shall constitute an offer to submit the Dispatchable Asset Related Demand to the ISO for commitment and dispatch in accordance with the terms of the Demand Bid, where such Demand Bid, with regard to operating limits, shall specify changes, including to the Maximum Consumption Limit and Minimum Consumption Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource;

(iii) Shall specify a Minimum Consumption Limit that is less than or equal to its Nominated Consumption Limit; and

(iv) Shall, in the case of a Demand Bid from a Storage DARD, also meet the requirements specified in Section III.1.10.6.

(e) **Demand Response Resource Demand Reduction Offers –** Market Participants selling into the New England Markets from Demand Response Resources may submit Demand Reduction Offers for the supply of energy for the following Operating Day. A Demand Reduction Offer shall constitute an offer to submit the Demand Response Resource to the ISO for commitment and dispatch in accordance with the terms of the Demand Reduction Offer. Demand Reduction Offers:

(i) Shall specify the Demand Response Resource and Blocks (price and demand reduction quantity pairs) for each hour of the Operating Day. The prices and demand reduction quantities may vary on an hourly basis.

(ii) Shall not specify a price that is below the Demand Reduction Threshold Price in effect for the Operating Day. For purposes of clearing the Day-Ahead and Real-Time Energy Markets and calculating Day-Ahead and Real-Time Locational Marginal Prices and Real-Time Reserve Clearing Prices, any price specified below the Demand Reduction Threshold price in effect for the Operating Day will be considered to be equal to the Demand Reduction Threshold Price for the Operating Day.

(iii) Shall not include average avoided peak transmission or distribution losses in the demand reduction quantity.

(iv) May specify an Interruption Cost for each hour of the Operating Day, which may vary on an hourly basis.

(v) Shall specify a Minimum Reduction Time to be used for scheduling purposes that does not exceed 24 hours.

(vi) Shall specify a Maximum Reduction amount no greater than the sum of the Maximum Interruptible Capacities of the Demand Response Resource's operational Demand Response Assets.

(vii) Shall specify changes to the Maximum Reduction and Minimum Reduction from those submitted as part of the Demand Response Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Demand Response Resource.

(f) **Demand Reduction Threshold Price –** The Demand Reduction Threshold Price for each month shall be determined through an analysis of a smoothed, historic supply curve for the month. The historic supply curve shall be derived from Real-Time generator and import Offer Data (excluding Coordinated External Transactions) for the same month of the previous year. The ISO may adjust the Offer Data to account for significant changes in generator and import availability or other significant changes to the historic supply curve. The historic supply curve shall be calculated as follows:

(a) Each generator and import offer Block (i.e., each price-quantity pair offered in the Real-Time Energy Market) for each day of the month shall be compiled and sorted in ascending order of price to create an unsmoothed supply curve.

(b) An unsmoothed supply curve for the month shall be formed from the price and cumulative quantity of each offer Block.

(c) A non-linear regression shall be performed on a sampled portion of the unsmoothed supply curve to produce an increasing, convex, smooth approximation of the supply curve.

(d) A historic threshold price P_{th} shall be determined as the point on the smoothed supply curve beyond which the benefit to load from the reduced LMP resulting from the demand reduction of Demand Response Resources exceeds the cost to load associated with compensating Demand Response Resources for demand reduction.

(e) The Demand Reduction Threshold Price for the upcoming month shall be determined by the following formula:

$$DRTP = P_{th}X—\frac{FPI_c}{FPI_h}$$

where FPI_h is the historic fuel price index for the same month of the previous year, and FPI_c is the fuel price index for the current month.

The historic and current fuel price indices used to establish the Demand Reduction Threshold Price for a month shall be based on the lesser of the monthly natural gas or heating oil fuel indices applicable to the New England Control Area, as calculated three business days before the start of the month preceding the Demand Reduction Threshold Price's effective date.

The ISO will post the Demand Reduction Threshold Price, along with the index-based fuel price values used in establishing the Demand Reduction Threshold Price, on its website by the 15th day of the month preceding the Demand Reduction Threshold Price's effective date.

(g) **Subsequent Operating Days** – Each Supply Offer, Demand Reduction Offer, or Demand Bid by a Market Participant of a Resource shall remain in effect for subsequent Operating Days until superseded or canceled except in the case of an External Transaction purchase, in which case, the Supply Offer shall remain in effect for the applicable Operating Day and shall not remain in effect for subsequent Operating Days. Hourly overrides of a Supply Offer, a Demand Reduction Offer, or a Demand Bid shall remain in effect only for the applicable Operating Day.

(h) **Load Estimate** – The ISO shall post on the internet the total hourly loads including Decrement Bids scheduled in the Day-Ahead Energy Market, as well as the ISO's estimate of the Control Area hourly load for the next Operating Day.

(i) **Prorated Supply** – In determining Day-Ahead schedules, in the event of multiple marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases at a pricing location, the ISO shall clear the marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases proportional to the amount of energy (MW) from each marginal offer and/or External Transaction at the pricing location. The Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions are not used in determining the amount of energy (MW) in each marginal Supply Offer or Demand Reduction Offer to be cleared on a pro-rated basis. However, the Day-Ahead schedules resulting from the pro-ration process will reflect Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions.

(j) **Prorated Demand** – In determining Day-Ahead schedules, in the event of multiple marginal Demand Bids, Decrement Bids and/or External Transaction sales at a pricing location, the ISO shall clear the marginal Demand Bids, Decrement Bids and/or External Transaction sales proportional to the amount of energy (MW) from each marginal bid and/or External Transaction at the pricing location.

(k) **Virtuals** – All Market Participants may submit Increment Offers and/or Decrement Bids that apply to the Day-Ahead Energy Market only. Such offers and bids must comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-Ahead Energy Market.

III.1.10.2 Pool-Scheduled Resources.

Pool-Scheduled Resources are those Resources for which Market Participants submitted Supply Offers, Demand Reduction Offers, or Demand Bids in the Day-Ahead Energy Market and which the ISO scheduled in the Day-Ahead Energy Market as well as Generator Assets, DARDs or Demand Response Resources committed by the ISO subsequent to the Day-Ahead Energy Market. Such Resources shall be committed to provide or consume energy in the Real-Time dispatch unless the schedules for such Resources are revised pursuant to Sections III.1.10.9 or III.1.11. Pool-Scheduled Resources shall be governed by the following principles and procedures.

(a) Pool-Scheduled Resources shall be selected by the ISO on the basis of the prices offered for energy supply or consumption and related services, Start-Up Fees, No-Load Fees, Interruption Cost and the specified operating characteristics, offered by Market Participants.

(b) The ISO shall optimize the dispatch of energyfrom Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources in the Day-Ahead Energy Market consistent with the Supply Offers and Demand Reduction Offers of other Resources, the submitted Demand Bids and Decrement Bids and Operating Reserve and Replacement Reserve requirements.

(c) Market Participants offering energy from facilities with fuel or environmental limitations may submit data to the ISO that is sufficient to enable the ISO to determine the available operating hours of such facilities.

(d) Market Participants shall make available their Pool-Scheduled Resources to the ISO for coordinated operation to supply the needs of the New England Control Area for energy and ancillary services.

III.1.10.3 Self-Scheduled Resources.

A Resource that is Self-Scheduled shall be governed by the following principles and procedures. The minimum duration of a Self-Schedule for a Generator Asset or DARD shall not result in the Generator Asset or DARD operating for less than its Minimum Run Time. A Generator Asset that is online as a result of a Self-Schedule will be dispatched above its Economic Minimum Limit based on the economic merit of its Supply Offer. A DARD that is consuming as a result of a Self-Schedule may be dispatched above its Minimum Consumption Limit based on the economic merit of its Demand Bid. A Demand Response Resource shall not be Self-Scheduled.

III.1.10.4 External Resources.

Market Participants with External Resources may submit External Transactions as detailed in Section III.1.10.7 and Section III.1.10.7.A of this Market Rule 1.

III.1.10.5 Dispatchable Asset Related Demand.

(a) External Transactions that are sales to an external Control Area are not eligible to be Dispatchable Asset Related Demands.

(b) A Market Participant with a Dispatchable Asset Related Demand in the New England Control Area must:

(i) notify the ISO of any outage (including partial outages) that may reduce the Dispatchable Asset Related Demand's ability to respond to Dispatch Instructions and the expected return date from the outage;

(ii) in accordance with the ISO New England Manuals and Operating Procedures, perform audit tests and submit the results to the ISO or provide to the ISO appropriate historical production data;

(iii) abide by the ISO maintenance coordination procedures; and

(iv) provide information reasonably requested by the ISO, including the name and location of the Dispatchable Asset Related Demand.

III.1.10.6 Electric Storage

A storage facility is a facility that is capable of receiving electricity from the grid and storing the energy for later injection of electricity back to the grid. A storage facility may participate in the New England Markets as described below.

(a) A storage facility that satisfies the requirements of this subsection (a) may participate in the New England Markets as an Electric Storage Facility. An Electric Storage Facility shall:

(i) comprise one or more storage facilities at the same point of interconnection;

(ii) have the ability to inject at least 0.1 MW and consume at least 0.1 MW;

(iii) be directly metered;

(iv) be registered as, and subject to all rules applicable to, a dispatchable Generator Asset;

(v) be registered as, and subject to all rules applicable to, a DARD that represents the same equipment as the Generator Asset;

(vi) settle its injection of electricity to the grid as a Generator Asset and its receipt of electricity from the grid as a DARD;

(vii) not be precluded from providing retail services so long as it is able to fulfill its wholesale Energy Market and Forward Capacity Market obligations including, but not limited to, satisfying meter data reporting requirements and notifying the ISO of any changes to operational capabilities; and

(viii) meet the requirements of either a Binary Storage Facility or a Continuous Storage Facility, as described in subsections (b) and (c) below.

(b) A storage facility that satisfies the requirements of this subsection (b) may participate in the New England Markets as a Binary Storage Facility. A Binary Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility; and

(ii) offer its Generator Asset and DARD into the Energy Market as Rapid Response Pricing Assets; and

(iii) be issued Dispatch Instructions in a manner that ensures the facility is not required to consume and inject simultaneously.

(c) A storage facility that satisfies the requirements of this subsection (c) may participate in the New England Markets as a Continuous Storage Facility. A Continuous Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility;

(ii) be registered as, may provide Regulation as, and is subject to all rules applicable to, an ATRR that represents the same equipment as the Generator Asset and DARD;

(iii) be capable of transitioning between the facility's maximum output and maximum consumption (and vice versa) in ten minutes or less;

(iv) not utilize storage capability that is shared with another Generator Asset, DARD or ATRR;

(v) specify in Supply Offers a zero MW value for Economic Minimum Limit and Emergency Minimum Limit (except for Generator Assets undergoing Facility and Equipment Testing or auditing); a zero time value for Minimum Run Time, Minimum Down Time, Notification Time, and Start-Up Time; and a zero cost value for Start-Up Fee and No-Load Fee;

(vi) specify in Demand Bids a zero MW value for Minimum Consumption Limit (except for DARDs undergoing Facility and Equipment Testing or auditing) and a zero time value for Minimum Run Time and Minimum Down Time;

(vii) be Self-Scheduled in the Day-Ahead Energy Market and Real-Time Energy Market, and operate in an on-line state, unless the facility is declared unavailable by the Market Participant; and

(viii) be issued a combined dispatch control signal equal to the Desired Dispatch Point (of the Generator Asset) minus the Desired Dispatch Point (of the DARD) plus the AGC SetPoint (of the ATRR).

(d) A storage facility shall comply with all applicable registration, metering, and accounting rules including, but not limited to, the following:

(i) A Market Participant wishing to purchase energy from the ISO-administered wholesale markets must first, jointly with its Host Participant, register one or more wholesale Load Assets with the ISO as described in ISO New England Manual M-28 and ISO New England Manual M-RPA; where the Market Participant wishes to register an Electric Storage Facility, the registered Load Asset must be a DARD.

(ii) A storage facility's charging energy shall not qualify as, or be billed to, a Storage DARD if that facility's charging energy is included in another Load Asset. A storage facility registered as a DARD will be charged the nodal Locational Marginal Price by the ISO and the Market Participant will not pay twice for the same charging energy.

(iii) The registration and metering of all Assets must comply with ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18, including with the requirement that an Asset's revenue metering must comply with the accuracy requirements found in ISO New England Operating Procedure No. 18.

(iv) Pursuant to ISO New England Manual M-28, the Assigned Meter Reader, the Host Participant, and the ISO provide the data for use in the daily settlement process within the timelines described in the manual. The data may be five-minute interval data, and may be no more than hourly data, as described in Section III.3.2 and in ISO New England Manual M-28.

(v) Based on the Metered Quantity For Settlement and the Locational Marginal Price in the settlement interval, the ISO shall conduct all Energy Market accounting pursuant to Section III.3.2.1.

(e) A facility registered as a dispatchable Generator Asset, an ATRR, and a DARD that each represent the same equipment must participate as a Continuous Storage Facility.

(f) A storage facility not participating as an Electric Storage Facility may, if it satisfies the associated requirements, be registered as a Generator Asset (including a Settlement Only Resource) for settlement of its injection of electricity to the grid and as an Asset Related Demand for settlement of its wholesale load.

(g) A storage facility may, if it satisfies the associated requirements, be registered as a Demand Response Asset. (As described in Section III.8.1.1, a Demand Response Asset and a Generator Asset may not be registered at the same end-use customer facility unless the Generator Asset is separately metered

and reported and its output does not reduce the load reported at the Retail Delivery Point of the Demand Response Asset.)

(h) A storage device may, if it satisfies the associated requirements, be registered as a component of either an On-Peak Demand Resource or a Seasonal Peak Demand Resource.

(i) A storage facility may, if it satisfies the associated requirements, provide Regulation pursuant to Section III.14.

III.1.10.7 External Transactions.

The provisions of this Section III.1.10.7 do not apply to Coordinated External Transactions.

(a) Market Participants that submit an External Transaction in the Day-Ahead Energy Market must also submit a corresponding External Transaction in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market. Priced External Transactions for the Real-Time Energy Market must be submitted by the offer submission deadline for the Day-Ahead Energy Market.

(b) Priced External Transactions submitted in both the Day-Ahead Energy Market and the Real-Time Energy Market will be treated as Self-Scheduled External Transactions in the Real-Time Energy Market for the associated megawatt amounts that cleared the Day-Ahead Energy Market, unless the Market Participant modifies the price component of its Real-Time offer during the Re-Offer Period.

(c) Any External Transaction, or portion thereof, submitted to the Real-Time Energy Market that did not clear in the Day-Ahead Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency. External Transactions cleared in the Day-Ahead Energy Market and associated with a Real-Time Energy Market submission will continue to be scheduled in Real-Time prior to and during an Emergency, until the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, require a change in schedule.

(d) External Transactions submitted to the Real-Time Energy Market must contain the associated e-Tag ID and transmission reservation, if required, at the time the transaction is submitted to the Real-Time Energy Market.

(e) [Reserved.]

(f) External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below receive priority in the scheduling and curtailment of transactions as set forth in Section II.44 of the OATT. External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below are referred to herein and in the OATT as being supported in Real-Time.

(i) Capacity Export Through Import Constrained Zone Transactions:

(1) The External Transaction is exporting across an external interface located in an import-constrained Capacity Zone that cleared in the Forward Capacity Auction with price separation, as determined in accordance with Section III.12.4 and Section III.13.2.3.4 of Market Rule 1;

(2) The External Transaction is directly associated with an Export Bid or Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The External Node associated with the cleared Export Bid or Administrative Export De-List Bid is connected to the import-constrained Capacity Zone, and is not connected to a Capacity Zone that is not import-constrained;

(4) The Resource, or portion thereof, that is associated with the cleared Export Bid or Administrative Export De-List Bid is not located in the import-constrained Capacity Zone;

(5) The External Transaction has been submitted and cleared in the Day-Ahead Energy Market;

(6) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(ii) FCA Cleared Export Transactions:

(1) The External Transaction sale is exporting to an External Node that is connected only to an import-constrained Reserve Zone;

(2) The External Transaction sale is directly associated with an Export Bid or an Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation associated with the Export Bid or Administrative Export De-List Bid is located outside the import-constrained Reserve Zone;

(4) The External Transaction sale is submitted and cleared in the Day-Ahead Energy Market;

(5) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(iii) Same Reserve Zone Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is connected only to the same Reserve Zone in which the associated Resource, or portion thereof, without a Capacity Supply Obligation is located;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(4) Neither the External Transaction sale nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(iv) Unconstrained Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is not connected only to an import-constrained Reserve Zone;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is not separated from the External Node by a transmission interface constraint as determined in Sections III.12.2.1(b) and III.12.2.2(b) of Market Rule 1 that was binding in the Forward Capacity Auction in the direction of the export;

(4) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(5) Neither the External Transaction sale, nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(g) Treatment of External Transaction sales in ISO commitment for local second contingency protection.

(i) Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: The transaction's export demand that clears in the Day-Ahead Energy Market will be explicitly considered as load in the exporting Reserve Zone by the ISO when committing Resources to provide local second contingency protection for the associated Operating Day.

(ii) The export demand of External Transaction sales not meeting the criteria in (i) above is not considered by the ISO when planning and committing Resources to provide local second contingency protection, and is assumed to be zero.

(iii) Same Reserve Zone Export Transactions and Unconstrained Export Transactions: If a Resource, or portion thereof, without a Capacity Supply Obligation is committed to be online during the Operating Day either through clearing in the Day-Ahead Energy Market or through Self-Scheduling subsequent to the Day-Ahead Energy Market and a Same Reserve Zone Export Transaction or Unconstrained Export Transaction is submitted before the end of the Re-Offer Period designating that Resource as supporting the transaction, the ISO will not utilize the portion of the Resource without a Capacity Supply Obligation supporting the export transaction to meet local second contingency protection requirements. The eligibility of Resources not meeting the foregoing criteria to be used to meet local second contingency protection requirements shall be in accordance with the relevant provisions of the ISO New England System Rules.

(h) Allocation of costs to Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: Market Participants with Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions shall incur a proportional share of the charges described below, which are allocated to Market Participants based on Day-Ahead Load Obligation or Real-Time Load Obligation. The share shall be determined by including the Day-Ahead Load Obligation or Real-Time Load Obligation associated with the External Transaction, as applicable, in the total Day-Ahead Load Obligation or Real-Time Load Obligation for the appropriate Reliability Region, Reserve Zone, or Load Zone used in each cost allocation calculation:

(i) NCPC for Local Second Contingency Protection Resources allocated within the exporting Reliability Region, pursuant to Section III.F.3.3.

(ii) Forward Reserve Market charges allocated within the exporting Load Zone, pursuant to Section III.9.9.

(iii) Real-Time Reserve Charges allocated within the exporting Load Zone, pursuant to Section III.10.3.

(i) When action is taken by the ISO to reduce External Transaction sales due to a system wide capacity deficient condition or the forecast of such a condition, and an External Transaction sale designates a Resource, or portion of a Resource, without a Capacity Supply Obligation, to support the transaction, the ISO will review the status of the designated Resource. If the designated Resource is Self-Scheduled and online at a megawatt level greater than or equal to the External Transaction sale, that External Transaction sale will not be reduced until such time as Regional Network Load within the New England Control Area is also being reduced. When reductions to such transactions are required, the affected transactions shall be reduced pro-rata.

(j) Market Participants shall submit External Transactions as megawatt blocks with intervals of one hour at the relevant External Node. External Transactions will be scheduled in the Day-Ahead Energy Market as megawatt blocks for hourly durations. The ISO may dispatch External Transactions in the Real-Time Energy Market as megawatt blocks for periods of less than one hour, to the extent allowed pursuant to inter-Control Area operating protocols.

III.1.10.7.A Coordinated Transaction Scheduling.

The provisions of this Section III.1.10.7.A apply to Coordinated External Transactions, which are implemented at the New York Northern AC external Location.

(a) Market Participants that submit a Coordinated External Transaction in the Day-Ahead Energy Market must also submit a corresponding Coordinated External Transaction, in the form of an Interface Bid, in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market.

(b) An Interface Bid submitted in the Real-Time Energy Market shall specify a duration consisting of one or more consecutive 15-minute increments. An Interface Bid shall include a bid price, a bid quantity, and a bid direction for each 15-minute increment. The bid price may be positive or negative. An Interface Bid may not be submitted or modified later than 75 minutes before the start of the clock hour for which it is offered.

(c) Interface Bids are cleared in economic merit order for each 15-minute increment, based upon the forecasted real-time price difference across the external interface. The total quantity of Interface Bids cleared shall determine the external interface schedule between New England and the adjacent Control Area. The total quantity of Interface Bids cleared shall depend upon, among other factors, bid production

costs of resources in both Control Areas, the Interface Bids of all Market Participants, transmission system conditions, and any real-time operating limits necessary to ensure reliable operation of the transmission system.

(d) All Coordinated External Transactions submitted either to the Day-Ahead Energy Market or the Real-Time Energy Market must contain the associated e-Tag ID at the time the transaction is submitted.

(e) Any Coordinated External Transaction, or portion thereof, submitted to the Real-Time Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency, unless the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, permit the transaction to be scheduled.

III.1.10.8 ISO Responsibilities.

(a) The ISO shall use its best efforts to determine (i) the least-cost means of satisfying hourly purchase requests for energy, the projected hourly requirements for Operating Reserve, Replacement Reserve and other ancillary services of the Market Participants, including the reliability requirements of the New England Control Area, of the Day-Ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve, Replacement Reserve and other ancillary service requirements for any portion of the load forecast of the ISO for the Operating Day in excess of that scheduled in the Day-Ahead Energy Market. In making these determinations, the ISO shall take into account: (i) the ISO's forecasts of New England Markets and New England Control Area energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Participants for the Day-Ahead Energy Market; (ii) the offers and bids submitted by Market Participants; (iii) the availability of Limited Energy Resources; (iv) the capacity, location, and other relevant characteristics of Self-Scheduled Resources; (v) the requirements of the New England Control Area for Operating Reserve and Replacement Reserve, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vi) the requirements of the New England Control Area for Regulation and other ancillary services, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; and (viii) such other factors as the ISO reasonably concludes are relevant to the foregoing determination. The ISO shall develop a Day-Ahead Energy schedule based on the applicable portions of the foregoing determination, and shall determine the Day-Ahead Prices resulting from such schedule. (b)

Not later than 1:30 p.m. of the day before each Operating Day, or such earlier deadline as may be

specified by the ISO in the ISO New England Manuals and ISO New England Administrative Procedures or such later deadline as necessary to account for software failures or other events, the ISO shall: (i) post the aggregate Day-Ahead Energy schedule; (ii) post the Day-Ahead Prices; and (iii) inform the Market Participants of their scheduled injections and withdrawals. In the event of an Emergency, the ISO will notify Market Participants as soon as practicable if the Day-Ahead Energy Market can not be operated.

(c) Following posting of the information specified in Section III.1.10.8(b), the ISO shall revise its schedule of Resources to reflect updated projections of load, conditions affecting electric system operations in the New England Control Area, the availability of and constraints on limited energy and other Resources, transmission constraints, and other relevant factors.

(d) Market Participants shall pay and be paid for the quantities of energy scheduled in the Day-Ahead Energy Market at the Day-Ahead Prices.

III.1.10.9 Hourly Scheduling.

(a) Following the initial posting by the ISO of the Locational Marginal Prices resulting from the Day-Ahead Energy Market, and subject to the right of the ISO to schedule and dispatch Resources and to direct that schedules be changed to address an actual or potential Emergency, a Resource Re-Offer Period shall exist from the time of the posting specified in Section III.1.10.8(b) until 2:00 p.m. on the day before each Operating Day or such other Re-Offer Period as necessary to account for software failures or other events. During the Re-Offer Period, Market Participants may submit revisions to Supply Offers, revisions to Demand Reduction Offers, and revisions to Demand Bids for any Dispatchable Asset Related Demand. Resources scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices.

(b) During the Re-Offer Period, Market Participants may submit revisions to the price of priced External Transactions. External Transactions scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices. A submission during the Re-Offer Period for any portion of a transaction that was cleared in the Day-Ahead Energy Market is subject to the provisions in Section III.1.10.7. A Market Participant may request to Self-Schedule an External Transaction and adjust the schedule on an hour-to-hour basis or request to reduce the quantity of a priced External Transaction. The ISO must be notified of the request not later than 60 minutes prior to the hour in which the adjustment is to take effect. The External

Transaction re-offer provisions of this Section III.1.10.9(b) shall not apply to Coordinated External Transactions, which are submitted pursuant to Section III.1.10.7.A.

(c) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may modify certain Supply Offer or Demand Bid parameters for a Generator Asset or a Dispatchable Asset Related Demand on an hour-to-hour basis, provided that the modification is made no later than 30 minutes prior to the beginning of the hour for which the modification is to take effect:

(i) For a Generator Asset, the Start-Up Fee, the No-Load Fee, the fuel type (for dual-fuel Generator Assets), and the quantity and price pairs of its Blocks may be modified.

(ii) For a Dispatchable Asset Related Demand, the quantity and price pairs of its Blocks may be modified.

(d) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may not modify any of the following Demand Reduction Offer parameters: price and demand reduction quantity pairs, Interruption Cost, Demand Response Resource Start-Up Time, Demand Response Resource Notification Time, Minimum Reduction Time, and Minimum Time Between Reductions.

(e) During the Operating Day, a Market Participant may request to Self-Schedule a Generator Asset or Dispatchable Asset Related Demand or may request to cancel a Self-Schedule for a Generator Asset or Dispatchable Asset Related Demand. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor a Self-Schedule request, a Generator Asset will be permitted to come online at its Economic Minimum Limit and a Dispatchable Asset Related Demand will be dispatched to its Minimum Consumption Limit. A Market Participant may not request to Self-Schedule a Demand Response Resource. A Market Participant may cancel the Self-Schedule of a Continuous Storage Generator Asset or a Continuous Storage DARD only by declaring the facility unavailable.

(f) During the Operating Day, in the event that in a given hour a Market Participant seeks to modify a Supply Offer or Demand Bid after the deadline for modifications specified in Section III.1.10.9(c), then:

(i) the Market Participant may request that a Generator Asset be dispatched above its Economic Minimum Limit at a specified output. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the

request, the Generator Asset will be dispatched as though it had offered the specified output for the hour in question at the Energy Offer Floor.

(ii) the Market Participant may request that a Dispatchable Asset Related Demand be dispatched above its Minimum Consumption Limit at a specified value. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the request, the Dispatchable Asset Related Demand will be dispatched at or above the requested amount for the hour in question.

(g) During the Operating Day, in any interval in which a Generator Asset is providing Regulation, the upper limit of its energy dispatch range shall be reduced by the amount of Regulation Capacity, and the lower limit of its energy dispatch range shall be increased by the amount of Regulation Capacity. Any such adjustment shall not affect the Real-Time Reserve Designation.

(h) During the Operating Day, in any interval in which a Continuous Storage ATRR is providing Regulation, the upper limit of the associated Generator Asset's energy dispatch range shall be reduced by the Regulation High Limit, and the associated DARD's consumption dispatch range shall be reduced by the Regulation Low Limit. Any such adjustment shall not affect the Real-Time Reserve Designation.

(i) For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this Section III.1.10, the ISO shall provide Market Participants and parties to External Transactions with any revisions to their schedules for the hour.

III.1.11 Dispatch.

The following procedures and principles shall govern the dispatch of the Resources available to the ISO.

III.1.11.1 Resource Output or Consumption and Demand Reduction.

The ISO shall have the authority to direct any Market Participant to adjust the output, consumption or demand reduction of any Dispatchable Resource within the operating characteristics specified in the Market Participant's Offer Data, Supply Offer, Demand Reduction Offer or Demand Bid. The ISO may cancel its selection of, or otherwise release, Pool-Scheduled Resources. The ISO shall adjust the output, consumption or demand reduction of Resources as necessary: (a) for both Dispatchable Resources and Non-Dispatchable Resources, to maintain reliability, and subject to that constraint, for Dispatchable Resources, (b) to minimize the cost of supplying the energy, reserves, and other services required by the

Market Participants and the operation of the New England Control Area; (c) to balance supply and demand, maintain scheduled tie flows, and provide frequency support within the New England Control Area; and (d) to minimize unscheduled interchange that is not frequency related between the New England Control Area and other Control Areas.

III.1.11.2 Operating Basis.

In carrying out the foregoing objectives, the ISO shall conduct the operation of the New England Control Area and shall, in accordance with the ISO New England Manuals and ISO New England Administrative Procedures, (i) utilize available Operating Reserve and replace such Operating Reserve when utilized; and (ii) monitor the availability of adequate Operating Reserve.

III.1.11.3 Dispatchable Resources.

With the exception of Settlement Only Resources, Generator Assets that meet the size criteria to be Settlement Only Resources, External Transactions, nuclear-powered Resources and photovoltaic Resources, all Resources must be Dispatchable Resources in the Energy Market and meet the technical specifications in ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18 for dispatchability.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market because the Resource is not connected to a remote terminal unit meeting the requirements of ISO New England Operating Procedure No. 18 shall take the following steps:

1. By January 15, 2017, the Market Participant shall submit to the ISO a circuit order form for the primary and secondary communication paths for the remote terminal unit.
2. The Market Participant shall work diligently with the ISO to ensure the Resource is able to receive and respond to electronic Dispatch Instructions within twelve months of the circuit order form submission.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market by the deadline set forth above shall provide the ISO with a written plan for remedying the deficiencies, and shall identify in the plan the specific actions to be taken and a reasonable timeline for rendering the Resource dispatchable. The Market Participant shall complete the remediation in accordance with and under the timeline set forth in the written plan. Until a Resource is dispatchable, it may only be Self-Scheduled in the Real-Time Energy Market and shall otherwise be treated as a Non-Dispatchable Resource.

Dispatchable Resources in the Energy Market are subject to the following requirements:

(a) The ISO shall optimize the dispatch of energy from Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources consistent with the dynamic load-following requirements of the New England Control Area and the availability of other Resources to the ISO.

(b) The ISO shall implement the dispatch of energy from Dispatchable Resources and the designation of Real-Time Operating Reserve to Dispatchable Resources, including the dispatchable portion of Resources which are otherwise Self-Scheduled, by sending appropriate signals and instructions to the entity controlling such Resources. Each Market Participant shall ensure that the entity controlling a Dispatchable Resource offered or made available by that Market Participant complies with the energy dispatch signals and instructions transmitted by the ISO.

(c) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed, and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(d) Market Participants shall exert all reasonable efforts to operate, or ensure the operation of, their Dispatchable Resources in the New England Control Area as close to dispatched output, consumption or demand reduction levels as practical, consistent with Good Utility Practice.

(e) Settlement Only Resources are not eligible to be DNE Dispatchable Generators.

Wind and hydro Intermittent Power Resources that are not Settlement Only Resources are required to receive and respond to Do Not Exceed Dispatch Points, except as follows:

(i) A wind or hydro Intermittent Power Resource not capable of receiving and responding to electronic Dispatch Instructions will be manually dispatched.

(ii) A Market Participant may elect, but is not required, to have a wind or hydro Intermittent Power Resource that is less than 5 MW and is connected through transmission facilities rated at less than 115 kV be dispatched as a DNE Dispatchable Generator.

(iii) A Market Participant with a hydro Intermittent Power Resource that is able to operate within a dispatchable range and is capable of responding to Dispatch Instructions to increase or decrease output within its dispatchable range may elect to have that resource dispatched as a DDP Dispatchable Resource.

(f) The ISO may request that dual-fuel Generator Assets that normally burn natural gas voluntarily take all necessary steps (within the limitations imposed by the operating limitations of their installed equipment and their environmental and operating permits) to prepare to switch to secondary fuel in anticipation of natural gas supply shortages. The ISO may request that Market Participants with dual-fuel Generator Assets that normally burn natural gas voluntarily switch to a secondary fuel in anticipation of natural gas supply shortages. The ISO may communicate with Market Participants with dual-fuel Generator Assets that normally burn natural gas to verify whether the Market Participants have switched or are planning to switch to an alternate fuel.

III.1.11.4 Emergency Condition.

If the ISO anticipates or declares an Emergency Condition, all External Transaction sales out of the New England Control Area that are not backed by a Resource may be interrupted, in accordance with the ISO New England Manuals, in order to serve load and Operating Reserve in the New England Control Area.

III.1.11.5 Dispatchability Requirements for Intermittent Power Resources.

(a) Intermittent Power Resources that are Dispatchable Resources with Supply Offers that do not clear in the Day-Ahead Energy Market and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market at the Resource's Economic Minimum Limit in order to operate in Real-Time.

(b) Intermittent Power Resources that are not Settlement Only Resources, are not Dispatchable Resources, and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market with the Resource's Economic Maximum Limit and Economic Minimum Limit redeclared to the same value in order to operate in Real-Time. Redeclarations must be updated throughout the Operating Day to reflect actual operating capabilities.

III.1.11.6 Non-Dispatchable Resources.

Non-Dispatchable Resources are subject to the following requirements:

(a) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Non-Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(b) Market Participants with Non-Dispatchable Resources shall exert all reasonable efforts to operate or ensure the operation of their Resources in the New England Control Area as close to dispatched levels as practical when dispatched by the ISO for reliability, consistent with Good Utility Practice.

I.2 Rules of Construction; Definitions

I.2.1. Rules of Construction:

In this Tariff, unless otherwise provided herein:

(a) words denoting the singular include the plural and vice versa;

(b) words denoting a gender include all genders;

(c) references to a particular part, clause, section, paragraph, article, exhibit, schedule, appendix or other attachment shall be a reference to a part, clause, section, paragraph, or article of, or an exhibit, schedule, appendix or other attachment to, this Tariff;

(d) the exhibits, schedules and appendices attached hereto are incorporated herein by reference and shall be construed with an as an integral part of this Tariff to the same extent as if they were set forth verbatim herein;

(e) a reference to any statute, regulation, proclamation, ordinance or law includes all statutes, regulations, proclamations, amendments, ordinances or laws varying, consolidating or replacing the same from time to time, and a reference to a statute includes all regulations, policies, protocols, codes, proclamations and ordinances issued or otherwise applicable under that statute unless, in any such case, otherwise expressly provided in any such statute or in this Tariff;

(f) a reference to a particular section, paragraph or other part of a particular statute shall be deemed to be a reference to any other section, paragraph or other part substituted therefor from time to time;

(g) a definition of or reference to any document, instrument or agreement includes any amendment or supplement to, or restatement, replacement, modification or novation of, any such document, instrument or agreement unless otherwise specified in such definition or in the context in which such reference is used;

(h) a reference to any person (as hereinafter defined) includes such person's successors and permitted assigns in that designated capacity;

(i) any reference to "days" shall mean calendar days unless "Business Days" (as hereinafter defined) are expressly specified;

(j) if the date as of which any right, option or election is exercisable, or the date upon which any amount is due and payable, is stated to be on a date or day that is not a Business Day, such right, option or election may be exercised, and such amount shall be deemed due and payable, on the next succeeding Business Day with the same effect as if the same was exercised or made on such date or day (without, in the case of any such payment, the payment or accrual of any interest or

other late payment or charge, provided such payment is made on such next succeeding Business Day);

(k) words such as "hereunder," "hereto," "hereof" and "herein" and other words of similar import shall, unless the context requires otherwise, refer to this Tariff as a whole and not to any particular article, section, subsection, paragraph or clause hereof; and a reference to "include" or "including" means including without limiting the generality of any description preceding such term, and for purposes hereof the rule of *ejusdem generis* shall not be applicable to limit a general statement, followed by or referable to an enumeration of specific matters, to matters similar to those specifically mentioned.

I.2.2. Definitions:

In this Tariff, the terms listed in this section shall be defined as described below:

Active Demand Capacity Resource is one or more Demand Response Resources located within the same Dispatch Zone, that is registered with the ISO, assigned a unique resource identification number by the ISO, and participates in the Forward Capacity Market to fulfill a Market Participant's Capacity Supply Obligation pursuant to Section III.13 of Market Rule 1.

Actual Capacity Provided is the measure of capacity provided during a Capacity Scarcity Condition, as described in Section III.13.7.2.2 of Market Rule 1.

Actual Load is the consumption at the Retail Delivery Point for the hour.

Additional Resource Blackstart O&M Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Additional Resource Specified-Term Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Additional Resource Standard Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Administrative Costs are those costs incurred in connection with the review of Applications for transmission service and the carrying out of System Impact Studies and Facilities Studies.

Administrative Export De-List Bid is a bid that may be submitted in a Forward Capacity Auction by certain Existing Generating Capacity Resources subject to a multi-year contract to sell capacity outside of the New England Control Area during the associated Capacity Commitment Period, as described in Section III.13.1.2.3.1.4 of Market Rule 1.

Administrative Sanctions are defined in Section III.B.4.1.2 of Appendix B of Market Rule 1.

ADR Neutrals are one or more firms or individuals identified by the ISO with the advice and consent of the Participants Committee that are prepared to act as neutrals in ADR proceedings under Appendix D to Market Rule 1.

Advance is defined in Section IV.A.3.2 of the Tariff.

Affected Party, for purposes of the ISO New England Billing Policy, is defined in Section 6.3.5 of the ISO New England Billing Policy.

Affiliate is any person or entity that controls, is controlled by, or is under common control by another person or entity. For purposes of this definition, "control" means the possession, directly or indirectly, of the authority to direct the management or policies of an entity. A voting interest of ten percent or more shall create a rebuttable presumption of control.

AGC is automatic generation control.

AGC SetPoint is the desired output signal for a Resource providing Regulation that is produced by the AGC system as frequently as every four seconds.

AGC SetPoint Deadband is a deadband expressed in megawatts that is applied to changing values of the AGC SetPoint for generating units.

Allocated Assessment is a Covered Entity's right to seek and obtain payment and recovery of its share in any shortfall payments under Section 3.3 or Section 3.4 of the ISO New England Billing Policy.

Alternative Dispute Resolution (ADR) is the procedure set forth in Appendix D to Market Rule 1.

Alternative Technology Regulation Resource (ATRR) is one or more facilities capable of providing Regulation that have been registered in accordance with the Asset Registration Process. An Alternative Technology Regulation Resource is eligible to participate in the Regulation Market.

Ancillary Services are those services that are necessary to support the transmission of electric capacity and energy from resources to loads while maintaining reliable operation of the New England Transmission System in accordance with Good Utility Practice.

Announced Schedule 1 EA Amount, Announced Schedule 2 EA Amount, Announced Schedule 3 EA Amount are defined in Section IV.B.2.2 of the Tariff.

Annual Transmission Revenue Requirements are the annual revenue requirements of a PTO's PTF or of all PTOs' PTF for purposes of the OATT shall be the amount determined in accordance with Attachment F to the OATT.

Annual Reconfiguration Transaction is a bilateral transaction that may be used in accordance with Section III.13.5.4 of Market Rule 1 to specify a price when a Capacity Supply Obligation is transferred using supply offers and demand bids in Annual Reconfiguration Auctions.

Applicants, for the purposes of the ISO New England Financial Assurance Policy, are entities applying for Market Participant status or for transmission service from the ISO.

Application is a written request by an Eligible Customer for transmission service pursuant to the provisions of the OATT.

Asset is a Generator Asset, a Demand Response Asset, a component of an On-Peak Demand Resource or Seasonal Peak Demand Resource, a Load Asset (including an Asset Related Demand), an Alternative Technology Regulation Resource, or a Tie-Line Asset.

Asset Registration Process is the ISO business process for registering an Asset.

Asset Related Demand is a Load Asset that has been discretely modeled within the ISO's dispatch and settlement systems, settles at a Node, has been registered in accordance with the Asset Registration

Process, and is made up of either: (1) one or more individual end-use metered customers receiving service from the same point or points of electrical supply with an aggregate average hourly load of 1 MW or greater during the 12 months preceding its registration; (2) a Storage DARD with a consumption capability of at least 0.1 MW; or (3) one or more storage facilities that are not Electric Storage Facilities with an aggregate consumption capability of at least 1 MW.

Asset Related Demand Bid Block-Hours are Block-Hours assigned to the Lead Market Participant for each Asset Related Demand bid. Blocks of the bid in effect for each hour will be totaled to determine the daily quantity of Asset Related Demand Bid Block-Hours. In the case that a Resource has a Real-Time unit status of "unavailable" for an entire day, that day will not contribute to the quantity of Asset Related Demand Bid Block-Hours. However, if the Resource has at least one hour of the day with a unit status of "available," the entire day will contribute to the quantity of Asset Related Demand Bid Block-Hours.

Asset-Specific Going Forward Costs are the net costs of an asset that is part of an Existing Generating Capacity Resource, calculated for the asset in the same manner as the net costs of Existing Generating Capacity Resources as described in Section III.13.1.2.3.2.1.1.1 (for an asset with a Static De-List Bid or an Export Bid) or Section III.13.1.2.3.2.1.1.2 (for an asset with a Permanent De-List Bid or Retirement De-List Bid).

Assigned Meter Reader reports to the ISO the hourly and monthly MWh associated with the Asset. These MWh are used for settlement. The Assigned Meter Reader may designate an agent to help fulfill its Assigned Meter Reader responsibilities; however, the Assigned Meter Reader remains functionally responsible to the ISO.

Auction Revenue Right (ARR) is a right to receive FTR Auction Revenues in accordance with Appendix C of Market Rule 1.

Auction Revenue Right Allocation (ARR Allocation) is defined in Section 1 of Appendix C of Market Rule 1.

Auction Revenue Right Holder (ARR Holder) is an entity which is the record holder of an Auction Revenue Right (excluding an Incremental ARR) in the register maintained by the ISO.

Authorized Commission is defined in Section 3.3 of the ISO New England Information Policy.

Authorized Person is defined in Section 3.3 of the ISO New England Information Policy.

Automatic Response Rate is the response rate, in MW/Minute, at which a Market Participant is willing to have a Regulation Resource change its output or consumption while providing Regulation between the Regulation High Limit and Regulation Low Limit.

Available Energy is a value that reflects the MWhs of energy available from an Electric Storage Facility for economic dispatch.

Available Storage is a value that reflects the MWhs of unused storage available from an Electric Storage Facility for economic dispatch of consumption.

Average Hourly Load Reduction is either: (i) the sum of the On-Peak Demand Resource's electrical energy reduction during Demand Resource On-Peak Hours in the month divided by the number of Demand Resource On-Peak Hours in the month; or (ii) the sum of the Seasonal Peak Demand Resource's electrical energy reduction during Demand Resource Seasonal Peak Hours in the month divided by the number of Demand Resource Seasonal Peak Hours in the month. The On-Peak Demand Resource's or Seasonal Peak Demand Resource's electrical energy reduction and Average Hourly Load Reduction shall be determined consistent with the resource's Measurement and Verification Plan, which shall be reviewed by the ISO to ensure consistency with the measurement and verification requirements, as described in Section III.13.1.4.3 of Market Rule 1 and the ISO New England Manuals.

Average Hourly Output is either: (i) the sum of the On-Peak Demand Resource's electrical energy output during Demand Resource On-Peak Hours in the month divided by the number of Demand Resource On-Peak Hours in the month; or (ii) the sum of the Seasonal Peak Demand Resource's electrical energy output during Demand Resource Seasonal Peak Hours in the month divided by the number of Demand Resource Seasonal Peak Hours in the month. Electrical energy output and Average Hourly Output shall be determined consistent with the resource's Measurement and Verification Plan, which shall be reviewed by the ISO to ensure consistency with the measurement and verification requirements, as described in Section III.13.1.4.3 of Market Rule 1 and the ISO New England Manuals.

Average Monthly PER is calculated in accordance with Section III.13.7.1.2.2 of Market Rule 1.

Backstop Transmission Solution is a solution proposed: (i) to address a reliability or market efficiency need identified by the ISO in a Needs Assessment reported by the ISO pursuant to Section 4.1(i) of Attachment K to the ISO OATT, (ii) by the PTO or PTOs with an obligation under Schedule 3.09(a) of the TOA to address the identified need; and (iii) in circumstances in which the competitive solution process specified in Section 4.3 of Attachment K to the ISO OATT will be utilized.

Bankruptcy Code is the United States Bankruptcy Code.

Bankruptcy Event occurs when a Covered Entity files a voluntary or involuntary petition in bankruptcy or commences a proceeding under the United States Bankruptcy Code or any other applicable law concerning insolvency, reorganization or bankruptcy by or against such Covered Entity as debtor.

Bilateral Contract (BC) is any of the following types of contracts: Internal Bilateral for Load, Internal Bilateral for Market for Energy, and External Transactions.

Bilateral Contract Block-Hours are Block-Hours assigned to the seller and purchaser of an Internal Bilateral for Load, Internal Bilateral for Market for Energy and External Transactions; provided, however, that only those contracts which apply to the Real-Time Energy Market will accrue Block-Hours.

Binary Storage DARD is a DARD that participates in the New England Markets as part of a Binary Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Binary Storage Facility is a type of Electric Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Blackstart Capability Test is the test, required by ISO New England Operating Documents, of a resource's capability to provide Blackstart Service.

Blackstart Capital Payment is the annual compensation, as calculated pursuant to Section 5.1, or as referred to in Section 5.2, of Schedule 16 to the OATT, for a Designated Blackstart Resource's Blackstart Equipment capital costs associated with the provision of Blackstart Service (excluding the capital costs associated with compliance with NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Blackstart Equipment is any equipment that is solely necessary to enable the Designated Blackstart Resource to provide Blackstart Service and is not required to provide other products or services under the Tariff.

Blackstart O&M Payment is the annual Blackstart O&M compensation calculated under either Section 5.1 or 5.2 of Schedule 16 of the OATT, as applicable.

Blackstart Owner is the Market Participant who is authorized on behalf of the Generator Owner(s) to offer or operate the resource as a Designated Blackstart Resource and is authorized to commit the resource to provide Blackstart Service.

Blackstart Service is the Ancillary Service described in Section II.47 of the Tariff and Schedule 16 of the OATT.

Blackstart Service Commitment is the commitment by a Blackstart Owner for its resource to provide Blackstart Service and the acceptance of that commitment by the ISO, in the manner detailed in ISO New England Operating Procedure No. 11 – Designated Blackstart Resource Administration (OP 11), and which includes a commitment to provide Blackstart Service established under Operating Procedure 11 – Designated Blackstart Resource Administration (OP11).

Blackstart Service Minimum Criteria are the minimum criteria that a Blackstart Owner and its resource must meet in order to establish and maintain a resource as a Designated Blackstart Resource.

Blackstart Standard Rate Payment is the formulaic rate of monthly compensation, as calculated pursuant to Section 5 of Schedule 16 to the OATT, paid to a Blackstart Owner for the provision of Blackstart Service from a Designated Blackstart Resource.

Blackstart Station is comprised of (i) a single Designated Blackstart Resource or (ii) two or more Designated Blackstart Resources that share Blackstart Equipment.

Blackstart Station-specific Rate Payment is the Commission-approved compensation, as calculated pursuant to Section 5.2 of Schedule 16 to the OATT, paid to a Blackstart Owner on a monthly basis for the provision of Blackstart Service by Designated Blackstart Resources located at a specific Blackstart Station.

Blackstart Station-specific Rate Capital Payment is a component of the Blackstart Station-specific Rate Payment that reflects a Blackstart Station's capital Blackstart Equipment costs associated with the provision of Blackstart Service (excluding the capital costs associated with compliance with NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Block is defined as follows: (1) With respect to Bilateral Contracts, a Bilateral Contract administered by the ISO for an hour; (2) with respect to Supply Offers administered by the ISO, a quantity with a related price for Energy (Supply Offers for Energy may contain multiple sets of quantity and price pairs for each hour); (3) with respect to Demand Bids administered by the ISO, a quantity with a related price for Energy (Demand Bids for Energy may contain multiple sets of quantity and price pairs for each hour); (4) with respect to Increment Offers administered by the ISO, a quantity with a related price for Energy (Increment Offers for Energy may contain multiple sets of quantity and price pairs for each hour); (5) with respect to Decrement Bids administered by the ISO, a quantity with a related price for Energy (Decrement Bids for Energy may contain multiple sets of quantity and price pairs for each hour); (6) with respect to Asset Related Demand bids administered by the ISO, a quantity with a related price for Energy (Asset Related Demand bids may contain multiple sets of quantity and price pairs for each hour); and (7) with respect to Demand Reduction Offers administered by the ISO, a quantity of reduced demand with a related price (Demand Reduction Offers may contain multiple sets of quantity and price pairs for the day).

Block-Hours are the number of Blocks administered for a particular hour.

Budget and Finance Subcommittee is a subcommittee of the Participants Committee, the responsibilities of which are specified in Section 8.4 of the Participants Agreement.

Business Day is any day other than a Saturday or Sunday or ISO holidays as posted by the ISO on its website.

Cancelled Start NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Capability Demonstration Year is the one year period from September 1 through August 31.

Capacity Acquiring Resource is a resource that is seeking to acquire a Capacity Supply Obligation through: (1) a Capacity Supply Obligation Bilateral, as described in Section III.13.5.1, or; (2) an annual or monthly reconfiguration auction, as described in Section III.13.4.

Capacity Balancing Ratio is a ratio used in calculating the Capacity Performance Payment in the Forward Capacity Market, as described in Section III.13.7.2.3 of Market Rule 1.

Capacity Base Payment is the portion of revenue received in the Forward Capacity Market as described in Section III.13.7.1 of Market Rule 1.

Capacity Capability Interconnection Standard has the meaning specified in Schedule 22, Schedule 23, and Schedule 25 of the OATT.

Capacity Clearing Price is the clearing price for a Capacity Zone for a Capacity Commitment Period resulting from the Forward Capacity Auction conducted for that Capacity Commitment Period, as determined in accordance with Section III.13.2.7 of Market Rule 1.

Capacity Commitment Period is the one-year period from June 1 through May 31 for which obligations are assumed and payments are made in the Forward Capacity Market.

Capacity Cost (CC) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

Capacity Export Through Import Constrained Zone Transaction is defined in Section III.1.10.7(f)(i) of Market Rule 1.

Capacity Load Obligation is the quantity of capacity for which a Market Participant is financially responsible as described in Section III.13.7.5.2 of Market Rule 1.

Capacity Load Obligation Acquiring Participant is a load serving entity or any other Market Participant seeking to acquire a Capacity Load Obligation through a Capacity Load Obligation Bilateral, as described in Section III.13.5.2 of Market Rule 1.

Capacity Network Import Capability (CNI Capability) is as defined in Section I of Schedule 25 of the OATT.

Capacity Network Import Interconnection Service (CNI Interconnection Service) is as defined in Section I of Schedule 25 of the OATT.

Capacity Load Obligation Bilateral is a bilateral contract through which a Market Participant may transfer all or a portion of its Capacity Load Obligation to another entity, as described in Section III.13.5 of Market Rule 1.

Capacity Load Obligation Transferring Participant is an entity that has a Capacity Load Obligation and is seeking to shed such obligation through a Capacity Load Obligation Bilateral, as described in Section III.13.5.2 of Market Rule 1.

Capacity Network Resource (CNR) is defined in Section I of Schedule 22 and Attachment 1 to Schedule 23 of the OATT.

Capacity Network Resource Interconnection Service (CNR Interconnection Service) is defined in Section I of Schedule 22 and Attachment 1 to Schedule 23 of the OATT.

Capacity Performance Bilateral is a transaction for transferring Capacity Performance Score, as described in Section III.13.5.3 of Market Rule 1.

Capacity Performance Payment is the performance-dependent portion of revenue received in the Forward Capacity Market, as described in Section III.13.7.2 of Market Rule 1.

Capacity Performance Payment Rate is a rate used in calculating Capacity Performance Payments, as described in Section III.13.7.2.5 of Market Rule 1.

Capacity Performance Score is a figure used in determining Capacity Performance Payments, as described in Section III.13.7.2.4 of Market Rule 1.

Capacity Rationing Rule addresses whether offers and bids in a Forward Capacity Auction may be rationed, as described in Section III.13.2.6 of Market Rule 1.

Capacity Scarcity Condition is a period during which performance is measured in the Forward Capacity Market, as described in Section III.13.7.2.1 of Market Rule 1.

Capacity Scarcity Condition is a period during which performance is measured in the Forward Capacity Market, as described in Section III.13.7.2.1 of Market Rule 1.

Capacity Supply Obligation is an obligation to provide capacity from a resource, or a portion thereof, to satisfy a portion of the Installed Capacity Requirement that is acquired through a Forward Capacity Auction in accordance with Section III.13.2, a reconfiguration auction in accordance with Section III.13.4, or a Capacity Supply Obligation Bilateral in accordance with Section III.13.5.1 of Market Rule 1.

Capacity Supply Obligation Bilateral is a bilateral contract through which a Market Participant may transfer all or a part of its Capacity Supply Obligation to another entity, as described in Section III.13.5.1 of Market Rule 1.

Capacity Transfer Rights (CTRs) are calculated in accordance with Section III.13.7.5.4.

Capacity Transferring Resource is a resource that has a Capacity Supply Obligation and is seeking to shed such obligation, or a portion thereof, through: (1) a Capacity Supply Obligation Bilateral, as described in Section III.13.5.1, or; (2) an annual or monthly reconfiguration auction, as described in Section III.13.4.

Capacity Zone is a geographic sub-region of the New England Control Area as determined in accordance with Section III.12.4 of Market Rule 1.

Capacity Zone Demand Curves are the demand curves used in the Forward Capacity Market for a Capacity Zone as specified in Sections III.13.2.2.2 and III.13.2.2.3.

Capital Funding Charge (CFC) is defined in Section IV.B.2 of the Tariff.

CARL Data is Control Area reliability data submitted to the ISO to permit an assessment of the ability of an external Control Area to provide energy to the New England Control Area in support of capacity offered to the New England Control Area by that external Control Area.

Category B Designated Blackstart Resource has the same meaning as Designated Blackstart Resource.

Charge is a sum of money due from a Covered Entity to the ISO, either in its individual capacity or as billing and collection agent for NEPOOL pursuant to the Participants Agreement.

CLAIM10 is the value, expressed in megawatts, calculated pursuant to Section III.9.5.3 of the Tariff.

CLAIM30 is the value, expressed in megawatts, calculated pursuant to Section III.9.5.3 of the Tariff.

Claimed Capability Audit is performed to determine the real power output capability of a Generator Asset or the demand reduction capability of a Demand Response Resource.

Cluster Enabling Transmission Upgrade (CETU) has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Cluster Enabling Transmission Upgrade Regional Planning Study (CRPS) has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Cluster Entry Deadline has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Cluster Interconnection System Impact Study (CSIS) has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Clustering has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

CNR Capability is defined in Section I of Schedule 22 and Attachment 1 to Schedule 23 of the OATT.

Coincident Peak Contribution is a Market Participant's share of the New England Control Area coincident peak demand for the prior calendar year as determined prior to the start of each Capacity Commitment Period, which reflects the sum of the prior year's annual coincident peak contributions of the customers served by the Market Participant at each Load Asset. Daily Coincident Peak Contribution

values shall be submitted by the Assigned Meter Reader or Host Participant by the meter reading deadline to the ISO.

Commercial Capacity is capacity that has achieved FCM Commercial Operation.

Commission is the Federal Energy Regulatory Commission.

Commitment Period is (i) for a Day-Ahead Energy Market commitment, a period of one or more contiguous hours for which a Resource is cleared in the Day-Ahead Energy Market, and (ii) for a Real-Time Energy Market commitment, the period of time for which the ISO indicates the Resource is being committed when it issues the Dispatch Instruction. If the ISO does not indicate the period of time for which the Resource is being committed in the Real-Time Energy Market, then the Commitment Period is the Minimum Run Time for an offline Resource and one hour for an online Resource.

Common Costs are those costs associated with a Station that are avoided only by the clearing of the Static De-List Bids, the Permanent De-List Bids, or the Retirement De-List Bids of all the Existing Generating Capacity Resources comprising the Station.

Completed Application is an Application that satisfies all of the information and other requirements of the OATT, including any required deposit.

Compliance Effective Date is the date upon which the changes in the predecessor NEPOOL Open Access Transmission Tariff which have been reflected herein to comply with the Commission's Order of April 20, 1998 became effective.

Composite FCM Transaction is a transaction for separate resources seeking to participate as a single composite resource in a Forward Capacity Auction in which multiple Designated FCM Participants provide capacity, as described in Section III.13.1.5 of Market Rule 1.

Conditional Qualified New Resource is defined in Section III.13.1.1.2.3(f) of Market Rule 1.

Confidential Information is defined in Section 2.1 of the ISO New England Information Policy, which is Attachment D to the Tariff.

Confidentiality Agreement is Attachment 1 to the ISO New England Billing Policy.

Congestion is a condition of the New England Transmission System in which transmission limitations prevent unconstrained regional economic dispatch of the power system. Congestion is the condition that results in the Congestion Component of the Locational Marginal Price at one Location being different from the Congestion Component of the Locational Marginal Price at another Location during any given hour of the dispatch day in the Day-Ahead Energy Market or Real-Time Energy Market.

Congestion Component is the component of the nodal price that reflects the marginal cost of congestion at a given Node or External Node relative to the reference point. When used in connection with Zonal Price and Hub Price, the term Congestion Component refers to the Congestion Components of the nodal prices that comprise the Zonal Price and Hub Price weighted and averaged in the same way that nodal prices are weighted to determine Zonal Price and averaged to determine the Hub Price.

Congestion Cost is the cost of congestion as measured by the difference between the Congestion Components of the Locational Marginal Prices at different Locations and/or Reliability Regions on the New England Transmission System.

Congestion Paying LSE is, for the purpose of the allocation of FTR Auction Revenues to ARR Holders as provided for in Appendix C of Market Rule 1, a Market Participant or Non-Market Participant Transmission Customer that is responsible for paying for Congestion Costs as a Transmission Customer paying for Regional Network Service under the Transmission, Markets and Services Tariff, unless such Transmission Customer has transferred its obligation to supply load in accordance with ISO New England System Rules, in which case the Congestion Paying LSE shall be the Market Participant supplying the transferred load obligation. The term Congestion Paying LSE shall be deemed to include, but not be limited to, the seller of internal bilateral transactions that transfer Real-Time Load Obligations under the ISO New England System Rules.

Congestion Revenue Fund is the amount available for payment of target allocations to FTR Holders from the collection of Congestion Cost.

Congestion Shortfall means congestion payments exceed congestion charges during the billing process in any billing period.

Continuous Storage ATRR is an ATRR that participates in the New England Markets as part of a Continuous Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Continuous Storage DARD is a DARD that participates in the New England Markets as part of a Continuous Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Continuous Storage Generator Asset is a Generator Asset that participates in the New England Markets as part of a Continuous Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Continuous Storage Facility is a type of Electric Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Control Agreement is the document posted on the ISO website that is required if a Market Participant's cash collateral is to be invested in BlackRock funds.

Control Area is an electric power system or combination of electric power systems to which a common automatic generation control scheme is applied in order to:

(1) match, at all times, the power output of the generators within the electric power system(s) and capacity and energy purchased from entities outside the electric power system(s), with the load within the electric power system(s);
(2) maintain scheduled interchange with other Control Areas, within the limits of Good Utility Practice;
(3) maintain the frequency of the electric power system(s) within reasonable limits in accordance with Good Utility Practice and the criteria of the applicable regional reliability council or the North American Electric Reliability Corporation; and
(4) provide sufficient generating capacity to maintain operating reserves in accordance with Good Utility Practice.

Controllable Behind-the-Meter Generation means generation whose output can be controlled located at the same facility as a DARD or a Demand Response Asset, excluding: (1) generators whose output is separately metered and reported and (2) generators that cannot operate electrically synchronized to, and that are operated only when the facility loses its supply of power from, the New England Transmission System, or when undergoing related testing.

Coordinated External Transaction is an External Transaction at an external interface for which the enhanced scheduling procedures in Section III.1.10.7.A are implemented. A transaction to wheel energy into, out of or through the New England Control Area is not a Coordinated External Transaction.
Coordinated Transaction Scheduling means the enhanced scheduling procedures set forth in Section III.1.10.7.A.

Correction Limit means the date that is one hundred and one (101) calendar days from the last Operating Day of the month to which the data applied. As described in Section III.3.6.1 of Market Rule 1, this will be the period during which meter data corrections must be submitted unless they qualify for submission as a Requested Billing Adjustment under Section III.3.7 of Market Rule 1.

Cost of Energy Consumed (CEC) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

Cost of Energy Produced (CEP) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

Cost of New Entry (CONE) is the estimated cost of new entry ($/kW-month) for a capacity resource that is determined by the ISO for each Forward Capacity Auction pursuant to Section III.13.2.4.

Counterparty means the status in which the ISO acts as the contracting party, in its name and own right and not as an agent, to an agreement or transaction with a Customer (including assignments involving Customers) involving sale to the ISO, and/or purchase from the ISO, of Regional Transmission Service and market and other products and services, and other transactions and assignments involving Customers, all as described in the Tariff.

Covered Entity is defined in the ISO New England Billing Policy.

Credit Coverage is third-party credit protection obtained by the ISO in the form of credit insurance coverage.

Credit Qualifying means a Rated Market Participant that has an Investment Grade Rating and an Unrated Market Participant that satisfies the Credit Threshold.

Credit Threshold consists of the conditions for Unrated Market Participants outlined in Section II.B.2 of the ISO New England Financial Assurance Policy.

Critical Energy Infrastructure Information (CEII) is defined in Section 3.0(j) of the ISO New England Information Policy, which is Attachment D to the Tariff.

Current Ratio is, on any date, all of a Market Participant's or Non-Market Participant Transmission Customer's current assets divided by all of its current liabilities, in each case as shown on the most recent financial statements provided by such Market Participant or Non-Market Participant Transmission Customer to the ISO.

Curtailment is a reduction in the dispatch of a transaction that was scheduled, using transmission service, in response to a transfer capability shortage as a result of system reliability conditions.

Customer is a Market Participant, a Transmission Customer or another customer of the ISO.

Data Reconciliation Process means the process by which meter reconciliation and data corrections that are discovered by Governance Participants after the Invoice has been issued for a particular month or that are discovered prior to the issuance of the Invoice for the relevant month but not included in that Invoice or in the other Invoices for that month and are reconciled by the ISO on an hourly basis based on data submitted to the ISO by the Host Participant Assigned Meter Reader or Assigned Meter Reader.

Day-Ahead is the calendar day immediately preceding the Operating Day.

Day-Ahead Adjusted Load Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Congestion Revenue is defined in Section III.3.2.1(i) of Market Rule 1.

Day-Ahead Demand Reduction Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Energy Market means the schedule of commitments for the purchase or sale of energy, purchase of demand reductions, payment of Congestion Costs, payment for losses developed by the ISO as a result of the offers and specifications submitted in accordance with Section III.1.10 of Market Rule 1.

Day-Ahead Energy Market Congestion Charge/Credit is defined in Section III.3.2.1(f) of Market Rule 1.

Day-Ahead Energy Market Energy Charge/Credit is defined in Section III.3.2.1(f) of Market Rule 1.

Day-Ahead Energy Market Loss Charge/Credit is defined in Section III.3.2.1(f) of Market Rule 1.

Day-Ahead Energy Market NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Day-Ahead External Transaction Export and Decrement Bid NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Day-Ahead External Transaction Import and Increment Offer NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Day-Ahead Generation Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Load Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Locational Adjusted Net Interchange is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Loss Charges or Credits is defined in Section III.3.2.1(k) of Market Rule 1.

Day-Ahead Loss Revenue is defined in Section III.3.2.1(j) of Market Rule 1.

Day-Ahead Prices means the Locational Marginal Prices resulting from the Day-Ahead Energy Market.

DDP Dispatchable Resource is any Dispatchable Resource that the ISO dispatches using Desired Dispatch Points in the Resource's Dispatch Instructions.

Debt-to-Total Capitalization Ratio is, on any date, a Market Participant's or Non-Market Participant Transmission Customer's total debt (including all current borrowings) divided by its total shareholders'

equity plus total debt, in each case as shown on the most recent financial statements provided by such Market Participant or Non-Market Participant Transmission Customer to the ISO.

Decrement Bid means a bid to purchase energy at a specified Location in the Day-Ahead Energy Market which is not associated with a physical load. An accepted Decrement Bid results in scheduled load at the specified Location in the Day-Ahead Energy Market.

Default Amount is all or any part of any amount due to be paid by any Covered Entity that the ISO, in its reasonable opinion, believes will not or has not been paid when due (other than in the case of a payment dispute for any amount due for transmission service under the OATT).

Default Period is defined in Section 3.3.h(i) of the ISO New England Billing Policy.

Delivering Party is the entity supplying capacity and/or energy to be transmitted at Point(s) of Receipt under the OATT.

Demand Bid means a request to purchase an amount of energy, at a specified Location, or an amount of energy at a specified price, that is associated with a physical load. A cleared Demand Bid in the Day-Ahead Energy Market results in scheduled load at the specified Location. Demand Bids submitted for use in the Real-Time Energy Market are specific to Dispatchable Asset Related Demands only.

Demand Bid Block-Hours are the Block-Hours assigned to the submitting Customer for each Demand Bid.

Demand Bid Cap is $2,000/MWh.

Demand Capacity Resource means an Existing Demand Capacity Resource or a New Demand Capacity Resource. There are three Demand Capacity Resource types: Active Demand Capacity Resources, On-Peak Demand Resources, and Seasonal Peak Demand Resources.

Demand Designated Entity is the entity designated by a Market Participant to receive Dispatch Instructions for Demand Response Resources in accordance with the provisions set forth in ISO New England Operating Procedure No. 14.

Demand Reduction Offer is an offer by a Market Participant with a Demand Response Resource to reduce demand.

Demand Reduction Offer Block-Hours are Block-Hours assigned to the Lead Market Participant for each Demand Reduction Offer. Blocks of the Demand Reduction Offer in effect for each hour will be totaled to determine the quantity of Demand Reduction Offer Block-Hours for a given day. In the case that a Resource has a Real-Time unit status of "unavailable" for the entire day, that day will not contribute to the quantity of Demand Reduction Offer Block-Hours. However, if the Resource has at least one hour of the day with a unit status of "available," the entire day will contribute to the quantity of Demand Reduction Offer Block-Hours.

Demand Reduction Threshold Price is a minimum offer price calculated pursuant to Section III.1.10.1A(f).

Demand Resource On-Peak Hours are hours ending 1400 through 1700, Monday through Friday on non-Demand Response Holidays during the months of June, July, and August and hours ending 1800 through 1900, Monday through Friday on non-Demand Response Holidays during the months of December and January.

Demand Resource Seasonal Peak Hours are those hours in which the actual, real-time hourly load, as measured using real-time telemetry (adjusted for transmission and distribution losses, and excluding load associated with Exports and Storage DARDs) for Monday through Friday on non-Demand Response Holidays, during the months of June, July, August, December, and January, as determined by the ISO, is equal to or greater than 90% of the most recent 50/50 system peak load forecast, as determined by the ISO, for the applicable summer or winter season.

Demand Response Asset is an asset comprising the demand reduction capability of an individual end-use customer at a Retail Delivery Point or the aggregated demand reduction capability of multiple end-use customers from multiple delivery points (as described in Section III.8.1.1(f)) that has been registered in accordance with III.8.1.1.

Demand Response Available is the capability of the Demand Response Resource, in whole or in part, at any given time, to reduce demand in response to a Dispatch Instruction.

Demand Response Baseline is the expected baseline demand of an individual end-use metered customer or group of end-use metered customers as determined pursuant to Section III.8.2.

Demand Response Holiday is New Year's Day, Memorial Day, Independence Day, Labor Day, Veterans Day, Thanksgiving Day, and Christmas Day. If the holiday falls on a Saturday, the holiday will be observed on the preceding Friday; if the holiday falls on a Sunday, the holiday will be observed on the following Monday.

Demand Response Resource is an individual Demand Response Asset or aggregation of Demand Response Assets within a DRR Aggregation Zone that has been registered in accordance with Section III.8.1.2.

Demand Response Resource Notification Time is the period of time between the receipt of a startup Dispatch Instruction and the time the Demand Response Resource starts reducing demand.

Demand Response Resource Ramp Rate is the average rate, expressed in MW per minute, at which the Demand Response Resource can reduce demand.

Demand Response Resource Start-Up Time is the period of time between the time a Demand Response Resource starts reducing demand at the conclusion of the Demand Response Resource Notification Time and the time the resource can reach its Minimum Reduction and be ready for further dispatch by the ISO.

Designated Agent is any entity that performs actions or functions required under the OATT on behalf of the ISO, a Transmission Owner, a Schedule 20A Service Provider, an Eligible Customer, or a Transmission Customer.

Designated Blackstart Resource is a resource that meets the eligibility requirements specified in Schedule 16 of the OATT, which includes any resource referred to previously as a Category B Designated Blackstart Resource.

Designated Entity is the entity designated by a Market Participant to receive Dispatch Instructions for a Generator Asset and/or Dispatchable Asset Related Demand in accordance with the provisions set forth in ISO New England Operating Procedure No. 14.

Designated FCM Participant is any Lead Market Participant, including any Provisional Member that is a Lead Market Participant, transacting in any Forward Capacity Auction, reconfiguration auctions or Capacity Supply Obligation Bilateral for capacity that is otherwise required to provide additional financial assurance under the ISO New England Financial Assurance Policy.

Designated FTR Participant is a Market Participant, including FTR-Only Customers, transacting in the FTR Auction that is otherwise required to provide additional financial assurance under the ISO New England Financial Assurance Policy.

Desired Dispatch Point (DDP) means the control signal, expressed in megawatts, transmitted to direct the output, consumption, or demand reduction level of each Generator Asset, Dispatchable Asset Related Demand, or Demand Response Resource dispatched by the ISO in accordance with the asset's Offer Data.

Direct Assignment Facilities are facilities or portions of facilities that are constructed for the sole use/benefit of a particular Transmission Customer requesting service under the OATT or a Generator Owner requesting an interconnection. Direct Assignment Facilities shall be specified in a separate agreement among the ISO, Interconnection Customer and Transmission Customer, as applicable, and the Transmission Owner whose transmission system is to be modified to include and/or interconnect with the Direct Assignment Facilities, shall be subject to applicable Commission requirements, and shall be paid for by the Customer in accordance with the applicable agreement and the Tariff.

Directly Metered Assets are specifically measured by OP-18 compliant metering as currently described in Section IV (Metering and Recording for Settlements) of OP-18. Directly Metered Assets include all Tie-Line Assets, all Generator Assets, as well as some Load Assets. Load Assets for which the Host Participant is not the Assigned Meter Reader are considered Directly Metered Assets. In addition, the Host Participant Assigned Meter Reader determines which additional Load Assets are considered Directly Metered Assets and which ones are considered Profiled Load Assets based upon the Host Participant Assigned Meter Reader reporting systems and process by which the Host Participant Assigned Meter Reader allocates non-PTF losses.

Disbursement Agreement is the Rate Design and Funds Disbursement Agreement among the PTOs, as amended and restated from time to time.

Dispatch Instruction means directions given by the ISO to Market Participants, which may include instructions to start up, shut down, raise or lower generation, curtail or restore loads from Demand Response Resources, change External Transactions, or change the status or consumption of a Dispatchable Asset Related Demand in accordance with the Supply Offer, Demand Bid, or Demand Reduction Offer parameters. Such instructions may also require a change to the operation of a Pool Transmission Facility. Such instructions are given through either electronic or verbal means.

Dispatch Zone means a subset of Nodes located within a Load Zone established by the ISO for each Capacity Commitment Period pursuant to Section III.12.4A.

Dispatchable Asset Related Demand (DARD) is an Asset Related Demand that is capable of having its energy consumption modified in Real-Time in response to Dispatch Instructions. A DARD must be capable of receiving and responding to electronic Dispatch Instructions, must be able to increase or decrease energy consumption between its Minimum Consumption Limit and Maximum Consumption Limit in accordance with Dispatch Instructions, and must meet the technical requirements specified in the ISO New England Operating Procedures and Manuals.

Dispatchable Resource is any Generator Asset, Dispatchable Asset Related Demand, Demand Response Resource, or, with respect to the Regulation Market only, Alternative Technology Regulation Resource, that, during the course of normal operation, is capable of receiving and responding to electronic Dispatch Instructions in accordance with the parameters contained in the Resource's Supply Offer, Demand Bid, Demand Reduction Offer or Regulation Service Offer. A Resource that is normally classified as a Dispatchable Resource remains a Dispatchable Resource when it is temporarily not capable of receiving and responding to electronic Dispatch Instructions.

Dispute Representatives are defined in 6.5.c of the ISO New England Billing Policy.

Disputed Amount is a Covered Entity's disputed amount due on any fully paid monthly Invoice and/or any amount believed to be due or owed on a Remittance Advice, as defined in Section 6 of the ISO New England Billing Policy.

Disputing Party, for the purposes of the ISO New England Billing Policy, is any Covered Entity seeking to recover a Disputed Amount.

Distributed Generation means generation directly connected to end-use customer load and located behind the end-use customer's Retail Delivery Point that reduces the amount of energy that would otherwise have been produced on the electricity network in the New England Control Area, provided that the facility's Net Supply Capability is (i) less than 5 MW or (ii) less than or equal to the Maximum Facility Load, whichever is greater.

DRR Aggregation Zone is a Dispatch Zone entirely within a single Reserve Zone or Rest of System or, where a Dispatch Zone is not entirely within a single Reserve Zone or Rest of System, each portion of the Dispatch Zone demarcated by the Reserve Zone boundary.

Do Not Exceed (DNE) Dispatchable Generator is any Generator Asset that is dispatched using Do Not Exceed Dispatch Points in its Dispatch Instructions and meets the criteria specified in Section III.1.11.3(e). Do Not Exceed Dispatchable Generators are Dispatchable Resources.

Do Not Exceed Dispatch Point is a Dispatch Instruction indicating a maximum output level that a DNE Dispatchable Generator must not exceed.

Dynamic De-List Bid is a bid that may be submitted by Existing Generating Capacity Resources, Existing Import Capacity Resources, and Existing Demand Capacity Resources in the Forward Capacity Auction below the Dynamic De-List Bid Threshold, as described in Section III.13.2.3.2(d) of Market Rule 1.

Dynamic De-List Bid Threshold is the price specified in Section III.13.1.2.3.1.A of Market Rule 1 associated with the submission of Dynamic De-List Bids in the Forward Capacity Auction.

EA Amount is defined in Section IV.B.2.2 of the Tariff.

Early Amortization Charge (EAC) is defined in Section IV.B.2 of the Tariff.

Early Amortization Working Capital Charge (EAWCC) is defined in Section IV.B.2 of the Tariff.

Early Payment Shortfall Funding Amount (EPSF Amount) is defined in Section IV.B.2.4 of the Tariff.

Early Payment Shortfall Funding Charge (EPSFC) is defined in Section IV.B.2 of the Tariff.

EAWW Amount is defined in Section IV.B.2.3 of the Tariff.

EBITDA-to-Interest Expense Ratio is, on any date, a Market Participant's or Non-Market Participant Transmission Customer's earnings before interest, taxes, depreciation and amortization in the most recent fiscal quarter divided by that Market Participant's or Non-Market Participant Transmission Customer's expense for interest in that fiscal quarter, in each case as shown on the most recent financial statements provided by such Market Participant or Non-Market Participant Transmission Customer to the ISO.

Economic Dispatch Point is the output, reduction, or consumption level to which a Resource would have been dispatched, based on the Resource's Supply Offer, Demand Reduction Offer, or Demand Bid and the Real-Time Price, and taking account of any operating limits, had the ISO not dispatched the Resource to another Desired Dispatch Point.

Economic Maximum Limit or Economic Max is the maximum available output, in MW, of a Generator Asset that a Market Participant offers to supply in the Day-Ahead Energy Market or Real-Time Energy Market, as reflected in the Generator Asset's Offer Data. This represents the highest MW output a Market Participant has offered for a Generator Asset for economic dispatch. A Market Participant must maintain an up-to-date Economic Maximum Limit (and where applicable, must provide the ISO with any telemetry required by ISO New England Operating Procedure No. 18 to allow the ISO to maintain an updated Economic Maximum Limit) for all hours in which a Generator Asset has been offered into the Day-Ahead Energy Market or Real-Time Energy Market.

Economic Minimum Limit or Economic Min is (a) for a Generator Asset with an incremental heat rate, the maximum of: (i) the lowest sustainable output level as specified by physical design characteristics, environmental regulations or licensing limits; and (ii) the lowest sustainable output level at which a one MW increment increase in the output level would not decrease the incremental cost, calculated based on the incremental heat rate, of providing an additional MW of output, and (b) for a Generator Asset without an incremental heat rate, the lowest sustainable output level that is consistent with the physical design characteristics of the Generator Asset and with meeting all environmental regulations and licensing limits, and (c) for a Generator Asset undergoing Facility and Equipment Testing or auditing, the level to which the Generator Asset requests and is approved to operate or is directed to operate for purposes of completing the Facility and Equipment Testing or auditing, and (d) for Non-Dispatchable Resources the

output level at which a Market Participant anticipates its Non-Dispatchable Resource will be available to operate based on fuel limitations, physical design characteristics, environmental regulations or licensing limits.

Economic Study is defined in Section 4.1(b) of Attachment K to the OATT.

Effective Offer is the Supply Offer, Demand Reduction Offer, or Demand Bid that is used for NCPC calculation purposes as specified in Section III.F.1(a).

EFT is electronic funds transfer.

Elective Transmission Upgrade is defined in Section I of Schedule 25 of the OATT.

Elective Transmission Upgrade Interconnection Customer is defined in Schedule 25 of the OATT.

Electric Reliability Organization (ERO) is defined in 18 C.F.R. § 39.1.

Electric Storage Facility is a storage facility that participates in the New England Markets as described in Section III.1.10.6 of Market Rule 1.

Eligible Customer is: (i) Any entity that is engaged, or proposes to engage, in the wholesale or retail electric power business is an Eligible Customer under the OATT. (ii) Any electric utility (including any power marketer), Federal power marketing agency, or any other entity generating electric energy for sale or for resale is an Eligible Customer under the OATT. Electric energy sold or produced by such entity may be electric energy produced in the United States, Canada or Mexico. However, with respect to transmission service that the Commission is prohibited from ordering by Section 212(h) of the Federal Power Act, such entity is eligible only if the service is provided pursuant to a state requirement that the Transmission Owner with which that entity is directly interconnected or the distribution company having the service territory in which that entity is located (if that entity is a retail customer) offer the unbundled transmission service or Local Delivery Service, or pursuant to a voluntary offer of such service by the Transmission Owner with which that entity is directly interconnected or the distribution company having the service territory in which that entity is located (if that entity is a retail customer). (iii) Any end user taking or eligible to take unbundled transmission service or Local Delivery Service pursuant to a state requirement that the Transmission Owner with which that end user is directly interconnected or the

distribution company having the service territory in which that entity is located (if that entity is a retail customer) offer the transmission service or Local Delivery Service, or pursuant to a voluntary offer of such service by the Transmission Owner with which that end user is directly interconnected, or the distribution company having the service territory in which that entity is located (if that entity is a retail customer) is an Eligible Customer under the OATT.

Eligible FTR Bidder is an entity that has satisfied applicable financial assurance criteria, and shall not include the auctioneer, its Affiliates, and their officers, directors, employees, consultants and other representatives.

Emergency is an abnormal system condition on the bulk power systems of New England or neighboring Control Areas requiring manual or automatic action to maintain system frequency, or to prevent the involuntary loss of load, equipment damage, or tripping of system elements that could adversely affect the reliability of an electric system or the safety of persons or property; or a fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel; or a condition that requires implementation of Emergency procedures as defined in the ISO New England Manuals.

Emergency Condition means an Emergency has been declared by the ISO in accordance with the procedures set forth in the ISO New England Manuals and ISO New England Administrative Procedures.

Emergency Energy is energy transferred from one control area operator to another in an Emergency.

Emergency Minimum Limit or Emergency Min means the minimum output, in MWs, that a Generator Asset can deliver for a limited period of time without exceeding specified limits of equipment stability and operating permits.

EMS is energy management system.

End-of-Round Price is the lowest price associated with a round of a Forward Capacity Auction, as described in Section III.13.2.3.1 of Market Rule 1.

End User Participant is defined in Section 1 of the Participants Agreement.

Energy is power produced in the form of electricity, measured in kilowatthours or megawatthours.

Energy Administration Service (EAS) is the service provided by the ISO, as described in Schedule 2 of Section IV.A of the Tariff.

Energy Component means the Locational Marginal Price at the reference point.

Energy Efficiency is installed measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that reduce the total amount of electrical energy needed, while delivering a comparable or improved level of end-use service. Such measures include, but are not limited to, the installation of more energy efficient lighting, motors, refrigeration, HVAC equipment and control systems, envelope measures, operations and maintenance procedures, and industrial process equipment.

Energy Imbalance Service is the form of Ancillary Service described in Schedule 4 of the OATT.

Energy Market is, collectively, the Day-Ahead Energy Market and the Real-Time Energy Market.

Energy Non-Zero Spot Market Settlement Hours are the sum of the hours for which the Customer has a positive or negative Real-Time System Adjusted Net Interchange or for which the Customer has a positive or negative Real-Time Demand Reduction Obligation as determined by the ISO settlement process for the Energy Market.

Energy Offer Floor is negative $150/MWh.

Energy Transaction Units (Energy TUs) are the sum for the month for a Customer of Bilateral Contract Block-Hours, Demand Bid Block-Hours, Asset Related Demand Bid Block-Hours, Supply Offer Block-Hours, Demand Reduction Offer Block-Hours, and Energy Non-Zero Spot Market Settlement Hours.

Equipment Damage Reimbursement is the compensation paid to the owner of a Designated Blackstart Resource as specified in Section 5.5 of Schedule 16 to the OATT.

Equivalent Demand Forced Outage Rate (EFORd) means the portion of time a unit is in demand, but is unavailable due to forced outages.

Estimated Capacity Load Obligation is, for the purposes of the ISO New England Financial Assurance Policy, a Market Participant's share of Zonal Capacity Obligation from the latest available month, adjusted as appropriate to account for any relevant Capacity Load Obligation Bilaterals, HQICCs, and Self-Supplied FCA Resource designations for the applicable month.

Establish Claimed Capability Audit is the audit performed pursuant to Section III.1.5.1.2.

Excepted Transaction is a transaction specified in Section II.40 of the Tariff for the applicable period specified in that Section.

Existing Capacity Qualification Deadline is a deadline, specified in Section III.13.1.10 of Market Rule 1, for submission of certain qualification materials for the Forward Capacity Auction, as discussed in Section III.13.1 of Market Rule 1.

Existing Capacity Qualification Package is information submitted for certain existing resources prior to participation in the Forward Capacity Auction, as described in Section III.13.1 of Market Rule 1.

Existing Capacity Resource is any resource that does not meet any of the eligibility criteria to participate in the Forward Capacity Auction as a New Capacity Resource.

Existing Capacity Retirement Deadline is a deadline, specified in Section III.13.1.10 of Market Rule 1, for submission of certain qualification materials for the Forward Capacity Auction, as discussed in Section III.13.1 of Market Rule 1.

Existing Capacity Retirement Package is information submitted for certain existing resources prior to participation in the Forward Capacity Auction, as described in Section III.13.1 of Market Rule 1.

Existing Demand Capacity Resource is a type of Demand Capacity Resource participating in the Forward Capacity Market, as defined in Section III.13.1.4.2 of Market Rule 1.

Existing Generating Capacity Resource is a type of resource participating in the Forward Capacity Market, as defined in Section III.13.1.2.1 of Market Rule 1.

Existing Import Capacity Resource is a type of resource participating in the Forward Capacity Market, as defined in Section III.13.1.3.1 of Market Rule 1.

Expedited Study Request is defined in Section II.34.7 of the OATT.

Export-Adjusted LSR is as defined in Section III.12.4(b)(ii).

Export Bid is a bid that may be submitted by certain resources in the Forward Capacity Auction to export capacity to an external Control Area, as described in Section III.13.1.2.3.1.3 of Market Rule 1.

Exports are Real-Time External Transactions, which are limited to sales from the New England Control Area, for exporting energy out of the New England Control Area.

External Elective Transmission Upgrade (External ETU) is defined in Section I of Schedule 25 of the OATT.

External Market Monitor means the person or entity appointed by the ISO Board of Directors pursuant to Section III.A.1.2 of Appendix A of Market Rule 1 to carry out the market monitoring and mitigation functions specified in Appendix A and elsewhere in Market Rule 1.

External Node is a proxy bus or buses used for establishing a Locational Marginal Price for energy received by Market Participants from, or delivered by Market Participants to, a neighboring Control Area or for establishing Locational Marginal Prices associated with energy delivered through the New England Control Area by Non-Market Participants for use in calculating Non-Market Participant Congestion Costs and loss costs.

External Resource means a generation resource located outside the metered boundaries of the New England Control Area.

External Transaction is the import of external energy into the New England Control Area by a Market Participant or the export of internal energy out of the New England Control Area by a Market Participant in the Day-Ahead Energy Market and/or Real-Time Energy Market, or the wheeling of external energy through the New England Control Area by a Market Participant or a Non-Market Participant in the Real-Time Energy Market.

External Transaction Cap is $2,000/MWh for External Transactions other than Coordinated External Transactions and $1,000/MWh for Coordinated External Transactions.

External Transaction Floor is the Energy Offer Floor for External Transactions other than Coordinated External Transactions and negative $1,000/MWh for Coordinated External Transactions.

External Transmission Project is a transmission project comprising facilities located wholly outside the New England Control Area and regarding which an agreement has been reached whereby New England ratepayers will support all or a portion of the cost of the facilities.

Facilities Study is an engineering study conducted pursuant to the OATT by the ISO (or, in the case of Local Service or interconnections to Local Area Facilities as defined in the TOA, by one or more affected PTOs) or some other entity designated by the ISO in consultation with any affected Transmission Owner(s), to determine the required modifications to the PTF and Non-PTF, including the cost and scheduled completion date for such modifications, that will be required to provide a requested transmission service or interconnection on the PTF and Non-PTF.

Facility and Equipment Testing means operation of a Resource to evaluate the functionality of the facility or equipment utilized in the operation of the facility.

Failure to Maintain Blackstart Capability is a failure of a Blackstart Owner or Designated Blackstart Resource to meet the Blackstart Service Minimum Criteria or Blackstart Service obligations, but does not include a Failure to Perform During a System Restoration event.

Failure to Perform During a System Restoration is a failure of a Blackstart Owner or Designated Blackstart Resource to follow ISO or Local Control Center dispatch instructions or perform in accordance with the dispatch instructions or the Blackstart Service Minimum Criteria and Blackstart Service obligations, described within the ISO New England Operating Documents, during a restoration of the New England Transmission System.

Fast Start Demand Response Resource is a Demand Response Resource that meets the following criteria: (i) Minimum Reduction Time does not exceed one hour; (ii) Minimum Time Between Reductions does not exceed one hour; (iii) Demand Response Resource Start-Up Time plus Demand Response

Resource Notification Time does not exceed 30 minutes; (iv) has personnel available to respond to Dispatch Instructions or has automatic remote response capability; and (v) is capable of receiving and acknowledging a Dispatch Instruction electronically.

Fast Start Generator means a Generator Asset that the ISO can dispatch to an on-line or off-line state through electronic dispatch and that meets the following criteria: (i) Minimum Run Time does not exceed one hour; (ii) Minimum Down Time does not exceed one hour; (iii) cold Notification Time plus cold Start-Up Time does not exceed 30 minutes; (iv) available for dispatch (when it is either in an on-line or off-line state) and manned or has automatic remote dispatch capability; and (v) capable of receiving and acknowledging a start-up or shut-down Dispatch Instruction electronically.

FCA Cleared Export Transaction is defined in Section III.1.10.7(f)(ii) of Market Rule 1.

FCA Qualified Capacity is the Qualified Capacity that is used in a Forward Capacity Auction.

FCM Capacity Charge Requirements are calculated in accordance with Section VII.C of the ISO New England Financial Assurance Policy.

FCM Charge Rate is calculated in accordance with Section VII.C of the ISO New England Financial Assurance Policy.

FCM Commercial Operation is defined in Section III.13.3.8 of Market Rule 1.

FCM Deposit is calculated in accordance with Section VII.B.1 of the ISO New England Financial Assurance Policy.

FCM Financial Assurance Requirements are described in Section VII of the ISO New England Financial Assurance Policy.

Final Forward Reserve Obligation is calculated in accordance with Section III.9.8(a) of Market Rule 1.

Financial Assurance Default results from a Market Participant or Non-Market Participant Transmission Customer's failure to comply with the ISO New England Financial Assurance Policy.

Financial Assurance Obligations relative to the ISO New England Financial Assurance Policy are determined in accordance with Section III.A(v) of the ISO New England Financial Assurance Policy.

Financial Transmission Right (FTR) is a financial instrument that evidences the rights and obligations specified in Sections III.5.2.2 and III.7 of the Tariff.

Firm Point-To-Point Service is service which is arranged for and administered between specified Points of Receipt and Delivery in accordance with Part II.C of the OATT.

Firm Transmission Service is Regional Network Service, Through or Out Service, service for Excepted Transactions, firm MTF Service, firm OTF Service, and firm Local Service.

Flexible DNE Dispatchable Generator is any DNE Dispatchable Generator that meets the following criteria: (i) Minimum Run Time does not exceed one hour; (ii) Minimum Down Time does not exceed one hour; and (iii) cold Notification Time plus cold Start-Up Time does not exceed 30 minutes.

Force Majeure - An event of Force Majeure means any act of God, labor disturbance, act of the public enemy or terrorists, war, invasion, insurrection, riot, fire, storm or flood, ice, explosion, breakage or accident to machinery or equipment, any curtailment, order, regulation or restriction imposed by governmental military or lawfully established civilian authorities, or any other cause beyond the control of the ISO, a Transmission Owner, a Schedule 20A Service Provider, or a Customer, including without limitation, in the case of the ISO, any action or inaction by a Customer, a Schedule 20A Service Provider, or a Transmission Owner, in the case of a Transmission Owner, any action or inaction by the ISO, any Customer, a Schedule 20A Service Provider, or any other Transmission Owner, in the case of a Schedule 20A Service Provider, any action or inaction by the ISO, any Customer, a Transmission Owner, or any other Schedule 20A Service Provider, and, in the case of a Transmission Customer, any action or inaction by the ISO, a Schedule 20A Service Provider, or any Transmission Owner.

Formal Warning is defined in Section III.B.4.1.1 of Appendix B of Market Rule 1.

Formula-Based Sanctions are defined in Section III.B.4.1.3 of Appendix B of Market Rule 1.

Forward Capacity Auction (FCA) is the annual Forward Capacity Market auction process described in Section III.13.2 of Market Rule 1.

Forward Capacity Auction Starting Price is calculated in accordance with Section III.13.2.4 of Market Rule 1.

Forward Capacity Market (FCM) is the forward market for procuring capacity in the New England Control Area, as described in Section III.13 of Market Rule 1.

Forward Energy Inventory Election is the total MWh value for which a Market Participant elects to be compensated at the forward rate in the inventoried energy program as described in Section III.K.1(d) of Market Rule 1.

Forward LNG Inventory Election is the portion of a Market Participant's Forward Energy Inventory Election attributed to liquefied natural gas in the inventoried energy program as described in Section III.K.1(d) of Market Rule 1.

Forward Reserve means TMNSR and TMOR purchased by the ISO on a forward basis on behalf of Market Participants as provided for in Section III.9 of Market Rule 1.

Forward Reserve Assigned Megawatts is the amount of Forward Reserve, in megawatts, that a Market Participant assigns to eligible Forward Reserve Resources to meet its Forward Reserve Obligation as defined in Section III.9.4.1 of Market Rule 1.

Forward Reserve Auction is the periodic auction conducted by the ISO in accordance with Section III.9 of Market Rule 1 to procure Forward Reserve.

Forward Reserve Auction Offers are offers to provide Forward Reserve to meet system and Reserve Zone requirements as submitted by a Market Participant in accordance with Section III.9.3 of Market Rule 1.

Forward Reserve Charge is a Market Participant's share of applicable system and Reserve Zone Forward Reserve costs attributable to meeting the Forward Reserve requirement as calculated in accordance with Section III.9.9 of Market Rule 1.

Forward Reserve Clearing Price is the clearing price for TMNSR or TMOR, as applicable, for the system and each Reserve Zone resulting from the Forward Reserve Auction as defined in Section III.9.4 of Market Rule 1.

Forward Reserve Credit is the credit received by a Market Participant that is associated with that Market Participant's Final Forward Reserve Obligation as calculated in accordance with Section III.9.8 of Market Rule 1.

Forward Reserve Delivered Megawatts are calculated in accordance with Section III.9.6.5 of Market Rule 1.

Forward Reserve Delivery Period is defined in Section III.9.1 of Market Rule 1.

Forward Reserve Failure-to-Activate Megawatts are calculated in accordance with Section III.9.7.2(a) of Market Rule 1.

Forward Reserve Failure-to-Activate Penalty is the penalty associated with a Market Participant's failure to activate Forward Reserve when requested to do so by the ISO and is defined in Section III.9.7.2 of Market Rule 1.

Forward Reserve Failure-to-Activate Penalty Rate is specified in Section III.9.7.2 of Market Rule 1.

Forward Reserve Failure-to-Reserve, as specified in Section III.9.7.1 of Market Rule 1, occurs when a Market Participant's Forward Reserve Delivered Megawatts for a Reserve Zone in an hour is less than that Market Participant's Forward Reserve Obligation for that Reserve Zone in that hour. Under these circumstances the Market Participant pays a penalty based upon the Forward Reserve Failure-to-Reserve Penalty Rate and that Market Participant's Forward Reserve Failure-to-Reserve Megawatts.

Forward Reserve Failure-to-Reserve Megawatts are calculated in accordance with Section III.9.7.1(a) of Market Rule 1.

Forward Reserve Failure-to-Reserve Penalty is the penalty associated with a Market Participant's failure to reserve Forward Reserve and is defined in Section III.9.7.1 of Market Rule 1.

Forward Reserve Failure-to-Reserve Penalty Rate is specified in Section III.9.7.1(b)(ii) of Market Rule 1.

Forward Reserve Fuel Index is the index or set of indices used to calculate the Forward Reserve Threshold Price as defined in Section III.9.6.2 of Market Rule 1.

Forward Reserve Heat Rate is the heat rate as defined in Section III.9.6.2 of Market Rule 1 that is used to calculate the Forward Reserve Threshold Price.

Forward Reserve Market is a market for forward procurement of two reserve products, Ten-Minute Non-Spinning Reserve (TMNSR) and Thirty-Minute Operating Reserve (TMOR).

Forward Reserve MWs are those megawatts assigned to specific eligible Forward Reserve Resources which convert a Forward Reserve Obligation into a Resource-specific obligation.

Forward Reserve Obligation is a Market Participant's amount, in megawatts, of Forward Reserve that cleared in the Forward Reserve Auction and adjusted, as applicable, to account for bilateral transactions that transfer Forward Reserve Obligations.

Forward Reserve Obligation Charge is defined in Section III.10.4 of Market Rule 1.

Forward Reserve Offer Cap is $9,000/megawatt-month.

Forward Reserve Payment Rate is defined in Section III.9.8 of Market Rule 1.

Forward Reserve Procurement Period is defined in Section III.9.1 of Market Rule 1.

Forward Reserve Qualifying Megawatts refer to all or a portion of a Forward Reserve Resource's capability offered into the Real-Time Energy Market at energy offer prices above the applicable Forward Reserve Threshold Price that are calculated in accordance with Section III.9.6.4 of Market Rule 1.

Forward Reserve Resource is a Resource that meets the eligibility requirements defined in Section III.9.5.2 of Market Rule 1 that has been assigned Forward Reserve Obligation by a Market Participant.

Forward Reserve Threshold Price is the minimum price at which assigned Forward Reserve Megawatts are required to be offered into the Real-Time Energy Market as calculated in Section III.9.6.2 of Market Rule 1.

FTR Auction is the periodic auction of FTRs conducted by the ISO in accordance with Section III.7 of Market Rule 1.

FTR Auction Revenue is the revenue collected from the sale of FTRs in FTR Auctions. FTR Auction Revenue is payable to FTR Holders who submit their FTRs for sale in the FTR Auction in accordance with Section III.7 of Market Rule 1 and to ARR Holders and Incremental ARR Holders in accordance with Appendix C of Market Rule 1.

FTR Credit Test Percentage is calculated in accordance with Section III.B.1(b) of the ISO New England Financial Assurance Policy.

FTR Financial Assurance Requirements are described in Section VI of the ISO New England Financial Assurance Policy.

FTR Holder is an entity that acquires an FTR through the FTR Auction to Section III.7 of Market Rule 1 and registers with the ISO as the holder of the FTR in accordance with Section III.7 of Market Rule 1 and applicable ISO New England Manuals.

FTR-Only Customer is a Market Participant that transacts in the FTR Auction and that does not participate in other markets or programs of the New England Markets. References in this Tariff to a "Non-Market Participant FTR Customers" and similar phrases shall be deemed references to an FTR-Only Customer.

FTR Settlement Risk Financial Assurance is an amount of financial assurance required by a Designated FTR Participant for each bid submission into an FTR Auction and for each bid awarded to the individual participant in an FTR Auction. This amount is calculated pursuant to Section VI.A of the ISO New England Financial Assurance Policy.

GADS Data means data submitted to the NERC for collection into the NERC's Generating Availability Data System (GADS).

Gap Request for Proposals (Gap RFP) is defined in Section III.11 of Market Rule 1.

Gas Day means a period of 24 consecutive hours beginning at 0900 hrs Central Time.

Generating Capacity Resource means a New Generating Capacity Resource or an Existing Generating Capacity Resource.

Generator Asset is a device (or a collection of devices) that is capable of injecting real power onto the grid that has been registered as a Generator Asset in accordance with the Asset Registration Process.

Generator Imbalance Service is the form of Ancillary Service described in Schedule 10 of the OATT.

Generator Interconnection Related Upgrade is an addition to or modification of the New England Transmission System (pursuant to Section II.47.1, Schedule 22 or Schedule 23 of the OATT) to effect the interconnection of a new generating unit or an existing generating unit whose energy capability or capacity capability is being materially changed and increased whether or not the interconnection is being effected to meet the Capacity Capability Interconnection Standard or the Network Capability Interconnection Standard. As to Category A Projects (as defined in Schedule 11 of the OATT), a Generator Interconnection Related Upgrade also includes an upgrade beyond that required to satisfy the Network Capability Interconnection Standard (or its predecessor) for which the Generator Owner has committed to pay prior to October 29, 1998.

Generator Owner is the owner, in whole or part, of a generating unit whether located within or outside the New England Control Area.

Good Utility Practice means any of the practices, methods and acts engaged in or approved by a significant portion of the electric utility industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather includes all acceptable practices, methods, or acts generally accepted in the region, including those practices required by Federal Power Act Section 215(a)(4).

Governance Only Member is defined in Section 1 of the Participants Agreement.

Governance Participant is defined in the Participants Agreement.

Governing Documents, for the purposes of the ISO New England Billing Policy, are the Transmission, Markets and Services Tariff and ISO Participants Agreement.

Governing Rating is the lowest corporate rating from any Rating Agency for that Market Participant, or, if the Market Participant has no corporate rating, then the lowest rating from any Rating Agency for that Market Participant's senior unsecured debt.

Grandfathered Agreements (GAs) is a transaction specified in Section II.45 for the applicable period specified in that Section.

Grandfathered Intertie Agreement (GIA) is defined pursuant to the TOA.

Handy-Whitman Index of Public Utility Construction Costs is the Total Other Production Plant index shown in the Cost Trends of Electric Utility Construction for the North Atlantic Region as published in the Handy-Whitman Index of Public Utility Construction Costs.

Highgate Transmission Facilities (HTF) are existing U. S.-based transmission facilities covered under the Agreement for Joint Ownership, Construction and Operation of the Highgate Transmission Interconnection dated as of August 1, 1984 including (1) the whole of a 200 megawatt high-voltage, back-to-back, direct-current converter facility located in Highgate, Vermont and (2) a 345 kilovolt transmission line within Highgate and Franklin, Vermont (which connects the converter facility at the U.S.-Canadian border to a Hydro-Quebec 120 kilovolt line in Bedford, Quebec). The HTF include any upgrades associated with increasing the capacity or changing the physical characteristics of these facilities as defined in the above stated agreement dated August 1, 1984 until the Operations Date, as defined in the TOA. The current HTF rating is a nominal 225 MW. The HTF are not defined as PTF. Coincident with the Operations Date and except as stipulated in Schedules, 9, 12, and Attachment F to the OATT, HTF shall be treated in the same manner as PTF for purposes of the OATT and all references to PTF in the OATT shall be deemed to apply to HTF as well. The treatment of the HTF is not intended to establish any binding precedent or presumption with regard to the treatment for other transmission facilities within

the New England Transmission System (including HVDC, MTF, or Control Area Interties) for purposes of the OATT.

Host Participant or Host Utility is a Market Participant or a Governance Participant transmission or distribution provider that reconciles the loads within the metering domain with OP-18 compliant metering.

Hourly Charges are defined in Section 1.3 of the ISO New England Billing Policy.

Hourly PER is calculated in accordance with Section III.13.7.1.2.1 of Market Rule 1.

Hourly Requirements are determined in accordance with Section III.A(i) of the ISO New England Financial Assurance Policy.

Hourly Shortfall NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Hub is a specific set of pre-defined Nodes for which a Locational Marginal Price will be calculated for the Day-Ahead Energy Market and Real-Time Energy Market and which can be used to establish a reference price for energy purchases and the transfer of Day-Ahead Adjusted Load Obligations and Real-Time Adjusted Load Obligations and for the designation of FTRs.

Hub Price is calculated in accordance with Section III.2.8 of Market Rule 1.

HQ Interconnection Capability Credit (HQICC) is a monthly value reflective of the annual installed capacity benefits of the Phase I/II HVDC-TF, as determined by the ISO, using a standard methodology on file with the Commission, in conjunction with the setting of the Installed Capacity Requirement. An appropriate share of the HQICC shall be assigned to an IRH if the Phase I/II HVDC-TF support costs are paid by that IRH and such costs are not included in the calculation of the Regional Network Service rate. The share of HQICC allocated to such an eligible IRH for a month is the sum in kilowatts of (1)(a) the IRH's percentage share, if any, of the Phase I Transfer Capability times (b) the Phase I Transfer Credit, plus (2)(a) the IRH's percentage share, if any, of the Phase II Transfer Capability, times (b) the Phase II Transfer Credit. The ISO shall establish appropriate HQICCs to apply for an IRH which has such a percentage share.

Import Capacity Resource means an Existing Import Capacity Resource or a New Import Capacity Resource offered to provide capacity in the New England Control Area from an external Control Area.

Inadvertent Energy Revenue is defined in Section III.3.2.1(o) of Market Rule 1.

Inadvertent Energy Revenue Charges or Credits is defined in Section III.3.2.1(p) of Market Rule 1.

Inadvertent Interchange means the difference between net actual energy flow and net scheduled energy flow into or out of the New England Control Area.

Increment Offer means an offer to sell energy at a specified Location in the Day-Ahead Energy Market which is not associated with a physical supply. An accepted Increment Offer results in scheduled supply at the specified Location in the Day-Ahead Energy Market.

Incremental ARR is an ARR provided in recognition of a participant-funded transmission system upgrade pursuant to Appendix C of this Market Rule.

Incremental ARR Holder is an entity which is the record holder of an Incremental Auction Revenue Right in the register maintained by the ISO.

Incremental Cost of Reliability Service is described in Section III.13.2.5.2.5.2 of Market Rule 1.

Independent Transmission Company (ITC) is a transmission entity that assumes certain responsibilities in accordance with Section 10.05 of the Transmission Operating Agreement and Attachment M to the OATT, subject to the acceptance or approval of the Commission and a finding of the Commission that the transmission entity satisfies applicable independence requirements.

Information Request is a request from a potential Disputing Party submitted in writing to the ISO for access to Confidential Information.

Initial Market Participant Financial Assurance Requirement is calculated for new Market Participants and Returning Market Participants, other than an FTR-Only Customer or a Governance Only Member, according to Section IV of the ISO New England Financial Assurance Policy.

Initial State of Charge is the State of Charge that an Electric Storage Facility offers at the start of hour one of the Day-Ahead Energy Market.

Installed Capacity Requirement means the level of capacity required to meet the reliability requirements defined for the New England Control Area, as described in Section III.12 of Market Rule 1.

Interchange Transactions are transactions deemed to be effected under Market Rule 1.

Interconnecting Transmission Owner has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Interconnection Agreement is the "Large Generator Interconnection Agreement", the "Small Generator Interconnection Agreement", or the "Elective Transmission Upgrade Interconnection Agreement" pursuant to Schedules 22, 23 or 25 of the ISO OATT or an interconnection agreement approved by the Commission prior to the adoption of the Interconnection Procedures.

Interconnection Customer has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Interconnection Feasibility Study Agreement has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, or Section I of Schedule 25 of the OATT.

Interconnection Procedure is the "Large Generator Interconnection Procedures", the "Small Generator Interconnection Procedures", or the "Elective Transmission Upgrade Interconnection Procedures" pursuant to Schedules 22, 23, and 25 of the ISO OATT.

Interconnection Reliability Operating Limit (IROL) has the meaning specified in the Glossary of Terms Used in NERC Reliability Standards.

Interconnection Request has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, or Section I of Schedule 25 of the OATT.

Interconnection Rights Holder(s) (IRH) has the meaning given to it in Schedule 20A to Section II of this Tariff.

Interconnection System Impact Study Agreement has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23 and Section I of Schedule 25 of the OATT.

Interest is interest calculated in the manner specified in Section II.8.3.

Interface Bid is a unified real-time bid to simultaneously purchase and sell energy on each side of an external interface for which the enhanced scheduling procedures in Section III.1.10.7.A are implemented.

Intermittent Power Resource is a wind, solar, run of river hydro or other renewable resource that does not have control over its net power output.

Internal Bilateral for Load is an internal bilateral transaction under which the buyer receives a reduction in Real-Time Load Obligation and the seller receives a corresponding increase in Real-Time Load Obligation in the amount of the sale, in MWs. An Internal Bilateral for Load transaction is only applicable in the Real-Time Energy Market.

Internal Bilateral for Market for Energy is an internal bilateral transaction for Energy which applies in the Day-Ahead Energy Market and Real-Time Energy Market or just the Real-Time Energy Market under which the buyer receives a reduction in Day-Ahead Adjusted Load Obligation and Real-Time Adjusted Load Obligation and the seller receives a corresponding increase in Day-Ahead Adjusted Load Obligation and Real-Time Adjusted Load Obligation in the amount of the sale, in MWs.

Internal Elective Transmission Upgrade (Internal ETU) is defined in Section I of Schedule 25 of the OATT.

Internal Market Monitor means the department of the ISO responsible for carrying out the market monitoring and mitigation functions specified in Appendix A and elsewhere in Market Rule 1.

Interregional Planning Stakeholder Advisory Committee (IPSAC) is the committee described as such in the Northeast Planning Protocol.

Interregional Transmission Project is a transmission project located within the New England Control Area and one or more of the neighboring transmission planning regions.

Interruption Cost is the amount, in dollars, that must be paid to a Market Participant each time the Market Participant's Demand Response Resource is scheduled or dispatched in the New England Markets to reduce demand.

Inventoried Energy Day is an Operating Day that occurs in the months of December, January, or February during the winters of 2023-2024 and 2024-2025 (inventoried energy program) and for which the average of the high temperature and the low temperature on that Operating Day, as measured and reported by the National Weather Service at Bradley International Airport in Windsor Locks, Connecticut, is less than or equal to 17 degrees Fahrenheit, as described in Section III.K.3.1 of Market Rule 1.

Investment Grade Rating, for a Market (other than an FTR-Only Customer) or Non-Market Participant Transmission Customer, is either (a) a corporate investment grade rating from one or more of the Rating Agencies, or (b) if the Market Participant or Non-Market Participant Transmission Customer does not have a corporate rating from one of the Rating Agencies, then an investment grade rating for the Market Participant's or Non-Market Participant Transmission Customer's senior unsecured debt from one or more of the Rating Agencies.

Invoice is a statement issued by the ISO for the net Charge owed by a Covered Entity pursuant to the ISO New England Billing Policy.

Invoice Date is the day on which the ISO issues an Invoice.

ISO means ISO New England Inc.

ISO Charges, for the purposes of the ISO New England Billing Policy, are both Non-Hourly Charges and Hourly Charges.

ISO Control Center is the primary control center established by the ISO for the exercise of its Operating Authority and the performance of functions as an RTO.

ISO-Initiated Claimed Capability Audit is the audit performed pursuant to Section III.1.5.1.4.

ISO New England Administrative Procedures means procedures adopted by the ISO to fulfill its responsibilities to apply and implement ISO New England System Rules.

ISO New England Billing Policy is Exhibit ID to Section I of the Transmission, Markets and Services Tariff.

ISO New England Filed Documents means the Transmission, Markets and Services Tariff, including but not limited to Market Rule 1, the Participants Agreement, the Transmission Operating Agreement or other documents that affect the rates, terms and conditions of service.

ISO New England Financial Assurance Policy is Exhibit IA to Section I of the Transmission, Markets and Services Tariff.

ISO New England Information Policy is the policy establishing guidelines regarding the information received, created and distributed by Market Participants and the ISO in connection with the settlement, operation and planning of the System, as the same may be amended from time to time in accordance with the provisions of this Tariff. The ISO New England Information Policy is Attachment D to the Transmission, Markets and Services Tariff.

ISO New England Manuals are the manuals implementing Market Rule 1, as amended from time to time in accordance with the Participants Agreement. Any elements of the ISO New England Manuals that substantially affect rates, terms, and/or conditions of service shall be filed with the Commission under Section 205 of the Federal Power Act.

ISO New England Operating Documents are the Tariff and the ISO New England Operating Procedures.

ISO New England Operating Procedures (OPs) are the ISO New England Planning Procedures and the operating guides, manuals, procedures and protocols developed and utilized by the ISO for operating the ISO bulk power system and the New England Markets.

ISO New England Planning Procedures are the procedures developed and utilized by the ISO for planning the ISO bulk power system.

ISO New England System Rules are Market Rule 1, the ISO New England Information Policy, the ISO New England Administrative Procedures, the ISO New England Manuals and any other system rules, procedures or criteria for the operation of the New England Transmission System and administration of the New England Markets and the Transmission, Markets and Services Tariff.

ITC Agreement is defined in Attachment M to the OATT.

ITC Rate Schedule is defined in Section 3.1 of Attachment M to the OATT.

ITC System is defined in Section 2.2 of Attachment M to the OATT.

ITC System Planning Procedures is defined in Section 15.4 of Attachment M to the OATT.

Joint ISO/RTO Planning Committee (JIPC) is the committee described as such in the Northeastern Planning Protocol.

Late Payment Account is a segregated interest-bearing account into which the ISO deposits Late Payment Charges due from ISO Charges and interest owed from participants for late payments that are collected and not distributed to the Covered Entities, until the Late Payment Account Limit is reached, under the ISO New England Billing Policy and penalties collected under the ISO New England Financial Assurance Policy.

Late Payment Account Limit is defined in Section 4.2 of the ISO New England Billing Policy.

Late Payment Charge is defined in Section 4.1 of the ISO New England Billing Policy.

Lead Market Participant, for purposes other than the Forward Capacity Market, is the entity authorized to submit Supply Offers, Demand Bids or Demand Reduction Offers for a Resource and to whom certain Energy TUs are assessed under Schedule 2 of Section IV.A of the Tariff. For purposes of the Forward Capacity Market, the Lead Market Participant is the entity designated to participate in that market on behalf of an Existing Capacity Resource or a New Capacity Resource.

Limited Energy Resource means a Generator Asset that, due to design considerations, environmental restriction on operations, cyclical requirements, such as the need to recharge or refill or manage water flow, or fuel limitations, are unable to operate continuously at full output on a daily basis.

Load Asset means a physical load that has been registered in accordance with the Asset Registration Process. A Load Asset can be an Asset Related Demand, including a Dispatchable Asset Related Demand.

Load Management means measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that curtail electrical usage or shift electrical usage while delivering a comparable or acceptable level of end-use service. Such measures include, but are not limited to, energy management systems, load control end-use cycling, load curtailment strategies, and energy storage that curtails or shifts electrical usage by means other than generating electricity.

Load Shedding is the systematic reduction of system demand by temporarily decreasing load.

Load Zone is a Reliability Region, except as otherwise provided for in Section III.2.7 of Market Rule 1.

Local Area Facilities are defined in the TOA**.**

Local Benefit Upgrade(s) (LBU) is an upgrade, modification or addition to the transmission system that is: (i) rated below 115kV or (ii) rated 115kV or above and does not meet all of the non-voltage criteria for PTF classification specified in the OATT.

Local Control Centers are those control centers in existence as of the effective date of the OATT (including the CONVEX, REMVEC, Maine and New Hampshire control centers) or established by the PTOs in accordance with the TOA that are separate from the ISO Control Center and perform certain functions in accordance with the OATT and the TOA.

Local Delivery Service is the service of delivering electric energy to end users. This service is subject to state jurisdiction regardless of whether such service is provided over local distribution or transmission facilities. An entity that is an Eligible Customer under the OATT is not excused from any requirements of state law, or any order or regulation issued pursuant to state law, to arrange for Local Delivery Service

with the Participating Transmission Owner and/or distribution company providing such service and to pay all applicable charges associated with such service, including charges for stranded costs and benefits.

Local Network is defined as the transmission facilities constituting a local network as identified in Attachment E, as such Attachment may be modified from time to time in accordance with the Transmission Operating Agreement.

Local Network Load is the load that a Network Customer designates for Local Network Service under Schedule 21 to the OATT.

Local Network RNS Rate is the rate applicable to Regional Network Service to effect a delivery to load in a particular Local Network, as determined in accordance with Schedule 9 to the OATT.

Local Network Service (LNS) is the network service provided under Schedule 21 and the Local Service Schedules to permit the Transmission Customer to efficiently and economically utilize its resources to serve its load.

Local Point-To-Point Service (LPTP) is Point-to-Point Service provided under Schedule 21 of the OATT and the Local Service Schedules to permit deliveries to or from an interconnection point on the PTF.

Local Public Policy Transmission Upgrade is any addition and/or upgrade to the New England Transmission System with a voltage level below 115kV that is required in connection with the construction of a Public Policy Transmission Upgrade approved for inclusion in the Regional System Plan pursuant to Attachment K to the ISO OATT or included in a Local System Plan in accordance with Appendix 1 to Attachment K.

Local Resource Adequacy Requirement is calculated pursuant to Section III.12.2.1.1.

Local Second Contingency Protection Resources are those Resources identified by the ISO on a daily basis as necessary for the provision of Operating Reserve requirements and adherence to NERC, NPCC and ISO reliability criteria over and above those Resources required to meet first contingency reliability criteria within a Reliability Region.

Local Service is transmission service provided under Schedule 21 and the Local Service Schedules thereto.

Local Service Schedule is a PTO-specific schedule to the OATT setting forth the rates, charges, terms and conditions applicable to Local Service.

Local Sourcing Requirement (LSR) is a value calculated as described in Section III.12.2.1 of Market Rule 1.

Local System Planning (LSP) is the process defined in Appendix 1 of Attachment K to the OATT.

Localized Costs are costs that the ISO, with advisory input from the Reliability Committee, determines in accordance with Schedule 12C of the OATT shall not be included in the Pool-Supported PTF costs recoverable under this OATT, or in costs allocated to Regional Network Load according to Section 6 of Schedule 12. If there are any Localized Costs, the ISO shall identify them in the Regional System Plan.

Location is a Node, External Node, Load Zone, DRR Aggregation Zone, or Hub.

Locational Marginal Price (LMP) is defined in Section III.2 of Market Rule 1. The Locational Marginal Price for a Node is the nodal price at that Node; the Locational Marginal Price for an External Node is the nodal price at that External Node; the Locational Marginal Price for a Load Zone, DRR Aggregation Zone or Reliability Region is the Zonal Price for that Load Zone, DRR Aggregation Zone or Reliability Region, respectively; and the Locational Marginal Price for a Hub is the Hub Price for that Hub.

Long Lead Time Facility (Long Lead Facility) has the meaning specified in Section I of Schedule 22 and Schedule 25 of the OATT.

Long-Term is a term of one year or more.

Long-Term Transmission Outage is a long-term transmission outage scheduled in accordance with ISO New England Operating Procedure No. 3.

Loss Component is the component of the nodal LMP at a given Node or External Node on the PTF that reflects the cost of losses at that Node or External Node relative to the reference point. The Loss Component of the nodal LMP at a given Node on the non-PTF system reflects the relative cost of losses at that Node adjusted as required to account for losses on the non-PTF system already accounted for through tariffs associated with the non-PTF. When used in connection with Hub Price or Zonal Price, the term Loss Component refers to the Loss Components of the nodal LMPs that comprise the Hub Price or Zonal Price, which Loss Components are averaged or weighted in the same way that nodal LMPs are averaged to determine Hub Price or weighted to determine Zonal Price.

Loss of Load Expectation (LOLE) is the probability of disconnecting non-interruptible customers due to a resource deficiency.

Lost Opportunity Cost (LOC) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

LSE means load serving entity.

Lump Sum Blackstart Payment is defined and calculated as specified in Section 5.4 of Schedule 16 to the OATT.

Lump Sum Blackstart Capital Payment is defined and calculated as specified in Section 5.4 of Schedule 16 to the OATT.

Manual Response Rate is the rate, in MW/Minute, at which the output of a Generator Asset, or the consumption of a Dispatchable Asset Related Demand, is capable of changing.

Marginal Loss Revenue Load Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Marginal Reliability Impact is the change, with respect to an increment of capacity supply, in expected unserved energy due to resource deficiency, as measured in hours per year.

Market Credit Limit is a credit limit for a Market Participant's Financial Assurance Obligations (except FTR Financial Assurance Requirements) established for each Market Participant in accordance with Section II.C of the ISO New England Financial Assurance Policy.

Market Credit Test Percentage is calculated in accordance with Section III.B.1(a) of the ISO New England Financial Assurance Policy.

Market Efficiency Transmission Upgrade is defined as those additions and upgrades that are not related to the interconnection of a generator, and, in the ISO's determination, are designed to reduce bulk power system costs to load system-wide, where the net present value of the reduction in bulk power system costs to load system-wide exceeds the net present value of the cost of the transmission addition or upgrade. For purposes of this definition, the term "bulk power system costs to load system-wide" includes, but is not limited to, the costs of energy, capacity, reserves, losses and impacts on bilateral prices for electricity.

Market Participant is a participant in the New England Markets (including a FTR-Only Customer) that has executed a Market Participant Service Agreement, or on whose behalf an unexecuted Market Participant Service Agreement has been filed with the Commission.

Market Participant Financial Assurance Requirement is defined in Section III of the ISO New England Financial Assurance Policy.

Market Participant Obligations is defined in Section III.B.1.1 of Appendix B of Market Rule 1.

Market Participant Service Agreement (MPSA) is an agreement between the ISO and a Market Participant, in the form specified in Attachment A or Attachment A-1 to the Tariff, as applicable.

Market Rule 1 is ISO Market Rule 1 and appendices set forth in Section III of this ISO New England Inc. Transmission, Markets and Services Tariff, as it may be amended from time to time.

Market Violation is a tariff violation, violation of a Commission-approved order, rule or regulation, market manipulation, or inappropriate dispatch that creates substantial concerns regarding unnecessary market inefficiencies.

Material Adverse Change is any change in financial status including, but not limited to a downgrade to below an Investment Grade Rating by any Rating Agency, being placed on credit watch with negative implication by any Rating Agency if the Market Participant or Non-Market Participant Transmission

Customer does not have an Investment Grade Rating, a bankruptcy filing or other insolvency, a report of a significant quarterly loss or decline of earnings, the resignation of key officer(s), the sanctioning of the Market Participant or Non-Market Participant Transmission Customer or any of its Principles imposed by the Federal Energy Regulatory Commission, the Securities Exchange Commission, any exchange monitored by the National Futures Association, or any state entity responsible for regulating activity in energy markets; the filing of a material lawsuit that could materially adversely impact current or future financial results; a significant change in the Market Participant's or Non-Market Participant Transmission Customer's credit default spreads; or a significant change in market capitalization.

Material Adverse Impact is defined, for purposes of review of ITC-proposed plans, as a proposed facility or project will be deemed to cause a "material adverse impact" on facilities outside of the ITC System if: (i) the proposed facility or project causes non-ITC facilities to exceed their capabilities or exceed their thermal, voltage or stability limits, consistent with all applicable reliability criteria, or (ii) the proposed facility or project would not satisfy the standards set forth in Section I.3.9 of the Transmission, Markets and Services Tariff. This standard is intended to assure the continued service of all non-ITC firm load customers and the ability of the non-ITC systems to meet outstanding transmission service obligations.

Maximum Capacity Limit is a value calculated as described in Section III.12.2.2 of Market Rule 1.

Maximum Consumption Limit is the maximum amount, in MW, available for economic dispatch from a DARD and is based on the physical characteristics as submitted as part of the DARD's Offer Data. A Market Participant must maintain an up-to-date Maximum Consumption Limit (and where applicable, must provide the ISO with any telemetry required by ISO New England Operating Procedure No. 18 to allow the ISO to maintain an updated Maximum Consumption Limit) for all hours in which a DARD has been offered into the Day-Ahead Energy Market or Real-Time Energy Market.

Maximum Daily Energy Limit is the maximum amount of megawatt-hours that a Limited Energy Resource expects to be able to generate in the next Operating Day.

Maximum Daily Consumption Limit is the maximum amount of megawatt-hours that a Storage DARD expects to be able to consume in the next Operating Day.

Maximum Facility Load is the highest demand of an end-use customer facility since the start of the prior calendar year (or, if unavailable, an estimate thereof), where the demand evaluated is established by adding metered demand measured at the Retail Delivery Point and the output of all generators located behind the Retail Delivery Point in the same time intervals.

Maximum Interruptible Capacity is an estimate of the maximum demand reduction and Net Supply that a Demand Response Asset can deliver, as measured at the Retail Delivery Point.

Maximum Load is the highest demand since the start of the prior calendar year (or, if unavailable, an estimate thereof), as measured at the Retail Delivery Point.

Maximum Number of Daily Starts is the maximum number of times that a Binary Storage DARD or a Generator Asset can be started or that a Demand Response Resource can be interrupted in the next Operating Day under normal operating conditions.

Maximum Reduction is the maximum available demand reduction, in MW, of a Demand Response Resource that a Market Participant offers to deliver in the Day-Ahead Energy Market or Real-Time Energy Market, as reflected in the Demand Response Resource's Demand Reduction Offer.

Maximum State of Charge is the megawatt-hour value of stored energy, submitted by an Electric Storage Facility as part of its Offer Data for a given hour of the Day-Ahead Energy Market, above which the ISO shall not schedule the Electric Storage Facility to receive electricity from the grid.

Measure Life is the estimated time an On-Peak Demand Resource or Seasonal Peak Demand Resource measure will remain in place, or the estimated time period over which the facility, structure, equipment or system in which a measure is installed continues to exist, whichever is shorter. Suppliers of On-Peak Demand Resources or Seasonal Peak Demand Resources comprised of an aggregation of measures with varied Measures Lives shall determine and document the Measure Life either: (i) for each type of measure with a different Measure Life and adjust the aggregate performance based on the individual measure life calculation in the portfolio; or (ii) as the average Measure Life for the aggregated measures as long as the demand reduction capability of the resource is greater than or equal to the amount that cleared in the Forward Capacity Auction or reconfiguration auction for the entire Capacity Commitment Period, and the demand reduction capability for an Existing On-Peak Demand Resource or Existing Seasonal Peak Demand Resource is not over-stated in a subsequent Capacity Commitment Period. Measure Life shall be

determined consistent with the resource's Measurement and Verification Plan, which shall be reviewed by the ISO to ensure consistency with the measurement and verification requirements of Market Rule 1 and the ISO New England Manuals.

Measurement and Verification Documents mean the measurement and verification documents described in Section 13.1.4.3.1 of Market Rule 1 that are submitted by On-Peak Demand Resources and Seasonal Peak Demand Resources, which include Measurement and Verification Plans, Updated Measurement and Verification Plans, Measurement and Verification Summary Reports, and Measurement and Verification Reference Reports.

Measurement and Verification Plan means the measurement and verification plan submitted by an On-Peak Demand Resource or Seasonal Peak Demand Resource as part of the qualification process for the Forward Capacity Auction pursuant to the requirements of Section III.13.1.4.3 of Market Rule 1 and the ISO New England Manuals.

Measurement and Verification Reference Reports are optional reports submitted by On-Peak Demand Resources or Seasonal Peak Demand Resources during the Capacity Commitment Period subject to the schedule in the Measurement and Verification Plan and consistent with the schedule and reporting standards set forth in the ISO New England Manuals. Measurement and Verification Reference Reports update the prospective demand reduction capability of the On-Peak Demand Resource or Seasonal Peak Demand Resource project based on measurement and verification studies performed during the Capacity Commitment Period.

Measurement and Verification Summary Report is the monthly report submitted by an On-Peak Demand Resource or Seasonal Peak Demand Resource with the monthly settlement report for the Forward Capacity Market, which documents the total demand reduction capability for all On-Peak Demand Resources and Seasonal Peak Demand Resources in operation as of the end of the previous month.

MEPCO Grandfathered Transmission Service Agreement (MGTSA) is a MEPCO long-term firm point-to-point transmission service agreement with a POR or POD at the New Brunswick border and a start date prior to June 1, 2007 where the holder has elected, by written notice delivered to MEPCO within five (5) days following the filing of the settlement agreement in Docket Nos. ER07-1289 and

EL08-56 or by September 1, 2008 (whichever is later), MGTSA treatment as further described in Section II.45.1.

Merchant Transmission Facilities (MTF) are the transmission facilities owned by MTOs, defined and classified as MTF pursuant to Schedule 18 of the OATT, over which the ISO shall exercise Operating Authority in accordance with the terms set forth in a MTOA or Attachment K to the OATT, rated 69 kV or above and required to allow energy from significant power sources to move freely on the New England Transmission System.

Merchant Transmission Facilities Provider (MTF Provider) is an entity as defined in Schedule 18 of the OATT.

Merchant Transmission Facilities Service (MTF Service) is transmission service over MTF as provided for in Schedule 18 of the OATT.

Merchant Transmission Operating Agreement (MTOA) is an agreement between the ISO and an MTO with respect to its MTF.

Merchant Transmission Owner (MTO) is an owner of MTF.

Meter Data Error means an error in meter data, including an error in Coincident Peak Contribution values, on an Invoice issued by the ISO after the completion of the Data Reconciliation Process as described in the ISO New England Manuals and in Section III.3.8 of Market Rule 1.

Meter Data Error RBA Submission Limit means the date thirty 30 calendar days after the issuance of the Invoice containing the results of the Data Reconciliation Process as described in the ISO New England Manuals and in Section III.3.6 of Market Rule 1.

Metered Quantity For Settlement is defined in Section III.3.2.1.1 of Market Rule 1.

Minimum Consumption Limit is (a) the lowest consumption level, in MW, available for economic dispatch from a DARD and is based on the physical characteristics as submitted as part of the DARD's Offer Data, and (b) for a DARD undergoing Facility and Equipment Testing or auditing, the level to

which the DARD requests and is approved to operate or is directed to operate for purposes of completing the Facility and Equipment Testing or auditing.

Minimum Down Time is the number of hours that must elapse after a Generator Asset or Storage DARD has been released for shutdown at or below its Economic Minimum Limit or Minimum Consumption Limit before the Generator Asset or Storage DARD can be brought online and be released for dispatch at its Economic Minimum Limit or Minimum Consumption Limit.

Minimum Generation Emergency means an Emergency declared by the ISO in which the ISO anticipates requesting one or more Generator Assets to operate at or below Economic Minimum Limit in order to manage, alleviate, or end the Emergency.

Minimum Generation Emergency Credits are those Real-Time Dispatch NCPC Credits calculated pursuant to Appendix F of Market Rule 1 for resources within a reliability region that are dispatched during a period for which a Minimum Generation Emergency has been declared.

Minimum Reduction is the minimum available demand reduction, in MW, of a Demand Response Resource that a Market Participant offers to deliver in the Day-Ahead Energy Market or Real-Time Energy Market, as reflected in the Demand Response Resource's Demand Reduction Offer.

Minimum Reduction Time is the minimum number of hours of demand reduction at or above the Minimum Reduction for which the ISO must dispatch a Demand Response Resource to reduce demand.

Minimum Run Time is the number of hours that a Generator Asset must remain online after it has been scheduled to reach its Economic Minimum Limit before it can be released for shutdown from its Economic Minimum Limit or the number of hours that must elapse after a Storage DARD has been scheduled to consume at its Minimum Consumption Limit before it can be released for shutdown.

Minimum State of Charge is the megawatt-hour value of stored energy, submitted by an Electric Storage Facility as part of its Offer Data for a given hour of the Day-Ahead Energy Market, below which the ISO shall not schedule the Electric Storage Facility to inject electricity to the grid.

Minimum Time Between Reductions is the number of hours that must elapse after a Demand Response Resource has received a Dispatch Instruction to stop reducing demand before the Demand Response

Resource can achieve its Minimum Reduction after receiving a Dispatch Instruction to start reducing demand.

Minimum Total Reserve Requirement, which does not include Replacement Reserve, is the combined amount of TMSR, TMNSR, and TMOR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Monthly Blackstart Service Charge is the charge made to Transmission Customers pursuant to Section 6 of Schedule 16 to the OATT.

Monthly Capacity Payment is the Forward Capacity Market payment described in Section III.13.7.3 of Market Rule 1.

Monthly Peak is defined in Section II.21.2 of the OATT.

Monthly PER is calculated in accordance with Section III.13.7.1.2.2 of Market Rule 1.

Monthly Real-Time Demand Reduction Obligation is the absolute value of a Customer's hourly Real-Time Demand Reduction Obligation summed for all hours in a month, in MWhs.

Monthly Real-Time Generation Obligation is the sum, for all hours in a month, at all Locations, of a Customer's Real-Time Generation Obligation, in MWhs.

Monthly Real-Time Load Obligation is the absolute value of a Customer's hourly Real-Time Load Obligation summed for all hours in a month, in MWhs.

Monthly Regional Network Load is defined in Section II.21.2 of the OATT.

Monthly Statement is the first weekly Statement issued on a Monday after the tenth of a calendar month that includes both the Hourly Charges for the relevant billing period and Non-Hourly Charges for the immediately preceding calendar month.

MRI Transition Period is the period specified in Section III.13.2.2.1.

MUI is the market user interface.

Municipal Market Participant is defined in Section II of the ISO New England Financial Assurance Policy.

MW is megawatt.

MWh is megawatt-hour.

Native Load Customers are the wholesale and retail power customers of a Transmission Owner on whose behalf the Transmission Owner, by statute, franchise, regulatory requirement, or contract, has undertaken an obligation to construct and operate its system to meet the reliable electric needs of such customers.

NCPC Charge means the charges to Market Participants calculated pursuant to Appendix F to Market Rule 1.

NCPC Credit means the credits to Market Participants calculated pursuant to Appendix F to Market Rule 1.

Needs Assessment is defined in Section 4.1 of Attachment K to the OATT.

NEMA, for purposes of Section III of the Tariff, is the Northeast Massachusetts Reliability Region.

NEMA Contract is a contract described in Appendix C of Market Rule 1 and listed in Exhibit 1 of Appendix C of Market Rule 1.

NEMA Load Serving Entity (NEMA LSE) is a Transmission Customer or Congestion Paying LSE Entity that serves load within NEMA.

NEMA or Northeast Massachusetts Upgrade, for purposes of Section II of the Tariff, is an addition to or modification of the PTF into or within the Northeast Massachusetts Reliability Region that was not, as of December 31, 1999, the subject of a System Impact Study or application filed pursuant to Section I.3.9 of the Transmission, Markets and Services Tariff; that is not related to generation interconnections; and

that will be completed and placed in service by June 30, 2004. Such upgrades include, but are not limited to, new transmission facilities and related equipment and/or modifications to existing transmission facilities and related equipment. The list of NEMA Upgrades is contained in Schedule 12A of the OATT.

NEPOOL is the New England Power Pool, and the entities that collectively participated in the New England Power Pool.

NEPOOL Agreement is the agreement among the participants in NEPOOL.

NEPOOL GIS is the generation information system.

NEPOOL GIS Administrator is the entity or entities that develop, administer, operate and maintain the NEPOOL GIS.

NEPOOL GIS API Fees are the one-time on-boarding fees and annual maintenance fees charged to NEPOOL by the NEPOOL GIS Administrator for each NEPOOL Participant or Market Participant that accesses the NEPOOL GIS through an application programming interface pursuant to Rule 3.9(b) of the operating rules of the NEPOOL GIS.

NEPOOL Participant is a party to the NEPOOL Agreement.

NERC is the North American Electric Reliability Corporation or its successor organization.

NESCOE is the New England States Committee on Electricity, recognized by the Commission as the regional state committee for the New England Control Area.

Net Commitment Period Compensation (NCPC) is the compensation methodology for Resources that is described in Appendix F to Market Rule 1.

Net CONE is an estimate of the Cost of New Entry, net of the first-year non-capacity market revenues, for a reference technology resource type and is intended to equal the amount of capacity revenue the reference technology resource would require, in its first year of operation, to be economically viable given reasonable expectations of the first year energy and ancillary services revenues, and projected revenue for subsequent years.

Net Regional Clearing Price is described in Section III.13.7.5 of Market Rule 1.

Net Supply is energy injected into the transmission or distribution system at a Retail Delivery Point.

Net Supply Capability is the maximum Net Supply a facility is physically and contractually able to inject into the transmission or distribution system at its Retail Delivery Point.

Network Capability Interconnection Standard has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Network Customer is a Transmission Customer receiving RNS or LNS.

Network Import Capability (NI Capability) is defined in Section I of Schedule 25 of the OATT.

Network Import Interconnection Service (NI Interconnection Service) is defined in Section I of Schedule 25 of the OATT.

Network Resource is defined as follows: (1) With respect to Market Participants, (a) any generating resource located in the New England Control Area which has been placed in service prior to the Compliance Effective Date (including a unit that has lost its capacity value when its capacity value is restored and a deactivated unit which may be reactivated without satisfying the requirements of Section II.46 of the OATT in accordance with the provisions thereof) until retired; (b) any generating resource located in the New England Control Area which is placed in service after the Compliance Effective Date until retired, provided that (i) the Generator Owner has complied with the requirements of Sections II.46 and II.47 and Schedules 22 and 23 of the OATT, and (ii) the output of the unit shall be limited in accordance with Sections II.46 and II.47 and Schedules 22 and 23, if required; and (c) any generating resource or combination of resources (including bilateral purchases) located outside the New England Control Area for so long as any Market Participant has an Ownership Share in the resource or resources which is being delivered to it in the New England Control Area to serve Regional Network Load located in the New England Control Area or other designated Regional Network Loads contemplated by Section II.18.3 of the OATT taking Regional Network Service. (2) With respect to Non-Market Participant Transmission Customers, any generating resource owned, purchased or leased by the Non-Market Participant Transmission Customer which it designates to serve Regional Network Load.

New Brunswick Security Energy is defined in Section III.3.2.6A of Market Rule 1.

New Capacity Offer is an offer in the Forward Capacity Auction to provide capacity from a New Generating Capacity Resource, New Import Capacity Resource or New Demand Capacity Resource.

New Capacity Qualification Deadline is a deadline, specified in Section III.13.1.10 of Market Rule 1, for submission of certain qualification materials for the Forward Capacity Auction, as discussed in Section III.13.1 of Market Rule 1.

New Capacity Qualification Package is information submitted by certain new resources prior to participation in the Forward Capacity Auction, as described in Section III.13.1 of Market Rule 1.

New Capacity Resource is a resource (i) that never previously received any payment as a capacity resource including any capacity payment pursuant to the market rules in effect prior to June 1, 2010 and that has not cleared in any previous Forward Capacity Auction; or (ii) that is otherwise eligible to participate in the Forward Capacity Auction as a New Capacity Resource.

New Capacity Show of Interest Form is described in Section III.13.1.1.2.1 of Market Rule 1.

New Capacity Show of Interest Submission Window is the period of time during which a Project Sponsor may submit a New Capacity Show of Interest Form or a New Demand Capacity Resource Show of Interest Form, as described in Section III.13.1.10 of Market Rule 1.

New Demand Capacity Resource is a type of Demand Capacity Resource participating in the Forward Capacity Market, as defined in Section III.13.1.4.1 of Market Rule 1.

New Demand Capacity Resource Qualification Package is the information that a Project Sponsor must submit, in accordance with Section III.13.1.4.1.1.2 of Market Rule 1, for each resource that it seeks to offer in the Forward Capacity Auction as a New Demand Capacity Resource.

New Demand Capacity Resource Show of Interest Form is described in Section III.13.1.4.1.1.1 of Market Rule 1.

New England Control Area is the Control Area for New England, which includes PTF, Non-PTF, MTF and OTF. The New England Control Area covers Connecticut, Rhode Island, Massachusetts, New Hampshire, Vermont, and part of Maine (i.e., excluding the portions of Northern Maine and the northern portion of Eastern Maine which are in the Maritimes Control Area).

New England Markets are markets or programs for the purchase of energy, capacity, ancillary services, demand response services or other related products or services (including Financial Transmission Rights) that are delivered through or useful to the operation of the New England Transmission System and that are administered by the ISO pursuant to rules, rates, or agreements on file from time to time with the Federal Energy Regulatory Commission.

New England System Restoration Plan is the plan that is developed by ISO, in accordance with NERC Reliability Standards, NPCC regional criteria and standards, ISO New England Operating Documents and ISO operating agreements, to facilitate the restoration of the New England Transmission System following a partial or complete shutdown of the New England Transmission System.

New England Transmission System is the system of transmission facilities, including PTF, Non-PTF, OTF and MTF, within the New England Control Area under the ISO's operational jurisdiction.

New Generating Capacity Resource is a type of resource participating in the Forward Capacity Market, as described in Section III.13.1.1.1 of Market Rule 1.

New Import Capacity Resource is a type of resource participating in the Forward Capacity Market, as defined in Section III.13.1.3.4 of Market Rule 1.

New Resource Offer Floor Price is defined in Section III.A.21.2.

NMPTC means Non-Market Participant Transmission Customer.

NMPTC Credit Threshold is described in Section V.A.2 of the ISO New England Financial Assurance Policy.

NMPTC Financial Assurance Requirement is an amount of additional financial assurance for Non-Market Participant Transmission Customers described in Section V.D of the ISO New England Financial Assurance Policy.

Node is a point on the New England Transmission System at which LMPs are calculated.

No-Load Fee is the amount, in dollars per hour, for a Generator Asset that must be paid to Market Participants with an Ownership Share in the Generator Asset for being scheduled in the New England Markets, in addition to the Start-Up Fee and price offered to supply energy, for each hour that the Generator Asset is scheduled in the New England Markets.

Nominated Consumption Limit is the consumption level specified by the Market Participant for a Dispatchable Asset Related Demand as adjusted in accordance with the provisions of Section III.13.7.5.1.3.

Non-Commercial Capacity is the capacity of a New Capacity Resource or an Existing Capacity Resource, or portion thereof, that has not achieved FCM Commercial Operation.

Non-Commercial Capacity Cure Period is the time period described in Section VII.D of the ISO New England Financial Assurance Policy.

Non-Commercial Capacity Financial Assurance Amount (Non-Commercial Capacity FA Amount) is the financial assurance amount held on Non-Commercial Capacity cleared in a Forward Capacity Auction as calculated in accordance with Section VII.B.2 of the ISO New England Financial Assurance Policy.

Non-Designated Blackstart Resource Study Cost Payments are the study costs reimbursed under Section 5.3 of Schedule 16 of the OATT.

Non-Dispatchable Resource is any Resource that does not meet the requirements to be a Dispatchable Resource.

Non-Hourly Charges are defined in Section 1.3 of the ISO New England Billing Policy.

Non-Hourly Requirements are determined in accordance with Section III.A(ii) of the ISO New England Financial Assurance Policy, which is Exhibit 1A of Section I of the Tariff.

Non-Incumbent Transmission Developer is a Qualified Transmission Project Sponsor that: (i) is not currently a PTO; (ii) has a transmission project listed in the RSP Project List; and (iii) has executed a Non-Incumbent Transmission Developer Operating Agreement. "Non-Incumbent Transmission Developer" also includes a PTO that proposes the development of a transmission facility not located within or connected to its existing electric system; however, because such a PTO is a party to the TOA, it is not required to enter into a Non-Incumbent Transmission Developer Operating Agreement.

Non-Incumbent Transmission Developer Operating Agreement (or NTDOA) is an agreement between the ISO and a Non-Incumbent Transmission Developer in the form specified in Attachment O to the OATT that sets forth their respective rights and responsibilities to each other with regard to proposals for and construction of certain transmission facilities.

Non-Market Participant is any entity that is not a Market Participant.

Non-Market Participant Transmission Customer is any entity which is not a Market Participant but is a Transmission Customer.

Non-Municipal Market Participant is defined in Section II of the ISO New England Financial Assurance Policy.

Non-PTF Transmission Facilities (Non-PTF) are the transmission facilities owned by the PTOs that do not constitute PTF, OTF or MTF.

Non-Qualifying means a Market Participant that is not a Credit Qualifying Market Participant.

Notice of RBA is defined in Section 6.3.2 of the ISO New England Billing Policy.

Notification Time is the time required for a Generator Asset to synchronize to the system from the time a startup Dispatch Instruction is received from the ISO.

Northeastern Planning Protocol is the Amended and Restated Northeastern ISO/RTO Planning Coordination Protocol on file with the Commission and posted on the ISO website at the following URL: www.iso-ne.com/static-assets/documents/2015/07/northeastern_protocol_dmeast.doc.

NPCC is the Northeast Power Coordinating Council.

Obligation Month means a time period of one calendar month for which capacity payments are issued and the costs associated with capacity payments are allocated.

Offer Data means the scheduling, operations planning, dispatch, new Resource, and other data, including Generator Asset, Dispatchable Asset Related Demand, and Demand Response Resource operating limits based on physical characteristics, and information necessary to schedule and dispatch Generator Assets, Dispatchable Asset Related Demands, and Demand Response Resources for the provision or consumption of energy, the provision of other services, and the maintenance of the reliability and security of the transmission system in the New England Control Area, and specified for submission to the New England Markets for such purposes by the ISO.

Offered CLAIM10 is a Supply Offer value or a Demand Reduction Offer value between 0 and the CLAIM10 of the resource that represents the amount of TMNSR available either from an off-line Fast Start Generator or from a Fast Start Demand Response Resource that has not been dispatched.

Offered CLAIM30 is a Supply Offer value or a Demand Reduction Offer value between 0 and the CLAIM30 of the resource that represents the amount of TMOR available either from an off-line Fast Start Generator or from a Fast Start Demand Response Resource that has not been dispatched.

On-Peak Demand Resource is a type of Demand Capacity Resource and means installed measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that reduce the total amount of electrical energy consumed during Demand Resource On-Peak Hours, while delivering a comparable or acceptable level of end-use service. Such measures include Energy Efficiency, Load Management, and Distributed Generation.

Open Access Same-Time Information System (OASIS) is the ISO information system and standards of conduct responding to requirements of 18 C.F.R. §37 of the Commission's regulations and all additional requirements implemented by subsequent Commission orders dealing with OASIS.

Open Access Transmission Tariff (OATT) is Section II of the ISO New England Inc. Transmission, Markets and Services Tariff.

Operating Authority is defined pursuant to a MTOA, an OTOA, the TOA or the OATT, as applicable.

Operating Data means GADS Data, data equivalent to GADS Data, CARL Data, metered load data, or actual system failure occurrences data, all as described in the ISO New England Operating Procedures.

Operating Day means the calendar day period beginning at midnight for which transactions on the New England Markets are scheduled.

Operating Reserve means Ten-Minute Spinning Reserve (TMSR), Ten-Minute Non-Spinning Reserve (TMNSR) and Thirty-Minute Operating Reserve (TMOR).

Operations Date is February 1, 2005.

OTF Service is transmission service over OTF as provided for in Schedule 20.

Other Transmission Facility (OTF) are the transmission facilities owned by Transmission Owners, defined and classified as OTF pursuant to Schedule 20, over which the ISO shall exercise Operating Authority in accordance with the terms set forth in the OTOA, rated 69 kV or above, and required to allow energy from significant power sources to move freely on the New England Transmission System. OTF classification shall be limited to the Phase I/II HVDC-TF.

Other Transmission Operating Agreements (OTOA) is the agreement(s) between the ISO, an OTO and/or the associated service provider(s) with respect to an OTF, which includes the HVDC Transmission Operating Agreement and the Phase I/II HVDC-TF Transmission Service Administration Agreement. With respect to the Phase I/II HVDC-TF, the HVDC Transmission Operating Agreement covers the rights and responsibilities for the operation of the facility and the Phase I/II HVDC-TF Transmission Service Administration Agreement covers the rights and responsibilities for the administration of transmission service.

Other Transmission Owner (OTO) is an owner of OTF.

Ownership Share is a right or obligation, for purposes of settlement, to a percentage share of all credits or charges associated with a Generator Asset or a Load Asset, where such facility is interconnected to the New England Transmission System.

Participant Expenses are defined in Section 1 of the Participants Agreement.

Participant Required Balance is defined in Section 5.3 of the ISO New England Billing Policy.

Participant Vote is defined in Section 1 of the Participants Agreement.

Participants Agreement is the agreement among the ISO, the New England Power Pool and Individual Participants, as amended from time to time, on file with the Commission.

Participants Committee is the principal committee referred to in the Participants Agreement.

Participating Transmission Owner (PTO) is a transmission owner that is a party to the TOA.

Passive DR Audit is the audit performed pursuant to Section III.13.6.1.5.4.

Passive DR Auditing Period is the summer Passive DR Auditing Period (June 1 to August 31) or winter Passive DR Auditing Period (December 1 to January 31) applicable to On-Peak Demand Resources and Seasonal Peak Demand Resources.

Payment is a sum of money due to a Covered Entity from the ISO.

Payment Default Shortfall Fund is defined in Section 5.1 of the ISO New England Billing Policy.

Peak Energy Rent (PER) is described in Section III.13.7.1.2 of Market Rule 1.

PER Proxy Unit is described in Section III.13.7.1.2.1 of Market Rule 1.

Permanent De-list Bid is a bid that may be submitted by an Existing Generating Capacity Resource, Existing Import Capacity Resource, or Existing Demand Capacity Resource in the Forward Capacity

Auction to permanently remove itself from the capacity market, as described in Section III.13.1.2.3.1.5 of Market Rule 1.

Phase I Transfer Credit is 40% of the HQICC, or such other fraction of the HQICC as the ISO may establish.

Phase I/II HVDC-TF is defined in Schedule 20A to Section II of this Tariff.

Phase I/II HVDC-TF Transfer Capability is the transfer capacity of the Phase I/II HVDC-TF under normal operating conditions, as determined in accordance with Good Utility Practice. The "Phase I Transfer Capability" is the transfer capacity under normal operating conditions, as determined in accordance with Good Utility Practice, of the Phase I terminal facilities as determined initially as of the time immediately prior to Phase II of the Phase I/II HVDC-TF first being placed in service, and as adjusted thereafter only to take into account changes in the transfer capacity which are independent of any effect of Phase II on the operation of Phase I. The "Phase II Transfer Capability" is the difference between the Phase I/II HVDC-TF Transfer Capability and the Phase I Transfer Capability. Determinations of, and any adjustment in, Phase I/II HVDC-TF Transfer Capability shall be made by the ISO, and the basis for any such adjustment shall be explained in writing and posted on the ISO website.

Phase One Proposal is a first round submission, as defined in Section 4.3 of Attachment K of the OATT, of a proposal for a Reliability Transmission Upgrade or Market Efficiency Transmission Upgrade, as applicable, by a Qualified Transmission Project Sponsor.

Phase II Transfer Credit is 60% of the HQICC, or such other fraction of the HQICC as the ISO may establish.

Phase Two Solution is a second round submission, as defined in Section 4.3 of Attachment K of the OATT, of a proposal for a Reliability Transmission Upgrade or Market Efficiency Transmission Upgrade by a Qualified Transmission Project Sponsor.

Planning Advisory Committee is the committee described in Attachment K of the OATT.

Planning and Reliability Criteria is defined in Section 3.3 of Attachment K to the OATT.

Planning Authority is an entity defined as such by the North American Electric Reliability Corporation.

Point(s) of Delivery (POD) is point(s) of interconnection where capacity and/or energy transmitted by a Transmission Customer will be made available to the Receiving Party under the OATT.

Point of Interconnection shall have the same meaning as that used for purposes of Schedules 22, 23 and 25 of the OATT.

Point(s) of Receipt (POR) is point(s) of interconnection where capacity and/or energy transmitted by a Transmission Customer will be made available by the Delivering Party under the OATT.

Point-To-Point Service is the transmission of capacity and/or energy on either a firm or non-firm basis from the Point(s) of Receipt to the Point(s) of Delivery under the OATT pursuant to Local Point-To-Point Service or OTF Service or MTF Service; and the transmission of capacity and/or energy from the Point(s) of Receipt to the Point(s) of Delivery under the OATT pursuant to Through or Out Service.

Pool-Planned Unit is one of the following units: New Haven Harbor Unit 1 (Coke Works), Mystic Unit 7, Canal Unit 2, Potter Unit 2, Wyman Unit 4, Stony Brook Units 1, 1A, 1B, 1C, 2A and 2B, Millstone Unit 3, Seabrook Unit 1 and Waters River Unit 2 (to the extent of 7 megawatts of its Summer capability and 12 megawatts of its Winter capability).

Pool PTF Rate is the transmission rate determined in accordance with Schedule 8 to the OATT.

Pool RNS Rate is the transmission rate determined in accordance with paragraph (2) of Schedule 9 of Section II of the Tariff.

Pool-Scheduled Resources are described in Section III.1.10.2 of Market Rule 1.

Pool Supported PTF is defined as: (i) PTF first placed in service prior to January 1, 2000; (ii) Generator Interconnection Related Upgrades with respect to Category A and B projects (as defined in Schedule 11), but only to the extent not paid for by the interconnecting Generator Owner; and (iii) other PTF upgrades, but only to the extent the costs therefore are determined to be Pool Supported PTF in accordance with Schedule 12.

Pool Transmission Facility (PTF) means the transmission facilities owned by PTOs which meet the criteria specified in Section II.49 of the OATT.

Posting Entity is any Market Participant or Non-Market Participant Transmission Customer providing financial security under the provisions of the ISO New England Financial Assurance Policy.

Posture means an action of the ISO to deviate from the jointly optimized security constrained economic dispatch for Energy and Operating Reserves solution for a Resource produced by the ISO's technical software for the purpose of maintaining sufficient Operating Reserve (both online and off-line) or for the provision of voltage or VAR support.

Posturing Credits are the Real-Time Posturing NCPC Credits for Generators (Other Than Limited Energy Resources) Postured for Reliability and the Real-Time Posturing NCPC Credit for Limited Energy Resources Postured for Reliability.

Power Purchaser is the entity that is purchasing the capacity and/or energy to be transmitted under the OATT.

Principal is (i) the sole proprietor of a sole proprietorship; (ii) a general partner of a partnership; (iii) a president, chief executive officer, chief operating officer or chief financial officer (or equivalent position) of an organization; (iv) a manager, managing member or a member vested with the management authority for a limited liability company or limited liability partnership; (v) any person or entity that has the power to exercise a controlling influence over an organization's activities that are subject to regulation by the Federal Energy Regulatory Commission, the Securities and Exchange Commission, the Commodity Futures Trading Commission, any exchange monitored by the National Futures Association, or any state entity responsible for regulating activity in energy markets; or (vi) any person or entity that: (a) is the direct owner of 10% or more of any class of an organization's equity securities; or (b) has directly contributed 10% or more of an organization's capital.

Profiled Load Assets include all Load Assets that are not directly metered by OP-18 compliant metering as currently described in Section IV (Metering and Recording for Settlements) of OP18, and some Load Assets that are measured by OP-18 compliant metering (as currently described in Section IV of OP-18) to which the Host Participant Assigned Meter Reader allocates non-PTF losses.

Project Sponsor is an entity seeking to have a New Generating Capacity Resource, New Import Capacity Resource or New Demand Capacity Resource participate in the Forward Capacity Market, as described in Section III.13.

Proxy De-List Bid is a type of bid used in the Forward Capacity Market.

Provisional Member is defined in Section I.68A of the Restated NEPOOL Agreement.

PTO Administrative Committee is the committee referred to in Section 11.04 of the TOA.

Public Policy Requirement is a requirement reflected in a statute enacted by, or a regulation promulgated by, the federal government or a state or local (e.g., municipal or county) government.

Public Policy Transmission Study is a study conducted by the ISO pursuant to the process set out in Section 4A.3 of Attachment K of the OATT, and consists of two phases: (i) an initial phase to produce a rough estimate of the costs and benefits of concepts that could meet transmission needs driven by public policy requirements; and (ii) a follow-on phase designed to produce more detailed analysis and engineering work on transmission concepts identified in the first phase.

Public Policy Local Transmission Study is a study conducted by a PTO pursuant to the process set out in Section 1.6 of Attachment K Appendix 1 of the OATT, and consists of two phases: (i) an initial phase to produce an estimate of the costs and benefits of concepts that could meet transmission needs driven by public policy requirements; and (ii) a follow-on phase designed to produce more detailed analysis and engineering work on transmission concepts identified in the first phase.

Public Policy Transmission Upgrade is an addition and/or upgrade to the New England Transmission System that meets the voltage and non-voltage criteria for Public Policy Transmission Upgrade PTF classification specified in the OATT, and has been included in the Regional System Plan and RSP Project List as a Public Policy Transmission Upgrade pursuant to the procedures described in Section 4A of Attachment K of the OATT.

Publicly Owned Entity is defined in Section I of the Restated NEPOOL Agreement.

Qualification Process Cost Reimbursement Deposit is described in Section III.13.1.9.3 of Market Rule 1.

Qualified Capacity is the amount of capacity a resource may provide in the summer or winter in a Capacity Commitment Period, as determined in the Forward Capacity Market qualification processes.

Qualified Generator Reactive Resource(s) is any generator source of dynamic reactive power that meets the criteria specified in Schedule 2 of the OATT.

Qualified Non-Generator Reactive Resource(s) is any non-generator source of dynamic reactive power that meets the criteria specified in Schedule 2 of the OATT.

Qualified Reactive Resource(s) is any Qualified Generator Reactive Resource and/or Qualified Non-Generator Reactive Resource that meets the criteria specified in Schedule 2 of the OATT.

Qualified Transmission Project Sponsor is defined in Sections 4B.2 and 4B.3 of Attachment K of the OATT.

Queue Position has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Rapid Response Pricing Asset is: (i) a Fast Start Generator; (ii) a Flexible DNE Dispatchable Generator; or (iii) a Binary Storage DARD with Offer Data specifying a Minimum Run Time and a Minimum Down Time not exceeding one hour each. A Rapid Response Pricing Asset shall also include a Fast Start Demand Response Resource for which the Market Participant's Offer Data meets the following criteria: (i) Minimum Reduction Time does not exceed one hour; and (ii) Demand Response Resource Notification Time plus Demand Response Resource Start-Up Time does not exceed 30 minutes.

Rapid Response Pricing Opportunity Cost is the NCPC Credit described in Section III.F.2.3.10.

Rated means a Market Participant that receives a credit rating from one or more of the Rating Agencies, or, if such Market Participant is not rated by one of the Rating Agencies, then a Market Participant that has outstanding unsecured debt rated by one or more of the Rating Agencies.

Rating Agencies are Standard and Poor's (S&P), Moody's, and Fitch.

Rationing Minimum Limit is the MW quantity for a New Generating Capacity Resource or Existing Generating Capacity Resource below which n offer or bid may not be rationed in the Forward Capacity Auction, but shall not apply to supply offers or demand bids in a substitution auction as specified in Section III.13.2.8.2 and Section III.13.2.8.3.

RBA Decision is a written decision provided by the ISO to a Disputing Party and to the Chair of the NEPOOL Budget and Finance Subcommittee accepting or denying a Requested Billing Adjustment within twenty Business Days of the date the ISO distributes a Notice of RBA, unless some later date is agreed upon by the Disputing Party and the ISO.

Reactive Capability Audit is an audit that measures the ability of a Reactive Resource to provide or absorb reactive power to or from the transmission system at a specified real power output or consumption.

Reactive Resource is a device that dynamically adjusts reactive power output automatically in Real-Time over a continuous range, taking into account control system response bandwidth, within a specified voltage bandwidth in response to grid voltage changes. These resources operate to maintain a set-point voltage and include, but are not limited to, Generator Assets, Dispatchable Asset Related Demands that are part of an Electric Storage Facility, and dynamic transmission devices.

Reactive Supply and Voltage Control Service is the form of Ancillary Service described in Schedule 2 of the OATT.

Real-Time is a period in the current Operating Day for which the ISO dispatches Resources for energy and Regulation, designates Resources for Regulation and Operating Reserve and, if necessary, commits additional Resources.

Real-Time Adjusted Load Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Adjusted Load Obligation Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time Commitment NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Congestion Revenue is defined in Section III.3.2.1(i) of Market Rule 1.

Real-Time Demand Reduction Obligation is defined in Section III.3.2.1(c) of Market Rule 1.

Real-Time Demand Reduction Obligation Deviation is defined in Section III.3.2.1(e) of Market Rule 1.

Real-Time Dispatch NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Energy Inventory is a component of the spot payment that a Market Participant may receive through the inventoried energy program, as described in Section III.K.3.2.1 of Market Rule 1.

Real-Time Energy Market means the purchase or sale of energy, purchase of demand reductions, payment of Congestion Costs, and payment for losses for quantity deviations from the Day-Ahead Energy Market in the Operating Day and designation of and payment for provision of Operating Reserve in Real-Time.

Real-Time Energy Market Deviation Congestion Charge/Credit is defined in Section III.3.2.1(g) of Market Rule 1.

Real-Time Energy Market Deviation Energy Charge/Credit is defined in Section III.3.2.1(g) of Market Rule 1.

Real-Time Energy Market Deviation Loss Charge/Credit is defined in Section III.3.2.1(g) of Market Rule 1.

Real-Time Energy Market NCPC Credits are the Real-Time Commitment NCPC Credit and the Real-Time Dispatch NCPC Credit.

Real-Time External Transaction NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Generation Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Generation Obligation Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time High Operating Limit is the maximum output, in MW, of a Generator Asset that could be achieved, consistent with Good Utility Practice, in response to an ISO request for Energy (including pursuant to Section III.13.6.4 of Market Rule 1), for each hour of the Operating Day, as reflected in the Generator Asset's Offer Data. This value is based on real-time operating conditions and the physical operating characteristics and operating permits of the facility and must be submitted for all Generator Assets (other than Settlement Only Resources).

Real-Time Load Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Load Obligation Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time Locational Adjusted Net Interchange is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Locational Adjusted Net Interchange Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time Loss Revenue is defined in Section III.3.2.1(l) of Market Rule 1.

Real-Time Loss Revenue Charges or Credits are defined in Section III.3.2.1(m) of Market Rule 1.

Real-Time NCP Load Obligation is the maximum hourly value, during a month, of a Market Participant's Real-Time Load Obligation summed over all Locations, excluding exports, in kilowatts.

Real-Time Offer Change is a modification to a Supply Offer pursuant to Section III.1.10.9(b).

Real-Time Posturing NCPC Credit for Generators (Other Than Limited Energy Resources) Postured for Reliability is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Posturing NCPC Credit for Limited Energy Resources Postured for Reliability is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Prices means the Locational Marginal Prices resulting from the ISO's dispatch of the New England Markets in the Operating Day.

Real-Time Reserve Charge is a Market Participant's share of applicable system and Reserve Zone Real-Time Operating Reserve costs attributable to meeting the Real-Time Operating Reserve requirement as calculated in accordance with Section III.10 of Market Rule 1.

Real-Time Reserve Clearing Price is the Real-Time TMSR, TMNSR or TMOR clearing price, as applicable, for the system and each Reserve Zone that is calculated in accordance with Section III.2.7A of Market Rule 1.

Real-Time Reserve Credit is a Market Participant's compensation associated with that Market Participant's Resources' Reserve Quantity For Settlement as calculated in accordance with Section III.10 of Market Rule 1.

Real-Time Reserve Designation is the amount, in MW, of Operating Reserve designated to a Resource in Real-Time by the ISO as described in Section III.1.7.19 of Market Rule 1.

Real-Time Reserve Opportunity Cost is defined in Section III.2.7A(b) of Market Rule 1.

Real-Time Synchronous Condensing NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time System Adjusted Net Interchange means, for each hour, the sum of Real-Time Locational Adjusted Net Interchange for a Market Participant over all Locations, in kilowatts.

Receiving Party is the entity receiving the capacity and/or energy transmitted to Point(s) of Delivery under the OATT.

Reference Level is defined in Section III.A.5.7 of Appendix A of Market Rule 1.

Regional Benefit Upgrade(s) (RBU) means a Transmission Upgrade that: (i) is rated 115kV or above; (ii) meets all of the non-voltage criteria for PTF classification specified in the OATT; and

(iii) is included in the Regional System Plan as either a Reliability Transmission Upgrade or a Market Efficiency Transmission Upgrade identified as needed pursuant to Attachment K of the OATT. The category of RBU shall not include any Transmission Upgrade that has been categorized under any of the other categories specified in Schedule 12 of the OATT (e.g., an Elective Transmission Upgrade shall not also be categorized as an RBU). Any upgrades to transmission facilities rated below 115kV that were PTF prior to January 1, 2004 shall remain classified as PTF and be categorized as an RBU if, and for so long as, such upgrades meet the criteria for PTF specified in the OATT.

Regional Network Load is the load that a Network Customer designates for Regional Network Service under Part II.B of the OATT. The Network Customer's Regional Network Load shall include all load designated by the Network Customer (including losses) and shall not be credited or reduced for any behind-the-meter generation. A Network Customer may elect to designate less than its total load as Regional Network Load but may not designate only part of the load at a discrete Point of Delivery. Where a Transmission Customer has elected not to designate a particular load at discrete Points of Delivery as Regional Network Load, the Transmission Customer is responsible for making separate arrangements under Part II.C of the OATT for any Point-To-Point Service that may be necessary for such non-designated load.

Regional Network Service (RNS) is the transmission service over the PTF described in Part II.B of the OATT, including such service which is used with respect to Network Resources or Regional Network Load that is not physically interconnected with the PTF.

Regional Planning Dispute Resolution Process is described in Section 12 of Attachment K to the OATT.

Regional System Plan (RSP) is the plan developed under the process specified in Attachment K of the OATT.

Regional Transmission Service (RTS) is Regional Network Service and Through or Out Service as provided over the PTF in accordance with Section II.B, Section II.C, Schedule 8 and Schedule 9 of the OATT.

Regulation is the capability of a specific Resource with appropriate telecommunications, control and response capability to respond to an AGC SetPoint.

Regulation and Frequency Response Service is the form of Ancillary Service described in Schedule 3 of the OATT. The capability of performing Regulation and Frequency Response Service is referred to as automatic generation control (AGC).

Regulation Capacity is the lesser of five times the Automatic Response Rate and one-half of the difference between the Regulation High Limit and the Regulation Low Limit of a Resource capable of providing Regulation.

Regulation Capacity Requirement is the amount of Regulation Capacity required to maintain system control and reliability in the New England Control Area as calculated and posted on the ISO website.

Regulation Capacity Offer is an offer by a Market Participant to provide Regulation Capacity.

Regulation High Limit is an offer parameter that establishes the upper bound for AGC SetPoints and is used in the determination of a Resource's Regulation Capacity.

Regulation Low Limit is an offer parameter that establishes the lower bound for AGC SetPoints and is used in the determination of a Resource's Regulation Capacity.

Regulation Market is the market described in Section III.14 of Market Rule 1.

Regulation Resources are those Alternative Technology Regulation Resources, Generator Assets, and Dispatchable Asset Related Demands that satisfy the requirements of Section III.14.2. Regulation Resources are eligible to participate in the Regulation Market.

Regulation Service is the change in output or consumption made in response to changing AGC SetPoints.

Regulation Service Requirement is the estimated amount of Regulation Service required to maintain system control and reliability in the New England Control Area as calculated and posted on the ISO website.

Regulation Service Offer is an offer by a Market Participant to provide Regulation Service.

Related Person is defined pursuant to Section 1.1 of the Participants Agreement.

Related Transaction is defined in Section III.1.4.3 of Market Rule 1.

Reliability Administration Service (RAS) is the service provided by the ISO, as described in Schedule 3 of Section IV.A of the Tariff, in order to administer the Reliability Markets and provide other reliability-related and informational functions.

Reliability Committee is the committee whose responsibilities are specified in Section 8.2.3 of the Participants Agreement.

Reliability Markets are, collectively, the ISO's administration of Regulation, the Forward Capacity Market, and Operating Reserve.

Reliability Region means any one of the regions identified on the ISO's website. Reliability Regions are intended to reflect the operating characteristics of, and the major transmission constraints on, the New England Transmission System.

Reliability Transmission Upgrade means those additions and upgrades not required by the interconnection of a generator that are nonetheless necessary to ensure the continued reliability of the New England Transmission System, taking into account load growth and known resource changes, and include those upgrades necessary to provide acceptable stability response, short circuit capability and system voltage levels, and those facilities required to provide adequate thermal capability and local voltage levels that cannot otherwise be achieved with reasonable assumptions for certain amounts of generation being unavailable (due to maintenance or forced outages) for purposes of long-term planning studies. Good Utility Practice, applicable reliability principles, guidelines, criteria, rules, procedures and standards of ERO and NPCC and any of their successors, applicable publicly available local reliability criteria, and the ISO System Rules, as they may be amended from time to time, will be used to define the system facilities required to maintain reliability in evaluating proposed Reliability Transmission Upgrades. A Reliability Transmission Upgrade may provide market efficiency benefits as well as reliability benefits to the New England Transmission System.

Remittance Advice is an issuance from the ISO for the net Payment owed to a Covered Entity where a Covered Entity's total Payments exceed its total Charges in a billing period.

Remittance Advice Date is the day on which the ISO issues a Remittance Advice.

Renewable Technology Resource is a Generating Capacity Resource or an On-Peak Demand Resource that satisfies the requirements specified in Section III.13.1.1.1.7.

Re-Offer Period is the period that normally occurs between the posting of the of the Day-Ahead Energy Market results and 2:00 p.m. on the day before the Operating Day during which a Market Participant may submit revised Supply Offers, revised External Transactions, or revised Demand Bids associated with Dispatchable Asset Related Demands or, revised Demand Reduction Offers associated with Demand Response Resources.

Replacement Reserve is described in Part III, Section VII of ISO New England Operating Procedure No. 8.

Request for Alternative Proposals (RFAP) is the request described in Attachment K of the OATT.

Requested Billing Adjustment (RBA) is defined in Section 6.1 of the ISO New England Billing Policy.

Required Balance is an amount as defined in Section 5.3 of the Billing Policy.

Reseller is a MGTSA holder that sells, assigns or transfers its rights under its MGTSA, as described in Section II.45.1(a) of the OATT.

Reserve Adequacy Analysis is the analysis performed by the ISO to determine if adequate Resources are committed to meet forecasted load, Operating Reserve, and security constraint requirements for the current and next Operating Day.

Reserve Constraint Penalty Factors (RCPFs) are rates, in $/MWh, that are used within the Real-Time dispatch and pricing algorithm to reflect the value of Operating Reserve shortages and are defined in Section III.2.7A(c) of Market Rule 1.

Reserve Quantity For Settlement is defined in Section III.10.1 of Market Rule 1.

Reserve Zone is defined in Section III.2.7 of Market Rule 1.

Reserved Capacity is the maximum amount of capacity and energy that is committed to the Transmission Customer for transmission over the New England Transmission System between the Point(s) of Receipt and the Point(s) of Delivery under Part II.C or Schedule 18, 20 or 21 of the OATT, as applicable. Reserved Capacity shall be expressed in terms of whole kilowatts on a sixty-minute interval (commencing on the clock hour) basis, or, in the case of Reserved Capacity for Local Point-to-Point Service, in terms of whole megawatts on a sixty-minute interval basis.

Resource means a Generator Asset, a Dispatchable Asset Related Demand, an External Resource, an External Transaction, or a Demand Response Resource.

Restated New England Power Pool Agreement (RNA) is the Second Restated New England Power Pool Agreement, which restated for a second time by an amendment dated as of August 16, 2004 the New England Power Pool Agreement dated September 1, 1971, as the same may be amended and restated from time to time, governing the relationship among the NEPOOL members.

Rest-of-Pool Capacity Zone is a single Capacity Zone made up of the adjacent Load Zones that are neither export-constrained nor import-constrained.

Rest of System is an area established under Section III.2.7(d) of Market Rule 1.

Retail Delivery Point is the point on the transmission or distribution system at which the load of an end-use facility, which is metered and assigned a unique account number by the Host Participant, is measured to determine the amount of energy delivered to the facility from the transmission and distribution system. If an end-use facility is connected to the transmission or distribution system at more than one location, the Retail Delivery Point shall consist of the metered load at each connection point, summed to measure the net energy delivered to the facility in each interval.

Retirement De-List Bid is a bid to retire an Existing Generating Capacity Resource, Existing Import Capacity Resource, or Existing Demand Capacity Resource from all New England Markets, as described in Section III.13.1.2.3.1.5.

Returning Market Participant is a Market Participant, other than an FTR-Only Customer or a Governance Only Member, whose previous membership as a Market Participant was involuntarily terminated due to a Financial Assurance Default or a payment default and, since returning, has been a Market Participant for less than six consecutive months.

Revenue Requirement is defined in Section IV.A.2.1 of the Tariff.

Reviewable Action is defined in Section III.D.1.1 of Appendix D of Market Rule 1.

Reviewable Determination is defined in Section 12.4(a) of Attachment K to the OATT.

Round-Trip Efficiency is a percentage expressing the megawatt-hours of energy that an Electric Storage Facility injects onto the grid per megawatt-hour of energy it receives from the grid.

RSP Project List is defined in Section 1 of Attachment K to the OATT.

RTEP02 Upgrade(s) means a Transmission Upgrade that was included in the annual NEPOOL Transmission Plan (also known as the "Regional Transmission Expansion Plan" or "RTEP") for the year 2002, as approved by ISO New England Inc.'s Board of Directors, or the functional equivalent of such Transmission Upgrade, as determined by ISO New England Inc. The RTEP02 Upgrades are listed in Schedule 12B of the OATT.

RTO is a regional transmission organization or comparable independent transmission organization that complies with Order No. 2000 and the Commission's corresponding regulation.

Same Reserve Zone Export Transaction is defined in Section III.1.10.7(f)(iii) of Market Rule 1.

Sanctionable Behavior is defined in Section III.B.3 of Appendix B of Market Rule 1.

Schedule, Schedules, Schedule 1, 2, 3, 4 and 5 are references to the individual or collective schedules to Section IV.A. of the Tariff.

Schedule 20A Service Provider (SSP) is defined in Schedule 20A to Section II of this Tariff.

Scheduling Service, for purposes of Section IV.A and Section IV.B of the Tariff, is the service described in Schedule 1 to Section IV.A of the Tariff.

Scheduling, System Control and Dispatch Service, for purposes of Section II of the Tariff, is the form of Ancillary Service described in Schedule 1 of the OATT.

Seasonal Claimed Capability is the summer or winter claimed capability of a Generator Asset or Generating Capacity Resource, and represents the maximum dependable load carrying ability of the asset or resource, excluding capacity required for station use.

Seasonal Claimed Capability Audit is the Generator Asset audit performed pursuant to Section III.1.5.1.3.

Seasonal DR Audit is the Demand Response Resource audit performed pursuant to Section III.1.5.1.3.1.

Seasonal Peak Demand Resource is a type of Demand Capacity Resource and shall mean installed measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that reduce the total amount of electrical energy consumed during Demand Resource Seasonal Peak Hours, while delivering a comparable or acceptable level of end-use service. Such measures include Energy Efficiency, Load Management, and Distributed Generation.

Section III.1.4 Transactions are defined in Section III.1.4.2 of Market Rule 1.

Section III.1.4 Conforming Transactions are defined in Section III.1.4.2 of Market Rule 1.

Security Agreement is Attachment 1 to the ISO New England Financial Assurance Policy.

Selected Qualified Transmission Project Sponsor is the Qualified Transmission Project Sponsor that proposed the Phase Two or Stage Two Solution that has been identified by the ISO as the preferred Phase Two or Stage Two Solution.

Selected Qualified Transmission Project Sponsor Agreement is the agreement between the ISO and a Selected Qualified Transmission Project Sponsor. The Selected Qualified Transmission Project Sponsor Agreement is provided in Attachment P to the OATT.

Self-Schedule is the action of a Market Participant in committing its Generator Asset or DARD, in accordance with applicable ISO New England Manuals, to provide service in an hour, whether or not in the absence of that action the Generator Asset or DARD would have been committed by the ISO to provide the service. For a Generator Asset, Self-Schedule is the action of a Market Participant in committing a Generator Asset to provide Energy in an hour at its Economic Minimum Limit, whether or not in the absence of that action the Generator Asset would have been committed by the ISO to provide the Energy. For a DARD, Self-Schedule is the action of a Market Participant in committing a DARD to consume Energy in an hour at its Minimum Consumption Limit, whether or not in the absence of that action the DARD would have been committed by the ISO to consume Energy. For an External Transaction, a Self-Schedule is a request by a Market Participant for the ISO to select the External Transaction regardless of the LMP. Demand Response Resources are not permitted to Self-Schedule.

Self-Supplied FCA Resource is described in Section III.13.1.6 of Market Rule 1.

Senior Officer means an officer of the subject entity with the title of vice president (or similar office) or higher, or another officer designated in writing to the ISO by that office.

Service Agreement is a Transmission Service Agreement or an MPSA.

Service Commencement Date is the date service is to begin pursuant to the terms of an executed Service Agreement, or the date service begins in accordance with the sections of the OATT addressing the filing of unexecuted Service Agreements.

Services means, collectively, the Scheduling Service, EAS and RAS; individually, a Service.

Settlement Financial Assurance is an amount of financial assurance required from a Designated FTR Participant awarded a bid in an FTR Auction. This amount is calculated pursuant to Section VI.C of the ISO New England Financial Assurance Policy.

Settlement Only Resources are generators of less than 5 MW of maximum net output when operating at any temperature at or above zero degrees Fahrenheit, that meet the metering, interconnection and other requirements in ISO New England Operating Procedure No. 14 and that have elected Settlement Only Resource treatment as described in the ISO New England Manual for Registration and Performance Auditing.

Shortfall Funding Arrangement, as specified in Section 5.1 of the ISO New England Billing Policy, is a separate financing arrangement that can be used to make up any non-congestion related differences between amounts received on Invoices and amounts due for ISO Charges in any bill issued.

Short-Term is a period of less than one year.

Significantly Reduced Congestion Costs are defined in Section III.G.2.2 of Appendix G to Market Rule 1.

SMD Effective Date is March 1, 2003.

Solutions Study is described in Section 4.2(b) of Attachment K to the OATT.

Special Constraint Resource (SCR) is a Resource that provides Special Constraint Resource Service under Schedule 19 of the OATT.

Special Constraint Resource Service is the form of Ancillary Service described in Schedule 19 of the OATT.

Specified-Term Blackstart Capital Payment is the annual compensation level, as calculated pursuant to Section 5.1 of Schedule 16 of the OATT, for a Designated Blackstart Resource's capital Blackstart Equipment costs associated with the provision of Blackstart Service (except for capital costs associated with adhering to NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Sponsored Policy Resource is a New Capacity Resource that: receives an out-of-market revenue source supported by a government-regulated rate, charge or other regulated cost recovery mechanism, and; qualifies as a renewable, clean or alternative energy resource under a renewable energy portfolio standard,

clean energy standard, alternative energy portfolio standard, renewable energy goal, or clean energy goal enacted (either by statute or regulation) in the New England state from which the resource receives the out-of-market revenue source and that is in effect on January 1, 2018.

Stage One Proposal is a first round submission, as defined in Sections 4A.5 of Attachment K of the OATT, of a proposal for a Public Policy Transmission Upgrade by a Qualified Transmission Project Sponsor.

Stage Two Solution is a second round submission, as defined in Section 4A.5 of Attachment K of the OATT, of a proposal for a Public Policy Transmission Upgrade by a Qualified Transmission Project Sponsor.

Standard Blackstart Capital Payment is the annual compensation level, as calculated pursuant to Section 5.1 of Schedule 16 of the OATT, for a Designated Blackstart Resource's capital Blackstart Equipment costs associated with the provision of Blackstart Service (except for capital costs associated with adhering to NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Start-of-Round Price is the highest price associated with a round of a Forward Capacity Auction as described in Section III.13.2.3.1 of Market Rule 1.

Start-Up Fee is the amount, in dollars, that must be paid for a Generator Asset to Market Participants with an Ownership Share in the Generator Asset each time the Generator Asset is scheduled in the New England Markets to start-up.

Start-Up Time is the time it takes the Generator Asset, after synchronizing to the system, to reach its Economic Minimum Limit and, for dispatchable Generator Assets, be ready for further dispatch by the ISO.

State Estimator means the computer model of power flows specified in Section III.2.3 of Market Rule 1.

State of Charge is the total quantity of megawatt-hours available to be injected by an Electric Storage Facility onto the grid.

Statements, for the purpose of the ISO New England Billing Policy, refer to both Invoices and Remittance Advices.

Static De-List Bid is a bid that may be submitted by an Existing Generating Capacity Resource, Existing Import Capacity Resource, or Existing Demand Capacity Resource in the Forward Capacity Auction to remove itself from the capacity market for a one year period, as described in Section III.13.1.2.3.1.1 of Market Rule 1.

Station is one or more Existing Generating Capacity Resources consisting of one or more assets located within a common property boundary.

Station Going Forward Common Costs are the net costs associated with a Station that are avoided only by the clearing of the Static De-List Bids, the Permanent De-List Bids or the Retirement De-List Bids of all the Existing Generating Capacity Resources comprising the Station.

Station-level Blackstart O&M Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Station-level Specified-Term Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Station-level Standard Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Storage DARD is a DARD that participates in the New England Markets as part of an Electric Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Summer ARA Qualified Capacity is described in Section III.13.4.2.1.2.1.1.1 of Market Rule 1.

Summer Capability Period means one of two time periods defined by the ISO for the purposes of rating and auditing resources pursuant to Section III.9. The time period associated with the Summer Capability Period is the period of June 1 through September 30.

Summer Intermittent Reliability Hours are defined in Section III.13.1.2.2.2.1(c) of Market Rule 1.

Supply Offer is a proposal to furnish energy at a Node or Regulation from a Resource that meets the applicable requirements set forth in the ISO New England Manuals submitted to the ISO by a Market Participant with authority to submit a Supply Offer for the Resource. The Supply Offer will be submitted pursuant to Market Rule 1 and applicable ISO New England Manuals, and include a price and information with respect to the quantity proposed to be furnished, technical parameters for the Resource, timing and other matters. A Supply Offer is a subset of the information required in a Market Participant's Offer Data.

Supply Offer Block-Hours are Block-Hours assigned to the Lead Market Participant for each Supply Offer. Blocks of the Supply Offer in effect for each hour will be totaled to determine the quantity of Supply Offer Block-Hours for a given day. In the case that a Resource has a Real-Time unit status of "unavailable" for the entire day, that day will not contribute to the quantity of Supply Offer Block-Hours. However, if the Resource has at least one hour of the day with a unit status of "available," the entire day will contribute to the quantity of Supply Offer Block-Hours.

Synchronous Condenser is a generator that is synchronized to the grid but supplying no energy for the purpose of providing Operating Reserve or VAR or voltage support.

System Condition is a specified condition on the New England Transmission System or on a neighboring system, such as a constrained transmission element or flowgate, that may trigger Curtailment of Long-Term Firm MTF or OTF Service on the MTF or the OTF using the curtailment priority pursuant to Section II.44 of the Tariff or Curtailment of Local Long-Term Firm Point-to-Point Transmission Service on the non-PTF using the curtailment priority pursuant to Schedule 21 of the Tariff. Such conditions must be identified in the Transmission Customer's Service Agreement.

System Impact Study is an assessment pursuant to Part II.B, II.C, II.G, Schedule 21, Schedule 22, Schedule 23, or Schedule 25 of the OATT of (i) the adequacy of the PTF or Non-PTF to accommodate a request for the interconnection of a new or materially changed generating unit or a new or materially changed interconnection to another Control Area or new Regional Network Service or new Local Service or an Elective Transmission Upgrade, and (ii) whether any additional costs may be required to be incurred in order to provide the interconnection or transmission service.

System Operator shall mean ISO New England Inc. or a successor organization.

System Operating Limit (SOL) has the meaning specified in the Glossary of Terms Used in NERC Reliability Standards.

System-Wide Capacity Demand Curve is the demand curve used in the Forward Capacity Market as specified in Section III.13.2.2.

TADO is the total amount due and owing (not including any amounts due under Section 14.1 of the RNA) at such time to the ISO, NEPOOL, the PTOs, the Market Participants and the Non-Market Participant Transmission Customers, by all PTOs, Market Participants and Non-Market Participant Transmission Customers.

Tangible Net Worth is the value, determined in accordance with international accounting standards or generally accepted accounting principles in the United States, of all of that entity's assets less the following: (i) assets the ISO reasonably believes to be restricted or potentially unavailable to settle a claim in the event of a default (e.g., regulatory assets, restricted assets, and Affiliate assets), net of any matching liabilities, to the extent that the result of that netting is a positive value; (ii) derivative assets, net of any matching liabilities, to the extent that the result of that netting is a positive value; (iii) the amount at which the liabilities of the entity would be shown on a balance sheet in accordance with international accounting standards or generally accepted accounting principles in the United States; (iv) preferred stock: (v) non-controlling interest; and (vi) all of that entity's intangible assets (e.g., patents, trademarks, franchises, intellectual property, goodwill and any other assets not having a physical existence), in each case as shown on the most recent financial statements provided by such entity to the ISO.

Technical Committee is defined in Section 8.2 of the Participants Agreement.

Ten-Minute Non-Spinning Reserve (TMNSR) is a form of ten-minute reserve capability, determined pursuant to Section III.1.7.19.2.

Ten-Minute Non-Spinning Reserve Service is the form of Ancillary Service described in Schedule 6 of the OATT.

Ten-Minute Reserve Requirement is the combined amount of TMSR and TMNSR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Ten-Minute Spinning Reserve (TMSR) is a form of ten-minute reserve capability, determined pursuant to Section III.1.7.19.2.

Ten-Minute Spinning Reserve Requirement is the amount of TMSR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Ten-Minute Spinning Reserve Service is the form of Ancillary Service described in Schedule 5 of the OATT.

Third-Party Sale is any sale for resale in interstate commerce to a Power Purchaser that is not designated as part of Regional Network Load or Local Network Load under the Regional Network Service or Local Network Service, as applicable.

Thirty-Minute Operating Reserve (TMOR) is a form of thirty-minute reserve capability, determined pursuant to Section III.1.7.19.2.

Thirty-Minute Operating Reserve Service is the form of Ancillary Service described in Schedule 7 of the OATT.

Through or Out Rate (TOUT Rate) is the rate per hour for Through or Out Service, as defined in Section II.25.2 of the OATT.

Through or Out Service (TOUT Service) means Point-To-Point Service over the PTF provided by the ISO with respect to a transaction that goes through the New England Control Area, as, for example, a single transaction where energy or capacity is transmitted into the New England Control Area from New Brunswick and subsequently out of the New England Control Area to New York, or a single transaction where energy or capacity is transmitted into the New England Control Area from New York through one point on the PTF and subsequently flows over the PTF prior to passing out of the New England Control Area to New York, or with respect to a transaction which originates at a point on the PTF and flows over the PTF prior to passing out of the New England Control Area, as, for example, from Boston to New York.

Tie-Line Asset is a physical transmission tie-line, or an inter-state or intra-state border arrangement created according to the ISO New England Manuals and registered in accordance with the Asset Registration Process.

Total Available Amount is the sum of the available amount of the Shortfall Funding Arrangement and the balance in the Payment Default Shortfall Fund.

Total Blackstart Capital Payment is the annual compensation calculated under either Section 5.1 or Section 5.2 of Schedule 16 of the OATT, as applicable.

Total Blackstart Service Payments is monthly compensation to Blackstart Owners or Market Participants, as applicable, and as calculated pursuant to Section 5.6 of Schedule 16 to the OATT.

Total Reserve Requirement, which includes Replacement Reserve, is the combined amount of TMSR, TMNSR, and TMOR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Total System Capacity is the aggregate capacity supply curve for the New England Control Area as determined in accordance with Section III.13.2.3.3 of Market Rule 1.

Transaction Unit (TU) is a type of billing determinant under Schedule 2 of Section IV.A of the Tariff used to assess charges to Customers.

Transition Period: The six-year period commencing on March 1, 1997.

Transmission Charges, for the purposes of the ISO New England Financial Assurance Policy and the ISO New England Billing Policy, are all charges and payments under Schedules 1, 8 and 9 of the OATT.

Transmission Congestion Credit means the allocated share of total Transmission Congestion Revenue credited to each holder of Financial Transmission Rights, calculated and allocated as specified in Section III.5.2 of Market Rule 1.

Transmission Congestion Revenue is defined in Section III.5.2.5(a) of Market Rule 1.

Transmission Constraint Penalty Factors are described in Section III.1.7.5 of Market Rule 1.

Transmission Credit Limit is a credit limit, not to be used to meet FTR Requirements, established for each Market Participant in accordance with Section II.D and each Non-Market Participant Transmission Customer in accordance with Section V.B.2 of the ISO New England Financial Assurance Policy.

Transmission Credit Test Percentage is calculated in accordance with Section III.B.1(c) of the ISO New England Financial Assurance Policy.

Transmission Customer is any Eligible Customer that (i) executes, on its own behalf or through its Designated Agent, an MPSA or TSA, or (ii) requests in writing, on its own behalf or through its Designated Agent, that the ISO, the Transmission Owner, or the Schedule 20A Service Provider, as applicable, file with the Commission, a proposed unexecuted MPSA or TSA containing terms and conditions deemed appropriate by the ISO (in consultation with the applicable PTO, OTO or Schedule 20A Service Provider) in order that the Eligible Customer may receive transmission service under Section II of this Tariff. A Transmission Customer under Section II of this Tariff includes a Market Participant or a Non-Market Participant taking Regional Network Service, Through or Out Service, MTF Service, OTF Service, Ancillary Services, or Local Service.

Transmission Default Amount is all or any part of any amount of Transmission Charges due to be paid by any Covered Entity that the ISO, in its reasonable opinion, believes will not or has not been paid when due.

Transmission Default Period is defined in Section 3.4.f of the ISO New England Billing Policy.

Transmission Late Payment Account is defined in Section 4.2 of the ISO New England Billing Policy.

Transmission Late Payment Account Limit is defined in Section 4.2 of the ISO New England Billing Policy.

Transmission Late Payment Charge is defined in Section 4.1 of the ISO New England Billing Policy.

Transmission, Markets and Services Tariff (Tariff) is the ISO New England Inc. Transmission, Markets and Services Tariff, as amended from time to time.

Transmission Obligations are determined in accordance with Section III.A(vi) of the ISO New England Financial Assurance Policy.

Transmission Operating Agreement (TOA) is the Transmission Operating Agreement between and among the ISO and the PTOs, as amended and restated from time to time.

Transmission Owner means a PTO, MTO or OTO.

Transmission Provider is the ISO for Regional Network Service and Through or Out Service as provided under Section II.B and II.C of the OATT; Cross-Sound Cable, LLC for Merchant Transmission Service as provided under Schedule 18 of the OATT; the Schedule 20A Service Providers for Phase I/II HVDC-TF Service as provided under Schedule 20A of the OATT; and the Participating Transmission Owners for Local Service as provided under Schedule 21 of the OATT.

Transmission Requirements are determined in accordance with Section III.A(iii) of the ISO New England Financial Assurance Policy.

Transmission Security Analysis Requirement shall be determined pursuant to Section III.12.2.1.2.

Transmission Service Agreement (TSA) is the initial agreement and any amendments or supplements thereto: (A) in the form specified in either Attachment A or B to the OATT, entered into by the Transmission Customer and the ISO for Regional Network Service or Through or Out Service; (B) entered into by the Transmission Customer with the ISO and PTO in the form specified in Attachment A to Schedule 21 of the OATT; (C) entered into by the Transmission Customer with an OTO or Schedule 20A Service Provider in the appropriate form specified under Schedule 20 of the OATT; or (D) entered into by the Transmission Customer with a MTO in the appropriate form specified under Schedule 18 of the OATT. A Transmission Service Agreement shall be required for Local Service, MTF Service and OTF Service, and shall be required for Regional Network Service and Through or Out Service if the Transmission Customer has not executed a MPSA.

Transmission Upgrade(s) means an upgrade, modification or addition to the PTF that becomes subject to the terms and conditions of the OATT governing rates and service on the PTF on or after January 1,

2004. This categorization and cost allocation of Transmission Upgrades shall be as provided for in Schedule 12 of the OATT.

UDS is unit dispatch system software.

Unconstrained Export Transaction is defined in Section III.1.10.7(f)(iv) of Market Rule 1.

Uncovered Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Uncovered Transmission Default Amounts are defined in Section 3.4.f of the ISO New England Billing Policy.

Unrated means a Market Participant that is not a Rated Market Participant.

Unsecured Covered Entity is, collectively, an Unsecured Municipal Market Participant and an Unsecured Non-Municipal Covered Entity.

Unsecured Municipal Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Unsecured Municipal Market Participant is defined in Section 3.3(h) of the ISO New England Billing Policy.

Unsecured Municipal Transmission Default Amount is defined in Section 3.4.f of the ISO New England Billing Policy.

Unsecured Non-Municipal Covered Entity is a Covered Entity that is not a Municipal Market Participant or a Non-Market Participant Transmission Customer and has a Market Credit Limit or Transmission Credit Limit of greater than $0 under the ISO New England Financial Assurance Policy.

Unsecured Non-Municipal Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Unsecured Non-Municipal Transmission Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Unsecured Transmission Default Amounts are, collectively, the Unsecured Municipal Transmission Default Amount and the Unsecured Non-Municipal Transmission Default Amount.

Unsettled FTR Financial Assurance is an amount of financial assurance required from a Designated FTR Participant as calculated pursuant to Section VI.B of the ISO New England Financial Assurance Policy.

Updated Measurement and Verification Plan is an optional Measurement and Verification Plan that may be submitted as part of a subsequent qualification process for a Forward Capacity Auction prior to the beginning of the Capacity Commitment Period of the On-Peak Demand Resource or Seasonal Peak Demand Response project. The Updated Measurement and Verification Plan may include updated project specifications, measurement and verification protocols, and performance data as described in Section III.13.1.4.3.1.2 of Market Rule 1 and the ISO New England Manuals.

VAR CC Rate is the CC rate paid to Qualified Reactive Resources for VAR Service capability under Section IV.A of Schedule 2 of the OATT.

VAR Payment is the payment made to Qualified Reactive Resources for VAR Service capability under Section IV.A of Schedule 2 of the OATT.

VAR Service is the provision of reactive power voltage support to the New England Transmission System by a Qualified Reactive Resource or by other generators that are dispatched by the ISO to provide dynamic reactive power as described in Schedule 2 of the OATT.

Virtual Cap is $2,000/MWh.

Virtual Requirements are determined in accordance with Section III.A(iv) of the ISO New England Financial Assurance Policy.

Volt Ampere Reactive (VAR) is a measurement of reactive power.

Volumetric Measure (VM) is a type of billing determinant under Schedule 2 of Section IV.A of the Tariff used to assess charges to Customers under Section IV.A of the Tariff.

Winter ARA Qualified Capacity is described in Section III.13.4.2.1.2.1.1.2 of Market Rule 1.

Winter Capability Period means one of two time periods defined by the ISO for the purposes of rating and auditing resources pursuant to Section III.9. The time period associated with the Winter Capability Period is the period October 1 through May 31.

Winter Intermittent Reliability Hours are defined in Section III.13.1.2.2.2.2(c) of Market Rule 1.

Year means a period of 365 or 366 days, whichever is appropriate, commencing on, or on the anniversary of March 1, 1997. Year One is the Year commencing on March 1, 1997, and Years Two and higher follow it in sequence.

Zonal Price is calculated in accordance with Section III.2.7 of Market Rule 1.

Zonal Capacity Obligation is calculated in accordance with Section III.13.7.5.2 of Market Rule 1.

Zonal Reserve Requirement is the combined amount of TMSR, TMNSR, and TMOR required for a Reserve Zone as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

STANDARD MARKET DESIGN

III.1 Market Operations

III.1.1 Introduction.

This Market Rule 1 sets forth the scheduling, other procedures, and certain general provisions applicable to the operation of the New England Markets within the New England Control Area. The ISO shall operate the New England Markets in compliance with NERC, NPCC and ISO reliability criteria. The ISO is the Counterparty for agreements and transactions with its Customers (including assignments involving Customers), including bilateral transactions described in Market Rule 1, and sales to the ISO and/or purchases from the ISO of energy, reserves, Ancillary Services, capacity, demand/load response, FTRs and other products, paying or charging (if and as applicable) its Customers the amounts produced by the pertinent market clearing process or through the other pricing mechanisms described in Market Rule 1. The bilateral transactions to which the ISO is the Counterparty (subject to compliance with the requirements of Section III.1.4) include, but are not limited to, Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). Notwithstanding the foregoing, the ISO will not act as Counterparty for the import into the New England Control Area, for the use of Publicly Owned Entities, of: (1) energy, capacity, and ancillary products associated therewith, to which the Publicly Owned Entities are given preference under Articles 407 and 408 of the project license for the New York Power Authority's Niagara Project; and (2) energy, capacity, and ancillary products associated therewith, to which Publicly Owned Entities are entitled under Article 419 of the project license for the New York Power Authority's Franklin D. Roosevelt – St. Lawrence Project. This Market Rule 1 addresses each of the three time frames pertinent to the daily operation of the New England Markets: "Pre-scheduling" as specified in Section III.1.9, "Scheduling" as specified in III.1.10, and "Dispatch" as specified in III.1.11. This Market Rule 1 became effective on February 1, 2005.

III.1.2 [Reserved.]

III.1.3 Definitions.

Whenever used in Market Rule 1, in either the singular or plural number, capitalized terms shall have the meanings specified in Section I of the Tariff. Terms used in Market Rule 1 that are not defined in Section

I shall have the meanings customarily attributed to such terms by the electric utility industry in New England or as defined elsewhere in the ISO New England Filed Documents. Terms used in Market Rule 1 that are defined in Section I are subject to the 60% Participant Vote threshold specified in Section 11.1.2 of the Participants Agreement.

III.1.3.1 [Reserved.]

III.1.3.2 [Reserved.]

III.1.3.3 [Reserved.]

III.1.4 Requirements for Certain Transactions.

III.1.4.1 ISO Settlement of Certain Transactions.

The ISO will settle, and act as Counterparty to, the transactions described in Section III.1.4.2 if the transactions (and their related transactions) conform to, and the transacting Market Participants comply with, the requirements specified in Section III.1.4.3.

III.1.4.2 Transactions Subject to Requirements of Section III.1.4.

Transactions that must conform to the requirements of Section III.1.4 include: Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). The foregoing are referred to collectively as "Section III.1.4 Transactions," and individually as a "Section III.1.4 Transaction." Transactions that conform to the standards are referred to collectively as "Section III.1.4 Conforming Transactions," and individually as a "Section III.1.4 Conforming Transaction."

III.1.4.3 Requirements for Section III.1.4 Conforming Transactions.

(a) To qualify as a Section III.1.4 Conforming Transaction, a Section III.1.4 Transaction must constitute an exchange for an off-market transaction (a "Related Transaction"), where the Related Transaction:

(i) is not cleared or settled by the ISO as Counterparty;

(ii) is a spot, forward or derivatives contract that contemplates the transfer of energy or a MW obligation to or from a Market Participant;

(iii) involves commercially appropriate obligations that impose a duty to transfer electricity or a MW obligation from the seller to the buyer, or from the buyer to the seller, with performance taking place within a reasonable time in accordance with prevailing cash market practices; and

(iv) is not contingent on either party to carry out the Section III.1.4 Transaction.

(b) In addition, to qualify as a Section III.1.4 Conforming Transaction:

(i) the Section III.1.4 Transaction must be executed between separate beneficial owners or separate parties trading for independently controlled accounts;

(ii) the Section III.1.4 Transaction and the Related Transaction must be separately identified in the records of the parties to the transactions; and

(iii) the Section III.1.4 Transaction must be separately identified in the records of the ISO.

(c) As further requirements:

(i) each party to the Section III.1.4 Transaction and Related Transaction must maintain, and produce upon request of the ISO, records demonstrating compliance with the requirements of Sections III.1.4.3(a) and (b) for the Section III.1.4 Transaction, the Related Transaction and any other transaction that is directly related to, or integrated in any way with, the Related Transaction, including the identity of the counterparties and the material economic terms of the transactions including their price, tenor, quantity and execution date; and

(ii) each party to the Section III.1.4 Transaction must be a Market Participant that meets all requirements of the ISO New England Financial Assurance Policy.

III.1.5 Resource Auditing.

III.1.5.1 Claimed Capability Audits.

III.1.5.1.1 General Audit Requirements.

(a) The following types of Claimed Capability Audits may be performed:

(i) An Establish Claimed Capability Audit establishes the Generator Asset's ability to respond to ISO Dispatch Instructions and to maintain performance at a specified output level for a specified duration.

(ii) A Seasonal Claimed Capability Audit determines a Generator Asset's capability to perform under specified summer and winter conditions for a specified duration.

(iii) A Seasonal DR Audit determines the ability of a Demand Response Resource to perform during specified months for a specified duration.

(iv) An ISO-Initiated Claimed Capability Audit is conducted by the ISO to verify the Generator Asset's Establish Claimed Capability Audit value or the Demand Response Resource's Seasonal DR Audit value.

(b) The Claimed Capability Audit value of a Generator Asset shall reflect any limitations based upon the interdependence of common elements between two or more Generator Assets such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(c) The Claimed Capability Audit value of gas turbine, combined cycle, and pseudo-combined cycle assets shall be normalized to standard 90° (summer) and 20° (winter) temperatures.

(d) The Claimed Capability Audit value for steam turbine assets with steam exports, combined cycle, or pseudo-combined cycle assets with steam exports where steam is exported for uses external to the electric power facility, shall be normalized to the facility's Seasonal Claimed Capability steam demand.

(e) A Claimed Capability Audit may be denied or rescheduled by the ISO if its performance will jeopardize the reliable operation of the electrical system.

III.1.5.1.2 Establish Claimed Capability Audit.

(a) An Establish Claimed Capability Audit may be performed only by a Generator Asset.

(b) The time and date of an Establish Claimed Capability Audit shall be unannounced.

(c) For a newly commercial Generator Asset:

(i) An Establish Claimed Capability Audit will be scheduled by the ISO within five Business Days of the commercial operation date for all Generator Assets except:

1. Non-intermittent daily cycle hydro;
2. Non-intermittent net-metered, or special qualifying facilities that do not elect to audit as described in Section III.1.5.1.3; and
3. Intermittent Generator Assets

(ii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iii) The Establish Claimed Capability Audit values shall be effective as of the commercial operation date of the Generator Asset.

(d) For Generator Assets with an Establish Claimed Capability Audit value:

(i) An Establish Claimed Capability Audit may be performed at the request of a Market Participant in order to support a change in the summer and winter Establish Claimed Capability Audit values for a Generator Asset.

(ii) An Establish Claimed Capability Audit shall be performed within five Business Days of the date of the request.

(iii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iv) The Establish Claimed Capability Audit values become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(e) An Establish Claimed Capability Audit value may not exceed the maximum interconnected flow specified in the Network Resource Capability for the resource associated with the Generator Asset.

(f) Establish Claimed Capability Audits shall be performed on non-NERC holiday weekdays between 0800 and 2200.

(g) To conduct an Establish Claimed Capability Audit, the ISO shall:

(i) Initiate an Establish Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset's net output to increase from the current operating level to its Real-Time High Operating Limit.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) Begin the audit with the first full clock hour after sufficient time has been allowed for the asset to ramp, based on its offered ramp rate from its current operating point to reach its Real-Time High Operating Limit.

(h) An Establish Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an Establish Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4
Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4

Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(i) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.2(h).

III.1.5.1.3. Seasonal Claimed Capability Audits.

(a) A Seasonal Claimed Capability Audit may be performed only by a Generator Asset.

(b) A Seasonal Claimed Capability Audit must be conducted by all Generator Assets except:

(i) Non-intermittent daily hydro; and

(ii) Intermittent, net-metered, and special qualifying facilities. Non-intermittent net-metered and special qualifying facilities may elect to perform Seasonal Claimed Capability Audits pursuant to Section III.1.7.11(c)(iv).

(c) An Establish Claimed Capability Audit or ISO-Initiated Claimed Capability Audit that meets the requirements of a Seasonal Claimed Capability Audit in this Section III.1.5.1.3 may be used to fulfill a Generator Asset's Seasonal Claimed Capability Audit obligation.

(d) Except as provided in Section III.1.5.1.3(n) below, a summer Seasonal Claimed Capability Audit must be conducted:

(i) At least once every Capability Demonstration Year;

(ii) Either (1) at a mean ambient temperature during the audit that is greater than or equal to 80 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced summer Seasonal Claimed Capability Audit window.

(e) A winter Seasonal Claimed Capability Audit must be conducted:

(i) At least once in the previous three Capability Demonstration Years, except that a newly commercial Generator Asset which becomes commercial on or after:

(1) September 1 and prior to December 31 shall perform a winter Seasonal Claimed Capability Audit prior to the end of that Capability Demonstration Year.

(2) January 1 shall perform a winter Seasonal Claimed Capability Audit prior to the end of the next Capability Demonstration Year.

(ii) Either (1) at a mean ambient temperature during the audit that is less than or equal to 32 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced winter Seasonal Claimed Capability Audit window.

(f) A Seasonal Claimed Capability Audit shall be performed by operating the Generator Asset for the audit time period and submitting to the ISO operational data that meets the following requirements:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal Claimed Capability Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal Claimed Capability Audit and other relevant operating data.

(g) The Seasonal Claimed Capability Audit value (summer or winter) will be the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(h) The Seasonal Claimed Capability Audit value (summer or winter) shall be the most recent audit data submitted to the ISO meeting the requirements of this Section III.1.5.1.3. In the event that a Market Participant fails to submit Seasonal Claimed Capability Audit data to meet the timing requirements in Section III.1.5.1.3(d) and (e), the Seasonal Claimed Capability Audit value for the season shall be set to zero.

(i) The Seasonal Claimed Capability Audit value shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(j) A Seasonal Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for a Seasonal Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	2
Combined Cycle	2

Integrated Coal Gasification Combustion Cycle	2
Pressurized Fluidized Bed Combustion	2
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine-Reversible (Electric Storage) Hydraulic Turbine-Other	2
Hydro-Conventional Weekly	2
Fuel Cell	1
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(k) A Generator Asset that is on a planned outage that was approved in the ISO's annual maintenance scheduling process during all hours that meet the temperature requirements for a Seasonal Claimed Capability Audit that is to be performed by the asset during that Capability Demonstration Year shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these auditing requirements;

(ii) Have its Seasonal Claimed Capability Audit value for the season set to zero; and

(iii) Perform the required Seasonal Claimed Capability Audit on the next available day that meets the Seasonal Claimed Capability Audit temperature requirements.

(l) A Generator Asset that does not meet the auditing requirements of this Section III.1.5.1.3 because (1) every time the temperature requirements were met at the Generator Asset's location the ISO denied the request to operate to full capability, or (2) the temperature requirements were not met at the Generator Asset's location during the Capability Demonstration Year during which the asset was required to perform a Seasonal Claimed Capability Audit during the hours 0700 to 2300 for each weekday excluding those weekdays that are defined as NERC holidays, shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these temperature requirements, including verifiable temperature data;

(ii) Retain the current Seasonal Claimed Capability Audit value for the season; and

(iii) Perform the required Seasonal Claimed Capability Audit during the next Capability Demonstration Year.

(m) The ISO may issue notice of a summer or winter Seasonal Claimed Capability Audit window for some or all of the New England Control Area if the ISO determines that weather forecasts indicate that temperatures during the audit window will meet the summer or winter Seasonal

Claimed Capability Audit temperature requirements. A notice shall be issued at least 48 hours prior to the opening of the audit window. Any audit performed during the announced audit window shall be deemed to meet the temperature requirement for the summer or winter audit. In the event that five or more audit windows for the summer Seasonal Claimed Capability Audit temperature requirement, each of at least a four hour duration between 0700 and 2300 and occurring on a weekday excluding those weekdays that are defined as NERC holidays, are not opened for a Generator Asset prior to August 15 during a Capability Demonstration Year, a two-week audit window shall be opened for that Generator Asset to perform a summer Seasonal Claimed Capability Audit, and any audit performed by that Generator Asset during the open audit window shall be deemed to meet the temperature requirement for the summer Seasonal Claimed Capability Audit. The open audit window shall be between 0700 and 2300 each day during August 15 through August 31.

(n) A Market Participant that is required to perform testing on a Generator Asset that is in addition to a summer Seasonal Claimed Capability Audit may notify the ISO that the summer Seasonal Claimed Capability Audit was performed in conjunction with this additional testing, provided that:

(i) The notification shall be provided at the time the Seasonal Claimed Capability Audit data is submitted under Section III.1.5.1.3(f).

(ii) The notification explains the nature of the additional testing and that the summer Seasonal Claimed Capability Audit was performed while the Generator Asset was online to perform this additional testing.

(iii) The summer Seasonal Claimed Capability Audit and additional testing are performed during the months of June, July or August between the hours of 0700 and 2300.

(iv) In the event that the summer Seasonal Claimed Capability Audit does not meet the temperature requirements of Section III.1.5.1.3(d)(ii), the summer Seasonal Claimed Capability Audit value may not exceed the summer Seasonal Claimed Capability Audit value from the prior Capability Demonstration Year.

(v) This Section III.1.5.1.3(n) may be utilized no more frequently than once every three Capability Demonstration Years for a Generator Asset.

(o) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.3(j).

III.1.5.1.3.1 Seasonal DR Audits.

(a) A Seasonal DR Audit may be performed only by a Demand Response Resource.

(b) A Seasonal DR Audit shall be performed for 12 contiguous five-minute intervals.

(c) A summer Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of April through November;

(d) A winter Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of December through March.

(e) A Seasonal DR Audit may be performed either:

(i) At the request of a Market Participant as described in subsection (f) below; or

(ii) By the Market Participant designating a period of dispatch after the fact as described in subsection (g) below.

(f) If a Market Participant requests a Seasonal DR Audit:

(i) The ISO shall perform the Seasonal DR Audit at an unannounced time between 0800 and 2200 on non-NERC holiday weekdays within five Business Days of the date of the request.

(ii) The ISO shall initiate the Seasonal DR Audit by issuing a Dispatch Instruction ordering the Demand Response Resource to its Maximum Reduction.

(iii) The ISO shall indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iv) The ISO shall begin the audit with the start of the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(g) If the Seasonal DR Audit is performed by the designation of a period of dispatch after the fact, the designated period must meet all of the requirements in this Section III.1.5.1.3.1 and:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal DR Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal DR Audit.

(iii) The demonstration period may begin with the start of any five-minute interval after the completion of the Demand Response Resource Notification Time.

(iv) A CLAIM10 audit or CLAIM30 audit that meets the requirements of a Seasonal DR Audit as provided in this Section III.1.5.1.3.1 may be used to fulfill the Seasonal DR Audit obligation of a Demand Response Resource.

(h) An ISO-Initiated Claimed Capability Audit fulfils the Seasonal DR Audit obligation of a Demand Response Resource.

(i) Each Demand Response Asset associated with a Demand Response Resource is evaluated during the Seasonal DR Audit of the Demand Response Resource.

(j) Any Demand Response Asset on a forced or scheduled curtailment as defined in Section III.8.3 is assessed a zero audit value.

(k) The Seasonal DR Audit value (summer or winter) of a Demand Response Resource resulting from the Seasonal DR Audit shall be the sum of the average demand reductions demonstrated during the audit by each of the Demand Response Resource's constituent Demand Response Assets.

(l) If a Demand Response Asset is added to or removed from a Demand Response Resource between audits, the Demand Response Resource's capability shall be updated to reflect the inclusion or exclusion of the audit value of the Demand Response Asset, such that at any point in time the summer or winter Seasonal DR Audit value of a Demand Response Resource shall equal the sum of the most recent valid like-season audit values of its constituent Demand Response Assets.

(m) The Seasonal DR Audit value shall become effective one calendar day following notification of the audit results to the Market Participant by the ISO.

(n) The summer or winter audit value of a Demand Response Asset shall be set to zero at the end of the Capability Demonstration Year if the Demand Response Asset did not perform a Seasonal DR Audit for that season as part of a Demand Response Resource during that Capability Demonstration Year.

(o) For a Demand Response Asset that was associated with a "Real-Time Demand Response Resource" or a "Real-Time Emergency Generation Resource," as those terms were defined prior to June 1, 2018, any valid result from an audit conducted prior to June 1, 2018 shall continue to be valid on June 1, 2018, and shall retain the same expiration date.

III.1.5.1.4. ISO-Initiated Claimed Capability Audits.

(a) An ISO-Initiated Claimed Capability Audit may be performed by the ISO at any time.

(b) An ISO-Initiated Claimed Capability Audit value shall replace either the summer or winter Seasonal DR Audit value for a Demand Response Resource and shall replace both the winter and summer Establish Claimed Capability Audit values for a Generator Asset, normalized for temperature and steam exports, except:

(i) The Establish Claimed Capability Audit values for a Generator Asset may not exceed the maximum interconnected flow specified in the Network Resource Capability for that resource.

(ii) An ISO-Initiated Claimed Capability Audit value for a Generator Asset shall not set the winter Establish Claimed Capability Audit value unless the ISO-Initiated Claimed Capability Audit was performed at a mean ambient temperature that is less than or equal to 32 degrees Fahrenheit at the Generator Asset location.

(c) If for a Generator Asset a Market Participant submits pressure and relative humidity data for the previous Establish Claimed Capability Audit and the current ISO-Initiated Claimed Capability Audit, the Establish Claimed Capability Audit values derived from the ISO-Initiated Claimed Capability Audit will be normalized to the pressure of the previous Establish Claimed Capability Audit and a relative humidity of 64%.

(d) The audit values derived from the ISO-Initiated Claimed Capability Audit shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(e) To conduct an ISO-Initiated Claimed Capability Audit, the ISO shall:

(i) Initiate an ISO-Initiated Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset to its Real-Time High Operating Limit or the Demand Response Resource to its Maximum Reduction.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) For Generator Assets, begin the audit with the first full clock hour after sufficient time has been allowed for the Generator Asset to ramp, based on its offered ramp rate, from its current operating point to its Real-Time High Operating Limit.

(iv) For Demand Response Resources, begin the audit with the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(f) An ISO-Initiated Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an ISO-Initiated Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4

Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine – Reversible)	2
Demand Response Resource	1

(g) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for an Asset or Resource type not listed in Section III.1.5.1.4(f).

III.1.5.2 ISO-Initiated Parameter Auditing.

(a) The ISO may perform an audit of any Supply Offer, Demand Reduction Offer or other operating parameter that impacts the ability of a Generator Asset or Demand Response Resource to provide real-time energy or reserves.

(b) Generator audits shall be performed using the following methods for the relevant parameter:

(i) **Economic Maximum Limit**. The Generator Asset shall be evaluated based upon its ability to achieve the current offered Economic Maximum Limit value, through a review of historical dispatch data or based on a response to a current ISO-issued Dispatch Instruction.

(ii) **Manual Response Rate**. The Generator Asset shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Manual Response Rate, including hold points and changes in Manual Response Rates.

(iii) **Start-Up Time**. The Generator Asset shall be evaluated based upon its ability to achieve the offered Start-Up Time.

(iv) **Notification Time**. The Generator Asset shall be evaluated based upon its ability to close its output breaker within its offered Notification Time.

(v) **CLAIM10**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(vii) **Automatic Response Rate**. The Generator Asset shall be analyzed, based upon a review of historical performance data, for its ability to respond to four-second electronic Dispatch Instructions.

(viii) **Dual Fuel Capability**. A Generator Asset that is capable of operating on multiple fuels may be required to audit on a specific fuel, as set out in Section III.1.5.2(f).

(c) Demand Response Resource audits shall be performed using the following methods:

(i) **Maximum Reduction**. The Demand Response Resource shall be evaluated based upon its ability to achieve the current offered Maximum Reduction value, through a review of historical dispatch data or based on a response to a current Dispatch Instruction.

(ii) **Demand Response Resource Ramp Rate**. The Demand Response Resource shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Demand Response Resource Ramp Rate.

(iii) **Demand Response Resource Start-Up Time**. The Demand Response Resource shall be evaluated based upon its ability to achieve its Minimum Reduction within the offered Demand Response Resource Start-Up Time, in response to a Dispatch Instruction and after completing its Demand Response Resource Notification Time.

(iv) **Demand Response Resource Notification Time**. The Demand Response Resource shall be evaluated based upon its ability to start reducing demand within its offered Demand Response Resource Notification Time, from the receipt of a Dispatch Instruction when the Demand Response Resource was not previously reducing demand.

(v) **CLAIM10**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(d) To conduct an audit based upon historical data, the ISO shall:

(i) Obtain data through random sampling of generator or Demand Response Resource performance in response to Dispatch Instructions; or

(ii) Obtain data through continual monitoring of generator or Demand Response Resource performance in response to Dispatch Instructions.

(e) To conduct an unannounced audit, the ISO shall initiate the audit by issuing a Dispatch Instruction ordering the Generator Asset or Demand Response Resource to change from the current operating level to a level that permits the ISO to evaluate the performance of the Generator Asset or Demand Response Resource for the parameters being audited.

(f) To conduct an audit of the capability of a Generator Asset described in Section III.1.5.2(b)(viii) to run on a specific fuel:

(i) The ISO shall notify the Lead Market Participant if a Generator Asset is required to undergo an audit on a specific fuel. The ISO, in consultation with the Lead Market Participant, shall develop a plan for the audit.

(ii) The Lead Market Participant will have the ability to propose the time and date of the audit within the ISO's prescribed time frame and must notify the ISO at least five Business Days in advance of the audit, unless otherwise agreed to by the ISO and the Lead Market Participant.

(g) To the extent that the audit results indicate a Market Participant is providing Supply Offer, Demand Reduction Offer or other operating parameter values that are not representative of the actual capability of the Generator Asset or Demand Response Resource, the values for the Generator Asset or Demand Response Resource shall be restricted to those values that are supported by the audit.

(h) In the event that a Generator Asset or Demand Response Resource has had a parameter value restricted:

(i) The Market Participant may submit a restoration plan to the ISO to restore that parameter. The restoration plan shall:

1. Provide an explanation of the discrepancy;
2. Indicate the steps that the Market Participant will take to re-establish the parameter's value;
3. Indicate the timeline for completing the restoration; and
4. Explain the testing that the Market Participant will undertake to verify restoration of the parameter value upon completion.

(ii) The ISO shall:

1. Accept the restoration plan if implementation of the plan, including the testing plan, is reasonably likely to support the proposed change in the parameter value restriction;
2. Coordinate with the Market Participant to perform required testing upon completion of the restoration; and
3. Modify the parameter value restriction following completion of the restoration plan, based upon tested values.

III.1.5.3 Reactive Capability Audits.

(a) Two types of Reactive Capability Audits may be performed:

(i) A lagging Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to provide reactive power to the transmission system at a specified real power output or consumption.

(ii) A leading Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to absorb reactive power from the transmission system at a specified real power output or consumption.

(b) The ISO shall develop a list of Reactive Resources that must conduct Reactive Capability Audits. The list shall include Reactive Resources that: (i) have a gross individual nameplate rating greater than 20 MVA; (ii) are directly connected, or are connected through equipment designed primarily for delivering real or reactive power to an interconnection point, to the transmission system at a voltage of 100 kV or above; and (iii) are not exempted from providing voltage control by the ISO. Additional criteria to be used in adding a Reactive Resource to the list includes, but is not limited to, the effect of the Reactive Resource on System Operating Limits, Interconnection Reliability Operating Limits, and local area voltage limits during the following operating states: normal, emergency, and system restoration.

(c) Unless otherwise directed by the ISO, Reactive Resources that are required to perform Reactive Capability Audits shall perform both a lagging Reactive Capability Audit and a leading Reactive Capability Audit.

(d) All Reactive Capability Audits shall meet the testing conditions specified in the ISO New England Operating Documents.

(e) The Reactive Capability Audit value of a Reactive Resource shall reflect any limitations based upon the interdependence of common elements between two or more Reactive Resources such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(f) A Reactive Capability Audit may be denied or rescheduled by the ISO if conducting the Reactive Capability Audit could jeopardize the reliable operation of the electrical system.

(g) Reactive Capability Audits shall be conducted at least every five years, unless otherwise required by the ISO. The ISO may require a Reactive Resource to conduct Reactive Capability Audits more often than every five years if:

(i) there is a change in the Reactive Resource that may affect the reactive power capability of the Reactive Resource;

(ii) there is a change in electrical system conditions that may affect the achievable reactive power output or absorption of the Reactive Resource; or

(iii) historical data shows that the amount of reactive power that the Reactive Resource can provide to or absorb from the transmission system is higher or lower than the latest audit data.

(h) A Lead Market Participant or Transmission Owner may request a waiver of the requirement to conduct a Reactive Capability Audit for its Reactive Resource. The ISO, at its sole discretion, shall determine whether and for how long a waiver may be granted.

III.1.6 [Reserved.]

III.1.6.1 [Reserved.]

III.1.6.2 [Reserved.]

III.1.6.3 [Reserved.]

III.1.6.4 ISO New England Manuals and ISO New England Administrative Procedures.

The ISO shall prepare, maintain and update the ISO New England Manuals and ISO New England Administrative Procedures consistent with the ISO New England Filed Documents. The ISO New England Manuals and ISO New England Administrative Procedures shall be available for inspection by the Market Participants, regulatory authorities with jurisdiction over the ISO or any Market Participant, and the public.

III.1.7 General.

III.1.7.1 Provision of Market Data to the Commission.

The ISO will electronically deliver to the Commission, on an ongoing basis and in a form and manner consistent with its collection of data and in a form and manner acceptable to the Commission, data related to the markets that it administers, in accordance with the Commission's regulations.

III.1.7.2 [Reserved.]

III.1.7.3 Agents.

A Market Participant may participate in the New England Markets through an agent, provided that such Market Participant informs the ISO in advance in writing of the appointment of such agent. A Market Participant using an agent shall be bound by all of the acts or representations of such agent with respect to transactions in the New England Markets, and shall ensure that any such agent complies with the

requirements of the ISO New England Manuals and ISO New England Administrative Procedures and the ISO New England Filed Documents.

III.1.7.4 [Reserved.]

III.1.7.5 Transmission Constraint Penalty Factors.

In the Day-Ahead Energy Market, the Transmission Constraint Penalty Factor for an interface constraint is $10,000/MWh and the Transmission Constraint Penalty Factor for all other transmission constraints is $30,000/MWh. In the Real-Time Energy Market, the Transmission Constraint Penalty Factor for any transmission constraint is $30,000/MWh. Transmission Constraint Penalty Factors are not used in calculating Locational Marginal Prices.

III.1.7.6 Scheduling and Dispatching.

(a) The ISO shall schedule Day-Ahead and schedule and dispatch in Real-Time Resources economically on the basis of least-cost, security-constrained dispatch and the prices and operating characteristics offered by Market Participants. The ISO shall schedule and dispatch sufficient Resources of the Market Participants to serve the New England Markets energy purchase requirements under normal system conditions of the Market Participants and meet the requirements of the New England Control Area for ancillary services provided by such Resources. The ISO shall use a joint optimization process to serve Real-Time Energy Market energy requirements and meet Real-Time Operating Reserve requirements based on a least-cost, security-constrained economic dispatch.

(b) In the event that one or more Resources cannot be scheduled in the Day-Ahead Energy Market on the basis of a least-cost, security-constrained dispatch as a result of one or more Self-Schedule offers contributing to a transmission limit violation, the following scheduling protocols will apply:

(i) When a single Self-Schedule offer contributes to a transmission limit violation, the Self-Schedule offer will not be scheduled for the entire Self-Schedule period in development of Day-Ahead schedules.

(ii) When two Self-Schedule offers contribute to a transmission limit violation, parallel clearing solutions will be executed such that, for each solution, one of the Self-Schedule offers

will be omitted for its entire Self-Schedule period. The least cost solution will be used for purposes of determining which Resources are scheduled in the Day-Ahead Energy Market.

(iii) When three or more Self-Schedule offers contribute to a transmission limit violation, the ISO will determine the total daily MWh for each Self-Schedule offer and will omit Self-Schedule offers in their entirety, in sequence from the offer with the least total daily MWh to the offer with the greatest total MWh, stopping when the transmission limit violation is resolved.

(c) Scheduling and dispatch shall be conducted in accordance with the ISO New England Filed Documents.

(d) The ISO shall undertake, together with Market Participants, to identify any conflict or incompatibility between the scheduling or other deadlines or specifications applicable to the New England Markets, and any relevant procedures of another Control Area, or any tariff (including the Transmission, Markets and Services Tariff). Upon determining that any such conflict or incompatibility exists, the ISO shall propose tariff or procedural changes, or undertake such other efforts as may be appropriate, to resolve any such conflict or incompatibility.

III.1.7.7 Energy Pricing.

The price paid for energy, including demand reductions, bought and sold by the ISO in the New England Markets will reflect the Locational Marginal Price at each Location, determined by the ISO in accordance with the ISO New England Filed Documents. Congestion Costs, which shall be determined by differences in the Congestion Component of Locational Marginal Prices caused by constraints, shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1. Loss costs associated with Pool Transmission Facilities, which shall be determined by the differences in Loss Components of the Locational Marginal Prices shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1.

III.1.7.8 Market Participant Resources.

A Market Participant may elect to Self-Schedule its Resources in accordance with and subject to the limitations and procedures specified in this Market Rule 1 and the ISO New England Manuals.

III.1.7.9 Real-Time Reserve Prices.

The price paid by the ISO for the provision of Real-Time Operating Reserve in the New England Markets will reflect Real-Time Reserve Clearing Prices determined by the ISO in accordance with the ISO New England Filed Documents for the system and each Reserve Zone.

III.1.7.10 Other Transactions.

Market Participants may enter into internal bilateral transactions and External Transactions for the purchase or sale of energy or other products to or from each other or any other entity, subject to the obligations of Market Participants to make resources with a Capacity Supply Obligation available for dispatch by the ISO. External Transactions that contemplate the physical transfer of energy or obligations to or from a Market Participant shall be reported to and coordinated with the ISO in accordance with this Market Rule 1 and the ISO New England Manuals.

III.1.7.11 Seasonal Claimed Capability of a Generating Capacity Resource.

(a) A Seasonal Claimed Capability value must be established and maintained for all Generating Capacity Resources. A summer Seasonal Claimed Capability is established for use from June 1 through September 30 and a winter Seasonal Claimed Capability is established for use from October 1 through May 31.

(b) The Seasonal Claimed Capability of a Generating Capacity Resource is the sum of the Seasonal Claimed Capabilities of the Generator Assets that are associated with the Generating Capacity Resource.

(c) The Seasonal Claimed Capability of a Generator Asset is:

(i) Based upon review of historical data for non-intermittent daily cycle hydro.

(ii) The median net real power output during reliability hours, as described in Section III.13.1.2.2.2, for (1) intermittent facilities, and (2) net-metered and special qualifying facilities that do not elect to audit, as reflected in hourly revenue metering data.

(iii) For non-intermittent net-metered and special qualifying facilities that elect to audit, the minimum of (1) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3; (2) the Generator Asset's current Establish Claimed Capability Audit value; and (3) the median hourly availability during hours ending 2:00 p.m. through 6:00 p.m. each day of the preceding June through September for Summer and hours ending 6:00 p.m. and 7:00 p.m. each day of the preceding October through May for Winter. The hourly availability:

a. For a Generator Asset that is available for commitment and following Dispatch Instructions, shall be the asset's Economic Maximum Limit, as submitted or redeclared.

b. For a Generator Asset that is off-line and not available for commitment shall be zero.

c. For a Generator Asset that is on-line but not able to follow Dispatch Instructions, shall be the asset's metered output.

(iv) For all other Generator Assets, the minimum of: (1) the Generator Asset's current Establish Claimed Capability Audit value and (2) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3.

III.1.7.12 Seasonal DR Audit Value of an Active Demand Capacity Resource.

(a) A Seasonal DR Audit value must be established and maintained for all Active Demand Capacity Resources. A summer Seasonal DR Audit value is established for use from April 1 through November 30 and a winter Seasonal DR Audit value is established for use from December 1 through March 31.

(b) The Seasonal DR Audit value of an Active Demand Capacity Resource is the sum of the Seasonal DR Audit values of the Demand Response Resources that are associated with the Active Demand Capacity Resource.

III.1.7.13 [Reserved.]

III.1.7.14 [Reserved.]

III.1.7.15 [Reserved.]

III.1.7.16 [Reserved.]

III.1.7.17 Operating Reserve.

The ISO shall endeavor to procure and maintain an amount of Operating Reserve in Real-Time equal to the system and zonal Operating Reserve requirements as specified in the ISO New England Manuals and ISO New England Administrative Procedures. Reserve requirements for the Forward Reserve Market are determined in accordance with the methodology specified in Section III.9.2 of Market Rule 1. Operating Reserve requirements for Real-Time dispatch within an Operating Day are determined in accordance with Market Rule 1 and ISO New England Operating Procedure No. 8, Operating Reserve and Regulation.

III.1.7.18 Ramping.

A Generator Asset, Dispatchable Asset Related Demand, or Demand Response Resource dispatched by the ISO pursuant to a control signal appropriate to increase or decrease the Resource's megawatt output, consumption, or demand reduction level shall be able to change output, consumption, or demand

reduction at the ramping rate specified in the Offer Data submitted to the ISO for that Resource and shall be subject to sanctions for failure to comply as described in **Appendix B**.

III.1.7.19 Real-Time Reserve Designation.

The ISO shall determine the Real-Time Reserve Designation for each eligible Resource in accordance with this Section III.1.7.19. The Real-Time Reserve Designation shall consist of a MW value, in no case less than zero, for each Operating Reserve product: Ten-Minute Spinning Reserve, Ten-Minute Non-Spinning Reserve, and Thirty-Minute Operating Reserve.

III.1.7.19.1 Eligibility.

To be eligible to receive a Real-Time Reserve Designation, a Resource must meet all of the criteria enumerated in this Section III.1.7.19.1. A Resource that does not meet all of these criteria is not eligible to provide Operating Reserve and will not receive a Real-Time Reserve Designation.

(1) The Resource must be a Dispatchable Resource located within the metered boundaries of the New England Control Area and capable of receiving and responding to electronic Dispatch Instructions.

(2) The Resource must not be part of the first contingency supply loss.

(3) The Resource must not be designated as constrained by transmission limitations.

(4) The Resource's Operating Reserve, if activated, must be sustainable for at least one hour from the time of activation. (This eligibility requirement does not affect a Resource's obligation to follow Dispatch Instructions, even after one hour from the time of activation.)

(5) The Resource must comply with the applicable standards and requirements for provision and dispatch of Operating Reserve as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

III.1.7.19.2 Calculation of Real-Time Reserve Designation.

III.1.7.19.2.1 Generator Assets.

III.1.7.19.2.1.1 On-line Generator Assets.

The Manual Response Rate used in calculations in this section shall be the lesser of the Generator Asset's offered Manual Response Rate and its audited Manual Response Rate as described in Section III.1.5.2.

(a) **Ten-Minute Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit). For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Non-Spinning Reserve shall be zero. For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit).

(c) **Thirty-Minute Operating Reserve.** For an on-line Generator Asset, Thirty-Minute Operating Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within thirty minutes given its Manual Response Rate (and in no case greater than its Economic Maximum Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (b) above.

III.1.7.19.2.1.2 Off-line Generator Assets.

For an off-line Generator Asset that is not a Fast Start Generator, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Fast Start Generator's Offered CLAIM10, its CLAIM10, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Ten-Minute Non-Spinning Reserve shall be zero, except during the last ten minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Ten-Minute Non-Spinning Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires).

(c) **Thirty-Minute Operating Reserve.** For an off-line Fast Start Generator, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Fast Start Generator's Offered CLAIM30, its CLAIM30, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Thirty-Minute Operating Reserve shall be zero, except during the last thirty minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Thirty-Minute Operating Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires), minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Fast Start Generator pursuant to subsection (b) above.

III.1.7.19.2.2 Dispatchable Asset Related Demand.

III.1.7.19.2.2.1 Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Storage DARD, Ten-Minute Spinning Reserve shall be calculated as the absolute value of the amount of current telemetered consumption.

(b) **Ten-Minute Non-Spinning Reserve.** For a Storage DARD, Ten-Minute Non-Spinning Reserve shall be zero.

(c) **Thirty-Minute Operating Reserve.** For a Storage DARD, Thirty-Minute Operating Reserve shall be zero.

III.1.7.19.2.2.2 Dispatchable Asset Related Demand Other Than Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit). For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit).

(c) **Thirty-Minute Operating Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (a) above. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Non-Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (b) above.

III.1.7.19.2.3 Demand Response Resources.

For a Demand Response Resource that does not provide one-minute telemetry to the ISO, notwithstanding any provision in this Section III.1.7.19.2.3 to the contrary, the Ten-Minute Spinning Reserve and Ten-Minute Non-Spinning Reserve components of the Real-Time Reserve Designation shall

be zero. The Demand Response Resource Ramp Rate used in calculations in this section shall be the lesser of the Resource's offered Demand Response Resource Ramp Rate and its audited Demand Response Resource Ramp Rate as described in Section III.1.5.2.

III.1.7.19.2.3.1 Dispatched.

(a) **Ten-Minute Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction). For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction).

(c) **Thirty-Minute Operating Reserve.** For a Demand Response Resource that is being dispatched, Thirty-Minute Operating Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within thirty minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction) minus the Ten-Minute Spinning Reserve quantity calculated for the Resource pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Resource pursuant to subsection (b) above.

III.1.7.19.2.3.2 Non-Dispatched.

For a Demand Response Resource that is not being dispatched that is not a Fast Start Demand Response Resource, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Demand Response Resource's Offered CLAIM10, its CLAIM10, and its Maximum Reduction.

(c) **Thirty-Minute Operating Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Demand Response Resource's Offered CLAIM30, its CLAIM30, and its Maximum Reduction, minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Demand Response Resource pursuant to subsection (b) above.

III.1.7.20 Information and Operating Requirements.

(a) [Reserved.]

(b) Market Participants selling from Resources within the New England Control Area shall: supply to the ISO all applicable Offer Data; report to the ISO Resources that are Self-Scheduled; report to the ISO External Transaction sales; confirm to the ISO bilateral sales to Market Participants within the New England Control Area; respond to the ISO's directives to start, shutdown or change output, consumption, or demand reduction levels of Generator Assets, DARDs, or Demand Response Resources, change scheduled voltages or reactive output levels; continuously maintain all Offer Data concurrent with on-line operating information; and ensure that, where so equipped, equipment is operated with control equipment functioning as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

(c) Market Participants selling from Resources outside the New England Control Area shall: provide to the ISO all applicable Offer Data, including offers specifying amounts of energy available, hours of availability and prices of energy and other services; respond to ISO directives to schedule delivery or change delivery schedules; and communicate delivery schedules to the source Control Area and any intermediary Control Areas.

(d) Market Participants, as applicable, shall: respond or ensure a response to ISO directives for load management steps; report to the ISO all bilateral purchase transactions including External Transaction

purchases; and respond or ensure a response to other ISO directives such as those required during Emergency operation.

(e) Market Participant, as applicable, shall provide to the ISO requests to purchase specified amounts of energy for each hour of the Operating Day during which it intends to purchase from the Day-Ahead Energy Market.

(f) Market Participants are responsible for reporting to the ISO anticipated availability and other information concerning Generator Assets, Demand Response Resources and Dispatchable Asset Related Demands required by the ISO New England Operating Documents, including but not limited to the Market Participant's ability to procure fuel and physical limitations that could reduce Resource output or demand reduction capability for the pertinent Operating Day.

III.1.8 [Reserved.]

III.1.9 Pre-scheduling.

III.1.9.1 Offer and Bid Caps and Cost Verification for Offers and Bids.

III.1.9.1.1 Cost Verification of Resource Offers.

The incremental energy values of Supply Offers and Demand Response Resources above $1,000/MWh for any Resource other than an External Resource are subject to the following cost verification requirements. Unless expressly stated otherwise, cost verification is utilized in all pricing, commitment, dispatch and settlement determinations. For purposes of the following requirements, Reference Levels are calculated using the procedures in Section III.A.7.5 for calculating cost-based Reference Levels.

(a) If the incremental energy value of a Resource's offer is greater than the incremental energy Reference Level value of the Resource, then the incremental energy value in the offer is replaced with the greater of the Reference Level for incremental energy or $1,000/MWh.

(b) For purposes of the price calculations in Sections III.2.5 and III.2.7A, if the adjusted offer calculated under Section III.2.4 for a Rapid Response Pricing Asset is greater than $1,000/MWh (after the incremental energy value is evaluated under Section III.1.9.1.1(a) above), then verification will be performed as follows using a Reference Level value calculated with the adjusted offer formulas specified in Section III.2.4.

(i) If the Reference Level value is less than or equal to $1,000/MWh, then the adjusted offer for the Resource is set at $1,000/MWh;

(ii) If the Reference Level value is greater than $1,000/MWh, then the adjusted offer for the Resource is set at the lower of the Reference Level value and the adjusted offer.

III.1.9.1.2 Offer and Bid Caps.

(a) For purposes of the price calculations described in Section III.2 and for purposes of scheduling a Resource in the Day-Ahead Energy Market in accordance with Section III.1.7.6 following the commitment of the Resource, the incremental energy value of an offer is capped at $2,000/MWh.

(b) Demand Bids shall not specify a bid price below the Energy Offer Floor or above the Demand Bid Cap.

(c) Supply Offers and Demand Reduction Offers shall not specify an offer price (for incremental energy) below the Energy Offer Floor.

(d) External Transactions shall not specify a price below the External Transaction Floor or above the External Transaction Cap.

(e) Increment Offers and Decrement Bids shall not specify an offer or bid price below the Energy Offer Floor or above the Virtual Cap.

III.1.9.2 [Reserved.]

III.1.9.3 [Reserved.]

III.1.9.4 [Reserved.]

III.1.9.5 [Reserved.]

III.1.9.6 [Reserved.]

III.1.9.7 Market Participant Responsibilities.

Market Participants authorized and intending to request market-based Start-Up Fees and No-Load Fee in their Offer Data shall submit a specification of such fees to the ISO for each Generator Asset as to which the Market Participant intends to request such fees. Any such specification shall identify the applicable period and be submitted on or before the applicable deadline and shall remain in effect unless otherwise modified in accordance with Section III.1.10.9. The ISO shall reject any request for Start-Up Fees and No-Load Fee in a Market Participant's Offer Data that does not conform to the Market Participant's specification on file with the ISO.

III.1.9.8 [Reserved.]

III.1.10 Scheduling.

III.1.10.1 General.

(a) The ISO shall administer scheduling processes to implement a Day-Ahead Energy Market and a Real-Time Energy Market.

(b) The Day-Ahead Energy Market shall enable Market Participants to purchase and sell energy through the New England Markets at Day-Ahead Prices and enable Market Participants to submit External Transactions conditioned upon Congestion Costs not exceeding a specified level. Market Participants whose purchases and sales and External Transactions are scheduled in the Day-Ahead Energy Market shall be obligated to purchase or sell energy or pay Congestion Costs and costs for losses, at the applicable Day-Ahead Prices for the amounts scheduled.

(c) In the Real-Time Energy Market,

(i) Market Participants that deviate from the amount of energy purchases or sales scheduled in the Day-Ahead Energy Market shall replace the energy not delivered with energy from the Real-Time Energy Market or an internal bilateral transaction and shall pay for such energy not delivered, net of any internal bilateral transactions, at the applicable Real-Time Price, unless otherwise specified by this Market Rule 1, and

(ii) Non-Market Participant Transmission Customers shall be obligated to pay Congestion Costs and costs for losses for the amount of the scheduled transmission uses in the Real-Time Energy Market at the applicable Real-Time Congestion Component and Loss Component price differences, unless otherwise specified by this Market Rule 1.

(d) The following scheduling procedures and principles shall govern the commitment of Resources to the Day-Ahead Energy Market and the Real-Time Energy Market over a period extending from one week to one hour prior to the Real-Time dispatch. Scheduling encompasses the Day-Ahead and hourly scheduling process, through which the ISO determines the Day-Ahead Energy Market schedule and determines, based on changing forecasts of conditions and actions by Market Participants and system constraints, a plan to serve the hourly energy and reserve requirements of the New England Control Area in the least costly manner, subject to maintaining the reliability of the New England Control Area.

Scheduling of External Transactions in the Real-Time Energy Market is subject to Section II.44 of the OATT.

(e) If the ISO's forecast for the next seven days projects a likelihood of Emergency Condition, the ISO may commit, for all or part of such seven day period, to the use of Generator Assets or Demand Response Resources with Notification Time greater than 24 hours as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Participants' binding Supply Offers or Demand Reduction Offers.

III.1.10.1A Energy Market Scheduling.

Market Participants may submit offers and bids in the Day-Ahead Energy Market until 10:30 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the ISO in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Market Rule 1.

(a) **Locational Demand Bids –** Each Market Participant may submit to the ISO specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-Ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures. Each Market Participant shall inform the ISO of (i) the prices, if any, at which it desires not to include its load in the Day-Ahead Energy Market rather than pay the Day-Ahead Price, (ii) hourly schedules for Resources Self-Scheduled by the Market Participant; and (iii) the Decrement Bid at which each such Self-Scheduled Resource will disconnect or reduce output, or confirmation of the Market Participant's intent not to reduce output. Price-sensitive Demand Bids and Decrement Bids must be greater than zero MW and shall not exceed the Demand Bid Cap and Virtual Cap.

(b) **External Transactions –** All Market Participants shall submit to the ISO schedules for any External Transactions involving use of Generator Assets or the New England Transmission System as specified below, and shall inform the ISO whether the transaction is to be included in the Day-Ahead Energy Market. Any Market Participant that elects to include an External Transaction in the Day-Ahead Energy Market may specify the price (such price not to exceed the maximum price that may be specified in the ISO New England Manuals and ISO New England Administrative Procedures), if any, at which it will be curtailed rather than pay Congestion Costs. The foregoing price specification shall apply to the price difference between the Locational Marginal Prices for specified External Transaction source and

sink points in the Day-Ahead scheduling process only. Any Market Participant that deviates from its Day-Ahead External Transaction schedule or elects not to include its External Transaction in the Day-Ahead Energy Market shall be subject to Congestion Costs in the Real-Time Energy Market in order to complete any such scheduled External Transaction. Scheduling of External Transactions shall be conducted in accordance with the specifications in the ISO New England Manuals and ISO New England Administrative Procedures and the following requirements:

(i) Market Participants shall submit schedules for all External Transaction purchases for delivery within the New England Control Area from Resources outside the New England Control Area;

(ii) Market Participants shall submit schedules for External Transaction sales to entities outside the New England Control Area from Resources within the New England Control Area;

(iii) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction purchases less External Transaction sales exceeds the import capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction purchases at the applicable External Node shall be set equal to the Energy Offer Floor;

(iv) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction sales less External Transaction purchases exceeds the export capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction sales at the applicable External Node shall be set equal to the External Transaction Cap;

(v) The ISO shall not consider Start-Up Fees, No-Load Fees, Notification Times or any other inter-temporal parameters in scheduling or dispatching External Transactions.

(c) **Generator Asset Supply Offers –** Market Participants selling into the New England Markets from Generator Assets may submit Supply Offers for the supply of energy for the following Operating Day.

Such Supply Offers:

(i) Shall specify the Resource and Blocks (price and quantity of Energy) for each hour of the Operating Day for each Resource offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) If based on energy from a Generator Asset internal to the New England Control Area, may specify, for Supply Offers, a Start-Up Fee and No-Load Fee for each hour of the Operating Day. Start-Up Fee and No-Load Fee may vary on an hourly basis;

(iii) Shall specify, for Supply Offers from a dual-fuel Generator Asset, the fuel type. The fuel type may vary on an hourly basis. A Market Participant that submits a Supply Offer using the higher cost fuel type must satisfy the consultation requirements for dual-fuel Generator Assets in Section III.A.3 of Appendix A;

(iv) Shall specify a Minimum Run Time to be used for commitment purposes that does not exceed 24 hours;

(v) Supply Offers shall constitute an offer to submit the Generator Asset to the ISO for commitment and dispatch in accordance with the terms of the Supply Offer, where such Supply Offer, with regard to operating limits, shall specify changes, including to the Economic Maximum Limit, Economic Minimum Limit and Emergency Minimum Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource (except that for a Limited Energy Resource, the Economic Maximum Limit may be revised to reflect an energy (MWh) limitation), which offer shall remain open through the Operating Day for which the Supply Offer is submitted; and

(vi) Shall, in the case of a Supply Offer from a Generator Asset associated with an Electric Storage Facility, also meet the requirements specified in Section III.1.10.6.

(d) DARD Demand Bids – Market Participants participating in the New England Markets with Dispatchable Asset Related Demands may submit Demand Bids for the consumption of energy for the following Operating Day.

Such Demand Bids:

(i) Shall specify the Dispatchable Asset Related Demand and Blocks (price and Energy quantity pairs) for each hour of the Operating Day for each Dispatchable Asset Related Demand offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) Shall constitute an offer to submit the Dispatchable Asset Related Demand to the ISO for commitment and dispatch in accordance with the terms of the Demand Bid, where such Demand Bid, with regard to operating limits, shall specify changes, including to the Maximum Consumption Limit and Minimum Consumption Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource;

(iii) Shall specify a Minimum Consumption Limit that is less than or equal to its Nominated Consumption Limit; and

(iv) Shall, in the case of a Demand Bid from a Storage DARD, also meet the requirements specified in Section III.1.10.6.

(e) **Demand Response Resource Demand Reduction Offers –** Market Participants selling into the New England Markets from Demand Response Resources may submit Demand Reduction Offers for the supply of energy for the following Operating Day. A Demand Reduction Offer shall constitute an offer to submit the Demand Response Resource to the ISO for commitment and dispatch in accordance with the terms of the Demand Reduction Offer. Demand Reduction Offers:

(i) Shall specify the Demand Response Resource and Blocks (price and demand reduction quantity pairs) for each hour of the Operating Day. The prices and demand reduction quantities may vary on an hourly basis.

(ii) Shall not specify a price that is below the Demand Reduction Threshold Price in effect for the Operating Day. For purposes of clearing the Day-Ahead and Real-Time Energy Markets and calculating Day-Ahead and Real-Time Locational Marginal Prices and Real-Time Reserve Clearing Prices, any price specified below the Demand Reduction Threshold price in effect for the Operating Day will be considered to be equal to the Demand Reduction Threshold Price for the Operating Day.

(iii) Shall not include average avoided peak transmission or distribution losses in the demand reduction quantity.

(iv) May specify an Interruption Cost for each hour of the Operating Day, which may vary on an hourly basis.

(v) Shall specify a Minimum Reduction Time to be used for scheduling purposes that does not exceed 24 hours.

(vi) Shall specify a Maximum Reduction amount no greater than the sum of the Maximum Interruptible Capacities of the Demand Response Resource's operational Demand Response Assets.

(vii) Shall specify changes to the Maximum Reduction and Minimum Reduction from those submitted as part of the Demand Response Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Demand Response Resource.

(f) **Demand Reduction Threshold Price –** The Demand Reduction Threshold Price for each month shall be determined through an analysis of a smoothed, historic supply curve for the month. The historic supply curve shall be derived from Real-Time generator and import Offer Data (excluding Coordinated External Transactions) for the same month of the previous year. The ISO may adjust the Offer Data to account for significant changes in generator and import availability or other significant changes to the historic supply curve. The historic supply curve shall be calculated as follows:

(a) Each generator and import offer Block (i.e., each price-quantity pair offered in the Real-Time Energy Market) for each day of the month shall be compiled and sorted in ascending order of price to create an unsmoothed supply curve.

(b) An unsmoothed supply curve for the month shall be formed from the price and cumulative quantity of each offer Block.

(c) A non-linear regression shall be performed on a sampled portion of the unsmoothed supply curve to produce an increasing, convex, smooth approximation of the supply curve.

(d) A historic threshold price P_{th} shall be determined as the point on the smoothed supply curve beyond which the benefit to load from the reduced LMP resulting from the demand reduction of Demand Response Resources exceeds the cost to load associated with compensating Demand Response Resources for demand reduction.

(e) The Demand Reduction Threshold Price for the upcoming month shall be determined by the following formula:

$$DRTP = P_{th} X — \frac{FPI_c}{FPI_h}$$

where FPI_h is the historic fuel price index for the same month of the previous year, and FPI_c is the fuel price index for the current month.

The historic and current fuel price indices used to establish the Demand Reduction Threshold Price for a month shall be based on the lesser of the monthly natural gas or heating oil fuel indices applicable to the New England Control Area, as calculated three business days before the start of the month preceding the Demand Reduction Threshold Price's effective date.

The ISO will post the Demand Reduction Threshold Price, along with the index-based fuel price values used in establishing the Demand Reduction Threshold Price, on its website by the 15th day of the month preceding the Demand Reduction Threshold Price's effective date.

(g) **Subsequent Operating Days** – Each Supply Offer, Demand Reduction Offer, or Demand Bid by a Market Participant of a Resource shall remain in effect for subsequent Operating Days until superseded or canceled except in the case of an External Transaction purchase, in which case, the Supply Offer shall remain in effect for the applicable Operating Day and shall not remain in effect for subsequent Operating Days. Hourly overrides of a Supply Offer, a Demand Reduction Offer, or a Demand Bid shall remain in effect only for the applicable Operating Day.

(h) **Load Estimate** – The ISO shall post on the internet the total hourly loads including Decrement Bids scheduled in the Day-Ahead Energy Market, as well as the ISO's estimate of the Control Area hourly load for the next Operating Day.

(i) **Prorated Supply** – In determining Day-Ahead schedules, in the event of multiple marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases at a pricing location, the ISO shall clear the marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases proportional to the amount of energy (MW) from each marginal offer and/or External Transaction at the pricing location. The Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions are not used in determining the amount of energy (MW) in each marginal Supply Offer or Demand Reduction Offer to be cleared on a pro-rated basis. However, the Day-Ahead schedules resulting from the pro-ration process will reflect Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions.

(j) **Prorated Demand** – In determining Day-Ahead schedules, in the event of multiple marginal Demand Bids, Decrement Bids and/or External Transaction sales at a pricing location, the ISO shall clear the marginal Demand Bids, Decrement Bids and/or External Transaction sales proportional to the amount of energy (MW) from each marginal bid and/or External Transaction at the pricing location.

(k) **Virtuals** – All Market Participants may submit Increment Offers and/or Decrement Bids that apply to the Day-Ahead Energy Market only. Such offers and bids must comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-Ahead Energy Market.

III.1.10.2 Pool-Scheduled Resources.

Pool-Scheduled Resources are those Resources for which Market Participants submitted Supply Offers, Demand Reduction Offers, or Demand Bids in the Day-Ahead Energy Market and which the ISO scheduled in the Day-Ahead Energy Market as well as Generator Assets, DARDs or Demand Response Resources committed by the ISO subsequent to the Day-Ahead Energy Market. Such Resources shall be committed to provide or consume energy in the Real-Time dispatch unless the schedules for such Resources are revised pursuant to Sections III.1.10.9 or III.1.11. Pool-Scheduled Resources shall be governed by the following principles and procedures.

(a) Pool-Scheduled Resources shall be selected by the ISO on the basis of the prices offered for energy supply or consumption and related services, Start-Up Fees, No-Load Fees, Interruption Cost and the specified operating characteristics, offered by Market Participants.

(b) The ISO shall optimize the dispatch of energyfrom Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources in the Day-Ahead Energy Market consistent with the Supply Offers and Demand Reduction Offers of other Resources, the submitted Demand Bids and Decrement Bids and Operating Reserve and Replacement Reserve requirements.

(c) Market Participants offering energy from facilities with fuel or environmental limitations may submit data to the ISO that is sufficient to enable the ISO to determine the available operating hours of such facilities.

(d) Market Participants shall make available their Pool-Scheduled Resources to the ISO for coordinated operation to supply the needs of the New England Control Area for energy and ancillary services.

III.1.10.3 Self-Scheduled Resources.

A Resource that is Self-Scheduled shall be governed by the following principles and procedures. The minimum duration of a Self-Schedule for a Generator Asset or DARD shall not result in the Generator Asset or DARD operating for less than its Minimum Run Time. A Generator Asset that is online as a result of a Self-Schedule will be dispatched above its Economic Minimum Limit based on the economic merit of its Supply Offer. A DARD that is consuming as a result of a Self-Schedule may be dispatched above its Minimum Consumption Limit based on the economic merit of its Demand Bid. A Demand Response Resource shall not be Self-Scheduled.

III.1.10.4 External Resources.

Market Participants with External Resources may submit External Transactions as detailed in Section III.1.10.7 and Section III.1.10.7.A of this Market Rule 1.

III.1.10.5 Dispatchable Asset Related Demand.

(a) External Transactions that are sales to an external Control Area are not eligible to be Dispatchable Asset Related Demands.

(b) A Market Participant with a Dispatchable Asset Related Demand in the New England Control Area must:

(i) notify the ISO of any outage (including partial outages) that may reduce the Dispatchable Asset Related Demand's ability to respond to Dispatch Instructions and the expected return date from the outage;

(ii) in accordance with the ISO New England Manuals and Operating Procedures, perform audit tests and submit the results to the ISO or provide to the ISO appropriate historical production data;

(iii) abide by the ISO maintenance coordination procedures; and

(iv) provide information reasonably requested by the ISO, including the name and location of the Dispatchable Asset Related Demand.

III.1.10.6 Electric Storage

A storage facility is a facility that is capable of receiving electricity from the grid and storing the energy for later injection of electricity back to the grid. A storage facility may participate in the New England Markets as described below.

(a) A storage facility that satisfies the requirements of this subsection (a) may participate in the New England Markets as an Electric Storage Facility. An Electric Storage Facility shall:

(i) comprise one or more storage facilities at the same point of interconnection;

(ii) have the ability to inject at least 0.1 MW and consume at least 0.1 MW;

(iii) be directly metered;

(iv) be registered as, and subject to all rules applicable to, a dispatchable Generator Asset;

(v) be registered as, and subject to all rules applicable to, a DARD that represents the same equipment as the Generator Asset;

(vi) settle its injection of electricity to the grid as a Generator Asset and its receipt of electricity from the grid as a DARD;

(vii) not be precluded from providing retail services so long as it is able to fulfill its wholesale Energy Market and Forward Capacity Market obligations including, but not limited to, satisfying meter data reporting requirements and notifying the ISO of any changes to operational capabilities; and

(viii) meet the requirements of either a Binary Storage Facility or a Continuous Storage Facility, as described in subsections (b) and (c) below.

(b) A storage facility that satisfies the requirements of this subsection (b) may participate in the New England Markets as a Binary Storage Facility. A Binary Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility; and

(ii) offer its Generator Asset and DARD into the Energy Market as Rapid Response Pricing Assets; and

(iii) be issued Dispatch Instructions in a manner that ensures the facility is not required to consume and inject simultaneously.

(c) A storage facility that satisfies the requirements of this subsection (c) may participate in the New England Markets as a Continuous Storage Facility. A Continuous Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility;

(ii) be registered as, may provide Regulation as, and is subject to all rules applicable to, an ATRR that represents the same equipment as the Generator Asset and DARD;

(iii) be capable of transitioning between the facility's maximum output and maximum consumption (and vice versa) in ten minutes or less;

(iv) not utilize storage capability that is shared with another Generator Asset, DARD or ATRR;

(v) specify in Supply Offers a zero MW value for Economic Minimum Limit and Emergency Minimum Limit (except for Generator Assets undergoing Facility and Equipment Testing or auditing); a zero time value for Minimum Run Time, Minimum Down Time, Notification Time, and Start-Up Time; and a zero cost value for Start-Up Fee and No-Load Fee;

(vi) specify in Demand Bids a zero MW value for Minimum Consumption Limit (except for DARDs undergoing Facility and Equipment Testing or auditing) and a zero time value for Minimum Run Time and Minimum Down Time;

(vii) be Self-Scheduled in the Day-Ahead Energy Market and Real-Time Energy Market, and operate in an on-line state, unless the facility is declared unavailable by the Market Participant; and

(viii) be issued a combined dispatch control signal equal to the Desired Dispatch Point (of the Generator Asset) minus the Desired Dispatch Point (of the DARD) plus the AGC SetPoint (of the ATRR).

(d) In clearing the Day-Ahead Energy Market, the ISO will respect Electric Storage Facility Initial State of Charge, Round Trip Efficiency, Maximum State of Charge, and Minimum State of Charge~~account for maximum run time, maximum charge time, state of charge, maximum state of charge, and~~

~~minimum state of charge through bidding parameters or other means, as required by the Commission in Order No. 841~~.

(e) A storage facility shall comply with all applicable registration, metering, and accounting rules including, but not limited to, the following:

(i) A Market Participant wishing to purchase energy from the ISO-administered wholesale markets must first, jointly with its Host Participant, register one or more wholesale Load Assets with the ISO as described in ISO New England Manual M-28 and ISO New England Manual M-RPA; where the Market Participant wishes to register an Electric Storage Facility, the registered Load Asset must be a DARD.

(ii) A storage facility's charging energy shall not qualify as, or be billed to, a Storage DARD if that facility's charging energy is included in another Load Asset. A storage facility registered as a DARD will be charged the nodal Locational Marginal Price by the ISO and the Market Participant will not pay twice for the same charging energy.

(iii) The registration and metering of all Assets must comply with ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18, including with the requirement that an Asset's revenue metering must comply with the accuracy requirements found in ISO New England Operating Procedure No. 18.

(iv) Pursuant to ISO New England Manual M-28, the Assigned Meter Reader, the Host Participant, and the ISO provide the data for use in the daily settlement process within the timelines described in the manual. The data may be five-minute interval data, and may be no more than hourly data, as described in Section III.3.2 and in ISO New England Manual M-28.

(v) Based on the Metered Quantity For Settlement and the Locational Marginal Price in the settlement interval, the ISO shall conduct all Energy Market accounting pursuant to Section III.3.2.1.

(f) A facility registered as a dispatchable Generator Asset, an ATRR, and a DARD that each represent the same equipment must participate as a Continuous Storage Facility.

(g) A storage facility not participating as an Electric Storage Facility may, if it satisfies the associated requirements, be registered as a Generator Asset (including a Settlement Only Resource) for settlement of its injection of electricity to the grid and as an Asset Related Demand for settlement of its wholesale load.

(h) A storage facility may, if it satisfies the associated requirements, be registered as a Demand Response Asset. (As described in Section III.8.1.1, a Demand Response Asset and a Generator Asset may not be registered at the same end-use customer facility unless the Generator Asset is separately metered and reported and its output does not reduce the load reported at the Retail Delivery Point of the Demand Response Asset.)

(i) A storage device may, if it satisfies the associated requirements, be registered as a component of either an On-Peak Demand Resource or a Seasonal Peak Demand Resource.

(j) A storage facility may, if it satisfies the associated requirements, provide Regulation pursuant to Section III.14.

III.1.10.7 External Transactions.

The provisions of this Section III.1.10.7 do not apply to Coordinated External Transactions.

(a) Market Participants that submit an External Transaction in the Day-Ahead Energy Market must also submit a corresponding External Transaction in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market. Priced External Transactions for the Real-Time Energy Market must be submitted by the offer submission deadline for the Day-Ahead Energy Market.

(b) Priced External Transactions submitted in both the Day-Ahead Energy Market and the Real-Time Energy Market will be treated as Self-Scheduled External Transactions in the Real-Time Energy Market for the associated megawatt amounts that cleared the Day-Ahead Energy Market, unless the Market Participant modifies the price component of its Real-Time offer during the Re-Offer Period.

(c) Any External Transaction, or portion thereof, submitted to the Real-Time Energy Market that did not clear in the Day-Ahead Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency. External Transactions cleared in the Day-Ahead Energy Market and associated with a Real-Time Energy Market submission will continue to be scheduled in Real-Time prior to and during an Emergency, until the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, require a change in schedule.

(d) External Transactions submitted to the Real-Time Energy Market must contain the associated e-Tag ID and transmission reservation, if required, at the time the transaction is submitted to the Real-Time Energy Market.

(e) [Reserved.]

(f) External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below receive priority in the scheduling and curtailment of transactions as set forth in Section II.44 of the OATT. External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below are referred to herein and in the OATT as being supported in Real-Time.

(i) Capacity Export Through Import Constrained Zone Transactions:

(1) The External Transaction is exporting across an external interface located in an import-constrained Capacity Zone that cleared in the Forward Capacity Auction with price separation, as determined in accordance with Section III.12.4 and Section III.13.2.3.4 of Market Rule 1;

(2) The External Transaction is directly associated with an Export Bid or Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The External Node associated with the cleared Export Bid or Administrative Export De-List Bid is connected to the import-constrained Capacity Zone, and is not connected to a Capacity Zone that is not import-constrained;

(4) The Resource, or portion thereof, that is associated with the cleared Export Bid or Administrative Export De-List Bid is not located in the import-constrained Capacity Zone;

(5) The External Transaction has been submitted and cleared in the Day-Ahead Energy Market;

(6) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in

accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(ii) FCA Cleared Export Transactions:

(1) The External Transaction sale is exporting to an External Node that is connected only to an import-constrained Reserve Zone;

(2) The External Transaction sale is directly associated with an Export Bid or an Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation associated with the Export Bid or Administrative Export De-List Bid is located outside the import-constrained Reserve Zone;

(4) The External Transaction sale is submitted and cleared in the Day-Ahead Energy Market;

(5) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(iii) Same Reserve Zone Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is connected only to the same Reserve Zone in which the associated Resource, or portion thereof, without a Capacity Supply Obligation is located;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(4) Neither the External Transaction sale nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(iv) Unconstrained Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is not connected only to an import-constrained Reserve Zone;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is not separated from the External Node by a transmission interface constraint as determined in Sections III.12.2.1(b) and III.12.2.2(b) of Market Rule 1 that was binding in the Forward Capacity Auction in the direction of the export;

(4) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(5) Neither the External Transaction sale, nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(g) Treatment of External Transaction sales in ISO commitment for local second contingency protection.

(i) Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: The transaction's export demand that clears in the Day-Ahead Energy

Market will be explicitly considered as load in the exporting Reserve Zone by the ISO when committing Resources to provide local second contingency protection for the associated Operating Day.

(ii) The export demand of External Transaction sales not meeting the criteria in (i) above is not considered by the ISO when planning and committing Resources to provide local second contingency protection, and is assumed to be zero.

(iii) Same Reserve Zone Export Transactions and Unconstrained Export Transactions: If a Resource, or portion thereof, without a Capacity Supply Obligation is committed to be online during the Operating Day either through clearing in the Day-Ahead Energy Market or through Self-Scheduling subsequent to the Day-Ahead Energy Market and a Same Reserve Zone Export Transaction or Unconstrained Export Transaction is submitted before the end of the Re-Offer Period designating that Resource as supporting the transaction, the ISO will not utilize the portion of the Resource without a Capacity Supply Obligation supporting the export transaction to meet local second contingency protection requirements. The eligibility of Resources not meeting the foregoing criteria to be used to meet local second contingency protection requirements shall be in accordance with the relevant provisions of the ISO New England System Rules.

(h) Allocation of costs to Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: Market Participants with Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions shall incur a proportional share of the charges described below, which are allocated to Market Participants based on Day-Ahead Load Obligation or Real-Time Load Obligation. The share shall be determined by including the Day-Ahead Load Obligation or Real-Time Load Obligation associated with the External Transaction, as applicable, in the total Day-Ahead Load Obligation or Real-Time Load Obligation for the appropriate Reliability Region, Reserve Zone, or Load Zone used in each cost allocation calculation:

(i) NCPC for Local Second Contingency Protection Resources allocated within the exporting Reliability Region, pursuant to Section III.F.3.3.

(ii) Forward Reserve Market charges allocated within the exporting Load Zone, pursuant to Section III.9.9.

(iii) Real-Time Reserve Charges allocated within the exporting Load Zone, pursuant to Section III.10.3.

(i) When action is taken by the ISO to reduce External Transaction sales due to a system wide capacity deficient condition or the forecast of such a condition, and an External Transaction sale designates a Resource, or portion of a Resource, without a Capacity Supply Obligation, to support the transaction, the ISO will review the status of the designated Resource. If the designated Resource is Self-Scheduled and online at a megawatt level greater than or equal to the External Transaction sale, that External Transaction sale will not be reduced until such time as Regional Network Load within the New England Control Area is also being reduced. When reductions to such transactions are required, the affected transactions shall be reduced pro-rata.

(j) Market Participants shall submit External Transactions as megawatt blocks with intervals of one hour at the relevant External Node. External Transactions will be scheduled in the Day-Ahead Energy Market as megawatt blocks for hourly durations. The ISO may dispatch External Transactions in the Real-Time Energy Market as megawatt blocks for periods of less than one hour, to the extent allowed pursuant to inter-Control Area operating protocols.

III.1.10.7.A Coordinated Transaction Scheduling.

The provisions of this Section III.1.10.7.A apply to Coordinated External Transactions, which are implemented at the New York Northern AC external Location.

(a) Market Participants that submit a Coordinated External Transaction in the Day-Ahead Energy Market must also submit a corresponding Coordinated External Transaction, in the form of an Interface Bid, in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market.

(b) An Interface Bid submitted in the Real-Time Energy Market shall specify a duration consisting of one or more consecutive 15-minute increments. An Interface Bid shall include a bid price, a bid quantity, and a bid direction for each 15-minute increment. The bid price may be positive or negative. An Interface Bid may not be submitted or modified later than 75 minutes before the start of the clock hour for which it is offered.

(c) Interface Bids are cleared in economic merit order for each 15-minute increment, based upon the forecasted real-time price difference across the external interface. The total quantity of Interface Bids cleared shall determine the external interface schedule between New England and the adjacent Control Area. The total quantity of Interface Bids cleared shall depend upon, among other factors, bid production costs of resources in both Control Areas, the Interface Bids of all Market Participants, transmission system conditions, and any real-time operating limits necessary to ensure reliable operation of the transmission system.

(d) All Coordinated External Transactions submitted either to the Day-Ahead Energy Market or the Real-Time Energy Market must contain the associated e-Tag ID at the time the transaction is submitted.

(e) Any Coordinated External Transaction, or portion thereof, submitted to the Real-Time Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency, unless the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, permit the transaction to be scheduled.

III.1.10.8 ISO Responsibilities.

(a) The ISO shall use its best efforts to determine (i) the least-cost means of satisfying hourly purchase requests for energy, the projected hourly requirements for Operating Reserve, Replacement Reserve and other ancillary services of the Market Participants, including the reliability requirements of the New England Control Area, of the Day-Ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve, Replacement Reserve and other ancillary service requirements for any portion of the load forecast of the ISO for the Operating Day in excess of that scheduled in the Day-Ahead Energy Market. In making these determinations, the ISO shall take into account: (i) the ISO's forecasts of New England Markets and New England Control Area energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Participants for the Day-Ahead Energy Market; (ii) the offers and bids submitted by Market Participants; (iii) the availability of Limited Energy Resources; (iv) the capacity, location, and other relevant characteristics of Self-Scheduled Resources; (v) the requirements of the New England Control Area for Operating Reserve and Replacement Reserve, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vi) the requirements of the New England Control Area for Regulation and other ancillary services, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the ISO New England Manuals and ISO New England Administrative

Procedures; and (viii) such other factors as the ISO reasonably concludes are relevant to the foregoing determination. The ISO shall develop a Day-Ahead Energy schedule based on the applicable portions of the foregoing determination, and shall determine the Day-Ahead Prices resulting from such schedule. (b)

Not later than 1:30 p.m. of the day before each Operating Day, or such earlier deadline as may be specified by the ISO in the ISO New England Manuals and ISO New England Administrative Procedures or such later deadline as necessary to account for software failures or other events, the ISO shall: (i) post the aggregate Day-Ahead Energy schedule; (ii) post the Day-Ahead Prices; and (iii) inform the Market Participants of their scheduled injections and withdrawals. In the event of an Emergency, the ISO will notify Market Participants as soon as practicable if the Day-Ahead Energy Market can not be operated.

(c) Following posting of the information specified in Section III.1.10.8(b), the ISO shall revise its schedule of Resources to reflect updated projections of load, conditions affecting electric system operations in the New England Control Area, the availability of and constraints on limited energy and other Resources, transmission constraints, and other relevant factors.

(d) Market Participants shall pay and be paid for the quantities of energy scheduled in the Day-Ahead Energy Market at the Day-Ahead Prices.

III.1.10.9 Hourly Scheduling.

(a) Following the initial posting by the ISO of the Locational Marginal Prices resulting from the Day-Ahead Energy Market, and subject to the right of the ISO to schedule and dispatch Resources and to direct that schedules be changed to address an actual or potential Emergency, a Resource Re-Offer Period shall exist from the time of the posting specified in Section III.1.10.8(b) until 2:00 p.m. on the day before each Operating Day or such other Re-Offer Period as necessary to account for software failures or other events. During the Re-Offer Period, Market Participants may submit revisions to Supply Offers, revisions to Demand Reduction Offers, and revisions to Demand Bids for any Dispatchable Asset Related Demand. Resources scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices.

(b) During the Re-Offer Period, Market Participants may submit revisions to the price of priced External Transactions. External Transactions scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices. A submission during the Re-Offer Period for any portion of a transaction that was cleared

in the Day-Ahead Energy Market is subject to the provisions in Section III.1.10.7. A Market Participant may request to Self-Schedule an External Transaction and adjust the schedule on an hour-to-hour basis or request to reduce the quantity of a priced External Transaction. The ISO must be notified of the request not later than 60 minutes prior to the hour in which the adjustment is to take effect. The External Transaction re-offer provisions of this Section III.1.10.9(b) shall not apply to Coordinated External Transactions, which are submitted pursuant to Section III.1.10.7.A.

(c) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may modify certain Supply Offer or Demand Bid parameters for a Generator Asset or a Dispatchable Asset Related Demand on an hour-to-hour basis, provided that the modification is made no later than 30 minutes prior to the beginning of the hour for which the modification is to take effect:

(i) For a Generator Asset, the Start-Up Fee, the No-Load Fee, the fuel type (for dual-fuel Generator Assets), and the quantity and price pairs of its Blocks may be modified.

(ii) For a Dispatchable Asset Related Demand, the quantity and price pairs of its Blocks may be modified.

(d) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may not modify any of the following Demand Reduction Offer parameters: price and demand reduction quantity pairs, Interruption Cost, Demand Response Resource Start-Up Time, Demand Response Resource Notification Time, Minimum Reduction Time, and Minimum Time Between Reductions.

(e) During the Operating Day, a Market Participant may request to Self-Schedule a Generator Asset or Dispatchable Asset Related Demand or may request to cancel a Self-Schedule for a Generator Asset or Dispatchable Asset Related Demand. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor a Self-Schedule request, a Generator Asset will be permitted to come online at its Economic Minimum Limit and a Dispatchable Asset Related Demand will be dispatched to its Minimum Consumption Limit. A Market Participant may not request to Self-Schedule a Demand Response Resource. A Market Participant may cancel the Self-Schedule of a Continuous Storage Generator Asset or a Continuous Storage DARD only by declaring the facility unavailable.

(f) During the Operating Day, in the event that in a given hour a Market Participant seeks to modify a Supply Offer or Demand Bid after the deadline for modifications specified in Section III.1.10.9(c), then:

(i) the Market Participant may request that a Generator Asset be dispatched above its Economic Minimum Limit at a specified output. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the request, the Generator Asset will be dispatched as though it had offered the specified output for the hour in question at the Energy Offer Floor.

(ii) the Market Participant may request that a Dispatchable Asset Related Demand be dispatched above its Minimum Consumption Limit at a specified value. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the request, the Dispatchable Asset Related Demand will be dispatched at or above the requested amount for the hour in question.

(g) During the Operating Day, in any interval in which a Generator Asset is providing Regulation, the upper limit of its energy dispatch range shall be reduced by the amount of Regulation Capacity, and the lower limit of its energy dispatch range shall be increased by the amount of Regulation Capacity. Any such adjustment shall not affect the Real-Time Reserve Designation.

(h) During the Operating Day, in any interval in which a Continuous Storage ATRR is providing Regulation, the upper limit of the associated Generator Asset's energy dispatch range shall be reduced by the Regulation High Limit, and the associated DARD's consumption dispatch range shall be reduced by the Regulation Low Limit. Any such adjustment shall not affect the Real-Time Reserve Designation.

(i) For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this Section III.1.10, the ISO shall provide Market Participants and parties to External Transactions with any revisions to their schedules for the hour.

III.1.11 Dispatch.

The following procedures and principles shall govern the dispatch of the Resources available to the ISO.

III.1.11.1 Resource Output or Consumption and Demand Reduction.

The ISO shall have the authority to direct any Market Participant to adjust the output, consumption or demand reduction of any Dispatchable Resource within the operating characteristics specified in the Market Participant's Offer Data, Supply Offer, Demand Reduction Offer or Demand Bid. The ISO may

cancel its selection of, or otherwise release, Pool-Scheduled Resources. The ISO shall adjust the output, consumption or demand reduction of Resources as necessary: (a) for both Dispatchable Resources and Non-Dispatchable Resources, to maintain reliability, and subject to that constraint, for Dispatchable Resources, (b) to minimize the cost of supplying the energy, reserves, and other services required by the Market Participants and the operation of the New England Control Area; (c) to balance supply and demand, maintain scheduled tie flows, and provide frequency support within the New England Control Area; and (d) to minimize unscheduled interchange that is not frequency related between the New England Control Area and other Control Areas.

III.1.11.2 Operating Basis.

In carrying out the foregoing objectives, the ISO shall conduct the operation of the New England Control Area and shall, in accordance with the ISO New England Manuals and ISO New England Administrative Procedures, (i) utilize available Operating Reserve and replace such Operating Reserve when utilized; and (ii) monitor the availability of adequate Operating Reserve.

III.1.11.3 Dispatchable Resources.

With the exception of Settlement Only Resources, Generator Assets that meet the size criteria to be Settlement Only Resources, External Transactions, nuclear-powered Resources and photovoltaic Resources, all Resources must be Dispatchable Resources in the Energy Market and meet the technical specifications in ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18 for dispatchability.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market because the Resource is not connected to a remote terminal unit meeting the requirements of ISO New England Operating Procedure No. 18 shall take the following steps:

1. By January 15, 2017, the Market Participant shall submit to the ISO a circuit order form for the primary and secondary communication paths for the remote terminal unit.
2. The Market Participant shall work diligently with the ISO to ensure the Resource is able to receive and respond to electronic Dispatch Instructions within twelve months of the circuit order form submission.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market by the deadline set forth above shall provide the ISO with a written plan for remedying the deficiencies, and shall identify in the plan the specific actions to be taken and a reasonable timeline for rendering the Resource dispatchable. The Market Participant shall complete the remediation

in accordance with and under the timeline set forth in the written plan. Until a Resource is dispatchable, it may only be Self-Scheduled in the Real-Time Energy Market and shall otherwise be treated as a Non-Dispatchable Resource.

Dispatchable Resources in the Energy Market are subject to the following requirements:

(a) The ISO shall optimize the dispatch of energy from Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources consistent with the dynamic load-following requirements of the New England Control Area and the availability of other Resources to the ISO.

(b) The ISO shall implement the dispatch of energy from Dispatchable Resources and the designation of Real-Time Operating Reserve to Dispatchable Resources, including the dispatchable portion of Resources which are otherwise Self-Scheduled, by sending appropriate signals and instructions to the entity controlling such Resources. Each Market Participant shall ensure that the entity controlling a Dispatchable Resource offered or made available by that Market Participant complies with the energy dispatch signals and instructions transmitted by the ISO.

(c) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed, and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(d) Market Participants shall exert all reasonable efforts to operate, or ensure the operation of, their Dispatchable Resources in the New England Control Area as close to dispatched output, consumption or demand reduction levels as practical, consistent with Good Utility Practice.

(e) Settlement Only Resources are not eligible to be DNE Dispatchable Generators.

Wind and hydro Intermittent Power Resources that are not Settlement Only Resources are required to receive and respond to Do Not Exceed Dispatch Points, except as follows:

(i) A wind or hydro Intermittent Power Resource not capable of receiving and responding to electronic Dispatch Instructions will be manually dispatched.

(ii) A Market Participant may elect, but is not required, to have a wind or hydro Intermittent Power Resource that is less than 5 MW and is connected through transmission facilities rated at less than 115 kV be dispatched as a DNE Dispatchable Generator.

(iii) A Market Participant with a hydro Intermittent Power Resource that is able to operate within a dispatchable range and is capable of responding to Dispatch Instructions to increase or decrease output within its dispatchable range may elect to have that resource dispatched as a DDP Dispatchable Resource.

(f) The ISO may request that dual-fuel Generator Assets that normally burn natural gas voluntarily take all necessary steps (within the limitations imposed by the operating limitations of their installed equipment and their environmental and operating permits) to prepare to switch to secondary fuel in anticipation of natural gas supply shortages. The ISO may request that Market Participants with dual-fuel Generator Assets that normally burn natural gas voluntarily switch to a secondary fuel in anticipation of natural gas supply shortages. The ISO may communicate with Market Participants with dual-fuel Generator Assets that normally burn natural gas to verify whether the Market Participants have switched or are planning to switch to an alternate fuel.

III.1.11.4 Emergency Condition.

If the ISO anticipates or declares an Emergency Condition, all External Transaction sales out of the New England Control Area that are not backed by a Resource may be interrupted, in accordance with the ISO New England Manuals, in order to serve load and Operating Reserve in the New England Control Area.

III.1.11.5 Dispatchability Requirements for Intermittent Power Resources.

(a) Intermittent Power Resources that are Dispatchable Resources with Supply Offers that do not clear in the Day-Ahead Energy Market and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market at the Resource's Economic Minimum Limit in order to operate in Real-Time.

(b) Intermittent Power Resources that are not Settlement Only Resources, are not Dispatchable Resources, and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market with the Resource's Economic Maximum Limit and Economic Minimum Limit redeclared to the same value in order to operate in Real-

Time. Redeclarations must be updated throughout the Operating Day to reflect actual operating capabilities.

III.1.11.6 Non-Dispatchable Resources.

Non-Dispatchable Resources are subject to the following requirements:

(a) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Non-Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(b) Market Participants with Non-Dispatchable Resources shall exert all reasonable efforts to operate or ensure the operation of their Resources in the New England Control Area as close to dispatched levels as practical when dispatched by the ISO for reliability, consistent with Good Utility Practice.

I.2 Rules of Construction; Definitions

I.2.1. Rules of Construction:

In this Tariff, unless otherwise provided herein:

(a) words denoting the singular include the plural and vice versa;

(b) words denoting a gender include all genders;

(c) references to a particular part, clause, section, paragraph, article, exhibit, schedule, appendix or other attachment shall be a reference to a part, clause, section, paragraph, or article of, or an exhibit, schedule, appendix or other attachment to, this Tariff;

(d) the exhibits, schedules and appendices attached hereto are incorporated herein by reference and shall be construed with an as an integral part of this Tariff to the same extent as if they were set forth verbatim herein;

(e) a reference to any statute, regulation, proclamation, ordinance or law includes all statutes, regulations, proclamations, amendments, ordinances or laws varying, consolidating or replacing the same from time to time, and a reference to a statute includes all regulations, policies, protocols, codes, proclamations and ordinances issued or otherwise applicable under that statute unless, in any such case, otherwise expressly provided in any such statute or in this Tariff;

(f) a reference to a particular section, paragraph or other part of a particular statute shall be deemed to be a reference to any other section, paragraph or other part substituted therefor from time to time;

(g) a definition of or reference to any document, instrument or agreement includes any amendment or supplement to, or restatement, replacement, modification or novation of, any such document, instrument or agreement unless otherwise specified in such definition or in the context in which such reference is used;

(h) a reference to any person (as hereinafter defined) includes such person's successors and permitted assigns in that designated capacity;

(i) any reference to "days" shall mean calendar days unless "Business Days" (as hereinafter defined) are expressly specified;

(j) if the date as of which any right, option or election is exercisable, or the date upon which any amount is due and payable, is stated to be on a date or day that is not a Business Day, such right, option or election may be exercised, and such amount shall be deemed due and payable, on the next succeeding Business Day with the same effect as if the same was exercised or made on such date or day (without, in the case of any such payment, the payment or accrual of any interest or

other late payment or charge, provided such payment is made on such next succeeding Business Day);

(k) words such as "hereunder," "hereto," "hereof" and "herein" and other words of similar import shall, unless the context requires otherwise, refer to this Tariff as a whole and not to any particular article, section, subsection, paragraph or clause hereof; and a reference to "include" or "including" means including without limiting the generality of any description preceding such term, and for purposes hereof the rule of *ejusdem generis* shall not be applicable to limit a general statement, followed by or referable to an enumeration of specific matters, to matters similar to those specifically mentioned.

I.2.2. Definitions:

In this Tariff, the terms listed in this section shall be defined as described below:

Active Demand Capacity Resource is one or more Demand Response Resources located within the same Dispatch Zone, that is registered with the ISO, assigned a unique resource identification number by the ISO, and participates in the Forward Capacity Market to fulfill a Market Participant's Capacity Supply Obligation pursuant to Section III.13 of Market Rule 1.

Actual Capacity Provided is the measure of capacity provided during a Capacity Scarcity Condition, as described in Section III.13.7.2.2 of Market Rule 1.

Actual Load is the consumption at the Retail Delivery Point for the hour.

Additional Resource Blackstart O&M Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Additional Resource Specified-Term Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Additional Resource Standard Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Administrative Costs are those costs incurred in connection with the review of Applications for transmission service and the carrying out of System Impact Studies and Facilities Studies.

Administrative Export De-List Bid is a bid that may be submitted in a Forward Capacity Auction by certain Existing Generating Capacity Resources subject to a multi-year contract to sell capacity outside of the New England Control Area during the associated Capacity Commitment Period, as described in Section III.13.1.2.3.1.4 of Market Rule 1.

Administrative Sanctions are defined in Section III.B.4.1.2 of Appendix B of Market Rule 1.

ADR Neutrals are one or more firms or individuals identified by the ISO with the advice and consent of the Participants Committee that are prepared to act as neutrals in ADR proceedings under Appendix D to Market Rule 1.

Advance is defined in Section IV.A.3.2 of the Tariff.

Affected Party, for purposes of the ISO New England Billing Policy, is defined in Section 6.3.5 of the ISO New England Billing Policy.

Affiliate is any person or entity that controls, is controlled by, or is under common control by another person or entity. For purposes of this definition, "control" means the possession, directly or indirectly, of the authority to direct the management or policies of an entity. A voting interest of ten percent or more shall create a rebuttable presumption of control.

AGC is automatic generation control.

AGC SetPoint is the desired output signal for a Resource providing Regulation that is produced by the AGC system as frequently as every four seconds.

AGC SetPoint Deadband is a deadband expressed in megawatts that is applied to changing values of the AGC SetPoint for generating units.

Allocated Assessment is a Covered Entity's right to seek and obtain payment and recovery of its share in any shortfall payments under Section 3.3 or Section 3.4 of the ISO New England Billing Policy.

Alternative Dispute Resolution (ADR) is the procedure set forth in Appendix D to Market Rule 1.

Alternative Technology Regulation Resource (ATRR) is one or more facilities capable of providing Regulation that have been registered in accordance with the Asset Registration Process. An Alternative Technology Regulation Resource is eligible to participate in the Regulation Market.

Ancillary Services are those services that are necessary to support the transmission of electric capacity and energy from resources to loads while maintaining reliable operation of the New England Transmission System in accordance with Good Utility Practice.

Announced Schedule 1 EA Amount, Announced Schedule 2 EA Amount, Announced Schedule 3 EA Amount are defined in Section IV.B.2.2 of the Tariff.

Annual Transmission Revenue Requirements are the annual revenue requirements of a PTO's PTF or of all PTOs' PTF for purposes of the OATT shall be the amount determined in accordance with Attachment F to the OATT.

Annual Reconfiguration Transaction is a bilateral transaction that may be used in accordance with Section III.13.5.4 of Market Rule 1 to specify a price when a Capacity Supply Obligation is transferred using supply offers and demand bids in Annual Reconfiguration Auctions.

Applicants, for the purposes of the ISO New England Financial Assurance Policy, are entities applying for Market Participant status or for transmission service from the ISO.

Application is a written request by an Eligible Customer for transmission service pursuant to the provisions of the OATT.

Asset is a Generator Asset, a Demand Response Asset, a component of an On-Peak Demand Resource or Seasonal Peak Demand Resource, a Load Asset (including an Asset Related Demand), an Alternative Technology Regulation Resource, or a Tie-Line Asset.

Asset Registration Process is the ISO business process for registering an Asset.

Asset Related Demand is a Load Asset that has been discretely modeled within the ISO's dispatch and settlement systems, settles at a Node, has been registered in accordance with the Asset Registration

Process, and is made up of either: (1) one or more individual end-use metered customers receiving service from the same point or points of electrical supply with an aggregate average hourly load of 1 MW or greater during the 12 months preceding its registration; (2) a Storage DARD with a consumption capability of at least 0.1 MW; or (3) one or more storage facilities that are not Electric Storage Facilities with an aggregate consumption capability of at least 1 MW.

Asset Related Demand Bid Block-Hours are Block-Hours assigned to the Lead Market Participant for each Asset Related Demand bid. Blocks of the bid in effect for each hour will be totaled to determine the daily quantity of Asset Related Demand Bid Block-Hours. In the case that a Resource has a Real-Time unit status of "unavailable" for an entire day, that day will not contribute to the quantity of Asset Related Demand Bid Block-Hours. However, if the Resource has at least one hour of the day with a unit status of "available," the entire day will contribute to the quantity of Asset Related Demand Bid Block-Hours.

Asset-Specific Going Forward Costs are the net costs of an asset that is part of an Existing Generating Capacity Resource, calculated for the asset in the same manner as the net costs of Existing Generating Capacity Resources as described in Section III.13.1.2.3.2.1.1.1 (for an asset with a Static De-List Bid or an Export Bid) or Section III.13.1.2.3.2.1.1.2 (for an asset with a Permanent De-List Bid or Retirement De-List Bid).

Assigned Meter Reader reports to the ISO the hourly and monthly MWh associated with the Asset. These MWh are used for settlement. The Assigned Meter Reader may designate an agent to help fulfill its Assigned Meter Reader responsibilities; however, the Assigned Meter Reader remains functionally responsible to the ISO.

Auction Revenue Right (ARR) is a right to receive FTR Auction Revenues in accordance with Appendix C of Market Rule 1.

Auction Revenue Right Allocation (ARR Allocation) is defined in Section 1 of Appendix C of Market Rule 1.

Auction Revenue Right Holder (ARR Holder) is an entity which is the record holder of an Auction Revenue Right (excluding an Incremental ARR) in the register maintained by the ISO.

Authorized Commission is defined in Section 3.3 of the ISO New England Information Policy.

Authorized Person is defined in Section 3.3 of the ISO New England Information Policy.

Automatic Response Rate is the response rate, in MW/Minute, at which a Market Participant is willing to have a Regulation Resource change its output or consumption while providing Regulation between the Regulation High Limit and Regulation Low Limit.

Available Energy is a value that reflects the MWhs of energy available from an Electric Storage Facility for economic dispatch.

Available Storage is a value that reflects the MWhs of unused storage available from an Electric Storage Facility for economic dispatch of consumption.

Average Hourly Load Reduction is either: (i) the sum of the On-Peak Demand Resource's electrical energy reduction during Demand Resource On-Peak Hours in the month divided by the number of Demand Resource On-Peak Hours in the month; or (ii) the sum of the Seasonal Peak Demand Resource's electrical energy reduction during Demand Resource Seasonal Peak Hours in the month divided by the number of Demand Resource Seasonal Peak Hours in the month. The On-Peak Demand Resource's or Seasonal Peak Demand Resource's electrical energy reduction and Average Hourly Load Reduction shall be determined consistent with the resource's Measurement and Verification Plan, which shall be reviewed by the ISO to ensure consistency with the measurement and verification requirements, as described in Section III.13.1.4.3 of Market Rule 1 and the ISO New England Manuals.

Average Hourly Output is either: (i) the sum of the On-Peak Demand Resource's electrical energy output during Demand Resource On-Peak Hours in the month divided by the number of Demand Resource On-Peak Hours in the month; or (ii) the sum of the Seasonal Peak Demand Resource's electrical energy output during Demand Resource Seasonal Peak Hours in the month divided by the number of Demand Resource Seasonal Peak Hours in the month. Electrical energy output and Average Hourly Output shall be determined consistent with the resource's Measurement and Verification Plan, which shall be reviewed by the ISO to ensure consistency with the measurement and verification requirements, as described in Section III.13.1.4.3 of Market Rule 1 and the ISO New England Manuals.

Average Monthly PER is calculated in accordance with Section III.13.7.1.2.2 of Market Rule 1.

Backstop Transmission Solution is a solution proposed: (i) to address a reliability or market efficiency need identified by the ISO in a Needs Assessment reported by the ISO pursuant to Section 4.1(i) of Attachment K to the ISO OATT, (ii) by the PTO or PTOs with an obligation under Schedule 3.09(a) of the TOA to address the identified need; and (iii) in circumstances in which the competitive solution process specified in Section 4.3 of Attachment K to the ISO OATT will be utilized.

Bankruptcy Code is the United States Bankruptcy Code.

Bankruptcy Event occurs when a Covered Entity files a voluntary or involuntary petition in bankruptcy or commences a proceeding under the United States Bankruptcy Code or any other applicable law concerning insolvency, reorganization or bankruptcy by or against such Covered Entity as debtor.

Bilateral Contract (BC) is any of the following types of contracts: Internal Bilateral for Load, Internal Bilateral for Market for Energy, and External Transactions.

Bilateral Contract Block-Hours are Block-Hours assigned to the seller and purchaser of an Internal Bilateral for Load, Internal Bilateral for Market for Energy and External Transactions; provided, however, that only those contracts which apply to the Real-Time Energy Market will accrue Block-Hours.

Binary Storage DARD is a DARD that participates in the New England Markets as part of a Binary Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Binary Storage Facility is a type of Electric Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Blackstart Capability Test is the test, required by ISO New England Operating Documents, of a resource's capability to provide Blackstart Service.

Blackstart Capital Payment is the annual compensation, as calculated pursuant to Section 5.1, or as referred to in Section 5.2, of Schedule 16 to the OATT, for a Designated Blackstart Resource's Blackstart Equipment capital costs associated with the provision of Blackstart Service (excluding the capital costs associated with compliance with NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Blackstart Equipment is any equipment that is solely necessary to enable the Designated Blackstart Resource to provide Blackstart Service and is not required to provide other products or services under the Tariff.

Blackstart O&M Payment is the annual Blackstart O&M compensation calculated under either Section 5.1 or 5.2 of Schedule 16 of the OATT, as applicable.

Blackstart Owner is the Market Participant who is authorized on behalf of the Generator Owner(s) to offer or operate the resource as a Designated Blackstart Resource and is authorized to commit the resource to provide Blackstart Service.

Blackstart Service is the Ancillary Service described in Section II.47 of the Tariff and Schedule 16 of the OATT.

Blackstart Service Commitment is the commitment by a Blackstart Owner for its resource to provide Blackstart Service and the acceptance of that commitment by the ISO, in the manner detailed in ISO New England Operating Procedure No. 11 – Designated Blackstart Resource Administration (OP 11), and which includes a commitment to provide Blackstart Service established under Operating Procedure 11 – Designated Blackstart Resource Administration (OP11).

Blackstart Service Minimum Criteria are the minimum criteria that a Blackstart Owner and its resource must meet in order to establish and maintain a resource as a Designated Blackstart Resource.

Blackstart Standard Rate Payment is the formulaic rate of monthly compensation, as calculated pursuant to Section 5 of Schedule 16 to the OATT, paid to a Blackstart Owner for the provision of Blackstart Service from a Designated Blackstart Resource.

Blackstart Station is comprised of (i) a single Designated Blackstart Resource or (ii) two or more Designated Blackstart Resources that share Blackstart Equipment.

Blackstart Station-specific Rate Payment is the Commission-approved compensation, as calculated pursuant to Section 5.2 of Schedule 16 to the OATT, paid to a Blackstart Owner on a monthly basis for the provision of Blackstart Service by Designated Blackstart Resources located at a specific Blackstart Station.

Blackstart Station-specific Rate Capital Payment is a component of the Blackstart Station-specific Rate Payment that reflects a Blackstart Station's capital Blackstart Equipment costs associated with the provision of Blackstart Service (excluding the capital costs associated with compliance with NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Block is defined as follows: (1) With respect to Bilateral Contracts, a Bilateral Contract administered by the ISO for an hour; (2) with respect to Supply Offers administered by the ISO, a quantity with a related price for Energy (Supply Offers for Energy may contain multiple sets of quantity and price pairs for each hour); (3) with respect to Demand Bids administered by the ISO, a quantity with a related price for Energy (Demand Bids for Energy may contain multiple sets of quantity and price pairs for each hour); (4) with respect to Increment Offers administered by the ISO, a quantity with a related price for Energy (Increment Offers for Energy may contain multiple sets of quantity and price pairs for each hour); (5) with respect to Decrement Bids administered by the ISO, a quantity with a related price for Energy (Decrement Bids for Energy may contain multiple sets of quantity and price pairs for each hour); (6) with respect to Asset Related Demand bids administered by the ISO, a quantity with a related price for Energy (Asset Related Demand bids may contain multiple sets of quantity and price pairs for each hour); and (7) with respect to Demand Reduction Offers administered by the ISO, a quantity of reduced demand with a related price (Demand Reduction Offers may contain multiple sets of quantity and price pairs for the day).

Block-Hours are the number of Blocks administered for a particular hour.

Budget and Finance Subcommittee is a subcommittee of the Participants Committee, the responsibilities of which are specified in Section 8.4 of the Participants Agreement.

Business Day is any day other than a Saturday or Sunday or ISO holidays as posted by the ISO on its website.

Cancelled Start NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Capability Demonstration Year is the one year period from September 1 through August 31.

Capacity Acquiring Resource is a resource that is seeking to acquire a Capacity Supply Obligation through: (1) a Capacity Supply Obligation Bilateral, as described in Section III.13.5.1, or; (2) an annual or monthly reconfiguration auction, as described in Section III.13.4.

Capacity Balancing Ratio is a ratio used in calculating the Capacity Performance Payment in the Forward Capacity Market, as described in Section III.13.7.2.3 of Market Rule 1.

Capacity Base Payment is the portion of revenue received in the Forward Capacity Market as described in Section III.13.7.1 of Market Rule 1.

Capacity Capability Interconnection Standard has the meaning specified in Schedule 22, Schedule 23, and Schedule 25 of the OATT.

Capacity Clearing Price is the clearing price for a Capacity Zone for a Capacity Commitment Period resulting from the Forward Capacity Auction conducted for that Capacity Commitment Period, as determined in accordance with Section III.13.2.7 of Market Rule 1.

Capacity Commitment Period is the one-year period from June 1 through May 31 for which obligations are assumed and payments are made in the Forward Capacity Market.

Capacity Cost (CC) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

Capacity Export Through Import Constrained Zone Transaction is defined in Section III.1.10.7(f)(i) of Market Rule 1.

Capacity Load Obligation is the quantity of capacity for which a Market Participant is financially responsible as described in Section III.13.7.5.2 of Market Rule 1.

Capacity Load Obligation Acquiring Participant is a load serving entity or any other Market Participant seeking to acquire a Capacity Load Obligation through a Capacity Load Obligation Bilateral, as described in Section III.13.5.2 of Market Rule 1.

Capacity Network Import Capability (CNI Capability) is as defined in Section I of Schedule 25 of the OATT.

Capacity Network Import Interconnection Service (CNI Interconnection Service) is as defined in Section I of Schedule 25 of the OATT.

Capacity Load Obligation Bilateral is a bilateral contract through which a Market Participant may transfer all or a portion of its Capacity Load Obligation to another entity, as described in Section III.13.5 of Market Rule 1.

Capacity Load Obligation Transferring Participant is an entity that has a Capacity Load Obligation and is seeking to shed such obligation through a Capacity Load Obligation Bilateral, as described in Section III.13.5.2 of Market Rule 1.

Capacity Network Resource (CNR) is defined in Section I of Schedule 22 and Attachment 1 to Schedule 23 of the OATT.

Capacity Network Resource Interconnection Service (CNR Interconnection Service) is defined in Section I of Schedule 22 and Attachment 1 to Schedule 23 of the OATT.

Capacity Performance Bilateral is a transaction for transferring Capacity Performance Score, as described in Section III.13.5.3 of Market Rule 1.

Capacity Performance Payment is the performance-dependent portion of revenue received in the Forward Capacity Market, as described in Section III.13.7.2 of Market Rule 1.

Capacity Performance Payment Rate is a rate used in calculating Capacity Performance Payments, as described in Section III.13.7.2.5 of Market Rule 1.

Capacity Performance Score is a figure used in determining Capacity Performance Payments, as described in Section III.13.7.2.4 of Market Rule 1.

Capacity Rationing Rule addresses whether offers and bids in a Forward Capacity Auction may be rationed, as described in Section III.13.2.6 of Market Rule 1.

Capacity Scarcity Condition is a period during which performance is measured in the Forward Capacity Market, as described in Section III.13.7.2.1 of Market Rule 1.

Capacity Scarcity Condition is a period during which performance is measured in the Forward Capacity Market, as described in Section III.13.7.2.1 of Market Rule 1.

Capacity Supply Obligation is an obligation to provide capacity from a resource, or a portion thereof, to satisfy a portion of the Installed Capacity Requirement that is acquired through a Forward Capacity Auction in accordance with Section III.13.2, a reconfiguration auction in accordance with Section III.13.4, or a Capacity Supply Obligation Bilateral in accordance with Section III.13.5.1 of Market Rule 1.

Capacity Supply Obligation Bilateral is a bilateral contract through which a Market Participant may transfer all or a part of its Capacity Supply Obligation to another entity, as described in Section III.13.5.1 of Market Rule 1.

Capacity Transfer Rights (CTRs) are calculated in accordance with Section III.13.7.5.4.

Capacity Transferring Resource is a resource that has a Capacity Supply Obligation and is seeking to shed such obligation, or a portion thereof, through: (1) a Capacity Supply Obligation Bilateral, as described in Section III.13.5.1, or; (2) an annual or monthly reconfiguration auction, as described in Section III.13.4.

Capacity Zone is a geographic sub-region of the New England Control Area as determined in accordance with Section III.12.4 of Market Rule 1.

Capacity Zone Demand Curves are the demand curves used in the Forward Capacity Market for a Capacity Zone as specified in Sections III.13.2.2.2 and III.13.2.2.3.

Capital Funding Charge (CFC) is defined in Section IV.B.2 of the Tariff.

CARL Data is Control Area reliability data submitted to the ISO to permit an assessment of the ability of an external Control Area to provide energy to the New England Control Area in support of capacity offered to the New England Control Area by that external Control Area.

Category B Designated Blackstart Resource has the same meaning as Designated Blackstart Resource.

Charge is a sum of money due from a Covered Entity to the ISO, either in its individual capacity or as billing and collection agent for NEPOOL pursuant to the Participants Agreement.

CLAIM10 is the value, expressed in megawatts, calculated pursuant to Section III.9.5.3 of the Tariff.

CLAIM30 is the value, expressed in megawatts, calculated pursuant to Section III.9.5.3 of the Tariff.

Claimed Capability Audit is performed to determine the real power output capability of a Generator Asset or the demand reduction capability of a Demand Response Resource.

Cluster Enabling Transmission Upgrade (CETU) has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Cluster Enabling Transmission Upgrade Regional Planning Study (CRPS) has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Cluster Entry Deadline has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Cluster Interconnection System Impact Study (CSIS) has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Clustering has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

CNR Capability is defined in Section I of Schedule 22 and Attachment 1 to Schedule 23 of the OATT.

Coincident Peak Contribution is a Market Participant's share of the New England Control Area coincident peak demand for the prior calendar year as determined prior to the start of each Capacity Commitment Period, which reflects the sum of the prior year's annual coincident peak contributions of the customers served by the Market Participant at each Load Asset. Daily Coincident Peak Contribution

values shall be submitted by the Assigned Meter Reader or Host Participant by the meter reading deadline to the ISO.

Commercial Capacity is capacity that has achieved FCM Commercial Operation.

Commission is the Federal Energy Regulatory Commission.

Commitment Period is (i) for a Day-Ahead Energy Market commitment, a period of one or more contiguous hours for which a Resource is cleared in the Day-Ahead Energy Market, and (ii) for a Real-Time Energy Market commitment, the period of time for which the ISO indicates the Resource is being committed when it issues the Dispatch Instruction. If the ISO does not indicate the period of time for which the Resource is being committed in the Real-Time Energy Market, then the Commitment Period is the Minimum Run Time for an offline Resource and one hour for an online Resource.

Common Costs are those costs associated with a Station that are avoided only by the clearing of the Static De-List Bids, the Permanent De-List Bids, or the Retirement De-List Bids of all the Existing Generating Capacity Resources comprising the Station.

Completed Application is an Application that satisfies all of the information and other requirements of the OATT, including any required deposit.

Compliance Effective Date is the date upon which the changes in the predecessor NEPOOL Open Access Transmission Tariff which have been reflected herein to comply with the Commission's Order of April 20, 1998 became effective.

Composite FCM Transaction is a transaction for separate resources seeking to participate as a single composite resource in a Forward Capacity Auction in which multiple Designated FCM Participants provide capacity, as described in Section III.13.1.5 of Market Rule 1.

Conditional Qualified New Resource is defined in Section III.13.1.1.2.3(f) of Market Rule 1.

Confidential Information is defined in Section 2.1 of the ISO New England Information Policy, which is Attachment D to the Tariff.

Confidentiality Agreement is Attachment 1 to the ISO New England Billing Policy.

Congestion is a condition of the New England Transmission System in which transmission limitations prevent unconstrained regional economic dispatch of the power system. Congestion is the condition that results in the Congestion Component of the Locational Marginal Price at one Location being different from the Congestion Component of the Locational Marginal Price at another Location during any given hour of the dispatch day in the Day-Ahead Energy Market or Real-Time Energy Market.

Congestion Component is the component of the nodal price that reflects the marginal cost of congestion at a given Node or External Node relative to the reference point. When used in connection with Zonal Price and Hub Price, the term Congestion Component refers to the Congestion Components of the nodal prices that comprise the Zonal Price and Hub Price weighted and averaged in the same way that nodal prices are weighted to determine Zonal Price and averaged to determine the Hub Price.

Congestion Cost is the cost of congestion as measured by the difference between the Congestion Components of the Locational Marginal Prices at different Locations and/or Reliability Regions on the New England Transmission System.

Congestion Paying LSE is, for the purpose of the allocation of FTR Auction Revenues to ARR Holders as provided for in Appendix C of Market Rule 1, a Market Participant or Non-Market Participant Transmission Customer that is responsible for paying for Congestion Costs as a Transmission Customer paying for Regional Network Service under the Transmission, Markets and Services Tariff, unless such Transmission Customer has transferred its obligation to supply load in accordance with ISO New England System Rules, in which case the Congestion Paying LSE shall be the Market Participant supplying the transferred load obligation. The term Congestion Paying LSE shall be deemed to include, but not be limited to, the seller of internal bilateral transactions that transfer Real-Time Load Obligations under the ISO New England System Rules.

Congestion Revenue Fund is the amount available for payment of target allocations to FTR Holders from the collection of Congestion Cost.

Congestion Shortfall means congestion payments exceed congestion charges during the billing process in any billing period.

Continuous Storage ATRR is an ATRR that participates in the New England Markets as part of a Continuous Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Continuous Storage DARD is a DARD that participates in the New England Markets as part of a Continuous Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Continuous Storage Generator Asset is a Generator Asset that participates in the New England Markets as part of a Continuous Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Continuous Storage Facility is a type of Electric Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Control Agreement is the document posted on the ISO website that is required if a Market Participant's cash collateral is to be invested in BlackRock funds.

Control Area is an electric power system or combination of electric power systems to which a common automatic generation control scheme is applied in order to:

(1) match, at all times, the power output of the generators within the electric power system(s) and capacity and energy purchased from entities outside the electric power system(s), with the load within the electric power system(s);
(2) maintain scheduled interchange with other Control Areas, within the limits of Good Utility Practice;
(3) maintain the frequency of the electric power system(s) within reasonable limits in accordance with Good Utility Practice and the criteria of the applicable regional reliability council or the North American Electric Reliability Corporation; and
(4) provide sufficient generating capacity to maintain operating reserves in accordance with Good Utility Practice.

Controllable Behind-the-Meter Generation means generation whose output can be controlled located at the same facility as a DARD or a Demand Response Asset, excluding: (1) generators whose output is separately metered and reported and (2) generators that cannot operate electrically synchronized to, and that are operated only when the facility loses its supply of power from, the New England Transmission System, or when undergoing related testing.

Coordinated External Transaction is an External Transaction at an external interface for which the enhanced scheduling procedures in Section III.1.10.7.A are implemented. A transaction to wheel energy into, out of or through the New England Control Area is not a Coordinated External Transaction. **Coordinated Transaction Scheduling** means the enhanced scheduling procedures set forth in Section III.1.10.7.A.

Correction Limit means the date that is one hundred and one (101) calendar days from the last Operating Day of the month to which the data applied. As described in Section III.3.6.1 of Market Rule 1, this will be the period during which meter data corrections must be submitted unless they qualify for submission as a Requested Billing Adjustment under Section III.3.7 of Market Rule 1.

Cost of Energy Consumed (CEC) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

Cost of Energy Produced (CEP) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

Cost of New Entry (CONE) is the estimated cost of new entry ($/kW-month) for a capacity resource that is determined by the ISO for each Forward Capacity Auction pursuant to Section III.13.2.4.

Counterparty means the status in which the ISO acts as the contracting party, in its name and own right and not as an agent, to an agreement or transaction with a Customer (including assignments involving Customers) involving sale to the ISO, and/or purchase from the ISO, of Regional Transmission Service and market and other products and services, and other transactions and assignments involving Customers, all as described in the Tariff.

Covered Entity is defined in the ISO New England Billing Policy.

Credit Coverage is third-party credit protection obtained by the ISO in the form of credit insurance coverage.

Credit Qualifying means a Rated Market Participant that has an Investment Grade Rating and an Unrated Market Participant that satisfies the Credit Threshold.

Credit Threshold consists of the conditions for Unrated Market Participants outlined in Section II.B.2 of the ISO New England Financial Assurance Policy.

Critical Energy Infrastructure Information (CEII) is defined in Section 3.0(j) of the ISO New England Information Policy, which is Attachment D to the Tariff.

Current Ratio is, on any date, all of a Market Participant's or Non-Market Participant Transmission Customer's current assets divided by all of its current liabilities, in each case as shown on the most recent financial statements provided by such Market Participant or Non-Market Participant Transmission Customer to the ISO.

Curtailment is a reduction in the dispatch of a transaction that was scheduled, using transmission service, in response to a transfer capability shortage as a result of system reliability conditions.

Customer is a Market Participant, a Transmission Customer or another customer of the ISO.

Data Reconciliation Process means the process by which meter reconciliation and data corrections that are discovered by Governance Participants after the Invoice has been issued for a particular month or that are discovered prior to the issuance of the Invoice for the relevant month but not included in that Invoice or in the other Invoices for that month and are reconciled by the ISO on an hourly basis based on data submitted to the ISO by the Host Participant Assigned Meter Reader or Assigned Meter Reader.

Day-Ahead is the calendar day immediately preceding the Operating Day.

Day-Ahead Adjusted Load Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Congestion Revenue is defined in Section III.3.2.1(i) of Market Rule 1.

Day-Ahead Demand Reduction Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Energy Market means the schedule of commitments for the purchase or sale of energy, purchase of demand reductions, payment of Congestion Costs, payment for losses developed by the ISO as a result of the offers and specifications submitted in accordance with Section III.1.10 of Market Rule 1.

Day-Ahead Energy Market Congestion Charge/Credit is defined in Section III.3.2.1(f) of Market Rule 1.

Day-Ahead Energy Market Energy Charge/Credit is defined in Section III.3.2.1(f) of Market Rule 1.

Day-Ahead Energy Market Loss Charge/Credit is defined in Section III.3.2.1(f) of Market Rule 1.

Day-Ahead Energy Market NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Day-Ahead External Transaction Export and Decrement Bid NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Day-Ahead External Transaction Import and Increment Offer NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Day-Ahead Generation Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Load Obligation is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Locational Adjusted Net Interchange is defined in Section III.3.2.1(a) of Market Rule 1.

Day-Ahead Loss Charges or Credits is defined in Section III.3.2.1(k) of Market Rule 1.

Day-Ahead Loss Revenue is defined in Section III.3.2.1(j) of Market Rule 1.

Day-Ahead Prices means the Locational Marginal Prices resulting from the Day-Ahead Energy Market.

DDP Dispatchable Resource is any Dispatchable Resource that the ISO dispatches using Desired Dispatch Points in the Resource's Dispatch Instructions.

Debt-to-Total Capitalization Ratio is, on any date, a Market Participant's or Non-Market Participant Transmission Customer's total debt (including all current borrowings) divided by its total shareholders'

equity plus total debt, in each case as shown on the most recent financial statements provided by such Market Participant or Non-Market Participant Transmission Customer to the ISO.

Decrement Bid means a bid to purchase energy at a specified Location in the Day-Ahead Energy Market which is not associated with a physical load. An accepted Decrement Bid results in scheduled load at the specified Location in the Day-Ahead Energy Market.

Default Amount is all or any part of any amount due to be paid by any Covered Entity that the ISO, in its reasonable opinion, believes will not or has not been paid when due (other than in the case of a payment dispute for any amount due for transmission service under the OATT).

Default Period is defined in Section 3.3.h(i) of the ISO New England Billing Policy.

Delivering Party is the entity supplying capacity and/or energy to be transmitted at Point(s) of Receipt under the OATT.

Demand Bid means a request to purchase an amount of energy, at a specified Location, or an amount of energy at a specified price, that is associated with a physical load. A cleared Demand Bid in the Day-Ahead Energy Market results in scheduled load at the specified Location. Demand Bids submitted for use in the Real-Time Energy Market are specific to Dispatchable Asset Related Demands only.

Demand Bid Block-Hours are the Block-Hours assigned to the submitting Customer for each Demand Bid.

Demand Bid Cap is $2,000/MWh.

Demand Capacity Resource means an Existing Demand Capacity Resource or a New Demand Capacity Resource. There are three Demand Capacity Resource types: Active Demand Capacity Resources, On-Peak Demand Resources, and Seasonal Peak Demand Resources.

Demand Designated Entity is the entity designated by a Market Participant to receive Dispatch Instructions for Demand Response Resources in accordance with the provisions set forth in ISO New England Operating Procedure No. 14.

Demand Reduction Offer is an offer by a Market Participant with a Demand Response Resource to reduce demand.

Demand Reduction Offer Block-Hours are Block-Hours assigned to the Lead Market Participant for each Demand Reduction Offer. Blocks of the Demand Reduction Offer in effect for each hour will be totaled to determine the quantity of Demand Reduction Offer Block-Hours for a given day. In the case that a Resource has a Real-Time unit status of "unavailable" for the entire day, that day will not contribute to the quantity of Demand Reduction Offer Block-Hours. However, if the Resource has at least one hour of the day with a unit status of "available," the entire day will contribute to the quantity of Demand Reduction Offer Block-Hours.

Demand Reduction Threshold Price is a minimum offer price calculated pursuant to Section III.1.10.1A(f).

Demand Resource On-Peak Hours are hours ending 1400 through 1700, Monday through Friday on non-Demand Response Holidays during the months of June, July, and August and hours ending 1800 through 1900, Monday through Friday on non-Demand Response Holidays during the months of December and January.

Demand Resource Seasonal Peak Hours are those hours in which the actual, real-time hourly load, as measured using real-time telemetry (adjusted for transmission and distribution losses, and excluding load associated with Exports and Storage DARDs) for Monday through Friday on non-Demand Response Holidays, during the months of June, July, August, December, and January, as determined by the ISO, is equal to or greater than 90% of the most recent 50/50 system peak load forecast, as determined by the ISO, for the applicable summer or winter season.

Demand Response Asset is an asset comprising the demand reduction capability of an individual end-use customer at a Retail Delivery Point or the aggregated demand reduction capability of multiple end-use customers from multiple delivery points (as described in Section III.8.1.1(f)) that has been registered in accordance with III.8.1.1.

Demand Response Available is the capability of the Demand Response Resource, in whole or in part, at any given time, to reduce demand in response to a Dispatch Instruction.

Demand Response Baseline is the expected baseline demand of an individual end-use metered customer or group of end-use metered customers as determined pursuant to Section III.8.2.

Demand Response Holiday is New Year's Day, Memorial Day, Independence Day, Labor Day, Veterans Day, Thanksgiving Day, and Christmas Day. If the holiday falls on a Saturday, the holiday will be observed on the preceding Friday; if the holiday falls on a Sunday, the holiday will be observed on the following Monday.

Demand Response Resource is an individual Demand Response Asset or aggregation of Demand Response Assets within a DRR Aggregation Zone that has been registered in accordance with Section III.8.1.2.

Demand Response Resource Notification Time is the period of time between the receipt of a startup Dispatch Instruction and the time the Demand Response Resource starts reducing demand.

Demand Response Resource Ramp Rate is the average rate, expressed in MW per minute, at which the Demand Response Resource can reduce demand.

Demand Response Resource Start-Up Time is the period of time between the time a Demand Response Resource starts reducing demand at the conclusion of the Demand Response Resource Notification Time and the time the resource can reach its Minimum Reduction and be ready for further dispatch by the ISO.

Designated Agent is any entity that performs actions or functions required under the OATT on behalf of the ISO, a Transmission Owner, a Schedule 20A Service Provider, an Eligible Customer, or a Transmission Customer.

Designated Blackstart Resource is a resource that meets the eligibility requirements specified in Schedule 16 of the OATT, which includes any resource referred to previously as a Category B Designated Blackstart Resource.

Designated Entity is the entity designated by a Market Participant to receive Dispatch Instructions for a Generator Asset and/or Dispatchable Asset Related Demand in accordance with the provisions set forth in ISO New England Operating Procedure No. 14.

Designated FCM Participant is any Lead Market Participant, including any Provisional Member that is a Lead Market Participant, transacting in any Forward Capacity Auction, reconfiguration auctions or Capacity Supply Obligation Bilateral for capacity that is otherwise required to provide additional financial assurance under the ISO New England Financial Assurance Policy.

Designated FTR Participant is a Market Participant, including FTR-Only Customers, transacting in the FTR Auction that is otherwise required to provide additional financial assurance under the ISO New England Financial Assurance Policy.

Desired Dispatch Point (DDP) means the control signal, expressed in megawatts, transmitted to direct the output, consumption, or demand reduction level of each Generator Asset, Dispatchable Asset Related Demand, or Demand Response Resource dispatched by the ISO in accordance with the asset's Offer Data.

Direct Assignment Facilities are facilities or portions of facilities that are constructed for the sole use/benefit of a particular Transmission Customer requesting service under the OATT or a Generator Owner requesting an interconnection. Direct Assignment Facilities shall be specified in a separate agreement among the ISO, Interconnection Customer and Transmission Customer, as applicable, and the Transmission Owner whose transmission system is to be modified to include and/or interconnect with the Direct Assignment Facilities, shall be subject to applicable Commission requirements, and shall be paid for by the Customer in accordance with the applicable agreement and the Tariff.

Directly Metered Assets are specifically measured by OP-18 compliant metering as currently described in Section IV (Metering and Recording for Settlements) of OP-18. Directly Metered Assets include all Tie-Line Assets, all Generator Assets, as well as some Load Assets. Load Assets for which the Host Participant is not the Assigned Meter Reader are considered Directly Metered Assets. In addition, the Host Participant Assigned Meter Reader determines which additional Load Assets are considered Directly Metered Assets and which ones are considered Profiled Load Assets based upon the Host Participant Assigned Meter Reader reporting systems and process by which the Host Participant Assigned Meter Reader allocates non-PTF losses.

Disbursement Agreement is the Rate Design and Funds Disbursement Agreement among the PTOs, as amended and restated from time to time.

Dispatch Instruction means directions given by the ISO to Market Participants, which may include instructions to start up, shut down, raise or lower generation, curtail or restore loads from Demand Response Resources, change External Transactions, or change the status or consumption of a Dispatchable Asset Related Demand in accordance with the Supply Offer, Demand Bid, or Demand Reduction Offer parameters. Such instructions may also require a change to the operation of a Pool Transmission Facility. Such instructions are given through either electronic or verbal means.

Dispatch Zone means a subset of Nodes located within a Load Zone established by the ISO for each Capacity Commitment Period pursuant to Section III.12.4A.

Dispatchable Asset Related Demand (DARD) is an Asset Related Demand that is capable of having its energy consumption modified in Real-Time in response to Dispatch Instructions. A DARD must be capable of receiving and responding to electronic Dispatch Instructions, must be able to increase or decrease energy consumption between its Minimum Consumption Limit and Maximum Consumption Limit in accordance with Dispatch Instructions, and must meet the technical requirements specified in the ISO New England Operating Procedures and Manuals.

Dispatchable Resource is any Generator Asset, Dispatchable Asset Related Demand, Demand Response Resource, or, with respect to the Regulation Market only, Alternative Technology Regulation Resource, that, during the course of normal operation, is capable of receiving and responding to electronic Dispatch Instructions in accordance with the parameters contained in the Resource's Supply Offer, Demand Bid, Demand Reduction Offer or Regulation Service Offer. A Resource that is normally classified as a Dispatchable Resource remains a Dispatchable Resource when it is temporarily not capable of receiving and responding to electronic Dispatch Instructions.

Dispute Representatives are defined in 6.5.c of the ISO New England Billing Policy.

Disputed Amount is a Covered Entity's disputed amount due on any fully paid monthly Invoice and/or any amount believed to be due or owed on a Remittance Advice, as defined in Section 6 of the ISO New England Billing Policy.

Disputing Party, for the purposes of the ISO New England Billing Policy, is any Covered Entity seeking to recover a Disputed Amount.

Distributed Generation means generation directly connected to end-use customer load and located behind the end-use customer's Retail Delivery Point that reduces the amount of energy that would otherwise have been produced on the electricity network in the New England Control Area, provided that the facility's Net Supply Capability is (i) less than 5 MW or (ii) less than or equal to the Maximum Facility Load, whichever is greater.

DRR Aggregation Zone is a Dispatch Zone entirely within a single Reserve Zone or Rest of System or, where a Dispatch Zone is not entirely within a single Reserve Zone or Rest of System, each portion of the Dispatch Zone demarcated by the Reserve Zone boundary.

Do Not Exceed (DNE) Dispatchable Generator is any Generator Asset that is dispatched using Do Not Exceed Dispatch Points in its Dispatch Instructions and meets the criteria specified in Section III.1.11.3(e). Do Not Exceed Dispatchable Generators are Dispatchable Resources.

Do Not Exceed Dispatch Point is a Dispatch Instruction indicating a maximum output level that a DNE Dispatchable Generator must not exceed.

Dynamic De-List Bid is a bid that may be submitted by Existing Generating Capacity Resources, Existing Import Capacity Resources, and Existing Demand Capacity Resources in the Forward Capacity Auction below the Dynamic De-List Bid Threshold, as described in Section III.13.2.3.2(d) of Market Rule 1.

Dynamic De-List Bid Threshold is the price specified in Section III.13.1.2.3.1.A of Market Rule 1 associated with the submission of Dynamic De-List Bids in the Forward Capacity Auction.

EA Amount is defined in Section IV.B.2.2 of the Tariff.

Early Amortization Charge (EAC) is defined in Section IV.B.2 of the Tariff.

Early Amortization Working Capital Charge (EAWCC) is defined in Section IV.B.2 of the Tariff.

Early Payment Shortfall Funding Amount (EPSF Amount) is defined in Section IV.B.2.4 of the Tariff.

Early Payment Shortfall Funding Charge (EPSFC) is defined in Section IV.B.2 of the Tariff.

EAWW Amount is defined in Section IV.B.2.3 of the Tariff.

EBITDA-to-Interest Expense Ratio is, on any date, a Market Participant's or Non-Market Participant Transmission Customer's earnings before interest, taxes, depreciation and amortization in the most recent fiscal quarter divided by that Market Participant's or Non-Market Participant Transmission Customer's expense for interest in that fiscal quarter, in each case as shown on the most recent financial statements provided by such Market Participant or Non-Market Participant Transmission Customer to the ISO.

Economic Dispatch Point is the output, reduction, or consumption level to which a Resource would have been dispatched, based on the Resource's Supply Offer, Demand Reduction Offer, or Demand Bid and the Real-Time Price, and taking account of any operating limits, had the ISO not dispatched the Resource to another Desired Dispatch Point.

Economic Maximum Limit or Economic Max is the maximum available output, in MW, of a Generator Asset that a Market Participant offers to supply in the Day-Ahead Energy Market or Real-Time Energy Market, as reflected in the Generator Asset's Offer Data. This represents the highest MW output a Market Participant has offered for a Generator Asset for economic dispatch. A Market Participant must maintain an up-to-date Economic Maximum Limit (and where applicable, must provide the ISO with any telemetry required by ISO New England Operating Procedure No. 18 to allow the ISO to maintain an updated Economic Maximum Limit) for all hours in which a Generator Asset has been offered into the Day-Ahead Energy Market or Real-Time Energy Market.

Economic Minimum Limit or Economic Min is (a) for a Generator Asset with an incremental heat rate, the maximum of: (i) the lowest sustainable output level as specified by physical design characteristics, environmental regulations or licensing limits; and (ii) the lowest sustainable output level at which a one MW increment increase in the output level would not decrease the incremental cost, calculated based on the incremental heat rate, of providing an additional MW of output, and (b) for a Generator Asset without an incremental heat rate, the lowest sustainable output level that is consistent with the physical design characteristics of the Generator Asset and with meeting all environmental regulations and licensing limits, and (c) for a Generator Asset undergoing Facility and Equipment Testing or auditing, the level to which the Generator Asset requests and is approved to operate or is directed to operate for purposes of completing the Facility and Equipment Testing or auditing, and (d) for Non-Dispatchable Resources the

output level at which a Market Participant anticipates its Non-Dispatchable Resource will be available to operate based on fuel limitations, physical design characteristics, environmental regulations or licensing limits.

Economic Study is defined in Section 4.1(b) of Attachment K to the OATT.

Effective Offer is the Supply Offer, Demand Reduction Offer, or Demand Bid that is used for NCPC calculation purposes as specified in Section III.F.1(a).

EFT is electronic funds transfer.

Elective Transmission Upgrade is defined in Section I of Schedule 25 of the OATT.

Elective Transmission Upgrade Interconnection Customer is defined in Schedule 25 of the OATT.

Electric Reliability Organization (ERO) is defined in 18 C.F.R. § 39.1.

Electric Storage Facility is a storage facility that participates in the New England Markets as described in Section III.1.10.6 of Market Rule 1.

Eligible Customer is: (i) Any entity that is engaged, or proposes to engage, in the wholesale or retail electric power business is an Eligible Customer under the OATT. (ii) Any electric utility (including any power marketer), Federal power marketing agency, or any other entity generating electric energy for sale or for resale is an Eligible Customer under the OATT. Electric energy sold or produced by such entity may be electric energy produced in the United States, Canada or Mexico. However, with respect to transmission service that the Commission is prohibited from ordering by Section 212(h) of the Federal Power Act, such entity is eligible only if the service is provided pursuant to a state requirement that the Transmission Owner with which that entity is directly interconnected or the distribution company having the service territory in which that entity is located (if that entity is a retail customer) offer the unbundled transmission service or Local Delivery Service, or pursuant to a voluntary offer of such service by the Transmission Owner with which that entity is directly interconnected or the distribution company having the service territory in which that entity is located (if that entity is a retail customer). (iii) Any end user taking or eligible to take unbundled transmission service or Local Delivery Service pursuant to a state requirement that the Transmission Owner with which that end user is directly interconnected or the

distribution company having the service territory in which that entity is located (if that entity is a retail customer) offer the transmission service or Local Delivery Service, or pursuant to a voluntary offer of such service by the Transmission Owner with which that end user is directly interconnected, or the distribution company having the service territory in which that entity is located (if that entity is a retail customer) is an Eligible Customer under the OATT.

Eligible FTR Bidder is an entity that has satisfied applicable financial assurance criteria, and shall not include the auctioneer, its Affiliates, and their officers, directors, employees, consultants and other representatives.

Emergency is an abnormal system condition on the bulk power systems of New England or neighboring Control Areas requiring manual or automatic action to maintain system frequency, or to prevent the involuntary loss of load, equipment damage, or tripping of system elements that could adversely affect the reliability of an electric system or the safety of persons or property; or a fuel shortage requiring departure from normal operating procedures in order to minimize the use of such scarce fuel; or a condition that requires implementation of Emergency procedures as defined in the ISO New England Manuals.

Emergency Condition means an Emergency has been declared by the ISO in accordance with the procedures set forth in the ISO New England Manuals and ISO New England Administrative Procedures.

Emergency Energy is energy transferred from one control area operator to another in an Emergency.

Emergency Minimum Limit or Emergency Min means the minimum output, in MWs, that a Generator Asset can deliver for a limited period of time without exceeding specified limits of equipment stability and operating permits.

EMS is energy management system.

End-of-Round Price is the lowest price associated with a round of a Forward Capacity Auction, as described in Section III.13.2.3.1 of Market Rule 1.

End User Participant is defined in Section 1 of the Participants Agreement.

Energy is power produced in the form of electricity, measured in kilowatthours or megawatthours.

Energy Administration Service (EAS) is the service provided by the ISO, as described in Schedule 2 of Section IV.A of the Tariff.

Energy Component means the Locational Marginal Price at the reference point.

Energy Efficiency is installed measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that reduce the total amount of electrical energy needed, while delivering a comparable or improved level of end-use service. Such measures include, but are not limited to, the installation of more energy efficient lighting, motors, refrigeration, HVAC equipment and control systems, envelope measures, operations and maintenance procedures, and industrial process equipment.

Energy Imbalance Service is the form of Ancillary Service described in Schedule 4 of the OATT.

Energy Market is, collectively, the Day-Ahead Energy Market and the Real-Time Energy Market.

Energy Non-Zero Spot Market Settlement Hours are the sum of the hours for which the Customer has a positive or negative Real-Time System Adjusted Net Interchange or for which the Customer has a positive or negative Real-Time Demand Reduction Obligation as determined by the ISO settlement process for the Energy Market.

Energy Offer Floor is negative $150/MWh.

Energy Transaction Units (Energy TUs) are the sum for the month for a Customer of Bilateral Contract Block-Hours, Demand Bid Block-Hours, Asset Related Demand Bid Block-Hours, Supply Offer Block-Hours, Demand Reduction Offer Block-Hours, and Energy Non-Zero Spot Market Settlement Hours.

Equipment Damage Reimbursement is the compensation paid to the owner of a Designated Blackstart Resource as specified in Section 5.5 of Schedule 16 to the OATT.

Equivalent Demand Forced Outage Rate (EFORd) means the portion of time a unit is in demand, but is unavailable due to forced outages.

Estimated Capacity Load Obligation is, for the purposes of the ISO New England Financial Assurance Policy, a Market Participant's share of Zonal Capacity Obligation from the latest available month, adjusted as appropriate to account for any relevant Capacity Load Obligation Bilaterals, HQICCs, and Self-Supplied FCA Resource designations for the applicable month.

Establish Claimed Capability Audit is the audit performed pursuant to Section III.1.5.1.2.

Excepted Transaction is a transaction specified in Section II.40 of the Tariff for the applicable period specified in that Section.

Existing Capacity Qualification Deadline is a deadline, specified in Section III.13.1.10 of Market Rule 1, for submission of certain qualification materials for the Forward Capacity Auction, as discussed in Section III.13.1 of Market Rule 1.

Existing Capacity Qualification Package is information submitted for certain existing resources prior to participation in the Forward Capacity Auction, as described in Section III.13.1 of Market Rule 1.

Existing Capacity Resource is any resource that does not meet any of the eligibility criteria to participate in the Forward Capacity Auction as a New Capacity Resource.

Existing Capacity Retirement Deadline is a deadline, specified in Section III.13.1.10 of Market Rule 1, for submission of certain qualification materials for the Forward Capacity Auction, as discussed in Section III.13.1 of Market Rule 1.

Existing Capacity Retirement Package is information submitted for certain existing resources prior to participation in the Forward Capacity Auction, as described in Section III.13.1 of Market Rule 1.

Existing Demand Capacity Resource is a type of Demand Capacity Resource participating in the Forward Capacity Market, as defined in Section III.13.1.4.2 of Market Rule 1.

Existing Generating Capacity Resource is a type of resource participating in the Forward Capacity Market, as defined in Section III.13.1.2.1 of Market Rule 1.

Existing Import Capacity Resource is a type of resource participating in the Forward Capacity Market, as defined in Section III.13.1.3.1 of Market Rule 1.

Expedited Study Request is defined in Section II.34.7 of the OATT.

Export-Adjusted LSR is as defined in Section III.12.4(b)(ii).

Export Bid is a bid that may be submitted by certain resources in the Forward Capacity Auction to export capacity to an external Control Area, as described in Section III.13.1.2.3.1.3 of Market Rule 1.

Exports are Real-Time External Transactions, which are limited to sales from the New England Control Area, for exporting energy out of the New England Control Area.

External Elective Transmission Upgrade (External ETU) is defined in Section I of Schedule 25 of the OATT.

External Market Monitor means the person or entity appointed by the ISO Board of Directors pursuant to Section III.A.1.2 of Appendix A of Market Rule 1 to carry out the market monitoring and mitigation functions specified in Appendix A and elsewhere in Market Rule 1.

External Node is a proxy bus or buses used for establishing a Locational Marginal Price for energy received by Market Participants from, or delivered by Market Participants to, a neighboring Control Area or for establishing Locational Marginal Prices associated with energy delivered through the New England Control Area by Non-Market Participants for use in calculating Non-Market Participant Congestion Costs and loss costs.

External Resource means a generation resource located outside the metered boundaries of the New England Control Area.

External Transaction is the import of external energy into the New England Control Area by a Market Participant or the export of internal energy out of the New England Control Area by a Market Participant in the Day-Ahead Energy Market and/or Real-Time Energy Market, or the wheeling of external energy through the New England Control Area by a Market Participant or a Non-Market Participant in the Real-Time Energy Market.

External Transaction Cap is $2,000/MWh for External Transactions other than Coordinated External Transactions and $1,000/MWh for Coordinated External Transactions.

External Transaction Floor is the Energy Offer Floor for External Transactions other than Coordinated External Transactions and negative $1,000/MWh for Coordinated External Transactions.

External Transmission Project is a transmission project comprising facilities located wholly outside the New England Control Area and regarding which an agreement has been reached whereby New England ratepayers will support all or a portion of the cost of the facilities.

Facilities Study is an engineering study conducted pursuant to the OATT by the ISO (or, in the case of Local Service or interconnections to Local Area Facilities as defined in the TOA, by one or more affected PTOs) or some other entity designated by the ISO in consultation with any affected Transmission Owner(s), to determine the required modifications to the PTF and Non-PTF, including the cost and scheduled completion date for such modifications, that will be required to provide a requested transmission service or interconnection on the PTF and Non-PTF.

Facility and Equipment Testing means operation of a Resource to evaluate the functionality of the facility or equipment utilized in the operation of the facility.

Failure to Maintain Blackstart Capability is a failure of a Blackstart Owner or Designated Blackstart Resource to meet the Blackstart Service Minimum Criteria or Blackstart Service obligations, but does not include a Failure to Perform During a System Restoration event.

Failure to Perform During a System Restoration is a failure of a Blackstart Owner or Designated Blackstart Resource to follow ISO or Local Control Center dispatch instructions or perform in accordance with the dispatch instructions or the Blackstart Service Minimum Criteria and Blackstart Service obligations, described within the ISO New England Operating Documents, during a restoration of the New England Transmission System.

Fast Start Demand Response Resource is a Demand Response Resource that meets the following criteria: (i) Minimum Reduction Time does not exceed one hour; (ii) Minimum Time Between Reductions does not exceed one hour; (iii) Demand Response Resource Start-Up Time plus Demand Response

Resource Notification Time does not exceed 30 minutes; (iv) has personnel available to respond to Dispatch Instructions or has automatic remote response capability; and (v) is capable of receiving and acknowledging a Dispatch Instruction electronically.

Fast Start Generator means a Generator Asset that the ISO can dispatch to an on-line or off-line state through electronic dispatch and that meets the following criteria: (i) Minimum Run Time does not exceed one hour; (ii) Minimum Down Time does not exceed one hour; (iii) cold Notification Time plus cold Start-Up Time does not exceed 30 minutes; (iv) available for dispatch (when it is either in an on-line or off-line state) and manned or has automatic remote dispatch capability; and (v) capable of receiving and acknowledging a start-up or shut-down Dispatch Instruction electronically.

FCA Cleared Export Transaction is defined in Section III.1.10.7(f)(ii) of Market Rule 1.

FCA Qualified Capacity is the Qualified Capacity that is used in a Forward Capacity Auction.

FCM Capacity Charge Requirements are calculated in accordance with Section VII.C of the ISO New England Financial Assurance Policy.

FCM Charge Rate is calculated in accordance with Section VII.C of the ISO New England Financial Assurance Policy.

FCM Commercial Operation is defined in Section III.13.3.8 of Market Rule 1.

FCM Deposit is calculated in accordance with Section VII.B.1 of the ISO New England Financial Assurance Policy.

FCM Financial Assurance Requirements are described in Section VII of the ISO New England Financial Assurance Policy.

Final Forward Reserve Obligation is calculated in accordance with Section III.9.8(a) of Market Rule 1.

Financial Assurance Default results from a Market Participant or Non-Market Participant Transmission Customer's failure to comply with the ISO New England Financial Assurance Policy.

Financial Assurance Obligations relative to the ISO New England Financial Assurance Policy are determined in accordance with Section III.A(v) of the ISO New England Financial Assurance Policy.

Financial Transmission Right (FTR) is a financial instrument that evidences the rights and obligations specified in Sections III.5.2.2 and III.7 of the Tariff.

Firm Point-To-Point Service is service which is arranged for and administered between specified Points of Receipt and Delivery in accordance with Part II.C of the OATT.

Firm Transmission Service is Regional Network Service, Through or Out Service, service for Excepted Transactions, firm MTF Service, firm OTF Service, and firm Local Service.

Flexible DNE Dispatchable Generator is any DNE Dispatchable Generator that meets the following criteria: (i) Minimum Run Time does not exceed one hour; (ii) Minimum Down Time does not exceed one hour; and (iii) cold Notification Time plus cold Start-Up Time does not exceed 30 minutes.

Force Majeure - An event of Force Majeure means any act of God, labor disturbance, act of the public enemy or terrorists, war, invasion, insurrection, riot, fire, storm or flood, ice, explosion, breakage or accident to machinery or equipment, any curtailment, order, regulation or restriction imposed by governmental military or lawfully established civilian authorities, or any other cause beyond the control of the ISO, a Transmission Owner, a Schedule 20A Service Provider, or a Customer, including without limitation, in the case of the ISO, any action or inaction by a Customer, a Schedule 20A Service Provider, or a Transmission Owner, in the case of a Transmission Owner, any action or inaction by the ISO, any Customer, a Schedule 20A Service Provider, or any other Transmission Owner, in the case of a Schedule 20A Service Provider, any action or inaction by the ISO, any Customer, a Transmission Owner, or any other Schedule 20A Service Provider, and, in the case of a Transmission Customer, any action or inaction by the ISO, a Schedule 20A Service Provider, or any Transmission Owner.

Formal Warning is defined in Section III.B.4.1.1 of Appendix B of Market Rule 1.

Formula-Based Sanctions are defined in Section III.B.4.1.3 of Appendix B of Market Rule 1.

Forward Capacity Auction (FCA) is the annual Forward Capacity Market auction process described in Section III.13.2 of Market Rule 1.

Forward Capacity Auction Starting Price is calculated in accordance with Section III.13.2.4 of Market Rule 1.

Forward Capacity Market (FCM) is the forward market for procuring capacity in the New England Control Area, as described in Section III.13 of Market Rule 1.

Forward Energy Inventory Election is the total MWh value for which a Market Participant elects to be compensated at the forward rate in the inventoried energy program as described in Section III.K.1(d) of Market Rule 1.

Forward LNG Inventory Election is the portion of a Market Participant's Forward Energy Inventory Election attributed to liquefied natural gas in the inventoried energy program as described in Section III.K.1(d) of Market Rule 1.

Forward Reserve means TMNSR and TMOR purchased by the ISO on a forward basis on behalf of Market Participants as provided for in Section III.9 of Market Rule 1.

Forward Reserve Assigned Megawatts is the amount of Forward Reserve, in megawatts, that a Market Participant assigns to eligible Forward Reserve Resources to meet its Forward Reserve Obligation as defined in Section III.9.4.1 of Market Rule 1.

Forward Reserve Auction is the periodic auction conducted by the ISO in accordance with Section III.9 of Market Rule 1 to procure Forward Reserve.

Forward Reserve Auction Offers are offers to provide Forward Reserve to meet system and Reserve Zone requirements as submitted by a Market Participant in accordance with Section III.9.3 of Market Rule 1.

Forward Reserve Charge is a Market Participant's share of applicable system and Reserve Zone Forward Reserve costs attributable to meeting the Forward Reserve requirement as calculated in accordance with Section III.9.9 of Market Rule 1.

Forward Reserve Clearing Price is the clearing price for TMNSR or TMOR, as applicable, for the system and each Reserve Zone resulting from the Forward Reserve Auction as defined in Section III.9.4 of Market Rule 1.

Forward Reserve Credit is the credit received by a Market Participant that is associated with that Market Participant's Final Forward Reserve Obligation as calculated in accordance with Section III.9.8 of Market Rule 1.

Forward Reserve Delivered Megawatts are calculated in accordance with Section III.9.6.5 of Market Rule 1.

Forward Reserve Delivery Period is defined in Section III.9.1 of Market Rule 1.

Forward Reserve Failure-to-Activate Megawatts are calculated in accordance with Section III.9.7.2(a) of Market Rule 1.

Forward Reserve Failure-to-Activate Penalty is the penalty associated with a Market Participant's failure to activate Forward Reserve when requested to do so by the ISO and is defined in Section III.9.7.2 of Market Rule 1.

Forward Reserve Failure-to-Activate Penalty Rate is specified in Section III.9.7.2 of Market Rule 1.

Forward Reserve Failure-to-Reserve, as specified in Section III.9.7.1 of Market Rule 1, occurs when a Market Participant's Forward Reserve Delivered Megawatts for a Reserve Zone in an hour is less than that Market Participant's Forward Reserve Obligation for that Reserve Zone in that hour. Under these circumstances the Market Participant pays a penalty based upon the Forward Reserve Failure-to-Reserve Penalty Rate and that Market Participant's Forward Reserve Failure-to-Reserve Megawatts.

Forward Reserve Failure-to-Reserve Megawatts are calculated in accordance with Section III.9.7.1(a) of Market Rule 1.

Forward Reserve Failure-to-Reserve Penalty is the penalty associated with a Market Participant's failure to reserve Forward Reserve and is defined in Section III.9.7.1 of Market Rule 1.

Forward Reserve Failure-to-Reserve Penalty Rate is specified in Section III.9.7.1(b)(ii) of Market Rule 1.

Forward Reserve Fuel Index is the index or set of indices used to calculate the Forward Reserve Threshold Price as defined in Section III.9.6.2 of Market Rule 1.

Forward Reserve Heat Rate is the heat rate as defined in Section III.9.6.2 of Market Rule 1 that is used to calculate the Forward Reserve Threshold Price.

Forward Reserve Market is a market for forward procurement of two reserve products, Ten-Minute Non-Spinning Reserve (TMNSR) and Thirty-Minute Operating Reserve (TMOR).

Forward Reserve MWs are those megawatts assigned to specific eligible Forward Reserve Resources which convert a Forward Reserve Obligation into a Resource-specific obligation.

Forward Reserve Obligation is a Market Participant's amount, in megawatts, of Forward Reserve that cleared in the Forward Reserve Auction and adjusted, as applicable, to account for bilateral transactions that transfer Forward Reserve Obligations.

Forward Reserve Obligation Charge is defined in Section III.10.4 of Market Rule 1.

Forward Reserve Offer Cap is $9,000/megawatt-month.

Forward Reserve Payment Rate is defined in Section III.9.8 of Market Rule 1.

Forward Reserve Procurement Period is defined in Section III.9.1 of Market Rule 1.

Forward Reserve Qualifying Megawatts refer to all or a portion of a Forward Reserve Resource's capability offered into the Real-Time Energy Market at energy offer prices above the applicable Forward Reserve Threshold Price that are calculated in accordance with Section III.9.6.4 of Market Rule 1.

Forward Reserve Resource is a Resource that meets the eligibility requirements defined in Section III.9.5.2 of Market Rule 1 that has been assigned Forward Reserve Obligation by a Market Participant.

Forward Reserve Threshold Price is the minimum price at which assigned Forward Reserve Megawatts are required to be offered into the Real-Time Energy Market as calculated in Section III.9.6.2 of Market Rule 1.

FTR Auction is the periodic auction of FTRs conducted by the ISO in accordance with Section III.7 of Market Rule 1.

FTR Auction Revenue is the revenue collected from the sale of FTRs in FTR Auctions. FTR Auction Revenue is payable to FTR Holders who submit their FTRs for sale in the FTR Auction in accordance with Section III.7 of Market Rule 1 and to ARR Holders and Incremental ARR Holders in accordance with Appendix C of Market Rule 1.

FTR Credit Test Percentage is calculated in accordance with Section III.B.1(b) of the ISO New England Financial Assurance Policy.

FTR Financial Assurance Requirements are described in Section VI of the ISO New England Financial Assurance Policy.

FTR Holder is an entity that acquires an FTR through the FTR Auction to Section III.7 of Market Rule 1 and registers with the ISO as the holder of the FTR in accordance with Section III.7 of Market Rule 1 and applicable ISO New England Manuals.

FTR-Only Customer is a Market Participant that transacts in the FTR Auction and that does not participate in other markets or programs of the New England Markets. References in this Tariff to a "Non-Market Participant FTR Customers" and similar phrases shall be deemed references to an FTR-Only Customer.

FTR Settlement Risk Financial Assurance is an amount of financial assurance required by a Designated FTR Participant for each bid submission into an FTR Auction and for each bid awarded to the individual participant in an FTR Auction. This amount is calculated pursuant to Section VI.A of the ISO New England Financial Assurance Policy.

GADS Data means data submitted to the NERC for collection into the NERC's Generating Availability Data System (GADS).

Gap Request for Proposals (Gap RFP) is defined in Section III.11 of Market Rule 1.

Gas Day means a period of 24 consecutive hours beginning at 0900 hrs Central Time.

Generating Capacity Resource means a New Generating Capacity Resource or an Existing Generating Capacity Resource.

Generator Asset is a device (or a collection of devices) that is capable of injecting real power onto the grid that has been registered as a Generator Asset in accordance with the Asset Registration Process.

Generator Imbalance Service is the form of Ancillary Service described in Schedule 10 of the OATT.

Generator Interconnection Related Upgrade is an addition to or modification of the New England Transmission System (pursuant to Section II.47.1, Schedule 22 or Schedule 23 of the OATT) to effect the interconnection of a new generating unit or an existing generating unit whose energy capability or capacity capability is being materially changed and increased whether or not the interconnection is being effected to meet the Capacity Capability Interconnection Standard or the Network Capability Interconnection Standard. As to Category A Projects (as defined in Schedule 11 of the OATT), a Generator Interconnection Related Upgrade also includes an upgrade beyond that required to satisfy the Network Capability Interconnection Standard (or its predecessor) for which the Generator Owner has committed to pay prior to October 29, 1998.

Generator Owner is the owner, in whole or part, of a generating unit whether located within or outside the New England Control Area.

Good Utility Practice means any of the practices, methods and acts engaged in or approved by a significant portion of the electric utility industry during the relevant time period, or any of the practices, methods and acts which, in the exercise of reasonable judgment in light of the facts known at the time the decision was made, could have been expected to accomplish the desired result at a reasonable cost consistent with good business practices, reliability, safety and expedition. Good Utility Practice is not intended to be limited to the optimum practice, method, or act to the exclusion of all others, but rather includes all acceptable practices, methods, or acts generally accepted in the region, including those practices required by Federal Power Act Section 215(a)(4).

Governance Only Member is defined in Section 1 of the Participants Agreement.

Governance Participant is defined in the Participants Agreement.

Governing Documents, for the purposes of the ISO New England Billing Policy, are the Transmission, Markets and Services Tariff and ISO Participants Agreement.

Governing Rating is the lowest corporate rating from any Rating Agency for that Market Participant, or, if the Market Participant has no corporate rating, then the lowest rating from any Rating Agency for that Market Participant's senior unsecured debt.

Grandfathered Agreements (GAs) is a transaction specified in Section II.45 for the applicable period specified in that Section.

Grandfathered Intertie Agreement (GIA) is defined pursuant to the TOA.

Handy-Whitman Index of Public Utility Construction Costs is the Total Other Production Plant index shown in the Cost Trends of Electric Utility Construction for the North Atlantic Region as published in the Handy-Whitman Index of Public Utility Construction Costs.

Highgate Transmission Facilities (HTF) are existing U. S.-based transmission facilities covered under the Agreement for Joint Ownership, Construction and Operation of the Highgate Transmission Interconnection dated as of August 1, 1984 including (1) the whole of a 200 megawatt high-voltage, back-to-back, direct-current converter facility located in Highgate, Vermont and (2) a 345 kilovolt transmission line within Highgate and Franklin, Vermont (which connects the converter facility at the U.S.-Canadian border to a Hydro-Quebec 120 kilovolt line in Bedford, Quebec). The HTF include any upgrades associated with increasing the capacity or changing the physical characteristics of these facilities as defined in the above stated agreement dated August 1, 1984 until the Operations Date, as defined in the TOA. The current HTF rating is a nominal 225 MW. The HTF are not defined as PTF. Coincident with the Operations Date and except as stipulated in Schedules, 9, 12, and Attachment F to the OATT, HTF shall be treated in the same manner as PTF for purposes of the OATT and all references to PTF in the OATT shall be deemed to apply to HTF as well. The treatment of the HTF is not intended to establish any binding precedent or presumption with regard to the treatment for other transmission facilities within

the New England Transmission System (including HVDC, MTF, or Control Area Interties) for purposes of the OATT.

Host Participant or Host Utility is a Market Participant or a Governance Participant transmission or distribution provider that reconciles the loads within the metering domain with OP-18 compliant metering.

Hourly Charges are defined in Section 1.3 of the ISO New England Billing Policy.

Hourly PER is calculated in accordance with Section III.13.7.1.2.1 of Market Rule 1.

Hourly Requirements are determined in accordance with Section III.A(i) of the ISO New England Financial Assurance Policy.

Hourly Shortfall NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Hub is a specific set of pre-defined Nodes for which a Locational Marginal Price will be calculated for the Day-Ahead Energy Market and Real-Time Energy Market and which can be used to establish a reference price for energy purchases and the transfer of Day-Ahead Adjusted Load Obligations and Real-Time Adjusted Load Obligations and for the designation of FTRs.

Hub Price is calculated in accordance with Section III.2.8 of Market Rule 1.

HQ Interconnection Capability Credit (HQICC) is a monthly value reflective of the annual installed capacity benefits of the Phase I/II HVDC-TF, as determined by the ISO, using a standard methodology on file with the Commission, in conjunction with the setting of the Installed Capacity Requirement. An appropriate share of the HQICC shall be assigned to an IRH if the Phase I/II HVDC-TF support costs are paid by that IRH and such costs are not included in the calculation of the Regional Network Service rate. The share of HQICC allocated to such an eligible IRH for a month is the sum in kilowatts of (1)(a) the IRH's percentage share, if any, of the Phase I Transfer Capability times (b) the Phase I Transfer Credit, plus (2)(a) the IRH's percentage share, if any, of the Phase II Transfer Capability, times (b) the Phase II Transfer Credit. The ISO shall establish appropriate HQICCs to apply for an IRH which has such a percentage share.

Import Capacity Resource means an Existing Import Capacity Resource or a New Import Capacity Resource offered to provide capacity in the New England Control Area from an external Control Area.

Inadvertent Energy Revenue is defined in Section III.3.2.1(o) of Market Rule 1.

Inadvertent Energy Revenue Charges or Credits is defined in Section III.3.2.1(p) of Market Rule 1.

Inadvertent Interchange means the difference between net actual energy flow and net scheduled energy flow into or out of the New England Control Area.

Increment Offer means an offer to sell energy at a specified Location in the Day-Ahead Energy Market which is not associated with a physical supply. An accepted Increment Offer results in scheduled supply at the specified Location in the Day-Ahead Energy Market.

Incremental ARR is an ARR provided in recognition of a participant-funded transmission system upgrade pursuant to Appendix C of this Market Rule.

Incremental ARR Holder is an entity which is the record holder of an Incremental Auction Revenue Right in the register maintained by the ISO.

Incremental Cost of Reliability Service is described in Section III.13.2.5.2.5.2 of Market Rule 1.

Independent Transmission Company (ITC) is a transmission entity that assumes certain responsibilities in accordance with Section 10.05 of the Transmission Operating Agreement and Attachment M to the OATT, subject to the acceptance or approval of the Commission and a finding of the Commission that the transmission entity satisfies applicable independence requirements.

Information Request is a request from a potential Disputing Party submitted in writing to the ISO for access to Confidential Information.

Initial Market Participant Financial Assurance Requirement is calculated for new Market Participants and Returning Market Participants, other than an FTR-Only Customer or a Governance Only Member, according to Section IV of the ISO New England Financial Assurance Policy.

Initial State of Charge is the State of Charge that an Electric Storage Facility offers at the start of hour one of the Day-Ahead Energy Market.

Installed Capacity Requirement means the level of capacity required to meet the reliability requirements defined for the New England Control Area, as described in Section III.12 of Market Rule 1.

Interchange Transactions are transactions deemed to be effected under Market Rule 1.

Interconnecting Transmission Owner has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Interconnection Agreement is the "Large Generator Interconnection Agreement", the "Small Generator Interconnection Agreement", or the "Elective Transmission Upgrade Interconnection Agreement" pursuant to Schedules 22, 23 or 25 of the ISO OATT or an interconnection agreement approved by the Commission prior to the adoption of the Interconnection Procedures.

Interconnection Customer has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Interconnection Feasibility Study Agreement has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, or Section I of Schedule 25 of the OATT.

Interconnection Procedure is the "Large Generator Interconnection Procedures", the "Small Generator Interconnection Procedures", or the "Elective Transmission Upgrade Interconnection Procedures" pursuant to Schedules 22, 23, and 25 of the ISO OATT.

Interconnection Reliability Operating Limit (IROL) has the meaning specified in the Glossary of Terms Used in NERC Reliability Standards.

Interconnection Request has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, or Section I of Schedule 25 of the OATT.

Interconnection Rights Holder(s) (IRH) has the meaning given to it in Schedule 20A to Section II of this Tariff.

Interconnection System Impact Study Agreement has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23 and Section I of Schedule 25 of the OATT.

Interest is interest calculated in the manner specified in Section II.8.3.

Interface Bid is a unified real-time bid to simultaneously purchase and sell energy on each side of an external interface for which the enhanced scheduling procedures in Section III.1.10.7.A are implemented.

Intermittent Power Resource is a wind, solar, run of river hydro or other renewable resource that does not have control over its net power output.

Internal Bilateral for Load is an internal bilateral transaction under which the buyer receives a reduction in Real-Time Load Obligation and the seller receives a corresponding increase in Real-Time Load Obligation in the amount of the sale, in MWs. An Internal Bilateral for Load transaction is only applicable in the Real-Time Energy Market.

Internal Bilateral for Market for Energy is an internal bilateral transaction for Energy which applies in the Day-Ahead Energy Market and Real-Time Energy Market or just the Real-Time Energy Market under which the buyer receives a reduction in Day-Ahead Adjusted Load Obligation and Real-Time Adjusted Load Obligation and the seller receives a corresponding increase in Day-Ahead Adjusted Load Obligation and Real-Time Adjusted Load Obligation in the amount of the sale, in MWs.

Internal Elective Transmission Upgrade (Internal ETU) is defined in Section I of Schedule 25 of the OATT.

Internal Market Monitor means the department of the ISO responsible for carrying out the market monitoring and mitigation functions specified in Appendix A and elsewhere in Market Rule 1.

Interregional Planning Stakeholder Advisory Committee (IPSAC) is the committee described as such in the Northeast Planning Protocol.

Interregional Transmission Project is a transmission project located within the New England Control Area and one or more of the neighboring transmission planning regions.

Interruption Cost is the amount, in dollars, that must be paid to a Market Participant each time the Market Participant's Demand Response Resource is scheduled or dispatched in the New England Markets to reduce demand.

Inventoried Energy Day is an Operating Day that occurs in the months of December, January, or February during the winters of 2023-2024 and 2024-2025 (inventoried energy program) and for which the average of the high temperature and the low temperature on that Operating Day, as measured and reported by the National Weather Service at Bradley International Airport in Windsor Locks, Connecticut, is less than or equal to 17 degrees Fahrenheit, as described in Section III.K.3.1 of Market Rule 1.

Investment Grade Rating, for a Market (other than an FTR-Only Customer) or Non-Market Participant Transmission Customer, is either (a) a corporate investment grade rating from one or more of the Rating Agencies, or (b) if the Market Participant or Non-Market Participant Transmission Customer does not have a corporate rating from one of the Rating Agencies, then an investment grade rating for the Market Participant's or Non-Market Participant Transmission Customer's senior unsecured debt from one or more of the Rating Agencies.

Invoice is a statement issued by the ISO for the net Charge owed by a Covered Entity pursuant to the ISO New England Billing Policy.

Invoice Date is the day on which the ISO issues an Invoice.

ISO means ISO New England Inc.

ISO Charges, for the purposes of the ISO New England Billing Policy, are both Non-Hourly Charges and Hourly Charges.

ISO Control Center is the primary control center established by the ISO for the exercise of its Operating Authority and the performance of functions as an RTO.

ISO-Initiated Claimed Capability Audit is the audit performed pursuant to Section III.1.5.1.4.

ISO New England Administrative Procedures means procedures adopted by the ISO to fulfill its responsibilities to apply and implement ISO New England System Rules.

ISO New England Billing Policy is Exhibit ID to Section I of the Transmission, Markets and Services Tariff.

ISO New England Filed Documents means the Transmission, Markets and Services Tariff, including but not limited to Market Rule 1, the Participants Agreement, the Transmission Operating Agreement or other documents that affect the rates, terms and conditions of service.

ISO New England Financial Assurance Policy is Exhibit IA to Section I of the Transmission, Markets and Services Tariff.

ISO New England Information Policy is the policy establishing guidelines regarding the information received, created and distributed by Market Participants and the ISO in connection with the settlement, operation and planning of the System, as the same may be amended from time to time in accordance with the provisions of this Tariff. The ISO New England Information Policy is Attachment D to the Transmission, Markets and Services Tariff.

ISO New England Manuals are the manuals implementing Market Rule 1, as amended from time to time in accordance with the Participants Agreement. Any elements of the ISO New England Manuals that substantially affect rates, terms, and/or conditions of service shall be filed with the Commission under Section 205 of the Federal Power Act.

ISO New England Operating Documents are the Tariff and the ISO New England Operating Procedures.

ISO New England Operating Procedures (OPs) are the ISO New England Planning Procedures and the operating guides, manuals, procedures and protocols developed and utilized by the ISO for operating the ISO bulk power system and the New England Markets.

ISO New England Planning Procedures are the procedures developed and utilized by the ISO for planning the ISO bulk power system.

ISO New England System Rules are Market Rule 1, the ISO New England Information Policy, the ISO New England Administrative Procedures, the ISO New England Manuals and any other system rules, procedures or criteria for the operation of the New England Transmission System and administration of the New England Markets and the Transmission, Markets and Services Tariff.

ITC Agreement is defined in Attachment M to the OATT.

ITC Rate Schedule is defined in Section 3.1 of Attachment M to the OATT.

ITC System is defined in Section 2.2 of Attachment M to the OATT.

ITC System Planning Procedures is defined in Section 15.4 of Attachment M to the OATT.

Joint ISO/RTO Planning Committee (JIPC) is the committee described as such in the Northeastern Planning Protocol.

Late Payment Account is a segregated interest-bearing account into which the ISO deposits Late Payment Charges due from ISO Charges and interest owed from participants for late payments that are collected and not distributed to the Covered Entities, until the Late Payment Account Limit is reached, under the ISO New England Billing Policy and penalties collected under the ISO New England Financial Assurance Policy.

Late Payment Account Limit is defined in Section 4.2 of the ISO New England Billing Policy.

Late Payment Charge is defined in Section 4.1 of the ISO New England Billing Policy.

Lead Market Participant, for purposes other than the Forward Capacity Market, is the entity authorized to submit Supply Offers, Demand Bids or Demand Reduction Offers for a Resource and to whom certain Energy TUs are assessed under Schedule 2 of Section IV.A of the Tariff. For purposes of the Forward Capacity Market, the Lead Market Participant is the entity designated to participate in that market on behalf of an Existing Capacity Resource or a New Capacity Resource.

Limited Energy Resource means a Generator Asset that, due to design considerations, environmental restriction on operations, cyclical requirements, such as the need to recharge or refill or manage water flow, or fuel limitations, are unable to operate continuously at full output on a daily basis.

Load Asset means a physical load that has been registered in accordance with the Asset Registration Process. A Load Asset can be an Asset Related Demand, including a Dispatchable Asset Related Demand.

Load Management means measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that curtail electrical usage or shift electrical usage while delivering a comparable or acceptable level of end-use service. Such measures include, but are not limited to, energy management systems, load control end-use cycling, load curtailment strategies, and energy storage that curtails or shifts electrical usage by means other than generating electricity.

Load Shedding is the systematic reduction of system demand by temporarily decreasing load.

Load Zone is a Reliability Region, except as otherwise provided for in Section III.2.7 of Market Rule 1.

Local Area Facilities are defined in the TOA**.**

Local Benefit Upgrade(s) (LBU) is an upgrade, modification or addition to the transmission system that is: (i) rated below 115kV or (ii) rated 115kV or above and does not meet all of the non-voltage criteria for PTF classification specified in the OATT.

Local Control Centers are those control centers in existence as of the effective date of the OATT (including the CONVEX, REMVEC, Maine and New Hampshire control centers) or established by the PTOs in accordance with the TOA that are separate from the ISO Control Center and perform certain functions in accordance with the OATT and the TOA.

Local Delivery Service is the service of delivering electric energy to end users. This service is subject to state jurisdiction regardless of whether such service is provided over local distribution or transmission facilities. An entity that is an Eligible Customer under the OATT is not excused from any requirements of state law, or any order or regulation issued pursuant to state law, to arrange for Local Delivery Service

with the Participating Transmission Owner and/or distribution company providing such service and to pay all applicable charges associated with such service, including charges for stranded costs and benefits.

Local Network is defined as the transmission facilities constituting a local network as identified in Attachment E, as such Attachment may be modified from time to time in accordance with the Transmission Operating Agreement.

Local Network Load is the load that a Network Customer designates for Local Network Service under Schedule 21 to the OATT.

Local Network RNS Rate is the rate applicable to Regional Network Service to effect a delivery to load in a particular Local Network, as determined in accordance with Schedule 9 to the OATT.

Local Network Service (LNS) is the network service provided under Schedule 21 and the Local Service Schedules to permit the Transmission Customer to efficiently and economically utilize its resources to serve its load.

Local Point-To-Point Service (LPTP) is Point-to-Point Service provided under Schedule 21 of the OATT and the Local Service Schedules to permit deliveries to or from an interconnection point on the PTF.

Local Public Policy Transmission Upgrade is any addition and/or upgrade to the New England Transmission System with a voltage level below 115kV that is required in connection with the construction of a Public Policy Transmission Upgrade approved for inclusion in the Regional System Plan pursuant to Attachment K to the ISO OATT or included in a Local System Plan in accordance with Appendix 1 to Attachment K.

Local Resource Adequacy Requirement is calculated pursuant to Section III.12.2.1.1.

Local Second Contingency Protection Resources are those Resources identified by the ISO on a daily basis as necessary for the provision of Operating Reserve requirements and adherence to NERC, NPCC and ISO reliability criteria over and above those Resources required to meet first contingency reliability criteria within a Reliability Region.

Local Service is transmission service provided under Schedule 21 and the Local Service Schedules thereto.

Local Service Schedule is a PTO-specific schedule to the OATT setting forth the rates, charges, terms and conditions applicable to Local Service.

Local Sourcing Requirement (LSR) is a value calculated as described in Section III.12.2.1 of Market Rule 1.

Local System Planning (LSP) is the process defined in Appendix 1 of Attachment K to the OATT.

Localized Costs are costs that the ISO, with advisory input from the Reliability Committee, determines in accordance with Schedule 12C of the OATT shall not be included in the Pool-Supported PTF costs recoverable under this OATT, or in costs allocated to Regional Network Load according to Section 6 of Schedule 12. If there are any Localized Costs, the ISO shall identify them in the Regional System Plan.

Location is a Node, External Node, Load Zone, DRR Aggregation Zone, or Hub.

Locational Marginal Price (LMP) is defined in Section III.2 of Market Rule 1. The Locational Marginal Price for a Node is the nodal price at that Node; the Locational Marginal Price for an External Node is the nodal price at that External Node; the Locational Marginal Price for a Load Zone, DRR Aggregation Zone or Reliability Region is the Zonal Price for that Load Zone, DRR Aggregation Zone or Reliability Region, respectively; and the Locational Marginal Price for a Hub is the Hub Price for that Hub.

Long Lead Time Facility (Long Lead Facility) has the meaning specified in Section I of Schedule 22 and Schedule 25 of the OATT.

Long-Term is a term of one year or more.

Long-Term Transmission Outage is a long-term transmission outage scheduled in accordance with ISO New England Operating Procedure No. 3.

Loss Component is the component of the nodal LMP at a given Node or External Node on the PTF that reflects the cost of losses at that Node or External Node relative to the reference point. The Loss Component of the nodal LMP at a given Node on the non-PTF system reflects the relative cost of losses at that Node adjusted as required to account for losses on the non-PTF system already accounted for through tariffs associated with the non-PTF. When used in connection with Hub Price or Zonal Price, the term Loss Component refers to the Loss Components of the nodal LMPs that comprise the Hub Price or Zonal Price, which Loss Components are averaged or weighted in the same way that nodal LMPs are averaged to determine Hub Price or weighted to determine Zonal Price.

Loss of Load Expectation (LOLE) is the probability of disconnecting non-interruptible customers due to a resource deficiency.

Lost Opportunity Cost (LOC) is one of four forms of compensation that may be paid to resources providing VAR Service under Schedule 2 of the OATT.

LSE means load serving entity.

Lump Sum Blackstart Payment is defined and calculated as specified in Section 5.4 of Schedule 16 to the OATT.

Lump Sum Blackstart Capital Payment is defined and calculated as specified in Section 5.4 of Schedule 16 to the OATT.

Manual Response Rate is the rate, in MW/Minute, at which the output of a Generator Asset, or the consumption of a Dispatchable Asset Related Demand, is capable of changing.

Marginal Loss Revenue Load Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Marginal Reliability Impact is the change, with respect to an increment of capacity supply, in expected unserved energy due to resource deficiency, as measured in hours per year.

Market Credit Limit is a credit limit for a Market Participant's Financial Assurance Obligations (except FTR Financial Assurance Requirements) established for each Market Participant in accordance with Section II.C of the ISO New England Financial Assurance Policy.

Market Credit Test Percentage is calculated in accordance with Section III.B.1(a) of the ISO New England Financial Assurance Policy.

Market Efficiency Transmission Upgrade is defined as those additions and upgrades that are not related to the interconnection of a generator, and, in the ISO's determination, are designed to reduce bulk power system costs to load system-wide, where the net present value of the reduction in bulk power system costs to load system-wide exceeds the net present value of the cost of the transmission addition or upgrade. For purposes of this definition, the term "bulk power system costs to load system-wide" includes, but is not limited to, the costs of energy, capacity, reserves, losses and impacts on bilateral prices for electricity.

Market Participant is a participant in the New England Markets (including a FTR-Only Customer) that has executed a Market Participant Service Agreement, or on whose behalf an unexecuted Market Participant Service Agreement has been filed with the Commission.

Market Participant Financial Assurance Requirement is defined in Section III of the ISO New England Financial Assurance Policy.

Market Participant Obligations is defined in Section III.B.1.1 of Appendix B of Market Rule 1.

Market Participant Service Agreement (MPSA) is an agreement between the ISO and a Market Participant, in the form specified in Attachment A or Attachment A-1 to the Tariff, as applicable.

Market Rule 1 is ISO Market Rule 1 and appendices set forth in Section III of this ISO New England Inc. Transmission, Markets and Services Tariff, as it may be amended from time to time.

Market Violation is a tariff violation, violation of a Commission-approved order, rule or regulation, market manipulation, or inappropriate dispatch that creates substantial concerns regarding unnecessary market inefficiencies.

Material Adverse Change is any change in financial status including, but not limited to a downgrade to below an Investment Grade Rating by any Rating Agency, being placed on credit watch with negative implication by any Rating Agency if the Market Participant or Non-Market Participant Transmission

Customer does not have an Investment Grade Rating, a bankruptcy filing or other insolvency, a report of a significant quarterly loss or decline of earnings, the resignation of key officer(s), the sanctioning of the Market Participant or Non-Market Participant Transmission Customer or any of its Principles imposed by the Federal Energy Regulatory Commission, the Securities Exchange Commission, any exchange monitored by the National Futures Association, or any state entity responsible for regulating activity in energy markets; the filing of a material lawsuit that could materially adversely impact current or future financial results; a significant change in the Market Participant's or Non-Market Participant Transmission Customer's credit default spreads; or a significant change in market capitalization.

Material Adverse Impact is defined, for purposes of review of ITC-proposed plans, as a proposed facility or project will be deemed to cause a "material adverse impact" on facilities outside of the ITC System if: (i) the proposed facility or project causes non-ITC facilities to exceed their capabilities or exceed their thermal, voltage or stability limits, consistent with all applicable reliability criteria, or (ii) the proposed facility or project would not satisfy the standards set forth in Section I.3.9 of the Transmission, Markets and Services Tariff. This standard is intended to assure the continued service of all non-ITC firm load customers and the ability of the non-ITC systems to meet outstanding transmission service obligations.

Maximum Capacity Limit is a value calculated as described in Section III.12.2.2 of Market Rule 1.

Maximum Consumption Limit is the maximum amount, in MW, available for economic dispatch from a DARD and is based on the physical characteristics as submitted as part of the DARD's Offer Data. A Market Participant must maintain an up-to-date Maximum Consumption Limit (and where applicable, must provide the ISO with any telemetry required by ISO New England Operating Procedure No. 18 to allow the ISO to maintain an updated Maximum Consumption Limit) for all hours in which a DARD has been offered into the Day-Ahead Energy Market or Real-Time Energy Market.

Maximum Daily Energy Limit is the maximum amount of megawatt-hours that a Limited Energy Resource expects to be able to generate in the next Operating Day.

Maximum Daily Consumption Limit is the maximum amount of megawatt-hours that a Storage DARD expects to be able to consume in the next Operating Day.

Maximum Facility Load is the highest demand of an end-use customer facility since the start of the prior calendar year (or, if unavailable, an estimate thereof), where the demand evaluated is established by adding metered demand measured at the Retail Delivery Point and the output of all generators located behind the Retail Delivery Point in the same time intervals.

Maximum Interruptible Capacity is an estimate of the maximum demand reduction and Net Supply that a Demand Response Asset can deliver, as measured at the Retail Delivery Point.

Maximum Load is the highest demand since the start of the prior calendar year (or, if unavailable, an estimate thereof), as measured at the Retail Delivery Point.

Maximum Number of Daily Starts is the maximum number of times that a Binary Storage DARD or a Generator Asset can be started or that a Demand Response Resource can be interrupted in the next Operating Day under normal operating conditions.

Maximum Reduction is the maximum available demand reduction, in MW, of a Demand Response Resource that a Market Participant offers to deliver in the Day-Ahead Energy Market or Real-Time Energy Market, as reflected in the Demand Response Resource's Demand Reduction Offer.

Maximum State of Charge is the megawatt-hour value of stored energy, submitted by an Electric Storage Facility as part of its Offer Data for a given hour of the Day-Ahead Energy Market, above which the ISO shall not schedule the Electric Storage Facility to receive electricity from the grid.

Measure Life is the estimated time an On-Peak Demand Resource or Seasonal Peak Demand Resource measure will remain in place, or the estimated time period over which the facility, structure, equipment or system in which a measure is installed continues to exist, whichever is shorter. Suppliers of On-Peak Demand Resources or Seasonal Peak Demand Resources comprised of an aggregation of measures with varied Measures Lives shall determine and document the Measure Life either: (i) for each type of measure with a different Measure Life and adjust the aggregate performance based on the individual measure life calculation in the portfolio; or (ii) as the average Measure Life for the aggregated measures as long as the demand reduction capability of the resource is greater than or equal to the amount that cleared in the Forward Capacity Auction or reconfiguration auction for the entire Capacity Commitment Period, and the demand reduction capability for an Existing On-Peak Demand Resource or Existing Seasonal Peak Demand Resource is not over-stated in a subsequent Capacity Commitment Period. Measure Life shall be

determined consistent with the resource's Measurement and Verification Plan, which shall be reviewed by the ISO to ensure consistency with the measurement and verification requirements of Market Rule 1 and the ISO New England Manuals.

Measurement and Verification Documents mean the measurement and verification documents described in Section 13.1.4.3.1 of Market Rule 1 that are submitted by On-Peak Demand Resources and Seasonal Peak Demand Resources, which include Measurement and Verification Plans, Updated Measurement and Verification Plans, Measurement and Verification Summary Reports, and Measurement and Verification Reference Reports.

Measurement and Verification Plan means the measurement and verification plan submitted by an On-Peak Demand Resource or Seasonal Peak Demand Resource as part of the qualification process for the Forward Capacity Auction pursuant to the requirements of Section III.13.1.4.3 of Market Rule 1 and the ISO New England Manuals.

Measurement and Verification Reference Reports are optional reports submitted by On-Peak Demand Resources or Seasonal Peak Demand Resources during the Capacity Commitment Period subject to the schedule in the Measurement and Verification Plan and consistent with the schedule and reporting standards set forth in the ISO New England Manuals. Measurement and Verification Reference Reports update the prospective demand reduction capability of the On-Peak Demand Resource or Seasonal Peak Demand Resource project based on measurement and verification studies performed during the Capacity Commitment Period.

Measurement and Verification Summary Report is the monthly report submitted by an On-Peak Demand Resource or Seasonal Peak Demand Resource with the monthly settlement report for the Forward Capacity Market, which documents the total demand reduction capability for all On-Peak Demand Resources and Seasonal Peak Demand Resources in operation as of the end of the previous month.

MEPCO Grandfathered Transmission Service Agreement (MGTSA) is a MEPCO long-term firm point-to-point transmission service agreement with a POR or POD at the New Brunswick border and a start date prior to June 1, 2007 where the holder has elected, by written notice delivered to MEPCO within five (5) days following the filing of the settlement agreement in Docket Nos. ER07-1289 and

EL08-56 or by September 1, 2008 (whichever is later), MGTSA treatment as further described in Section II.45.1.

Merchant Transmission Facilities (MTF) are the transmission facilities owned by MTOs, defined and classified as MTF pursuant to Schedule 18 of the OATT, over which the ISO shall exercise Operating Authority in accordance with the terms set forth in a MTOA or Attachment K to the OATT, rated 69 kV or above and required to allow energy from significant power sources to move freely on the New England Transmission System.

Merchant Transmission Facilities Provider (MTF Provider) is an entity as defined in Schedule 18 of the OATT.

Merchant Transmission Facilities Service (MTF Service) is transmission service over MTF as provided for in Schedule 18 of the OATT.

Merchant Transmission Operating Agreement (MTOA) is an agreement between the ISO and an MTO with respect to its MTF.

Merchant Transmission Owner (MTO) is an owner of MTF.

Meter Data Error means an error in meter data, including an error in Coincident Peak Contribution values, on an Invoice issued by the ISO after the completion of the Data Reconciliation Process as described in the ISO New England Manuals and in Section III.3.8 of Market Rule 1.

Meter Data Error RBA Submission Limit means the date thirty 30 calendar days after the issuance of the Invoice containing the results of the Data Reconciliation Process as described in the ISO New England Manuals and in Section III.3.6 of Market Rule 1.

Metered Quantity For Settlement is defined in Section III.3.2.1.1 of Market Rule 1.

Minimum Consumption Limit is (a) the lowest consumption level, in MW, available for economic dispatch from a DARD and is based on the physical characteristics as submitted as part of the DARD's Offer Data, and (b) for a DARD undergoing Facility and Equipment Testing or auditing, the level to

which the DARD requests and is approved to operate or is directed to operate for purposes of completing the Facility and Equipment Testing or auditing.

Minimum Down Time is the number of hours that must elapse after a Generator Asset or Storage DARD has been released for shutdown at or below its Economic Minimum Limit or Minimum Consumption Limit before the Generator Asset or Storage DARD can be brought online and be released for dispatch at its Economic Minimum Limit or Minimum Consumption Limit.

Minimum Generation Emergency means an Emergency declared by the ISO in which the ISO anticipates requesting one or more Generator Assets to operate at or below Economic Minimum Limit in order to manage, alleviate, or end the Emergency.

Minimum Generation Emergency Credits are those Real-Time Dispatch NCPC Credits calculated pursuant to Appendix F of Market Rule 1 for resources within a reliability region that are dispatched during a period for which a Minimum Generation Emergency has been declared.

Minimum Reduction is the minimum available demand reduction, in MW, of a Demand Response Resource that a Market Participant offers to deliver in the Day-Ahead Energy Market or Real-Time Energy Market, as reflected in the Demand Response Resource's Demand Reduction Offer.

Minimum Reduction Time is the minimum number of hours of demand reduction at or above the Minimum Reduction for which the ISO must dispatch a Demand Response Resource to reduce demand.

Minimum Run Time is the number of hours that a Generator Asset must remain online after it has been scheduled to reach its Economic Minimum Limit before it can be released for shutdown from its Economic Minimum Limit or the number of hours that must elapse after a Storage DARD has been scheduled to consume at its Minimum Consumption Limit before it can be released for shutdown.

Minimum State of Charge is the megawatt-hour value of stored energy, submitted by an Electric Storage Facility as part of its Offer Data for a given hour of the Day-Ahead Energy Market, below which the ISO shall not schedule the Electric Storage Facility to inject electricity to the grid.

Minimum Time Between Reductions is the number of hours that must elapse after a Demand Response Resource has received a Dispatch Instruction to stop reducing demand before the Demand Response

Resource can achieve its Minimum Reduction after receiving a Dispatch Instruction to start reducing demand.

Minimum Total Reserve Requirement, which does not include Replacement Reserve, is the combined amount of TMSR, TMNSR, and TMOR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Monthly Blackstart Service Charge is the charge made to Transmission Customers pursuant to Section 6 of Schedule 16 to the OATT.

Monthly Capacity Payment is the Forward Capacity Market payment described in Section III.13.7.3 of Market Rule 1.

Monthly Peak is defined in Section II.21.2 of the OATT.

Monthly PER is calculated in accordance with Section III.13.7.1.2.2 of Market Rule 1.

Monthly Real-Time Demand Reduction Obligation is the absolute value of a Customer's hourly Real-Time Demand Reduction Obligation summed for all hours in a month, in MWhs.

Monthly Real-Time Generation Obligation is the sum, for all hours in a month, at all Locations, of a Customer's Real-Time Generation Obligation, in MWhs.

Monthly Real-Time Load Obligation is the absolute value of a Customer's hourly Real-Time Load Obligation summed for all hours in a month, in MWhs.

Monthly Regional Network Load is defined in Section II.21.2 of the OATT.

Monthly Statement is the first weekly Statement issued on a Monday after the tenth of a calendar month that includes both the Hourly Charges for the relevant billing period and Non-Hourly Charges for the immediately preceding calendar month.

MRI Transition Period is the period specified in Section III.13.2.2.1.

MUI is the market user interface.

Municipal Market Participant is defined in Section II of the ISO New England Financial Assurance Policy.

MW is megawatt.

MWh is megawatt-hour.

Native Load Customers are the wholesale and retail power customers of a Transmission Owner on whose behalf the Transmission Owner, by statute, franchise, regulatory requirement, or contract, has undertaken an obligation to construct and operate its system to meet the reliable electric needs of such customers.

NCPC Charge means the charges to Market Participants calculated pursuant to Appendix F to Market Rule 1.

NCPC Credit means the credits to Market Participants calculated pursuant to Appendix F to Market Rule 1.

Needs Assessment is defined in Section 4.1 of Attachment K to the OATT.

NEMA, for purposes of Section III of the Tariff, is the Northeast Massachusetts Reliability Region.

NEMA Contract is a contract described in Appendix C of Market Rule 1 and listed in Exhibit 1 of Appendix C of Market Rule 1.

NEMA Load Serving Entity (NEMA LSE) is a Transmission Customer or Congestion Paying LSE Entity that serves load within NEMA.

NEMA or Northeast Massachusetts Upgrade, for purposes of Section II of the Tariff, is an addition to or modification of the PTF into or within the Northeast Massachusetts Reliability Region that was not, as of December 31, 1999, the subject of a System Impact Study or application filed pursuant to Section I.3.9 of the Transmission, Markets and Services Tariff; that is not related to generation interconnections; and

that will be completed and placed in service by June 30, 2004. Such upgrades include, but are not limited to, new transmission facilities and related equipment and/or modifications to existing transmission facilities and related equipment. The list of NEMA Upgrades is contained in Schedule 12A of the OATT.

NEPOOL is the New England Power Pool, and the entities that collectively participated in the New England Power Pool.

NEPOOL Agreement is the agreement among the participants in NEPOOL.

NEPOOL GIS is the generation information system.

NEPOOL GIS Administrator is the entity or entities that develop, administer, operate and maintain the NEPOOL GIS.

NEPOOL GIS API Fees are the one-time on-boarding fees and annual maintenance fees charged to NEPOOL by the NEPOOL GIS Administrator for each NEPOOL Participant or Market Participant that accesses the NEPOOL GIS through an application programming interface pursuant to Rule 3.9(b) of the operating rules of the NEPOOL GIS.

NEPOOL Participant is a party to the NEPOOL Agreement.

NERC is the North American Electric Reliability Corporation or its successor organization.

NESCOE is the New England States Committee on Electricity, recognized by the Commission as the regional state committee for the New England Control Area.

Net Commitment Period Compensation (NCPC) is the compensation methodology for Resources that is described in Appendix F to Market Rule 1.

Net CONE is an estimate of the Cost of New Entry, net of the first-year non-capacity market revenues, for a reference technology resource type and is intended to equal the amount of capacity revenue the reference technology resource would require, in its first year of operation, to be economically viable given reasonable expectations of the first year energy and ancillary services revenues, and projected revenue for subsequent years.

Net Regional Clearing Price is described in Section III.13.7.5 of Market Rule 1.

Net Supply is energy injected into the transmission or distribution system at a Retail Delivery Point.

Net Supply Capability is the maximum Net Supply a facility is physically and contractually able to inject into the transmission or distribution system at its Retail Delivery Point.

Network Capability Interconnection Standard has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Network Customer is a Transmission Customer receiving RNS or LNS.

Network Import Capability (NI Capability) is defined in Section I of Schedule 25 of the OATT.

Network Import Interconnection Service (NI Interconnection Service) is defined in Section I of Schedule 25 of the OATT.

Network Resource is defined as follows: (1) With respect to Market Participants, (a) any generating resource located in the New England Control Area which has been placed in service prior to the Compliance Effective Date (including a unit that has lost its capacity value when its capacity value is restored and a deactivated unit which may be reactivated without satisfying the requirements of Section II.46 of the OATT in accordance with the provisions thereof) until retired; (b) any generating resource located in the New England Control Area which is placed in service after the Compliance Effective Date until retired, provided that (i) the Generator Owner has complied with the requirements of Sections II.46 and II.47 and Schedules 22 and 23 of the OATT, and (ii) the output of the unit shall be limited in accordance with Sections II.46 and II.47 and Schedules 22 and 23, if required; and (c) any generating resource or combination of resources (including bilateral purchases) located outside the New England Control Area for so long as any Market Participant has an Ownership Share in the resource or resources which is being delivered to it in the New England Control Area to serve Regional Network Load located in the New England Control Area or other designated Regional Network Loads contemplated by Section II.18.3 of the OATT taking Regional Network Service. (2) With respect to Non-Market Participant Transmission Customers, any generating resource owned, purchased or leased by the Non-Market Participant Transmission Customer which it designates to serve Regional Network Load.

New Brunswick Security Energy is defined in Section III.3.2.6A of Market Rule 1.

New Capacity Offer is an offer in the Forward Capacity Auction to provide capacity from a New Generating Capacity Resource, New Import Capacity Resource or New Demand Capacity Resource.

New Capacity Qualification Deadline is a deadline, specified in Section III.13.1.10 of Market Rule 1, for submission of certain qualification materials for the Forward Capacity Auction, as discussed in Section III.13.1 of Market Rule 1.

New Capacity Qualification Package is information submitted by certain new resources prior to participation in the Forward Capacity Auction, as described in Section III.13.1 of Market Rule 1.

New Capacity Resource is a resource (i) that never previously received any payment as a capacity resource including any capacity payment pursuant to the market rules in effect prior to June 1, 2010 and that has not cleared in any previous Forward Capacity Auction; or (ii) that is otherwise eligible to participate in the Forward Capacity Auction as a New Capacity Resource.

New Capacity Show of Interest Form is described in Section III.13.1.1.2.1 of Market Rule 1.

New Capacity Show of Interest Submission Window is the period of time during which a Project Sponsor may submit a New Capacity Show of Interest Form or a New Demand Capacity Resource Show of Interest Form, as described in Section III.13.1.10 of Market Rule 1.

New Demand Capacity Resource is a type of Demand Capacity Resource participating in the Forward Capacity Market, as defined in Section III.13.1.4.1 of Market Rule 1.

New Demand Capacity Resource Qualification Package is the information that a Project Sponsor must submit, in accordance with Section III.13.1.4.1.1.2 of Market Rule 1, for each resource that it seeks to offer in the Forward Capacity Auction as a New Demand Capacity Resource.

New Demand Capacity Resource Show of Interest Form is described in Section III.13.1.4.1.1.1 of Market Rule 1.

New England Control Area is the Control Area for New England, which includes PTF, Non-PTF, MTF and OTF. The New England Control Area covers Connecticut, Rhode Island, Massachusetts, New Hampshire, Vermont, and part of Maine (i.e., excluding the portions of Northern Maine and the northern portion of Eastern Maine which are in the Maritimes Control Area).

New England Markets are markets or programs for the purchase of energy, capacity, ancillary services, demand response services or other related products or services (including Financial Transmission Rights) that are delivered through or useful to the operation of the New England Transmission System and that are administered by the ISO pursuant to rules, rates, or agreements on file from time to time with the Federal Energy Regulatory Commission.

New England System Restoration Plan is the plan that is developed by ISO, in accordance with NERC Reliability Standards, NPCC regional criteria and standards, ISO New England Operating Documents and ISO operating agreements, to facilitate the restoration of the New England Transmission System following a partial or complete shutdown of the New England Transmission System.

New England Transmission System is the system of transmission facilities, including PTF, Non-PTF, OTF and MTF, within the New England Control Area under the ISO's operational jurisdiction.

New Generating Capacity Resource is a type of resource participating in the Forward Capacity Market, as described in Section III.13.1.1.1 of Market Rule 1.

New Import Capacity Resource is a type of resource participating in the Forward Capacity Market, as defined in Section III.13.1.3.4 of Market Rule 1.

New Resource Offer Floor Price is defined in Section III.A.21.2.

NMPTC means Non-Market Participant Transmission Customer.

NMPTC Credit Threshold is described in Section V.A.2 of the ISO New England Financial Assurance Policy.

NMPTC Financial Assurance Requirement is an amount of additional financial assurance for Non-Market Participant Transmission Customers described in Section V.D of the ISO New England Financial Assurance Policy.

Node is a point on the New England Transmission System at which LMPs are calculated.

No-Load Fee is the amount, in dollars per hour, for a Generator Asset that must be paid to Market Participants with an Ownership Share in the Generator Asset for being scheduled in the New England Markets, in addition to the Start-Up Fee and price offered to supply energy, for each hour that the Generator Asset is scheduled in the New England Markets.

Nominated Consumption Limit is the consumption level specified by the Market Participant for a Dispatchable Asset Related Demand as adjusted in accordance with the provisions of Section III.13.7.5.1.3.

Non-Commercial Capacity is the capacity of a New Capacity Resource or an Existing Capacity Resource, or portion thereof, that has not achieved FCM Commercial Operation.

Non-Commercial Capacity Cure Period is the time period described in Section VII.D of the ISO New England Financial Assurance Policy.

Non-Commercial Capacity Financial Assurance Amount (Non-Commercial Capacity FA Amount) is the financial assurance amount held on Non-Commercial Capacity cleared in a Forward Capacity Auction as calculated in accordance with Section VII.B.2 of the ISO New England Financial Assurance Policy.

Non-Designated Blackstart Resource Study Cost Payments are the study costs reimbursed under Section 5.3 of Schedule 16 of the OATT.

Non-Dispatchable Resource is any Resource that does not meet the requirements to be a Dispatchable Resource.

Non-Hourly Charges are defined in Section 1.3 of the ISO New England Billing Policy.

Non-Hourly Requirements are determined in accordance with Section III.A(ii) of the ISO New England Financial Assurance Policy, which is Exhibit 1A of Section I of the Tariff.

Non-Incumbent Transmission Developer is a Qualified Transmission Project Sponsor that: (i) is not currently a PTO; (ii) has a transmission project listed in the RSP Project List; and (iii) has executed a Non-Incumbent Transmission Developer Operating Agreement. "Non-Incumbent Transmission Developer" also includes a PTO that proposes the development of a transmission facility not located within or connected to its existing electric system; however, because such a PTO is a party to the TOA, it is not required to enter into a Non-Incumbent Transmission Developer Operating Agreement.

Non-Incumbent Transmission Developer Operating Agreement (or NTDOA) is an agreement between the ISO and a Non-Incumbent Transmission Developer in the form specified in Attachment O to the OATT that sets forth their respective rights and responsibilities to each other with regard to proposals for and construction of certain transmission facilities.

Non-Market Participant is any entity that is not a Market Participant.

Non-Market Participant Transmission Customer is any entity which is not a Market Participant but is a Transmission Customer.

Non-Municipal Market Participant is defined in Section II of the ISO New England Financial Assurance Policy.

Non-PTF Transmission Facilities (Non-PTF) are the transmission facilities owned by the PTOs that do not constitute PTF, OTF or MTF.

Non-Qualifying means a Market Participant that is not a Credit Qualifying Market Participant.

Notice of RBA is defined in Section 6.3.2 of the ISO New England Billing Policy.

Notification Time is the time required for a Generator Asset to synchronize to the system from the time a startup Dispatch Instruction is received from the ISO.

Northeastern Planning Protocol is the Amended and Restated Northeastern ISO/RTO Planning Coordination Protocol on file with the Commission and posted on the ISO website at the following URL: www.iso-ne.com/static-assets/documents/2015/07/northeastern_protocol_dmeast.doc.

NPCC is the Northeast Power Coordinating Council.

Obligation Month means a time period of one calendar month for which capacity payments are issued and the costs associated with capacity payments are allocated.

Offer Data means the scheduling, operations planning, dispatch, new Resource, and other data, including Generator Asset, Dispatchable Asset Related Demand, and Demand Response Resource operating limits based on physical characteristics, and information necessary to schedule and dispatch Generator Assets, Dispatchable Asset Related Demands, and Demand Response Resources for the provision or consumption of energy, the provision of other services, and the maintenance of the reliability and security of the transmission system in the New England Control Area, and specified for submission to the New England Markets for such purposes by the ISO.

Offered CLAIM10 is a Supply Offer value or a Demand Reduction Offer value between 0 and the CLAIM10 of the resource that represents the amount of TMNSR available either from an off-line Fast Start Generator or from a Fast Start Demand Response Resource that has not been dispatched.

Offered CLAIM30 is a Supply Offer value or a Demand Reduction Offer value between 0 and the CLAIM30 of the resource that represents the amount of TMOR available either from an off-line Fast Start Generator or from a Fast Start Demand Response Resource that has not been dispatched.

On-Peak Demand Resource is a type of Demand Capacity Resource and means installed measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that reduce the total amount of electrical energy consumed during Demand Resource On-Peak Hours, while delivering a comparable or acceptable level of end-use service. Such measures include Energy Efficiency, Load Management, and Distributed Generation.

Open Access Same-Time Information System (OASIS) is the ISO information system and standards of conduct responding to requirements of 18 C.F.R. §37 of the Commission's regulations and all additional requirements implemented by subsequent Commission orders dealing with OASIS.

Open Access Transmission Tariff (OATT) is Section II of the ISO New England Inc. Transmission, Markets and Services Tariff.

Operating Authority is defined pursuant to a MTOA, an OTOA, the TOA or the OATT, as applicable.

Operating Data means GADS Data, data equivalent to GADS Data, CARL Data, metered load data, or actual system failure occurrences data, all as described in the ISO New England Operating Procedures.

Operating Day means the calendar day period beginning at midnight for which transactions on the New England Markets are scheduled.

Operating Reserve means Ten-Minute Spinning Reserve (TMSR), Ten-Minute Non-Spinning Reserve (TMNSR) and Thirty-Minute Operating Reserve (TMOR).

Operations Date is February 1, 2005.

OTF Service is transmission service over OTF as provided for in Schedule 20.

Other Transmission Facility (OTF) are the transmission facilities owned by Transmission Owners, defined and classified as OTF pursuant to Schedule 20, over which the ISO shall exercise Operating Authority in accordance with the terms set forth in the OTOA, rated 69 kV or above, and required to allow energy from significant power sources to move freely on the New England Transmission System. OTF classification shall be limited to the Phase I/II HVDC-TF.

Other Transmission Operating Agreements (OTOA) is the agreement(s) between the ISO, an OTO and/or the associated service provider(s) with respect to an OTF, which includes the HVDC Transmission Operating Agreement and the Phase I/II HVDC-TF Transmission Service Administration Agreement. With respect to the Phase I/II HVDC-TF, the HVDC Transmission Operating Agreement covers the rights and responsibilities for the operation of the facility and the Phase I/II HVDC-TF Transmission Service Administration Agreement covers the rights and responsibilities for the administration of transmission service.

Other Transmission Owner (OTO) is an owner of OTF.

Ownership Share is a right or obligation, for purposes of settlement, to a percentage share of all credits or charges associated with a Generator Asset or a Load Asset, where such facility is interconnected to the New England Transmission System.

Participant Expenses are defined in Section 1 of the Participants Agreement.

Participant Required Balance is defined in Section 5.3 of the ISO New England Billing Policy.

Participant Vote is defined in Section 1 of the Participants Agreement.

Participants Agreement is the agreement among the ISO, the New England Power Pool and Individual Participants, as amended from time to time, on file with the Commission.

Participants Committee is the principal committee referred to in the Participants Agreement.

Participating Transmission Owner (PTO) is a transmission owner that is a party to the TOA.

Passive DR Audit is the audit performed pursuant to Section III.13.6.1.5.4.

Passive DR Auditing Period is the summer Passive DR Auditing Period (June 1 to August 31) or winter Passive DR Auditing Period (December 1 to January 31) applicable to On-Peak Demand Resources and Seasonal Peak Demand Resources.

Payment is a sum of money due to a Covered Entity from the ISO.

Payment Default Shortfall Fund is defined in Section 5.1 of the ISO New England Billing Policy.

Peak Energy Rent (PER) is described in Section III.13.7.1.2 of Market Rule 1.

PER Proxy Unit is described in Section III.13.7.1.2.1 of Market Rule 1.

Permanent De-list Bid is a bid that may be submitted by an Existing Generating Capacity Resource, Existing Import Capacity Resource, or Existing Demand Capacity Resource in the Forward Capacity

Auction to permanently remove itself from the capacity market, as described in Section III.13.1.2.3.1.5 of Market Rule 1.

Phase I Transfer Credit is 40% of the HQICC, or such other fraction of the HQICC as the ISO may establish.

Phase I/II HVDC-TF is defined in Schedule 20A to Section II of this Tariff.

Phase I/II HVDC-TF Transfer Capability is the transfer capacity of the Phase I/II HVDC-TF under normal operating conditions, as determined in accordance with Good Utility Practice. The "Phase I Transfer Capability" is the transfer capacity under normal operating conditions, as determined in accordance with Good Utility Practice, of the Phase I terminal facilities as determined initially as of the time immediately prior to Phase II of the Phase I/II HVDC-TF first being placed in service, and as adjusted thereafter only to take into account changes in the transfer capacity which are independent of any effect of Phase II on the operation of Phase I. The "Phase II Transfer Capability" is the difference between the Phase I/II HVDC-TF Transfer Capability and the Phase I Transfer Capability. Determinations of, and any adjustment in, Phase I/II HVDC-TF Transfer Capability shall be made by the ISO, and the basis for any such adjustment shall be explained in writing and posted on the ISO website.

Phase One Proposal is a first round submission, as defined in Section 4.3 of Attachment K of the OATT, of a proposal for a Reliability Transmission Upgrade or Market Efficiency Transmission Upgrade, as applicable, by a Qualified Transmission Project Sponsor.

Phase II Transfer Credit is 60% of the HQICC, or such other fraction of the HQICC as the ISO may establish.

Phase Two Solution is a second round submission, as defined in Section 4.3 of Attachment K of the OATT, of a proposal for a Reliability Transmission Upgrade or Market Efficiency Transmission Upgrade by a Qualified Transmission Project Sponsor.

Planning Advisory Committee is the committee described in Attachment K of the OATT.

Planning and Reliability Criteria is defined in Section 3.3 of Attachment K to the OATT.

Planning Authority is an entity defined as such by the North American Electric Reliability Corporation.

Point(s) of Delivery (POD) is point(s) of interconnection where capacity and/or energy transmitted by a Transmission Customer will be made available to the Receiving Party under the OATT.

Point of Interconnection shall have the same meaning as that used for purposes of Schedules 22, 23 and 25 of the OATT.

Point(s) of Receipt (POR) is point(s) of interconnection where capacity and/or energy transmitted by a Transmission Customer will be made available by the Delivering Party under the OATT.

Point-To-Point Service is the transmission of capacity and/or energy on either a firm or non-firm basis from the Point(s) of Receipt to the Point(s) of Delivery under the OATT pursuant to Local Point-To-Point Service or OTF Service or MTF Service; and the transmission of capacity and/or energy from the Point(s) of Receipt to the Point(s) of Delivery under the OATT pursuant to Through or Out Service.

Pool-Planned Unit is one of the following units: New Haven Harbor Unit 1 (Coke Works), Mystic Unit 7, Canal Unit 2, Potter Unit 2, Wyman Unit 4, Stony Brook Units 1, 1A, 1B, 1C, 2A and 2B, Millstone Unit 3, Seabrook Unit 1 and Waters River Unit 2 (to the extent of 7 megawatts of its Summer capability and 12 megawatts of its Winter capability).

Pool PTF Rate is the transmission rate determined in accordance with Schedule 8 to the OATT.

Pool RNS Rate is the transmission rate determined in accordance with paragraph (2) of Schedule 9 of Section II of the Tariff.

Pool-Scheduled Resources are described in Section III.1.10.2 of Market Rule 1.

Pool Supported PTF is defined as: (i) PTF first placed in service prior to January 1, 2000; (ii) Generator Interconnection Related Upgrades with respect to Category A and B projects (as defined in Schedule 11), but only to the extent not paid for by the interconnecting Generator Owner; and (iii) other PTF upgrades, but only to the extent the costs therefore are determined to be Pool Supported PTF in accordance with Schedule 12.

Pool Transmission Facility (PTF) means the transmission facilities owned by PTOs which meet the criteria specified in Section II.49 of the OATT.

Posting Entity is any Market Participant or Non-Market Participant Transmission Customer providing financial security under the provisions of the ISO New England Financial Assurance Policy.

Posture means an action of the ISO to deviate from the jointly optimized security constrained economic dispatch for Energy and Operating Reserves solution for a Resource produced by the ISO's technical software for the purpose of maintaining sufficient Operating Reserve (both online and off-line) or for the provision of voltage or VAR support.

Posturing Credits are the Real-Time Posturing NCPC Credits for Generators (Other Than Limited Energy Resources) Postured for Reliability and the Real-Time Posturing NCPC Credit for Limited Energy Resources Postured for Reliability.

Power Purchaser is the entity that is purchasing the capacity and/or energy to be transmitted under the OATT.

Principal is (i) the sole proprietor of a sole proprietorship; (ii) a general partner of a partnership; (iii) a president, chief executive officer, chief operating officer or chief financial officer (or equivalent position) of an organization; (iv) a manager, managing member or a member vested with the management authority for a limited liability company or limited liability partnership; (v) any person or entity that has the power to exercise a controlling influence over an organization's activities that are subject to regulation by the Federal Energy Regulatory Commission, the Securities and Exchange Commission, the Commodity Futures Trading Commission, any exchange monitored by the National Futures Association, or any state entity responsible for regulating activity in energy markets; or (vi) any person or entity that: (a) is the direct owner of 10% or more of any class of an organization's equity securities; or (b) has directly contributed 10% or more of an organization's capital.

Profiled Load Assets include all Load Assets that are not directly metered by OP-18 compliant metering as currently described in Section IV (Metering and Recording for Settlements) of OP18, and some Load Assets that are measured by OP-18 compliant metering (as currently described in Section IV of OP-18) to which the Host Participant Assigned Meter Reader allocates non-PTF losses.

Project Sponsor is an entity seeking to have a New Generating Capacity Resource, New Import Capacity Resource or New Demand Capacity Resource participate in the Forward Capacity Market, as described in Section III.13.

Proxy De-List Bid is a type of bid used in the Forward Capacity Market.

Provisional Member is defined in Section I.68A of the Restated NEPOOL Agreement.

PTO Administrative Committee is the committee referred to in Section 11.04 of the TOA.

Public Policy Requirement is a requirement reflected in a statute enacted by, or a regulation promulgated by, the federal government or a state or local (e.g., municipal or county) government.

Public Policy Transmission Study is a study conducted by the ISO pursuant to the process set out in Section 4A.3 of Attachment K of the OATT, and consists of two phases: (i) an initial phase to produce a rough estimate of the costs and benefits of concepts that could meet transmission needs driven by public policy requirements; and (ii) a follow-on phase designed to produce more detailed analysis and engineering work on transmission concepts identified in the first phase.

Public Policy Local Transmission Study is a study conducted by a PTO pursuant to the process set out in Section 1.6 of Attachment K Appendix 1 of the OATT, and consists of two phases: (i) an initial phase to produce an estimate of the costs and benefits of concepts that could meet transmission needs driven by public policy requirements; and (ii) a follow-on phase designed to produce more detailed analysis and engineering work on transmission concepts identified in the first phase.

Public Policy Transmission Upgrade is an addition and/or upgrade to the New England Transmission System that meets the voltage and non-voltage criteria for Public Policy Transmission Upgrade PTF classification specified in the OATT, and has been included in the Regional System Plan and RSP Project List as a Public Policy Transmission Upgrade pursuant to the procedures described in Section 4A of Attachment K of the OATT.

Publicly Owned Entity is defined in Section I of the Restated NEPOOL Agreement.

Qualification Process Cost Reimbursement Deposit is described in Section III.13.1.9.3 of Market Rule 1.

Qualified Capacity is the amount of capacity a resource may provide in the summer or winter in a Capacity Commitment Period, as determined in the Forward Capacity Market qualification processes.

Qualified Generator Reactive Resource(s) is any generator source of dynamic reactive power that meets the criteria specified in Schedule 2 of the OATT.

Qualified Non-Generator Reactive Resource(s) is any non-generator source of dynamic reactive power that meets the criteria specified in Schedule 2 of the OATT.

Qualified Reactive Resource(s) is any Qualified Generator Reactive Resource and/or Qualified Non-Generator Reactive Resource that meets the criteria specified in Schedule 2 of the OATT.

Qualified Transmission Project Sponsor is defined in Sections 4B.2 and 4B.3 of Attachment K of the OATT.

Queue Position has the meaning specified in Section I of Schedule 22, Attachment 1 to Schedule 23, and Section I of Schedule 25 of the OATT.

Rapid Response Pricing Asset is: (i) a Fast Start Generator; (ii) a Flexible DNE Dispatchable Generator; or (iii) a Binary Storage DARD with Offer Data specifying a Minimum Run Time and a Minimum Down Time not exceeding one hour each. A Rapid Response Pricing Asset shall also include a Fast Start Demand Response Resource for which the Market Participant's Offer Data meets the following criteria: (i) Minimum Reduction Time does not exceed one hour; and (ii) Demand Response Resource Notification Time plus Demand Response Resource Start-Up Time does not exceed 30 minutes.

Rapid Response Pricing Opportunity Cost is the NCPC Credit described in Section III.F.2.3.10.

Rated means a Market Participant that receives a credit rating from one or more of the Rating Agencies, or, if such Market Participant is not rated by one of the Rating Agencies, then a Market Participant that has outstanding unsecured debt rated by one or more of the Rating Agencies.

Rating Agencies are Standard and Poor's (S&P), Moody's, and Fitch.

Rationing Minimum Limit is the MW quantity for a New Generating Capacity Resource or Existing Generating Capacity Resource below which n offer or bid may not be rationed in the Forward Capacity Auction, but shall not apply to supply offers or demand bids in a substitution auction as specified in Section III.13.2.8.2 and Section III.13.2.8.3.

RBA Decision is a written decision provided by the ISO to a Disputing Party and to the Chair of the NEPOOL Budget and Finance Subcommittee accepting or denying a Requested Billing Adjustment within twenty Business Days of the date the ISO distributes a Notice of RBA, unless some later date is agreed upon by the Disputing Party and the ISO.

Reactive Capability Audit is an audit that measures the ability of a Reactive Resource to provide or absorb reactive power to or from the transmission system at a specified real power output or consumption.

Reactive Resource is a device that dynamically adjusts reactive power output automatically in Real-Time over a continuous range, taking into account control system response bandwidth, within a specified voltage bandwidth in response to grid voltage changes. These resources operate to maintain a set-point voltage and include, but are not limited to, Generator Assets, Dispatchable Asset Related Demands that are part of an Electric Storage Facility, and dynamic transmission devices.

Reactive Supply and Voltage Control Service is the form of Ancillary Service described in Schedule 2 of the OATT.

Real-Time is a period in the current Operating Day for which the ISO dispatches Resources for energy and Regulation, designates Resources for Regulation and Operating Reserve and, if necessary, commits additional Resources.

Real-Time Adjusted Load Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Adjusted Load Obligation Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time Commitment NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Congestion Revenue is defined in Section III.3.2.1(i) of Market Rule 1.

Real-Time Demand Reduction Obligation is defined in Section III.3.2.1(c) of Market Rule 1.

Real-Time Demand Reduction Obligation Deviation is defined in Section III.3.2.1(e) of Market Rule 1.

Real-Time Dispatch NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Energy Inventory is a component of the spot payment that a Market Participant may receive through the inventoried energy program, as described in Section III.K.3.2.1 of Market Rule 1.

Real-Time Energy Market means the purchase or sale of energy, purchase of demand reductions, payment of Congestion Costs, and payment for losses for quantity deviations from the Day-Ahead Energy Market in the Operating Day and designation of and payment for provision of Operating Reserve in Real-Time.

Real-Time Energy Market Deviation Congestion Charge/Credit is defined in Section III.3.2.1(g) of Market Rule 1.

Real-Time Energy Market Deviation Energy Charge/Credit is defined in Section III.3.2.1(g) of Market Rule 1.

Real-Time Energy Market Deviation Loss Charge/Credit is defined in Section III.3.2.1(g) of Market Rule 1.

Real-Time Energy Market NCPC Credits are the Real-Time Commitment NCPC Credit and the Real-Time Dispatch NCPC Credit.

Real-Time External Transaction NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Generation Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Generation Obligation Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time High Operating Limit is the maximum output, in MW, of a Generator Asset that could be achieved, consistent with Good Utility Practice, in response to an ISO request for Energy (including pursuant to Section III.13.6.4 of Market Rule 1), for each hour of the Operating Day, as reflected in the Generator Asset's Offer Data. This value is based on real-time operating conditions and the physical operating characteristics and operating permits of the facility and must be submitted for all Generator Assets (other than Settlement Only Resources).

Real-Time Load Obligation is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Load Obligation Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time Locational Adjusted Net Interchange is defined in Section III.3.2.1(b) of Market Rule 1.

Real-Time Locational Adjusted Net Interchange Deviation is defined in Section III.3.2.1(d) of Market Rule 1.

Real-Time Loss Revenue is defined in Section III.3.2.1(l) of Market Rule 1.

Real-Time Loss Revenue Charges or Credits are defined in Section III.3.2.1(m) of Market Rule 1.

Real-Time NCP Load Obligation is the maximum hourly value, during a month, of a Market Participant's Real-Time Load Obligation summed over all Locations, excluding exports, in kilowatts.

Real-Time Offer Change is a modification to a Supply Offer pursuant to Section III.1.10.9(b).

Real-Time Posturing NCPC Credit for Generators (Other Than Limited Energy Resources) Postured for Reliability is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Posturing NCPC Credit for Limited Energy Resources Postured for Reliability is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time Prices means the Locational Marginal Prices resulting from the ISO's dispatch of the New England Markets in the Operating Day.

Real-Time Reserve Charge is a Market Participant's share of applicable system and Reserve Zone Real-Time Operating Reserve costs attributable to meeting the Real-Time Operating Reserve requirement as calculated in accordance with Section III.10 of Market Rule 1.

Real-Time Reserve Clearing Price is the Real-Time TMSR, TMNSR or TMOR clearing price, as applicable, for the system and each Reserve Zone that is calculated in accordance with Section III.2.7A of Market Rule 1.

Real-Time Reserve Credit is a Market Participant's compensation associated with that Market Participant's Resources' Reserve Quantity For Settlement as calculated in accordance with Section III.10 of Market Rule 1.

Real-Time Reserve Designation is the amount, in MW, of Operating Reserve designated to a Resource in Real-Time by the ISO as described in Section III.1.7.19 of Market Rule 1.

Real-Time Reserve Opportunity Cost is defined in Section III.2.7A(b) of Market Rule 1.

Real-Time Synchronous Condensing NCPC Credit is an NCPC Credit calculated pursuant to Appendix F to Market Rule 1.

Real-Time System Adjusted Net Interchange means, for each hour, the sum of Real-Time Locational Adjusted Net Interchange for a Market Participant over all Locations, in kilowatts.

Receiving Party is the entity receiving the capacity and/or energy transmitted to Point(s) of Delivery under the OATT.

Reference Level is defined in Section III.A.5.7 of Appendix A of Market Rule 1.

Regional Benefit Upgrade(s) (RBU) means a Transmission Upgrade that: (i) is rated 115kV or above; (ii) meets all of the non-voltage criteria for PTF classification specified in the OATT; and

(iii) is included in the Regional System Plan as either a Reliability Transmission Upgrade or a Market Efficiency Transmission Upgrade identified as needed pursuant to Attachment K of the OATT. The category of RBU shall not include any Transmission Upgrade that has been categorized under any of the other categories specified in Schedule 12 of the OATT (e.g., an Elective Transmission Upgrade shall not also be categorized as an RBU). Any upgrades to transmission facilities rated below 115kV that were PTF prior to January 1, 2004 shall remain classified as PTF and be categorized as an RBU if, and for so long as, such upgrades meet the criteria for PTF specified in the OATT.

Regional Network Load is the load that a Network Customer designates for Regional Network Service under Part II.B of the OATT. The Network Customer's Regional Network Load shall include all load designated by the Network Customer (including losses) and shall not be credited or reduced for any behind-the-meter generation. A Network Customer may elect to designate less than its total load as Regional Network Load but may not designate only part of the load at a discrete Point of Delivery. Where a Transmission Customer has elected not to designate a particular load at discrete Points of Delivery as Regional Network Load, the Transmission Customer is responsible for making separate arrangements under Part II.C of the OATT for any Point-To-Point Service that may be necessary for such non-designated load.

Regional Network Service (RNS) is the transmission service over the PTF described in Part II.B of the OATT, including such service which is used with respect to Network Resources or Regional Network Load that is not physically interconnected with the PTF.

Regional Planning Dispute Resolution Process is described in Section 12 of Attachment K to the OATT.

Regional System Plan (RSP) is the plan developed under the process specified in Attachment K of the OATT.

Regional Transmission Service (RTS) is Regional Network Service and Through or Out Service as provided over the PTF in accordance with Section II.B, Section II.C, Schedule 8 and Schedule 9 of the OATT.

Regulation is the capability of a specific Resource with appropriate telecommunications, control and response capability to respond to an AGC SetPoint.

Regulation and Frequency Response Service is the form of Ancillary Service described in Schedule 3 of the OATT. The capability of performing Regulation and Frequency Response Service is referred to as automatic generation control (AGC).

Regulation Capacity is the lesser of five times the Automatic Response Rate and one-half of the difference between the Regulation High Limit and the Regulation Low Limit of a Resource capable of providing Regulation.

Regulation Capacity Requirement is the amount of Regulation Capacity required to maintain system control and reliability in the New England Control Area as calculated and posted on the ISO website.

Regulation Capacity Offer is an offer by a Market Participant to provide Regulation Capacity.

Regulation High Limit is an offer parameter that establishes the upper bound for AGC SetPoints and is used in the determination of a Resource's Regulation Capacity.

Regulation Low Limit is an offer parameter that establishes the lower bound for AGC SetPoints and is used in the determination of a Resource's Regulation Capacity.

Regulation Market is the market described in Section III.14 of Market Rule 1.

Regulation Resources are those Alternative Technology Regulation Resources, Generator Assets, and Dispatchable Asset Related Demands that satisfy the requirements of Section III.14.2. Regulation Resources are eligible to participate in the Regulation Market.

Regulation Service is the change in output or consumption made in response to changing AGC SetPoints.

Regulation Service Requirement is the estimated amount of Regulation Service required to maintain system control and reliability in the New England Control Area as calculated and posted on the ISO website.

Regulation Service Offer is an offer by a Market Participant to provide Regulation Service.

Related Person is defined pursuant to Section 1.1 of the Participants Agreement.

Related Transaction is defined in Section III.1.4.3 of Market Rule 1.

Reliability Administration Service (RAS) is the service provided by the ISO, as described in Schedule 3 of Section IV.A of the Tariff, in order to administer the Reliability Markets and provide other reliability-related and informational functions.

Reliability Committee is the committee whose responsibilities are specified in Section 8.2.3 of the Participants Agreement.

Reliability Markets are, collectively, the ISO's administration of Regulation, the Forward Capacity Market, and Operating Reserve.

Reliability Region means any one of the regions identified on the ISO's website. Reliability Regions are intended to reflect the operating characteristics of, and the major transmission constraints on, the New England Transmission System.

Reliability Transmission Upgrade means those additions and upgrades not required by the interconnection of a generator that are nonetheless necessary to ensure the continued reliability of the New England Transmission System, taking into account load growth and known resource changes, and include those upgrades necessary to provide acceptable stability response, short circuit capability and system voltage levels, and those facilities required to provide adequate thermal capability and local voltage levels that cannot otherwise be achieved with reasonable assumptions for certain amounts of generation being unavailable (due to maintenance or forced outages) for purposes of long-term planning studies. Good Utility Practice, applicable reliability principles, guidelines, criteria, rules, procedures and standards of ERO and NPCC and any of their successors, applicable publicly available local reliability criteria, and the ISO System Rules, as they may be amended from time to time, will be used to define the system facilities required to maintain reliability in evaluating proposed Reliability Transmission Upgrades. A Reliability Transmission Upgrade may provide market efficiency benefits as well as reliability benefits to the New England Transmission System.

Remittance Advice is an issuance from the ISO for the net Payment owed to a Covered Entity where a Covered Entity's total Payments exceed its total Charges in a billing period.

Remittance Advice Date is the day on which the ISO issues a Remittance Advice.

Renewable Technology Resource is a Generating Capacity Resource or an On-Peak Demand Resource that satisfies the requirements specified in Section III.13.1.1.1.7.

Re-Offer Period is the period that normally occurs between the posting of the of the Day-Ahead Energy Market results and 2:00 p.m. on the day before the Operating Day during which a Market Participant may submit revised Supply Offers, revised External Transactions, or revised Demand Bids associated with Dispatchable Asset Related Demands or, revised Demand Reduction Offers associated with Demand Response Resources.

Replacement Reserve is described in Part III, Section VII of ISO New England Operating Procedure No. 8.

Request for Alternative Proposals (RFAP) is the request described in Attachment K of the OATT.

Requested Billing Adjustment (RBA) is defined in Section 6.1 of the ISO New England Billing Policy.

Required Balance is an amount as defined in Section 5.3 of the Billing Policy.

Reseller is a MGTSA holder that sells, assigns or transfers its rights under its MGTSA, as described in Section II.45.1(a) of the OATT.

Reserve Adequacy Analysis is the analysis performed by the ISO to determine if adequate Resources are committed to meet forecasted load, Operating Reserve, and security constraint requirements for the current and next Operating Day.

Reserve Constraint Penalty Factors (RCPFs) are rates, in $/MWh, that are used within the Real-Time dispatch and pricing algorithm to reflect the value of Operating Reserve shortages and are defined in Section III.2.7A(c) of Market Rule 1.

Reserve Quantity For Settlement is defined in Section III.10.1 of Market Rule 1.

Reserve Zone is defined in Section III.2.7 of Market Rule 1.

Reserved Capacity is the maximum amount of capacity and energy that is committed to the Transmission Customer for transmission over the New England Transmission System between the Point(s) of Receipt and the Point(s) of Delivery under Part II.C or Schedule 18, 20 or 21 of the OATT, as applicable. Reserved Capacity shall be expressed in terms of whole kilowatts on a sixty-minute interval (commencing on the clock hour) basis, or, in the case of Reserved Capacity for Local Point-to-Point Service, in terms of whole megawatts on a sixty-minute interval basis.

Resource means a Generator Asset, a Dispatchable Asset Related Demand, an External Resource, an External Transaction, or a Demand Response Resource.

Restated New England Power Pool Agreement (RNA) is the Second Restated New England Power Pool Agreement, which restated for a second time by an amendment dated as of August 16, 2004 the New England Power Pool Agreement dated September 1, 1971, as the same may be amended and restated from time to time, governing the relationship among the NEPOOL members.

Rest-of-Pool Capacity Zone is a single Capacity Zone made up of the adjacent Load Zones that are neither export-constrained nor import-constrained.

Rest of System is an area established under Section III.2.7(d) of Market Rule 1.

Retail Delivery Point is the point on the transmission or distribution system at which the load of an end-use facility, which is metered and assigned a unique account number by the Host Participant, is measured to determine the amount of energy delivered to the facility from the transmission and distribution system. If an end-use facility is connected to the transmission or distribution system at more than one location, the Retail Delivery Point shall consist of the metered load at each connection point, summed to measure the net energy delivered to the facility in each interval.

Retirement De-List Bid is a bid to retire an Existing Generating Capacity Resource, Existing Import Capacity Resource, or Existing Demand Capacity Resource from all New England Markets, as described in Section III.13.1.2.3.1.5.

Returning Market Participant is a Market Participant, other than an FTR-Only Customer or a Governance Only Member, whose previous membership as a Market Participant was involuntarily terminated due to a Financial Assurance Default or a payment default and, since returning, has been a Market Participant for less than six consecutive months.

Revenue Requirement is defined in Section IV.A.2.1 of the Tariff.

Reviewable Action is defined in Section III.D.1.1 of Appendix D of Market Rule 1.

Reviewable Determination is defined in Section 12.4(a) of Attachment K to the OATT.

Round-Trip Efficiency is a percentage expressing the megawatt-hours of energy that an Electric Storage Facility injects onto the grid per megawatt-hour of energy it receives from the grid.

RSP Project List is defined in Section 1 of Attachment K to the OATT.

RTEP02 Upgrade(s) means a Transmission Upgrade that was included in the annual NEPOOL Transmission Plan (also known as the "Regional Transmission Expansion Plan" or "RTEP") for the year 2002, as approved by ISO New England Inc.'s Board of Directors, or the functional equivalent of such Transmission Upgrade, as determined by ISO New England Inc. The RTEP02 Upgrades are listed in Schedule 12B of the OATT.

RTO is a regional transmission organization or comparable independent transmission organization that complies with Order No. 2000 and the Commission's corresponding regulation.

Same Reserve Zone Export Transaction is defined in Section III.1.10.7(f)(iii) of Market Rule 1.

Sanctionable Behavior is defined in Section III.B.3 of Appendix B of Market Rule 1.

Schedule, Schedules, Schedule 1, 2, 3, 4 and 5 are references to the individual or collective schedules to Section IV.A. of the Tariff.

Schedule 20A Service Provider (SSP) is defined in Schedule 20A to Section II of this Tariff.

Scheduling Service, for purposes of Section IV.A and Section IV.B of the Tariff, is the service described in Schedule 1 to Section IV.A of the Tariff.

Scheduling, System Control and Dispatch Service, for purposes of Section II of the Tariff, is the form of Ancillary Service described in Schedule 1 of the OATT.

Seasonal Claimed Capability is the summer or winter claimed capability of a Generator Asset or Generating Capacity Resource, and represents the maximum dependable load carrying ability of the asset or resource, excluding capacity required for station use.

Seasonal Claimed Capability Audit is the Generator Asset audit performed pursuant to Section III.1.5.1.3.

Seasonal DR Audit is the Demand Response Resource audit performed pursuant to Section III.1.5.1.3.1.

Seasonal Peak Demand Resource is a type of Demand Capacity Resource and shall mean installed measures (e.g., products, equipment, systems, services, practices and/or strategies) on end-use customer facilities that reduce the total amount of electrical energy consumed during Demand Resource Seasonal Peak Hours, while delivering a comparable or acceptable level of end-use service. Such measures include Energy Efficiency, Load Management, and Distributed Generation.

Section III.1.4 Transactions are defined in Section III.1.4.2 of Market Rule 1.

Section III.1.4 Conforming Transactions are defined in Section III.1.4.2 of Market Rule 1.

Security Agreement is Attachment 1 to the ISO New England Financial Assurance Policy.

Selected Qualified Transmission Project Sponsor is the Qualified Transmission Project Sponsor that proposed the Phase Two or Stage Two Solution that has been identified by the ISO as the preferred Phase Two or Stage Two Solution.

Selected Qualified Transmission Project Sponsor Agreement is the agreement between the ISO and a Selected Qualified Transmission Project Sponsor. The Selected Qualified Transmission Project Sponsor Agreement is provided in Attachment P to the OATT.

Self-Schedule is the action of a Market Participant in committing its Generator Asset or DARD, in accordance with applicable ISO New England Manuals, to provide service in an hour, whether or not in the absence of that action the Generator Asset or DARD would have been committed by the ISO to provide the service. For a Generator Asset, Self-Schedule is the action of a Market Participant in committing a Generator Asset to provide Energy in an hour at its Economic Minimum Limit, whether or not in the absence of that action the Generator Asset would have been committed by the ISO to provide the Energy. For a DARD, Self-Schedule is the action of a Market Participant in committing a DARD to consume Energy in an hour at its Minimum Consumption Limit, whether or not in the absence of that action the DARD would have been committed by the ISO to consume Energy. For an External Transaction, a Self-Schedule is a request by a Market Participant for the ISO to select the External Transaction regardless of the LMP. Demand Response Resources are not permitted to Self-Schedule.

Self-Supplied FCA Resource is described in Section III.13.1.6 of Market Rule 1.

Senior Officer means an officer of the subject entity with the title of vice president (or similar office) or higher, or another officer designated in writing to the ISO by that office.

Service Agreement is a Transmission Service Agreement or an MPSA.

Service Commencement Date is the date service is to begin pursuant to the terms of an executed Service Agreement, or the date service begins in accordance with the sections of the OATT addressing the filing of unexecuted Service Agreements.

Services means, collectively, the Scheduling Service, EAS and RAS; individually, a Service.

Settlement Financial Assurance is an amount of financial assurance required from a Designated FTR Participant awarded a bid in an FTR Auction. This amount is calculated pursuant to Section VI.C of the ISO New England Financial Assurance Policy.

Settlement Only Resources are generators of less than 5 MW of maximum net output when operating at any temperature at or above zero degrees Fahrenheit, that meet the metering, interconnection and other requirements in ISO New England Operating Procedure No. 14 and that have elected Settlement Only Resource treatment as described in the ISO New England Manual for Registration and Performance Auditing.

Shortfall Funding Arrangement, as specified in Section 5.1 of the ISO New England Billing Policy, is a separate financing arrangement that can be used to make up any non-congestion related differences between amounts received on Invoices and amounts due for ISO Charges in any bill issued.

Short-Term is a period of less than one year.

Significantly Reduced Congestion Costs are defined in Section III.G.2.2 of Appendix G to Market Rule 1.

SMD Effective Date is March 1, 2003.

Solutions Study is described in Section 4.2(b) of Attachment K to the OATT.

Special Constraint Resource (SCR) is a Resource that provides Special Constraint Resource Service under Schedule 19 of the OATT.

Special Constraint Resource Service is the form of Ancillary Service described in Schedule 19 of the OATT.

Specified-Term Blackstart Capital Payment is the annual compensation level, as calculated pursuant to Section 5.1 of Schedule 16 of the OATT, for a Designated Blackstart Resource's capital Blackstart Equipment costs associated with the provision of Blackstart Service (except for capital costs associated with adhering to NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Sponsored Policy Resource is a New Capacity Resource that: receives an out-of-market revenue source supported by a government-regulated rate, charge or other regulated cost recovery mechanism, and; qualifies as a renewable, clean or alternative energy resource under a renewable energy portfolio standard,

clean energy standard, alternative energy portfolio standard, renewable energy goal, or clean energy goal enacted (either by statute or regulation) in the New England state from which the resource receives the out-of-market revenue source and that is in effect on January 1, 2018.

Stage One Proposal is a first round submission, as defined in Sections 4A.5 of Attachment K of the OATT, of a proposal for a Public Policy Transmission Upgrade by a Qualified Transmission Project Sponsor.

Stage Two Solution is a second round submission, as defined in Section 4A.5 of Attachment K of the OATT, of a proposal for a Public Policy Transmission Upgrade by a Qualified Transmission Project Sponsor.

Standard Blackstart Capital Payment is the annual compensation level, as calculated pursuant to Section 5.1 of Schedule 16 of the OATT, for a Designated Blackstart Resource's capital Blackstart Equipment costs associated with the provision of Blackstart Service (except for capital costs associated with adhering to NERC Critical Infrastructure Protection Reliability Standards as part of Blackstart Service).

Start-of-Round Price is the highest price associated with a round of a Forward Capacity Auction as described in Section III.13.2.3.1 of Market Rule 1.

Start-Up Fee is the amount, in dollars, that must be paid for a Generator Asset to Market Participants with an Ownership Share in the Generator Asset each time the Generator Asset is scheduled in the New England Markets to start-up.

Start-Up Time is the time it takes the Generator Asset, after synchronizing to the system, to reach its Economic Minimum Limit and, for dispatchable Generator Assets, be ready for further dispatch by the ISO.

State Estimator means the computer model of power flows specified in Section III.2.3 of Market Rule 1.

State of Charge is the total quantity of megawatt-hours available to be injected by an Electric Storage Facility onto the grid.

Statements, for the purpose of the ISO New England Billing Policy, refer to both Invoices and Remittance Advices.

Static De-List Bid is a bid that may be submitted by an Existing Generating Capacity Resource, Existing Import Capacity Resource, or Existing Demand Capacity Resource in the Forward Capacity Auction to remove itself from the capacity market for a one year period, as described in Section III.13.1.2.3.1.1 of Market Rule 1.

Station is one or more Existing Generating Capacity Resources consisting of one or more assets located within a common property boundary.

Station Going Forward Common Costs are the net costs associated with a Station that are avoided only by the clearing of the Static De-List Bids, the Permanent De-List Bids or the Retirement De-List Bids of all the Existing Generating Capacity Resources comprising the Station.

Station-level Blackstart O&M Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Station-level Specified-Term Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Station-level Standard Blackstart Capital Payment is defined and calculated as specified in Section 5.1.2 of Schedule 16 to the OATT.

Storage DARD is a DARD that participates in the New England Markets as part of an Electric Storage Facility, as described in Section III.1.10.6 of Market Rule 1.

Summer ARA Qualified Capacity is described in Section III.13.4.2.1.2.1.1.1 of Market Rule 1.

Summer Capability Period means one of two time periods defined by the ISO for the purposes of rating and auditing resources pursuant to Section III.9. The time period associated with the Summer Capability Period is the period of June 1 through September 30.

Summer Intermittent Reliability Hours are defined in Section III.13.1.2.2.2.1(c) of Market Rule 1.

Supply Offer is a proposal to furnish energy at a Node or Regulation from a Resource that meets the applicable requirements set forth in the ISO New England Manuals submitted to the ISO by a Market Participant with authority to submit a Supply Offer for the Resource. The Supply Offer will be submitted pursuant to Market Rule 1 and applicable ISO New England Manuals, and include a price and information with respect to the quantity proposed to be furnished, technical parameters for the Resource, timing and other matters. A Supply Offer is a subset of the information required in a Market Participant's Offer Data.

Supply Offer Block-Hours are Block-Hours assigned to the Lead Market Participant for each Supply Offer. Blocks of the Supply Offer in effect for each hour will be totaled to determine the quantity of Supply Offer Block-Hours for a given day. In the case that a Resource has a Real-Time unit status of "unavailable" for the entire day, that day will not contribute to the quantity of Supply Offer Block-Hours. However, if the Resource has at least one hour of the day with a unit status of "available," the entire day will contribute to the quantity of Supply Offer Block-Hours.

Synchronous Condenser is a generator that is synchronized to the grid but supplying no energy for the purpose of providing Operating Reserve or VAR or voltage support.

System Condition is a specified condition on the New England Transmission System or on a neighboring system, such as a constrained transmission element or flowgate, that may trigger Curtailment of Long-Term Firm MTF or OTF Service on the MTF or the OTF using the curtailment priority pursuant to Section II.44 of the Tariff or Curtailment of Local Long-Term Firm Point-to-Point Transmission Service on the non-PTF using the curtailment priority pursuant to Schedule 21 of the Tariff. Such conditions must be identified in the Transmission Customer's Service Agreement.

System Impact Study is an assessment pursuant to Part II.B, II.C, II.G, Schedule 21, Schedule 22, Schedule 23, or Schedule 25 of the OATT of (i) the adequacy of the PTF or Non-PTF to accommodate a request for the interconnection of a new or materially changed generating unit or a new or materially changed interconnection to another Control Area or new Regional Network Service or new Local Service or an Elective Transmission Upgrade, and (ii) whether any additional costs may be required to be incurred in order to provide the interconnection or transmission service.

System Operator shall mean ISO New England Inc. or a successor organization.

System Operating Limit (SOL) has the meaning specified in the Glossary of Terms Used in NERC Reliability Standards.

System-Wide Capacity Demand Curve is the demand curve used in the Forward Capacity Market as specified in Section III.13.2.2.

TADO is the total amount due and owing (not including any amounts due under Section 14.1 of the RNA) at such time to the ISO, NEPOOL, the PTOs, the Market Participants and the Non-Market Participant Transmission Customers, by all PTOs, Market Participants and Non-Market Participant Transmission Customers.

Tangible Net Worth is the value, determined in accordance with international accounting standards or generally accepted accounting principles in the United States, of all of that entity's assets less the following: (i) assets the ISO reasonably believes to be restricted or potentially unavailable to settle a claim in the event of a default (e.g., regulatory assets, restricted assets, and Affiliate assets), net of any matching liabilities, to the extent that the result of that netting is a positive value; (ii) derivative assets, net of any matching liabilities, to the extent that the result of that netting is a positive value; (iii) the amount at which the liabilities of the entity would be shown on a balance sheet in accordance with international accounting standards or generally accepted accounting principles in the United States; (iv) preferred stock: (v) non-controlling interest; and (vi) all of that entity's intangible assets (e.g., patents, trademarks, franchises, intellectual property, goodwill and any other assets not having a physical existence), in each case as shown on the most recent financial statements provided by such entity to the ISO.

Technical Committee is defined in Section 8.2 of the Participants Agreement.

Ten-Minute Non-Spinning Reserve (TMNSR) is a form of ten-minute reserve capability, determined pursuant to Section III.1.7.19.2.

Ten-Minute Non-Spinning Reserve Service is the form of Ancillary Service described in Schedule 6 of the OATT.

Ten-Minute Reserve Requirement is the combined amount of TMSR and TMNSR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Ten-Minute Spinning Reserve (TMSR) is a form of ten-minute reserve capability, determined pursuant to Section III.1.7.19.2.

Ten-Minute Spinning Reserve Requirement is the amount of TMSR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Ten-Minute Spinning Reserve Service is the form of Ancillary Service described in Schedule 5 of the OATT.

Third-Party Sale is any sale for resale in interstate commerce to a Power Purchaser that is not designated as part of Regional Network Load or Local Network Load under the Regional Network Service or Local Network Service, as applicable.

Thirty-Minute Operating Reserve (TMOR) is a form of thirty-minute reserve capability, determined pursuant to Section III.1.7.19.2.

Thirty-Minute Operating Reserve Service is the form of Ancillary Service described in Schedule 7 of the OATT.

Through or Out Rate (TOUT Rate) is the rate per hour for Through or Out Service, as defined in Section II.25.2 of the OATT.

Through or Out Service (TOUT Service) means Point-To-Point Service over the PTF provided by the ISO with respect to a transaction that goes through the New England Control Area, as, for example, a single transaction where energy or capacity is transmitted into the New England Control Area from New Brunswick and subsequently out of the New England Control Area to New York, or a single transaction where energy or capacity is transmitted into the New England Control Area from New York through one point on the PTF and subsequently flows over the PTF prior to passing out of the New England Control Area to New York, or with respect to a transaction which originates at a point on the PTF and flows over the PTF prior to passing out of the New England Control Area, as, for example, from Boston to New York.

Tie-Line Asset is a physical transmission tie-line, or an inter-state or intra-state border arrangement created according to the ISO New England Manuals and registered in accordance with the Asset Registration Process.

Total Available Amount is the sum of the available amount of the Shortfall Funding Arrangement and the balance in the Payment Default Shortfall Fund.

Total Blackstart Capital Payment is the annual compensation calculated under either Section 5.1 or Section 5.2 of Schedule 16 of the OATT, as applicable.

Total Blackstart Service Payments is monthly compensation to Blackstart Owners or Market Participants, as applicable, and as calculated pursuant to Section 5.6 of Schedule 16 to the OATT.

Total Reserve Requirement, which includes Replacement Reserve, is the combined amount of TMSR, TMNSR, and TMOR required system-wide as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

Total System Capacity is the aggregate capacity supply curve for the New England Control Area as determined in accordance with Section III.13.2.3.3 of Market Rule 1.

Transaction Unit (TU) is a type of billing determinant under Schedule 2 of Section IV.A of the Tariff used to assess charges to Customers.

Transition Period: The six-year period commencing on March 1, 1997.

Transmission Charges, for the purposes of the ISO New England Financial Assurance Policy and the ISO New England Billing Policy, are all charges and payments under Schedules 1, 8 and 9 of the OATT.

Transmission Congestion Credit means the allocated share of total Transmission Congestion Revenue credited to each holder of Financial Transmission Rights, calculated and allocated as specified in Section III.5.2 of Market Rule 1.

Transmission Congestion Revenue is defined in Section III.5.2.5(a) of Market Rule 1.

Transmission Constraint Penalty Factors are described in Section III.1.7.5 of Market Rule 1.

Transmission Credit Limit is a credit limit, not to be used to meet FTR Requirements, established for each Market Participant in accordance with Section II.D and each Non-Market Participant Transmission Customer in accordance with Section V.B.2 of the ISO New England Financial Assurance Policy.

Transmission Credit Test Percentage is calculated in accordance with Section III.B.1(c) of the ISO New England Financial Assurance Policy.

Transmission Customer is any Eligible Customer that (i) executes, on its own behalf or through its Designated Agent, an MPSA or TSA, or (ii) requests in writing, on its own behalf or through its Designated Agent, that the ISO, the Transmission Owner, or the Schedule 20A Service Provider, as applicable, file with the Commission, a proposed unexecuted MPSA or TSA containing terms and conditions deemed appropriate by the ISO (in consultation with the applicable PTO, OTO or Schedule 20A Service Provider) in order that the Eligible Customer may receive transmission service under Section II of this Tariff. A Transmission Customer under Section II of this Tariff includes a Market Participant or a Non-Market Participant taking Regional Network Service, Through or Out Service, MTF Service, OTF Service, Ancillary Services, or Local Service.

Transmission Default Amount is all or any part of any amount of Transmission Charges due to be paid by any Covered Entity that the ISO, in its reasonable opinion, believes will not or has not been paid when due.

Transmission Default Period is defined in Section 3.4.f of the ISO New England Billing Policy.

Transmission Late Payment Account is defined in Section 4.2 of the ISO New England Billing Policy.

Transmission Late Payment Account Limit is defined in Section 4.2 of the ISO New England Billing Policy.

Transmission Late Payment Charge is defined in Section 4.1 of the ISO New England Billing Policy.

Transmission, Markets and Services Tariff (Tariff) is the ISO New England Inc. Transmission, Markets and Services Tariff, as amended from time to time.

Transmission Obligations are determined in accordance with Section III.A(vi) of the ISO New England Financial Assurance Policy.

Transmission Operating Agreement (TOA) is the Transmission Operating Agreement between and among the ISO and the PTOs, as amended and restated from time to time.

Transmission Owner means a PTO, MTO or OTO.

Transmission Provider is the ISO for Regional Network Service and Through or Out Service as provided under Section II.B and II.C of the OATT; Cross-Sound Cable, LLC for Merchant Transmission Service as provided under Schedule 18 of the OATT; the Schedule 20A Service Providers for Phase I/II HVDC-TF Service as provided under Schedule 20A of the OATT; and the Participating Transmission Owners for Local Service as provided under Schedule 21 of the OATT.

Transmission Requirements are determined in accordance with Section III.A(iii) of the ISO New England Financial Assurance Policy.

Transmission Security Analysis Requirement shall be determined pursuant to Section III.12.2.1.2.

Transmission Service Agreement (TSA) is the initial agreement and any amendments or supplements thereto: (A) in the form specified in either Attachment A or B to the OATT, entered into by the Transmission Customer and the ISO for Regional Network Service or Through or Out Service; (B) entered into by the Transmission Customer with the ISO and PTO in the form specified in Attachment A to Schedule 21 of the OATT; (C) entered into by the Transmission Customer with an OTO or Schedule 20A Service Provider in the appropriate form specified under Schedule 20 of the OATT; or (D) entered into by the Transmission Customer with a MTO in the appropriate form specified under Schedule 18 of the OATT. A Transmission Service Agreement shall be required for Local Service, MTF Service and OTF Service, and shall be required for Regional Network Service and Through or Out Service if the Transmission Customer has not executed a MPSA.

Transmission Upgrade(s) means an upgrade, modification or addition to the PTF that becomes subject to the terms and conditions of the OATT governing rates and service on the PTF on or after January 1,

2004. This categorization and cost allocation of Transmission Upgrades shall be as provided for in Schedule 12 of the OATT.

UDS is unit dispatch system software.

Unconstrained Export Transaction is defined in Section III.1.10.7(f)(iv) of Market Rule 1.

Uncovered Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Uncovered Transmission Default Amounts are defined in Section 3.4.f of the ISO New England Billing Policy.

Unrated means a Market Participant that is not a Rated Market Participant.

Unsecured Covered Entity is, collectively, an Unsecured Municipal Market Participant and an Unsecured Non-Municipal Covered Entity.

Unsecured Municipal Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Unsecured Municipal Market Participant is defined in Section 3.3(h) of the ISO New England Billing Policy.

Unsecured Municipal Transmission Default Amount is defined in Section 3.4.f of the ISO New England Billing Policy.

Unsecured Non-Municipal Covered Entity is a Covered Entity that is not a Municipal Market Participant or a Non-Market Participant Transmission Customer and has a Market Credit Limit or Transmission Credit Limit of greater than $0 under the ISO New England Financial Assurance Policy.

Unsecured Non-Municipal Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Unsecured Non-Municipal Transmission Default Amount is defined in Section 3.3(i) of the ISO New England Billing Policy.

Unsecured Transmission Default Amounts are, collectively, the Unsecured Municipal Transmission Default Amount and the Unsecured Non-Municipal Transmission Default Amount.

Unsettled FTR Financial Assurance is an amount of financial assurance required from a Designated FTR Participant as calculated pursuant to Section VI.B of the ISO New England Financial Assurance Policy.

Updated Measurement and Verification Plan is an optional Measurement and Verification Plan that may be submitted as part of a subsequent qualification process for a Forward Capacity Auction prior to the beginning of the Capacity Commitment Period of the On-Peak Demand Resource or Seasonal Peak Demand Response project. The Updated Measurement and Verification Plan may include updated project specifications, measurement and verification protocols, and performance data as described in Section III.13.1.4.3.1.2 of Market Rule 1 and the ISO New England Manuals.

VAR CC Rate is the CC rate paid to Qualified Reactive Resources for VAR Service capability under Section IV.A of Schedule 2 of the OATT.

VAR Payment is the payment made to Qualified Reactive Resources for VAR Service capability under Section IV.A of Schedule 2 of the OATT.

VAR Service is the provision of reactive power voltage support to the New England Transmission System by a Qualified Reactive Resource or by other generators that are dispatched by the ISO to provide dynamic reactive power as described in Schedule 2 of the OATT.

Virtual Cap is $2,000/MWh.

Virtual Requirements are determined in accordance with Section III.A(iv) of the ISO New England Financial Assurance Policy.

Volt Ampere Reactive (VAR) is a measurement of reactive power.

Volumetric Measure (VM) is a type of billing determinant under Schedule 2 of Section IV.A of the Tariff used to assess charges to Customers under Section IV.A of the Tariff.

Winter ARA Qualified Capacity is described in Section III.13.4.2.1.2.1.1.2 of Market Rule 1.

Winter Capability Period means one of two time periods defined by the ISO for the purposes of rating and auditing resources pursuant to Section III.9. The time period associated with the Winter Capability Period is the period October 1 through May 31.

Winter Intermittent Reliability Hours are defined in Section III.13.1.2.2.2.2(c) of Market Rule 1.

Year means a period of 365 or 366 days, whichever is appropriate, commencing on, or on the anniversary of March 1, 1997. Year One is the Year commencing on March 1, 1997, and Years Two and higher follow it in sequence.

Zonal Price is calculated in accordance with Section III.2.7 of Market Rule 1.

Zonal Capacity Obligation is calculated in accordance with Section III.13.7.5.2 of Market Rule 1.

Zonal Reserve Requirement is the combined amount of TMSR, TMNSR, and TMOR required for a Reserve Zone as described in Section III.2.7A and ISO New England Operating Procedure No. 8.

STANDARD MARKET DESIGN

III.1 Market Operations

III.1.1 Introduction.

This Market Rule 1 sets forth the scheduling, other procedures, and certain general provisions applicable to the operation of the New England Markets within the New England Control Area. The ISO shall operate the New England Markets in compliance with NERC, NPCC and ISO reliability criteria. The ISO is the Counterparty for agreements and transactions with its Customers (including assignments involving Customers), including bilateral transactions described in Market Rule 1, and sales to the ISO and/or purchases from the ISO of energy, reserves, Ancillary Services, capacity, demand/load response, FTRs and other products, paying or charging (if and as applicable) its Customers the amounts produced by the pertinent market clearing process or through the other pricing mechanisms described in Market Rule 1. The bilateral transactions to which the ISO is the Counterparty (subject to compliance with the requirements of Section III.1.4) include, but are not limited to, Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). Notwithstanding the foregoing, the ISO will not act as Counterparty for the import into the New England Control Area, for the use of Publicly Owned Entities, of: (1) energy, capacity, and ancillary products associated therewith, to which the Publicly Owned Entities are given preference under Articles 407 and 408 of the project license for the New York Power Authority's Niagara Project; and (2) energy, capacity, and ancillary products associated therewith, to which Publicly Owned Entities are entitled under Article 419 of the project license for the New York Power Authority's Franklin D. Roosevelt – St. Lawrence Project. This Market Rule 1 addresses each of the three time frames pertinent to the daily operation of the New England Markets: "Pre-scheduling" as specified in Section III.1.9, "Scheduling" as specified in III.1.10, and "Dispatch" as specified in III.1.11. This Market Rule 1 became effective on February 1, 2005.

III.1.2 [Reserved.]

III.1.3 Definitions.

Whenever used in Market Rule 1, in either the singular or plural number, capitalized terms shall have the meanings specified in Section I of the Tariff. Terms used in Market Rule 1 that are not defined in Section

I shall have the meanings customarily attributed to such terms by the electric utility industry in New England or as defined elsewhere in the ISO New England Filed Documents. Terms used in Market Rule 1 that are defined in Section I are subject to the 60% Participant Vote threshold specified in Section 11.1.2 of the Participants Agreement.

III.1.3.1 [Reserved.]

III.1.3.2 [Reserved.]

III.1.3.3 [Reserved.]

III.1.4 Requirements for Certain Transactions.

III.1.4.1 ISO Settlement of Certain Transactions.

The ISO will settle, and act as Counterparty to, the transactions described in Section III.1.4.2 if the transactions (and their related transactions) conform to, and the transacting Market Participants comply with, the requirements specified in Section III.1.4.3.

III.1.4.2 Transactions Subject to Requirements of Section III.1.4.

Transactions that must conform to the requirements of Section III.1.4 include: Internal Bilaterals for Load, Internal Bilaterals for Market for Energy, Annual Reconfiguration Transactions, Capacity Supply Obligation Bilaterals, Capacity Load Obligation Bilaterals, Capacity Performance Bilaterals, and the transactions described in Sections III.9.4.1 (internal bilateral transactions that transfer Forward Reserve Obligations), and III.13.1.6 (Self-Supplied FCA Resources). The foregoing are referred to collectively as "Section III.1.4 Transactions," and individually as a "Section III.1.4 Transaction." Transactions that conform to the standards are referred to collectively as "Section III.1.4 Conforming Transactions," and individually as a "Section III.1.4 Conforming Transaction."

III.1.4.3 Requirements for Section III.1.4 Conforming Transactions.

(a) To qualify as a Section III.1.4 Conforming Transaction, a Section III.1.4 Transaction must constitute an exchange for an off-market transaction (a "Related Transaction"), where the Related Transaction:

(i) is not cleared or settled by the ISO as Counterparty;

(ii) is a spot, forward or derivatives contract that contemplates the transfer of energy or a MW obligation to or from a Market Participant;

(iii) involves commercially appropriate obligations that impose a duty to transfer electricity or a MW obligation from the seller to the buyer, or from the buyer to the seller, with performance taking place within a reasonable time in accordance with prevailing cash market practices; and

(iv) is not contingent on either party to carry out the Section III.1.4 Transaction.

(b) In addition, to qualify as a Section III.1.4 Conforming Transaction:

(i) the Section III.1.4 Transaction must be executed between separate beneficial owners or separate parties trading for independently controlled accounts;

(ii) the Section III.1.4 Transaction and the Related Transaction must be separately identified in the records of the parties to the transactions; and

(iii) the Section III.1.4 Transaction must be separately identified in the records of the ISO.

(c) As further requirements:

(i) each party to the Section III.1.4 Transaction and Related Transaction must maintain, and produce upon request of the ISO, records demonstrating compliance with the requirements of Sections III.1.4.3(a) and (b) for the Section III.1.4 Transaction, the Related Transaction and any other transaction that is directly related to, or integrated in any way with, the Related Transaction, including the identity of the counterparties and the material economic terms of the transactions including their price, tenor, quantity and execution date; and

(ii) each party to the Section III.1.4 Transaction must be a Market Participant that meets all requirements of the ISO New England Financial Assurance Policy.

III.1.5 Resource Auditing.

III.1.5.1 Claimed Capability Audits.

III.1.5.1.1 General Audit Requirements.

(a) The following types of Claimed Capability Audits may be performed:

(i) An Establish Claimed Capability Audit establishes the Generator Asset's ability to respond to ISO Dispatch Instructions and to maintain performance at a specified output level for a specified duration.

(ii) A Seasonal Claimed Capability Audit determines a Generator Asset's capability to perform under specified summer and winter conditions for a specified duration.

(iii) A Seasonal DR Audit determines the ability of a Demand Response Resource to perform during specified months for a specified duration.

(iv) An ISO-Initiated Claimed Capability Audit is conducted by the ISO to verify the Generator Asset's Establish Claimed Capability Audit value or the Demand Response Resource's Seasonal DR Audit value.

(b) The Claimed Capability Audit value of a Generator Asset shall reflect any limitations based upon the interdependence of common elements between two or more Generator Assets such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(c) The Claimed Capability Audit value of gas turbine, combined cycle, and pseudo-combined cycle assets shall be normalized to standard 90° (summer) and 20° (winter) temperatures.

(d) The Claimed Capability Audit value for steam turbine assets with steam exports, combined cycle, or pseudo-combined cycle assets with steam exports where steam is exported for uses external to the electric power facility, shall be normalized to the facility's Seasonal Claimed Capability steam demand.

(e) A Claimed Capability Audit may be denied or rescheduled by the ISO if its performance will jeopardize the reliable operation of the electrical system.

III.1.5.1.2 Establish Claimed Capability Audit.

(a) An Establish Claimed Capability Audit may be performed only by a Generator Asset.

(b) The time and date of an Establish Claimed Capability Audit shall be unannounced.

(c) For a newly commercial Generator Asset:

(i) An Establish Claimed Capability Audit will be scheduled by the ISO within five Business Days of the commercial operation date for all Generator Assets except:

1. Non-intermittent daily cycle hydro;
2. Non-intermittent net-metered, or special qualifying facilities that do not elect to audit as described in Section III.1.5.1.3; and
3. Intermittent Generator Assets

(ii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iii) The Establish Claimed Capability Audit values shall be effective as of the commercial operation date of the Generator Asset.

(d) For Generator Assets with an Establish Claimed Capability Audit value:

(i) An Establish Claimed Capability Audit may be performed at the request of a Market Participant in order to support a change in the summer and winter Establish Claimed Capability Audit values for a Generator Asset.

(ii) An Establish Claimed Capability Audit shall be performed within five Business Days of the date of the request.

(iii) The Establish Claimed Capability Audit values for both summer and winter shall equal the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(iv) The Establish Claimed Capability Audit values become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(e) An Establish Claimed Capability Audit value may not exceed the maximum interconnected flow specified in the Network Resource Capability for the resource associated with the Generator Asset.

(f) Establish Claimed Capability Audits shall be performed on non-NERC holiday weekdays between 0800 and 2200.

(g) To conduct an Establish Claimed Capability Audit, the ISO shall:

(i) Initiate an Establish Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset's net output to increase from the current operating level to its Real-Time High Operating Limit.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) Begin the audit with the first full clock hour after sufficient time has been allowed for the asset to ramp, based on its offered ramp rate from its current operating point to reach its Real-Time High Operating Limit.

(h) An Establish Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an Establish Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4
Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4

Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(i) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.2(h).

III.1.5.1.3. Seasonal Claimed Capability Audits.

(a) A Seasonal Claimed Capability Audit may be performed only by a Generator Asset.

(b) A Seasonal Claimed Capability Audit must be conducted by all Generator Assets except:

(i) Non-intermittent daily hydro; and

(ii) Intermittent, net-metered, and special qualifying facilities. Non-intermittent net-metered and special qualifying facilities may elect to perform Seasonal Claimed Capability Audits pursuant to Section III.1.7.11(c)(iv).

(c) An Establish Claimed Capability Audit or ISO-Initiated Claimed Capability Audit that meets the requirements of a Seasonal Claimed Capability Audit in this Section III.1.5.1.3 may be used to fulfill a Generator Asset's Seasonal Claimed Capability Audit obligation.

(d) Except as provided in Section III.1.5.1.3(n) below, a summer Seasonal Claimed Capability Audit must be conducted:

(i) At least once every Capability Demonstration Year;

(ii) Either (1) at a mean ambient temperature during the audit that is greater than or equal to 80 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced summer Seasonal Claimed Capability Audit window.

(e) A winter Seasonal Claimed Capability Audit must be conducted:

(i) At least once in the previous three Capability Demonstration Years, except that a newly commercial Generator Asset which becomes commercial on or after:

(1) September 1 and prior to December 31 shall perform a winter Seasonal Claimed Capability Audit prior to the end of that Capability Demonstration Year.

(2) January 1 shall perform a winter Seasonal Claimed Capability Audit prior to the end of the next Capability Demonstration Year.

(ii) Either (1) at a mean ambient temperature during the audit that is less than or equal to 32 degrees Fahrenheit at the location of the Generator Asset, or (2) during an ISO-announced winter Seasonal Claimed Capability Audit window.

(f) A Seasonal Claimed Capability Audit shall be performed by operating the Generator Asset for the audit time period and submitting to the ISO operational data that meets the following requirements:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal Claimed Capability Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal Claimed Capability Audit and other relevant operating data.

(g) The Seasonal Claimed Capability Audit value (summer or winter) will be the mean net real power output demonstrated over the duration of the audit, as reflected in hourly revenue metering data, normalized for temperature and steam exports.

(h) The Seasonal Claimed Capability Audit value (summer or winter) shall be the most recent audit data submitted to the ISO meeting the requirements of this Section III.1.5.1.3. In the event that a Market Participant fails to submit Seasonal Claimed Capability Audit data to meet the timing requirements in Section III.1.5.1.3(d) and (e), the Seasonal Claimed Capability Audit value for the season shall be set to zero.

(i) The Seasonal Claimed Capability Audit value shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(j) A Seasonal Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for a Seasonal Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	2
Combined Cycle	2

Integrated Coal Gasification Combustion Cycle	2
Pressurized Fluidized Bed Combustion	2
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine-Reversible (Electric Storage) Hydraulic Turbine-Other	2
Hydro-Conventional Weekly	2
Fuel Cell	1
Other Electric Storage (Excludes Hydraulic Turbine - Reversible)	2

(k) A Generator Asset that is on a planned outage that was approved in the ISO's annual maintenance scheduling process during all hours that meet the temperature requirements for a Seasonal Claimed Capability Audit that is to be performed by the asset during that Capability Demonstration Year shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these auditing requirements;

(ii) Have its Seasonal Claimed Capability Audit value for the season set to zero; and

(iii) Perform the required Seasonal Claimed Capability Audit on the next available day that meets the Seasonal Claimed Capability Audit temperature requirements.

(l) A Generator Asset that does not meet the auditing requirements of this Section III.1.5.1.3 because (1) every time the temperature requirements were met at the Generator Asset's location the ISO denied the request to operate to full capability, or (2) the temperature requirements were not met at the Generator Asset's location during the Capability Demonstration Year during which the asset was required to perform a Seasonal Claimed Capability Audit during the hours 0700 to 2300 for each weekday excluding those weekdays that are defined as NERC holidays, shall:

(i) Submit to the ISO, prior to September 10, an explanation of the circumstances rendering it incapable of meeting these temperature requirements, including verifiable temperature data;

(ii) Retain the current Seasonal Claimed Capability Audit value for the season; and

(iii) Perform the required Seasonal Claimed Capability Audit during the next Capability Demonstration Year.

(m) The ISO may issue notice of a summer or winter Seasonal Claimed Capability Audit window for some or all of the New England Control Area if the ISO determines that weather forecasts indicate that temperatures during the audit window will meet the summer or winter Seasonal

Claimed Capability Audit temperature requirements. A notice shall be issued at least 48 hours prior to the opening of the audit window. Any audit performed during the announced audit window shall be deemed to meet the temperature requirement for the summer or winter audit. In the event that five or more audit windows for the summer Seasonal Claimed Capability Audit temperature requirement, each of at least a four hour duration between 0700 and 2300 and occurring on a weekday excluding those weekdays that are defined as NERC holidays, are not opened for a Generator Asset prior to August 15 during a Capability Demonstration Year, a two-week audit window shall be opened for that Generator Asset to perform a summer Seasonal Claimed Capability Audit, and any audit performed by that Generator Asset during the open audit window shall be deemed to meet the temperature requirement for the summer Seasonal Claimed Capability Audit. The open audit window shall be between 0700 and 2300 each day during August 15 through August 31.

(n) A Market Participant that is required to perform testing on a Generator Asset that is in addition to a summer Seasonal Claimed Capability Audit may notify the ISO that the summer Seasonal Claimed Capability Audit was performed in conjunction with this additional testing, provided that:

(i) The notification shall be provided at the time the Seasonal Claimed Capability Audit data is submitted under Section III.1.5.1.3(f).

(ii) The notification explains the nature of the additional testing and that the summer Seasonal Claimed Capability Audit was performed while the Generator Asset was online to perform this additional testing.

(iii) The summer Seasonal Claimed Capability Audit and additional testing are performed during the months of June, July or August between the hours of 0700 and 2300.

(iv) In the event that the summer Seasonal Claimed Capability Audit does not meet the temperature requirements of Section III.1.5.1.3(d)(ii), the summer Seasonal Claimed Capability Audit value may not exceed the summer Seasonal Claimed Capability Audit value from the prior Capability Demonstration Year.

(v) This Section III.1.5.1.3(n) may be utilized no more frequently than once every three Capability Demonstration Years for a Generator Asset.

(o) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for a Generator Asset of a type not listed in Section III.1.5.1.3(j).

III.1.5.1.3.1 Seasonal DR Audits.

(a) A Seasonal DR Audit may be performed only by a Demand Response Resource.

(b) A Seasonal DR Audit shall be performed for 12 contiguous five-minute intervals.

(c) A summer Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of April through November;

(d) A winter Seasonal DR Audit must be conducted by all Demand Response Resources:

(i) At least once every Capability Demonstration Year;

(ii) During the months of December through March.

(e) A Seasonal DR Audit may be performed either:

(i) At the request of a Market Participant as described in subsection (f) below; or

(ii) By the Market Participant designating a period of dispatch after the fact as described in subsection (g) below.

(f) If a Market Participant requests a Seasonal DR Audit:

(i) The ISO shall perform the Seasonal DR Audit at an unannounced time between 0800 and 2200 on non-NERC holiday weekdays within five Business Days of the date of the request.

(ii) The ISO shall initiate the Seasonal DR Audit by issuing a Dispatch Instruction ordering the Demand Response Resource to its Maximum Reduction.

(iii) The ISO shall indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iv) The ISO shall begin the audit with the start of the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(v) A Market Participant may cancel an audit request prior to issuance of the audit Dispatch Instruction.

(g) If the Seasonal DR Audit is performed by the designation of a period of dispatch after the fact, the designated period must meet all of the requirements in this Section III.1.5.1.3.1 and:

(i) The Market Participant must notify the ISO of its request to use the dispatch to satisfy the Seasonal DR Audit requirement by 5:00 p.m. on the fifth Business Day following the day on which the audit concludes.

(ii) The notification must include the date and time period of the demonstration to be used for the Seasonal DR Audit.

(iii) The demonstration period may begin with the start of any five-minute interval after the completion of the Demand Response Resource Notification Time.

(iv) A CLAIM10 audit or CLAIM30 audit that meets the requirements of a Seasonal DR Audit as provided in this Section III.1.5.1.3.1 may be used to fulfill the Seasonal DR Audit obligation of a Demand Response Resource.

(h) An ISO-Initiated Claimed Capability Audit fulfils the Seasonal DR Audit obligation of a Demand Response Resource.

(i) Each Demand Response Asset associated with a Demand Response Resource is evaluated during the Seasonal DR Audit of the Demand Response Resource.

(j) Any Demand Response Asset on a forced or scheduled curtailment as defined in Section III.8.3 is assessed a zero audit value.

(k) The Seasonal DR Audit value (summer or winter) of a Demand Response Resource resulting from the Seasonal DR Audit shall be the sum of the average demand reductions demonstrated during the audit by each of the Demand Response Resource's constituent Demand Response Assets.

(l) If a Demand Response Asset is added to or removed from a Demand Response Resource between audits, the Demand Response Resource's capability shall be updated to reflect the inclusion or exclusion of the audit value of the Demand Response Asset, such that at any point in time the summer or winter Seasonal DR Audit value of a Demand Response Resource shall equal the sum of the most recent valid like-season audit values of its constituent Demand Response Assets.

(m) The Seasonal DR Audit value shall become effective one calendar day following notification of the audit results to the Market Participant by the ISO.

(n) The summer or winter audit value of a Demand Response Asset shall be set to zero at the end of the Capability Demonstration Year if the Demand Response Asset did not perform a Seasonal DR Audit for that season as part of a Demand Response Resource during that Capability Demonstration Year.

(o) For a Demand Response Asset that was associated with a "Real-Time Demand Response Resource" or a "Real-Time Emergency Generation Resource," as those terms were defined prior to June 1, 2018, any valid result from an audit conducted prior to June 1, 2018 shall continue to be valid on June 1, 2018, and shall retain the same expiration date.

III.1.5.1.4. ISO-Initiated Claimed Capability Audits.

(a) An ISO-Initiated Claimed Capability Audit may be performed by the ISO at any time.

(b) An ISO-Initiated Claimed Capability Audit value shall replace either the summer or winter Seasonal DR Audit value for a Demand Response Resource and shall replace both the winter and summer Establish Claimed Capability Audit values for a Generator Asset, normalized for temperature and steam exports, except:

(i) The Establish Claimed Capability Audit values for a Generator Asset may not exceed the maximum interconnected flow specified in the Network Resource Capability for that resource.

(ii) An ISO-Initiated Claimed Capability Audit value for a Generator Asset shall not set the winter Establish Claimed Capability Audit value unless the ISO-Initiated Claimed Capability Audit was performed at a mean ambient temperature that is less than or equal to 32 degrees Fahrenheit at the Generator Asset location.

(c) If for a Generator Asset a Market Participant submits pressure and relative humidity data for the previous Establish Claimed Capability Audit and the current ISO-Initiated Claimed Capability Audit, the Establish Claimed Capability Audit values derived from the ISO-Initiated Claimed Capability Audit will be normalized to the pressure of the previous Establish Claimed Capability Audit and a relative humidity of 64%.

(d) The audit values derived from the ISO-Initiated Claimed Capability Audit shall become effective one Business Day following notification of the audit results to the Market Participant by the ISO.

(e) To conduct an ISO-Initiated Claimed Capability Audit, the ISO shall:

(i) Initiate an ISO-Initiated Claimed Capability Audit by issuing a Dispatch Instruction ordering the Generator Asset to its Real-Time High Operating Limit or the Demand Response Resource to its Maximum Reduction.

(ii) Indicate when issuing the Dispatch Instruction that an audit will be conducted.

(iii) For Generator Assets, begin the audit with the first full clock hour after sufficient time has been allowed for the Generator Asset to ramp, based on its offered ramp rate, from its current operating point to its Real-Time High Operating Limit.

(iv) For Demand Response Resources, begin the audit with the first five-minute interval after sufficient time has been allowed for the resource to ramp, based on its Demand Reduction Offer parameters, to its Maximum Reduction.

(f) An ISO-Initiated Claimed Capability Audit shall be performed for the following contiguous duration:

Duration Required for an ISO-Initiated Claimed Capability Audit	
Type	**Claimed Capability Audit Duration (Hrs)**
Steam Turbine (Includes Nuclear)	4
Combined Cycle	4

Integrated Coal Gasification Combustion Cycle	4
Pressurized Fluidized Bed Combustion	4
Combustion Gas Turbine	1
Internal Combustion Engine	1
Hydraulic Turbine – Reversible (Electric Storage) Hydraulic Turbine – Other	2
Hydro-Conventional Daily Pondage Hydro-Conventional Run of River Hydro-Conventional Weekly	2
Wind Photovoltaic Fuel Cell	2
Other Electric Storage (Excludes Hydraulic Turbine – Reversible)	2
Demand Response Resource	1

(g) The ISO, in consultation with the Market Participant, will determine the contiguous audit duration for an Asset or Resource type not listed in Section III.1.5.1.4(f).

III.1.5.2 ISO-Initiated Parameter Auditing.

(a) The ISO may perform an audit of any Supply Offer, Demand Reduction Offer or other operating parameter that impacts the ability of a Generator Asset or Demand Response Resource to provide real-time energy or reserves.

(b) Generator audits shall be performed using the following methods for the relevant parameter:

(i) **Economic Maximum Limit**. The Generator Asset shall be evaluated based upon its ability to achieve the current offered Economic Maximum Limit value, through a review of historical dispatch data or based on a response to a current ISO-issued Dispatch Instruction.

(ii) **Manual Response Rate**. The Generator Asset shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Manual Response Rate, including hold points and changes in Manual Response Rates.

(iii) **Start-Up Time**. The Generator Asset shall be evaluated based upon its ability to achieve the offered Start-Up Time.

(iv) **Notification Time**. The Generator Asset shall be evaluated based upon its ability to close its output breaker within its offered Notification Time.

(v) **CLAIM10**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Generator Asset shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(vii) **Automatic Response Rate**. The Generator Asset shall be analyzed, based upon a review of historical performance data, for its ability to respond to four-second electronic Dispatch Instructions.

(viii) **Dual Fuel Capability**. A Generator Asset that is capable of operating on multiple fuels may be required to audit on a specific fuel, as set out in Section III.1.5.2(f).

(c) Demand Response Resource audits shall be performed using the following methods:

(i) **Maximum Reduction**. The Demand Response Resource shall be evaluated based upon its ability to achieve the current offered Maximum Reduction value, through a review of historical dispatch data or based on a response to a current Dispatch Instruction.

(ii) **Demand Response Resource Ramp Rate**. The Demand Response Resource shall be evaluated based upon its ability to respond to Dispatch Instructions at its offered Demand Response Resource Ramp Rate.

(iii) **Demand Response Resource Start-Up Time**. The Demand Response Resource shall be evaluated based upon its ability to achieve its Minimum Reduction within the offered Demand Response Resource Start-Up Time, in response to a Dispatch Instruction and after completing its Demand Response Resource Notification Time.

(iv) **Demand Response Resource Notification Time**. The Demand Response Resource shall be evaluated based upon its ability to start reducing demand within its offered Demand Response Resource Notification Time, from the receipt of a Dispatch Instruction when the Demand Response Resource was not previously reducing demand.

(v) **CLAIM10**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM10 in accordance with Section III.9.5.

(vi) **CLAIM30**. The Demand Response Resource shall be evaluated based upon its ability to reach its CLAIM30 in accordance with Section III.9.5.

(d) To conduct an audit based upon historical data, the ISO shall:

(i) Obtain data through random sampling of generator or Demand Response Resource performance in response to Dispatch Instructions; or

(ii) Obtain data through continual monitoring of generator or Demand Response Resource performance in response to Dispatch Instructions.

(e) To conduct an unannounced audit, the ISO shall initiate the audit by issuing a Dispatch Instruction ordering the Generator Asset or Demand Response Resource to change from the current operating level to a level that permits the ISO to evaluate the performance of the Generator Asset or Demand Response Resource for the parameters being audited.

(f) To conduct an audit of the capability of a Generator Asset described in Section III.1.5.2(b)(viii) to run on a specific fuel:

(i) The ISO shall notify the Lead Market Participant if a Generator Asset is required to undergo an audit on a specific fuel. The ISO, in consultation with the Lead Market Participant, shall develop a plan for the audit.

(ii) The Lead Market Participant will have the ability to propose the time and date of the audit within the ISO's prescribed time frame and must notify the ISO at least five Business Days in advance of the audit, unless otherwise agreed to by the ISO and the Lead Market Participant.

(g) To the extent that the audit results indicate a Market Participant is providing Supply Offer, Demand Reduction Offer or other operating parameter values that are not representative of the actual capability of the Generator Asset or Demand Response Resource, the values for the Generator Asset or Demand Response Resource shall be restricted to those values that are supported by the audit.

(h) In the event that a Generator Asset or Demand Response Resource has had a parameter value restricted:

(i) The Market Participant may submit a restoration plan to the ISO to restore that parameter. The restoration plan shall:

1. Provide an explanation of the discrepancy;
2. Indicate the steps that the Market Participant will take to re-establish the parameter's value;
3. Indicate the timeline for completing the restoration; and
4. Explain the testing that the Market Participant will undertake to verify restoration of the parameter value upon completion.

(ii) The ISO shall:

1. Accept the restoration plan if implementation of the plan, including the testing plan, is reasonably likely to support the proposed change in the parameter value restriction;
2. Coordinate with the Market Participant to perform required testing upon completion of the restoration; and
3. Modify the parameter value restriction following completion of the restoration plan, based upon tested values.

III.1.5.3 Reactive Capability Audits.

(a) Two types of Reactive Capability Audits may be performed:

(i) A lagging Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to provide reactive power to the transmission system at a specified real power output or consumption.

(ii) A leading Reactive Capability Audit, which is an audit that measures a Reactive Resource's ability to absorb reactive power from the transmission system at a specified real power output or consumption.

(b) The ISO shall develop a list of Reactive Resources that must conduct Reactive Capability Audits. The list shall include Reactive Resources that: (i) have a gross individual nameplate rating greater than 20 MVA; (ii) are directly connected, or are connected through equipment designed primarily for delivering real or reactive power to an interconnection point, to the transmission system at a voltage of 100 kV or above; and (iii) are not exempted from providing voltage control by the ISO. Additional criteria to be used in adding a Reactive Resource to the list includes, but is not limited to, the effect of the Reactive Resource on System Operating Limits, Interconnection Reliability Operating Limits, and local area voltage limits during the following operating states: normal, emergency, and system restoration.

(c) Unless otherwise directed by the ISO, Reactive Resources that are required to perform Reactive Capability Audits shall perform both a lagging Reactive Capability Audit and a leading Reactive Capability Audit.

(d) All Reactive Capability Audits shall meet the testing conditions specified in the ISO New England Operating Documents.

(e) The Reactive Capability Audit value of a Reactive Resource shall reflect any limitations based upon the interdependence of common elements between two or more Reactive Resources such as: auxiliaries, limiting operating parameters, and the deployment of operating personnel.

(f) A Reactive Capability Audit may be denied or rescheduled by the ISO if conducting the Reactive Capability Audit could jeopardize the reliable operation of the electrical system.

(g) Reactive Capability Audits shall be conducted at least every five years, unless otherwise required by the ISO. The ISO may require a Reactive Resource to conduct Reactive Capability Audits more often than every five years if:

(i) there is a change in the Reactive Resource that may affect the reactive power capability of the Reactive Resource;

(ii) there is a change in electrical system conditions that may affect the achievable reactive power output or absorption of the Reactive Resource; or

(iii) historical data shows that the amount of reactive power that the Reactive Resource can provide to or absorb from the transmission system is higher or lower than the latest audit data.

(h) A Lead Market Participant or Transmission Owner may request a waiver of the requirement to conduct a Reactive Capability Audit for its Reactive Resource. The ISO, at its sole discretion, shall determine whether and for how long a waiver may be granted.

III.1.6 [Reserved.]

III.1.6.1 [Reserved.]

III.1.6.2 [Reserved.]

III.1.6.3 [Reserved.]

III.1.6.4 ISO New England Manuals and ISO New England Administrative Procedures.

The ISO shall prepare, maintain and update the ISO New England Manuals and ISO New England Administrative Procedures consistent with the ISO New England Filed Documents. The ISO New England Manuals and ISO New England Administrative Procedures shall be available for inspection by the Market Participants, regulatory authorities with jurisdiction over the ISO or any Market Participant, and the public.

III.1.7 General.

III.1.7.1 Provision of Market Data to the Commission.

The ISO will electronically deliver to the Commission, on an ongoing basis and in a form and manner consistent with its collection of data and in a form and manner acceptable to the Commission, data related to the markets that it administers, in accordance with the Commission's regulations.

III.1.7.2 [Reserved.]

III.1.7.3 Agents.

A Market Participant may participate in the New England Markets through an agent, provided that such Market Participant informs the ISO in advance in writing of the appointment of such agent. A Market Participant using an agent shall be bound by all of the acts or representations of such agent with respect to transactions in the New England Markets, and shall ensure that any such agent complies with the

requirements of the ISO New England Manuals and ISO New England Administrative Procedures and the ISO New England Filed Documents.

III.1.7.4 [Reserved.]

III.1.7.5 Transmission Constraint Penalty Factors.

In the Day-Ahead Energy Market, the Transmission Constraint Penalty Factor for an interface constraint is $10,000/MWh and the Transmission Constraint Penalty Factor for all other transmission constraints is $30,000/MWh. In the Real-Time Energy Market, the Transmission Constraint Penalty Factor for any transmission constraint is $30,000/MWh. Transmission Constraint Penalty Factors are not used in calculating Locational Marginal Prices.

III.1.7.6 Scheduling and Dispatching.

(a) The ISO shall schedule Day-Ahead and schedule and dispatch in Real-Time Resources economically on the basis of least-cost, security-constrained dispatch and the prices and operating characteristics offered by Market Participants. The ISO shall schedule and dispatch sufficient Resources of the Market Participants to serve the New England Markets energy purchase requirements under normal system conditions of the Market Participants and meet the requirements of the New England Control Area for ancillary services provided by such Resources. The ISO shall use a joint optimization process to serve Real-Time Energy Market energy requirements and meet Real-Time Operating Reserve requirements based on a least-cost, security-constrained economic dispatch.

(b) In the event that one or more Resources cannot be scheduled in the Day-Ahead Energy Market on the basis of a least-cost, security-constrained dispatch as a result of one or more Self-Schedule offers contributing to a transmission limit violation, the following scheduling protocols will apply:

(i) When a single Self-Schedule offer contributes to a transmission limit violation, the Self-Schedule offer will not be scheduled for the entire Self-Schedule period in development of Day-Ahead schedules.

(ii) When two Self-Schedule offers contribute to a transmission limit violation, parallel clearing solutions will be executed such that, for each solution, one of the Self-Schedule offers

will be omitted for its entire Self-Schedule period. The least cost solution will be used for purposes of determining which Resources are scheduled in the Day-Ahead Energy Market.

(iii) When three or more Self-Schedule offers contribute to a transmission limit violation, the ISO will determine the total daily MWh for each Self-Schedule offer and will omit Self-Schedule offers in their entirety, in sequence from the offer with the least total daily MWh to the offer with the greatest total MWh, stopping when the transmission limit violation is resolved.

(c) Scheduling and dispatch shall be conducted in accordance with the ISO New England Filed Documents.

(d) The ISO shall undertake, together with Market Participants, to identify any conflict or incompatibility between the scheduling or other deadlines or specifications applicable to the New England Markets, and any relevant procedures of another Control Area, or any tariff (including the Transmission, Markets and Services Tariff). Upon determining that any such conflict or incompatibility exists, the ISO shall propose tariff or procedural changes, or undertake such other efforts as may be appropriate, to resolve any such conflict or incompatibility.

III.1.7.7 Energy Pricing.

The price paid for energy, including demand reductions, bought and sold by the ISO in the New England Markets will reflect the Locational Marginal Price at each Location, determined by the ISO in accordance with the ISO New England Filed Documents. Congestion Costs, which shall be determined by differences in the Congestion Component of Locational Marginal Prices caused by constraints, shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1. Loss costs associated with Pool Transmission Facilities, which shall be determined by the differences in Loss Components of the Locational Marginal Prices shall be calculated and collected, and the resulting revenues disbursed, by the ISO in accordance with this Market Rule 1.

III.1.7.8 Market Participant Resources.

A Market Participant may elect to Self-Schedule its Resources in accordance with and subject to the limitations and procedures specified in this Market Rule 1 and the ISO New England Manuals.

III.1.7.9 Real-Time Reserve Prices.

The price paid by the ISO for the provision of Real-Time Operating Reserve in the New England Markets will reflect Real-Time Reserve Clearing Prices determined by the ISO in accordance with the ISO New England Filed Documents for the system and each Reserve Zone.

III.1.7.10 Other Transactions.

Market Participants may enter into internal bilateral transactions and External Transactions for the purchase or sale of energy or other products to or from each other or any other entity, subject to the obligations of Market Participants to make resources with a Capacity Supply Obligation available for dispatch by the ISO. External Transactions that contemplate the physical transfer of energy or obligations to or from a Market Participant shall be reported to and coordinated with the ISO in accordance with this Market Rule 1 and the ISO New England Manuals.

III.1.7.11 Seasonal Claimed Capability of a Generating Capacity Resource.

(a) A Seasonal Claimed Capability value must be established and maintained for all Generating Capacity Resources. A summer Seasonal Claimed Capability is established for use from June 1 through September 30 and a winter Seasonal Claimed Capability is established for use from October 1 through May 31.

(b) The Seasonal Claimed Capability of a Generating Capacity Resource is the sum of the Seasonal Claimed Capabilities of the Generator Assets that are associated with the Generating Capacity Resource.

(c) The Seasonal Claimed Capability of a Generator Asset is:

(i) Based upon review of historical data for non-intermittent daily cycle hydro.

(ii) The median net real power output during reliability hours, as described in Section III.13.1.2.2.2, for (1) intermittent facilities, and (2) net-metered and special qualifying facilities that do not elect to audit, as reflected in hourly revenue metering data.

(iii) For non-intermittent net-metered and special qualifying facilities that elect to audit, the minimum of (1) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3; (2) the Generator Asset's current Establish Claimed Capability Audit value; and (3) the median hourly availability during hours ending 2:00 p.m. through 6:00 p.m. each day of the preceding June through September for Summer and hours ending 6:00 p.m. and 7:00 p.m. each day of the preceding October through May for Winter. The hourly availability:

a. For a Generator Asset that is available for commitment and following Dispatch Instructions, shall be the asset's Economic Maximum Limit, as submitted or redeclared.

b. For a Generator Asset that is off-line and not available for commitment shall be zero.

c. For a Generator Asset that is on-line but not able to follow Dispatch Instructions, shall be the asset's metered output.

(iv) For all other Generator Assets, the minimum of: (1) the Generator Asset's current Establish Claimed Capability Audit value and (2) the Generator Asset's current Seasonal Claimed Capability Audit value, as performed pursuant to Section III.1.5.1.3.

III.1.7.12 Seasonal DR Audit Value of an Active Demand Capacity Resource.

(a) A Seasonal DR Audit value must be established and maintained for all Active Demand Capacity Resources. A summer Seasonal DR Audit value is established for use from April 1 through November 30 and a winter Seasonal DR Audit value is established for use from December 1 through March 31.

(b) The Seasonal DR Audit value of an Active Demand Capacity Resource is the sum of the Seasonal DR Audit values of the Demand Response Resources that are associated with the Active Demand Capacity Resource.

III.1.7.13 [Reserved.]

III.1.7.14 [Reserved.]

III.1.7.15 [Reserved.]

III.1.7.16 [Reserved.]

III.1.7.17 Operating Reserve.

The ISO shall endeavor to procure and maintain an amount of Operating Reserve in Real-Time equal to the system and zonal Operating Reserve requirements as specified in the ISO New England Manuals and ISO New England Administrative Procedures. Reserve requirements for the Forward Reserve Market are determined in accordance with the methodology specified in Section III.9.2 of Market Rule 1. Operating Reserve requirements for Real-Time dispatch within an Operating Day are determined in accordance with Market Rule 1 and ISO New England Operating Procedure No. 8, Operating Reserve and Regulation.

III.1.7.18 Ramping.

A Generator Asset, Dispatchable Asset Related Demand, or Demand Response Resource dispatched by the ISO pursuant to a control signal appropriate to increase or decrease the Resource's megawatt output, consumption, or demand reduction level shall be able to change output, consumption, or demand

reduction at the ramping rate specified in the Offer Data submitted to the ISO for that Resource and shall be subject to sanctions for failure to comply as described in **Appendix B**.

III.1.7.19 Real-Time Reserve Designation.

The ISO shall determine the Real-Time Reserve Designation for each eligible Resource in accordance with this Section III.1.7.19. The Real-Time Reserve Designation shall consist of a MW value, in no case less than zero, for each Operating Reserve product: Ten-Minute Spinning Reserve, Ten-Minute Non-Spinning Reserve, and Thirty-Minute Operating Reserve.

III.1.7.19.1 Eligibility.

To be eligible to receive a Real-Time Reserve Designation, a Resource must meet all of the criteria enumerated in this Section III.1.7.19.1. A Resource that does not meet all of these criteria is not eligible to provide Operating Reserve and will not receive a Real-Time Reserve Designation.

(1) The Resource must be a Dispatchable Resource located within the metered boundaries of the New England Control Area and capable of receiving and responding to electronic Dispatch Instructions.

(2) The Resource must not be part of the first contingency supply loss.

(3) The Resource must not be designated as constrained by transmission limitations.

(4) The Resource's Operating Reserve, if activated, must be sustainable for at least one hour from the time of activation. (This eligibility requirement does not affect a Resource's obligation to follow Dispatch Instructions, even after one hour from the time of activation.)

(5) The Resource must comply with the applicable standards and requirements for provision and dispatch of Operating Reserve as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

III.1.7.19.2 Calculation of Real-Time Reserve Designation.

III.1.7.19.2.1 Generator Assets.

III.1.7.19.2.1.1 On-line Generator Assets.

The Manual Response Rate used in calculations in this section shall be the lesser of the Generator Asset's offered Manual Response Rate and its audited Manual Response Rate as described in Section III.1.5.2.

(a) **Ten-Minute Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit). For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an on-line Generator Asset (other than one registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO), Ten-Minute Non-Spinning Reserve shall be zero. For an on-line Generator Asset registered as being composed of multiple generating units whose synchronized capability cannot be determined by the ISO, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within ten minutes given its Manual Response Rate (and in no case to a level greater than its Economic Maximum Limit).

(c) **Thirty-Minute Operating Reserve.** For an on-line Generator Asset, Thirty-Minute Operating Reserve shall be calculated as the increase in output the Generator Asset could achieve, relative to its current telemetered output, within thirty minutes given its Manual Response Rate (and in no case greater than its Economic Maximum Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Generator Asset pursuant to subsection (b) above.

III.1.7.19.2.1.2 Off-line Generator Assets.

For an off-line Generator Asset that is not a Fast Start Generator, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For an off-line Fast Start Generator, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Fast Start Generator's Offered CLAIM10, its CLAIM10, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Ten-Minute Non-Spinning Reserve shall be zero, except during the last ten minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Ten-Minute Non-Spinning Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires).

(c) **Thirty-Minute Operating Reserve.** For an off-line Fast Start Generator, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Fast Start Generator's Offered CLAIM30, its CLAIM30, and its Economic Maximum Limit (provided, however, that during the Fast Start Generator's Minimum Down Time, the Fast Start Generator's Thirty-Minute Operating Reserve shall be zero, except during the last thirty minutes of its Minimum Down Time, at which time the ISO will prorate the Fast Start Generator's Thirty-Minute Operating Reserve to account for the remaining amount of time until the Fast Start Generator's Minimum Down Time expires), minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Fast Start Generator pursuant to subsection (b) above.

III.1.7.19.2.2 Dispatchable Asset Related Demand.

III.1.7.19.2.2.1 Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Storage DARD, Ten-Minute Spinning Reserve shall be calculated as the absolute value of the amount of current telemetered consumption.

(b) **Ten-Minute Non-Spinning Reserve.** For a Storage DARD, Ten-Minute Non-Spinning Reserve shall be zero.

(c) **Thirty-Minute Operating Reserve.** For a Storage DARD, Thirty-Minute Operating Reserve shall be zero.

III.1.7.19.2.2.2 Dispatchable Asset Related Demand Other Than Storage DARDs.

(a) **Ten-Minute Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit). For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within ten minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit).

(c) **Thirty-Minute Operating Reserve.** For a Dispatchable Asset Related Demand (other than a Storage DARD) that has no Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (a) above. For a Dispatchable Asset Related Demand (other than a Storage DARD) having Controllable Behind-the-Meter Generation, Thirty-Minute Operating Reserve shall be calculated as the decrease in consumption that the Dispatchable Asset Related Demand could achieve, relative to its current telemetered consumption, within thirty minutes given its ramp rate (and in no case to an amount less than its Minimum Consumption Limit) minus the Ten-Minute Non-Spinning Reserve quantity calculated for the Dispatchable Asset Related Demand pursuant to subsection (b) above.

III.1.7.19.2.3 Demand Response Resources.

For a Demand Response Resource that does not provide one-minute telemetry to the ISO, notwithstanding any provision in this Section III.1.7.19.2.3 to the contrary, the Ten-Minute Spinning Reserve and Ten-Minute Non-Spinning Reserve components of the Real-Time Reserve Designation shall

be zero. The Demand Response Resource Ramp Rate used in calculations in this section shall be the lesser of the Resource's offered Demand Response Resource Ramp Rate and its audited Demand Response Resource Ramp Rate as described in Section III.1.5.2.

III.1.7.19.2.3.1 Dispatched.

(a) **Ten-Minute Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction). For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Demand Response Resource that is being dispatched and that has no Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be zero. For a Demand Response Resource that is being dispatched and that has Controllable Behind-the-Meter Generation, Ten-Minute Non-Spinning Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within ten minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction).

(c) **Thirty-Minute Operating Reserve.** For a Demand Response Resource that is being dispatched, Thirty-Minute Operating Reserve shall be calculated as the increase in demand reduction that the Demand Response Resource could achieve, relative to the estimated current demand reduction level, within thirty minutes given its Demand Response Resource Ramp Rate (and in no case greater than its Maximum Reduction) minus the Ten-Minute Spinning Reserve quantity calculated for the Resource pursuant to subsection (a) above and the Ten-Minute Non-Spinning Reserve quantity calculated for the Resource pursuant to subsection (b) above.

III.1.7.19.2.3.2 Non-Dispatched.

For a Demand Response Resource that is not being dispatched that is not a Fast Start Demand Response Resource, all components of the Real-Time Reserve Designation shall be zero.

(a) **Ten-Minute Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Spinning Reserve shall be zero.

(b) **Ten-Minute Non-Spinning Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Ten-Minute Non-Spinning Reserve shall be calculated as the minimum of the Demand Response Resource's Offered CLAIM10, its CLAIM10, and its Maximum Reduction.

(c) **Thirty-Minute Operating Reserve.** For a Fast Start Demand Response Resource that is not being dispatched, Thirty-Minute Operating Reserve shall be calculated as: (i) the minimum of the Demand Response Resource's Offered CLAIM30, its CLAIM30, and its Maximum Reduction, minus (ii) the Ten-Minute Non-Spinning Reserve quantity calculated for the Demand Response Resource pursuant to subsection (b) above.

III.1.7.20 Information and Operating Requirements.

(a) [Reserved.]

(b) Market Participants selling from Resources within the New England Control Area shall: supply to the ISO all applicable Offer Data; report to the ISO Resources that are Self-Scheduled; report to the ISO External Transaction sales; confirm to the ISO bilateral sales to Market Participants within the New England Control Area; respond to the ISO's directives to start, shutdown or change output, consumption, or demand reduction levels of Generator Assets, DARDs, or Demand Response Resources, change scheduled voltages or reactive output levels; continuously maintain all Offer Data concurrent with on-line operating information; and ensure that, where so equipped, equipment is operated with control equipment functioning as specified in the ISO New England Manuals and ISO New England Administrative Procedures.

(c) Market Participants selling from Resources outside the New England Control Area shall: provide to the ISO all applicable Offer Data, including offers specifying amounts of energy available, hours of availability and prices of energy and other services; respond to ISO directives to schedule delivery or change delivery schedules; and communicate delivery schedules to the source Control Area and any intermediary Control Areas.

(d) Market Participants, as applicable, shall: respond or ensure a response to ISO directives for load management steps; report to the ISO all bilateral purchase transactions including External Transaction

purchases; and respond or ensure a response to other ISO directives such as those required during Emergency operation.

(e) Market Participant, as applicable, shall provide to the ISO requests to purchase specified amounts of energy for each hour of the Operating Day during which it intends to purchase from the Day-Ahead Energy Market.

(f) Market Participants are responsible for reporting to the ISO anticipated availability and other information concerning Generator Assets, Demand Response Resources and Dispatchable Asset Related Demands required by the ISO New England Operating Documents, including but not limited to the Market Participant's ability to procure fuel and physical limitations that could reduce Resource output or demand reduction capability for the pertinent Operating Day.

III.1.8 [Reserved.]

III.1.9 Pre-scheduling.

III.1.9.1 Offer and Bid Caps and Cost Verification for Offers and Bids.

III.1.9.1.1 Cost Verification of Resource Offers.

The incremental energy values of Supply Offers and Demand Response Resources above $1,000/MWh for any Resource other than an External Resource are subject to the following cost verification requirements. Unless expressly stated otherwise, cost verification is utilized in all pricing, commitment, dispatch and settlement determinations. For purposes of the following requirements, Reference Levels are calculated using the procedures in Section III.A.7.5 for calculating cost-based Reference Levels.

(a) If the incremental energy value of a Resource's offer is greater than the incremental energy Reference Level value of the Resource, then the incremental energy value in the offer is replaced with the greater of the Reference Level for incremental energy or $1,000/MWh.

(b) For purposes of the price calculations in Sections III.2.5 and III.2.7A, if the adjusted offer calculated under Section III.2.4 for a Rapid Response Pricing Asset is greater than $1,000/MWh (after the incremental energy value is evaluated under Section III.1.9.1.1(a) above), then verification will be performed as follows using a Reference Level value calculated with the adjusted offer formulas specified in Section III.2.4.

(i) If the Reference Level value is less than or equal to $1,000/MWh, then the adjusted offer for the Resource is set at $1,000/MWh;

(ii) If the Reference Level value is greater than $1,000/MWh, then the adjusted offer for the Resource is set at the lower of the Reference Level value and the adjusted offer.

III.1.9.1.2 Offer and Bid Caps.

(a) For purposes of the price calculations described in Section III.2 and for purposes of scheduling a Resource in the Day-Ahead Energy Market in accordance with Section III.1.7.6 following the commitment of the Resource, the incremental energy value of an offer is capped at $2,000/MWh.

(b) Demand Bids shall not specify a bid price below the Energy Offer Floor or above the Demand Bid Cap.

(c) Supply Offers and Demand Reduction Offers shall not specify an offer price (for incremental energy) below the Energy Offer Floor.

(d) External Transactions shall not specify a price below the External Transaction Floor or above the External Transaction Cap.

(e) Increment Offers and Decrement Bids shall not specify an offer or bid price below the Energy Offer Floor or above the Virtual Cap.

III.1.9.2 [Reserved.]

III.1.9.3 [Reserved.]

III.1.9.4 [Reserved.]

III.1.9.5 [Reserved.]

III.1.9.6 [Reserved.]

III.1.9.7 Market Participant Responsibilities.

Market Participants authorized and intending to request market-based Start-Up Fees and No-Load Fee in their Offer Data shall submit a specification of such fees to the ISO for each Generator Asset as to which the Market Participant intends to request such fees. Any such specification shall identify the applicable period and be submitted on or before the applicable deadline and shall remain in effect unless otherwise modified in accordance with Section III.1.10.9. The ISO shall reject any request for Start-Up Fees and No-Load Fee in a Market Participant's Offer Data that does not conform to the Market Participant's specification on file with the ISO.

III.1.9.8 [Reserved.]

III.1.10 Scheduling.

III.1.10.1 General.

(a) The ISO shall administer scheduling processes to implement a Day-Ahead Energy Market and a Real-Time Energy Market.

(b) The Day-Ahead Energy Market shall enable Market Participants to purchase and sell energy through the New England Markets at Day-Ahead Prices and enable Market Participants to submit External Transactions conditioned upon Congestion Costs not exceeding a specified level. Market Participants whose purchases and sales and External Transactions are scheduled in the Day-Ahead Energy Market shall be obligated to purchase or sell energy or pay Congestion Costs and costs for losses, at the applicable Day-Ahead Prices for the amounts scheduled.

(c) In the Real-Time Energy Market,

(i) Market Participants that deviate from the amount of energy purchases or sales scheduled in the Day-Ahead Energy Market shall replace the energy not delivered with energy from the Real-Time Energy Market or an internal bilateral transaction and shall pay for such energy not delivered, net of any internal bilateral transactions, at the applicable Real-Time Price, unless otherwise specified by this Market Rule 1, and

(ii) Non-Market Participant Transmission Customers shall be obligated to pay Congestion Costs and costs for losses for the amount of the scheduled transmission uses in the Real-Time Energy Market at the applicable Real-Time Congestion Component and Loss Component price differences, unless otherwise specified by this Market Rule 1.

(d) The following scheduling procedures and principles shall govern the commitment of Resources to the Day-Ahead Energy Market and the Real-Time Energy Market over a period extending from one week to one hour prior to the Real-Time dispatch. Scheduling encompasses the Day-Ahead and hourly scheduling process, through which the ISO determines the Day-Ahead Energy Market schedule and determines, based on changing forecasts of conditions and actions by Market Participants and system constraints, a plan to serve the hourly energy and reserve requirements of the New England Control Area in the least costly manner, subject to maintaining the reliability of the New England Control Area.

Scheduling of External Transactions in the Real-Time Energy Market is subject to Section II.44 of the OATT.

(e) If the ISO's forecast for the next seven days projects a likelihood of Emergency Condition, the ISO may commit, for all or part of such seven day period, to the use of Generator Assets or Demand Response Resources with Notification Time greater than 24 hours as necessary in order to alleviate or mitigate such Emergency, in accordance with the Market Participants' binding Supply Offers or Demand Reduction Offers.

III.1.10.1A Energy Market Scheduling.

Market Participants may submit offers and bids in the Day-Ahead Energy Market until 10:30 a.m. on the day before the Operating Day for which transactions are being scheduled, or such other deadline as may be specified by the ISO in order to comply with the practical requirements and the economic and efficiency objectives of the scheduling process specified in this Market Rule 1.

(a) **Locational Demand Bids –** Each Market Participant may submit to the ISO specifications of the amount and location of its customer loads and/or energy purchases to be included in the Day-Ahead Energy Market for each hour of the next Operating Day, such specifications to comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures. Each Market Participant shall inform the ISO of (i) the prices, if any, at which it desires not to include its load in the Day-Ahead Energy Market rather than pay the Day-Ahead Price, (ii) hourly schedules for Resources Self-Scheduled by the Market Participant; and (iii) the Decrement Bid at which each such Self-Scheduled Resource will disconnect or reduce output, or confirmation of the Market Participant's intent not to reduce output. Price-sensitive Demand Bids and Decrement Bids must be greater than zero MW and shall not exceed the Demand Bid Cap and Virtual Cap.

(b) **External Transactions –** All Market Participants shall submit to the ISO schedules for any External Transactions involving use of Generator Assets or the New England Transmission System as specified below, and shall inform the ISO whether the transaction is to be included in the Day-Ahead Energy Market. Any Market Participant that elects to include an External Transaction in the Day-Ahead Energy Market may specify the price (such price not to exceed the maximum price that may be specified in the ISO New England Manuals and ISO New England Administrative Procedures), if any, at which it will be curtailed rather than pay Congestion Costs. The foregoing price specification shall apply to the price difference between the Locational Marginal Prices for specified External Transaction source and

sink points in the Day-Ahead scheduling process only. Any Market Participant that deviates from its Day-Ahead External Transaction schedule or elects not to include its External Transaction in the Day-Ahead Energy Market shall be subject to Congestion Costs in the Real-Time Energy Market in order to complete any such scheduled External Transaction. Scheduling of External Transactions shall be conducted in accordance with the specifications in the ISO New England Manuals and ISO New England Administrative Procedures and the following requirements:

(i) Market Participants shall submit schedules for all External Transaction purchases for delivery within the New England Control Area from Resources outside the New England Control Area;

(ii) Market Participants shall submit schedules for External Transaction sales to entities outside the New England Control Area from Resources within the New England Control Area;

(iii) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction purchases less External Transaction sales exceeds the import capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction purchases at the applicable External Node shall be set equal to the Energy Offer Floor;

(iv) In the Day-Ahead Energy Market, if the sum of all submitted Self-Scheduled External Transaction sales less External Transaction purchases exceeds the export capability associated with the applicable External Node, the offer prices for all Self-Scheduled External Transaction sales at the applicable External Node shall be set equal to the External Transaction Cap;

(v) The ISO shall not consider Start-Up Fees, No-Load Fees, Notification Times or any other inter-temporal parameters in scheduling or dispatching External Transactions.

(c) **Generator Asset Supply Offers –** Market Participants selling into the New England Markets from Generator Assets may submit Supply Offers for the supply of energy for the following Operating Day.

Such Supply Offers:

(i) Shall specify the Resource and Blocks (price and quantity of Energy) for each hour of the Operating Day for each Resource offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) If based on energy from a Generator Asset internal to the New England Control Area, may specify, for Supply Offers, a Start-Up Fee and No-Load Fee for each hour of the Operating Day. Start-Up Fee and No-Load Fee may vary on an hourly basis;

(iii) Shall specify, for Supply Offers from a dual-fuel Generator Asset, the fuel type. The fuel type may vary on an hourly basis. A Market Participant that submits a Supply Offer using the higher cost fuel type must satisfy the consultation requirements for dual-fuel Generator Assets in Section III.A.3 of Appendix A;

(iv) Shall specify a Minimum Run Time to be used for commitment purposes that does not exceed 24 hours;

(v) Supply Offers shall constitute an offer to submit the Generator Asset to the ISO for commitment and dispatch in accordance with the terms of the Supply Offer, where such Supply Offer, with regard to operating limits, shall specify changes, including to the Economic Maximum Limit, Economic Minimum Limit and Emergency Minimum Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource (except that for a Limited Energy Resource, the Economic Maximum Limit may be revised to reflect an energy (MWh) limitation), which offer shall remain open through the Operating Day for which the Supply Offer is submitted; and

(vi) Shall, in the case of a Supply Offer from a Generator Asset associated with an Electric Storage Facility, also meet the requirements specified in Section III.1.10.6.

(d) DARD Demand Bids – Market Participants participating in the New England Markets with Dispatchable Asset Related Demands may submit Demand Bids for the consumption of energy for the following Operating Day.

Such Demand Bids:

(i) Shall specify the Dispatchable Asset Related Demand and Blocks (price and Energy quantity pairs) for each hour of the Operating Day for each Dispatchable Asset Related Demand offered by the Market Participant to the ISO. The prices and quantities in a Block may each vary on an hourly basis;

(ii) Shall constitute an offer to submit the Dispatchable Asset Related Demand to the ISO for commitment and dispatch in accordance with the terms of the Demand Bid, where such Demand Bid, with regard to operating limits, shall specify changes, including to the Maximum Consumption Limit and Minimum Consumption Limit, from those submitted as part of the Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Resource;

(iii) Shall specify a Minimum Consumption Limit that is less than or equal to its Nominated Consumption Limit; and

(iv) Shall, in the case of a Demand Bid from a Storage DARD, also meet the requirements specified in Section III.1.10.6.

(e) **Demand Response Resource Demand Reduction Offers –** Market Participants selling into the New England Markets from Demand Response Resources may submit Demand Reduction Offers for the supply of energy for the following Operating Day. A Demand Reduction Offer shall constitute an offer to submit the Demand Response Resource to the ISO for commitment and dispatch in accordance with the terms of the Demand Reduction Offer. Demand Reduction Offers:

(i) Shall specify the Demand Response Resource and Blocks (price and demand reduction quantity pairs) for each hour of the Operating Day. The prices and demand reduction quantities may vary on an hourly basis.

(ii) Shall not specify a price that is below the Demand Reduction Threshold Price in effect for the Operating Day. For purposes of clearing the Day-Ahead and Real-Time Energy Markets and calculating Day-Ahead and Real-Time Locational Marginal Prices and Real-Time Reserve Clearing Prices, any price specified below the Demand Reduction Threshold price in effect for the Operating Day will be considered to be equal to the Demand Reduction Threshold Price for the Operating Day.

(iii) Shall not include average avoided peak transmission or distribution losses in the demand reduction quantity.

(iv) May specify an Interruption Cost for each hour of the Operating Day, which may vary on an hourly basis.

(v) Shall specify a Minimum Reduction Time to be used for scheduling purposes that does not exceed 24 hours.

(vi) Shall specify a Maximum Reduction amount no greater than the sum of the Maximum Interruptible Capacities of the Demand Response Resource's operational Demand Response Assets.

(vii) Shall specify changes to the Maximum Reduction and Minimum Reduction from those submitted as part of the Demand Response Resource's Offer Data to reflect the physical operating characteristics and/or availability of the Demand Response Resource.

(f) **Demand Reduction Threshold Price –** The Demand Reduction Threshold Price for each month shall be determined through an analysis of a smoothed, historic supply curve for the month. The historic supply curve shall be derived from Real-Time generator and import Offer Data (excluding Coordinated External Transactions) for the same month of the previous year. The ISO may adjust the Offer Data to account for significant changes in generator and import availability or other significant changes to the historic supply curve. The historic supply curve shall be calculated as follows:

(a) Each generator and import offer Block (i.e., each price-quantity pair offered in the Real-Time Energy Market) for each day of the month shall be compiled and sorted in ascending order of price to create an unsmoothed supply curve.

(b) An unsmoothed supply curve for the month shall be formed from the price and cumulative quantity of each offer Block.

(c) A non-linear regression shall be performed on a sampled portion of the unsmoothed supply curve to produce an increasing, convex, smooth approximation of the supply curve.

(d) A historic threshold price P_{th} shall be determined as the point on the smoothed supply curve beyond which the benefit to load from the reduced LMP resulting from the demand reduction of Demand Response Resources exceeds the cost to load associated with compensating Demand Response Resources for demand reduction.

(e) The Demand Reduction Threshold Price for the upcoming month shall be determined by the following formula:

$$DRTP = P_{th}X—\frac{FPI_c}{FPI_h}$$

where FPI_h is the historic fuel price index for the same month of the previous year, and FPI_c is the fuel price index for the current month.

The historic and current fuel price indices used to establish the Demand Reduction Threshold Price for a month shall be based on the lesser of the monthly natural gas or heating oil fuel indices applicable to the New England Control Area, as calculated three business days before the start of the month preceding the Demand Reduction Threshold Price's effective date.

The ISO will post the Demand Reduction Threshold Price, along with the index-based fuel price values used in establishing the Demand Reduction Threshold Price, on its website by the 15th day of the month preceding the Demand Reduction Threshold Price's effective date.

(g) **Subsequent Operating Days** – Each Supply Offer, Demand Reduction Offer, or Demand Bid by a Market Participant of a Resource shall remain in effect for subsequent Operating Days until superseded or canceled except in the case of an External Transaction purchase, in which case, the Supply Offer shall remain in effect for the applicable Operating Day and shall not remain in effect for subsequent Operating Days. Hourly overrides of a Supply Offer, a Demand Reduction Offer, or a Demand Bid shall remain in effect only for the applicable Operating Day.

(h) **Load Estimate** – The ISO shall post on the internet the total hourly loads including Decrement Bids scheduled in the Day-Ahead Energy Market, as well as the ISO's estimate of the Control Area hourly load for the next Operating Day.

(i) **Prorated Supply** – In determining Day-Ahead schedules, in the event of multiple marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases at a pricing location, the ISO shall clear the marginal Supply Offers, Demand Reduction Offers, Increment Offers and/or External Transaction purchases proportional to the amount of energy (MW) from each marginal offer and/or External Transaction at the pricing location. The Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions are not used in determining the amount of energy (MW) in each marginal Supply Offer or Demand Reduction Offer to be cleared on a pro-rated basis. However, the Day-Ahead schedules resulting from the pro-ration process will reflect Economic Maximum Limits, Economic Minimum Limits, Minimum Reductions and Maximum Reductions.

(j) **Prorated Demand** – In determining Day-Ahead schedules, in the event of multiple marginal Demand Bids, Decrement Bids and/or External Transaction sales at a pricing location, the ISO shall clear the marginal Demand Bids, Decrement Bids and/or External Transaction sales proportional to the amount of energy (MW) from each marginal bid and/or External Transaction at the pricing location.

(k) **Virtuals** – All Market Participants may submit Increment Offers and/or Decrement Bids that apply to the Day-Ahead Energy Market only. Such offers and bids must comply with the requirements set forth in the ISO New England Manuals and ISO New England Administrative Procedures and must specify amount, location and price, if any, at which the Market Participant desires to purchase or sell energy in the Day-Ahead Energy Market.

III.1.10.2 Pool-Scheduled Resources.

Pool-Scheduled Resources are those Resources for which Market Participants submitted Supply Offers, Demand Reduction Offers, or Demand Bids in the Day-Ahead Energy Market and which the ISO scheduled in the Day-Ahead Energy Market as well as Generator Assets, DARDs or Demand Response Resources committed by the ISO subsequent to the Day-Ahead Energy Market. Such Resources shall be committed to provide or consume energy in the Real-Time dispatch unless the schedules for such Resources are revised pursuant to Sections III.1.10.9 or III.1.11. Pool-Scheduled Resources shall be governed by the following principles and procedures.

(a) Pool-Scheduled Resources shall be selected by the ISO on the basis of the prices offered for energy supply or consumption and related services, Start-Up Fees, No-Load Fees, Interruption Cost and the specified operating characteristics, offered by Market Participants.

(b) The ISO shall optimize the dispatch of energyfrom Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources in the Day-Ahead Energy Market consistent with the Supply Offers and Demand Reduction Offers of other Resources, the submitted Demand Bids and Decrement Bids and Operating Reserve and Replacement Reserve requirements.

(c) Market Participants offering energy from facilities with fuel or environmental limitations may submit data to the ISO that is sufficient to enable the ISO to determine the available operating hours of such facilities.

(d) Market Participants shall make available their Pool-Scheduled Resources to the ISO for coordinated operation to supply the needs of the New England Control Area for energy and ancillary services.

III.1.10.3 Self-Scheduled Resources.

A Resource that is Self-Scheduled shall be governed by the following principles and procedures. The minimum duration of a Self-Schedule for a Generator Asset or DARD shall not result in the Generator Asset or DARD operating for less than its Minimum Run Time. A Generator Asset that is online as a result of a Self-Schedule will be dispatched above its Economic Minimum Limit based on the economic merit of its Supply Offer. A DARD that is consuming as a result of a Self-Schedule may be dispatched above its Minimum Consumption Limit based on the economic merit of its Demand Bid. A Demand Response Resource shall not be Self-Scheduled.

III.1.10.4 External Resources.

Market Participants with External Resources may submit External Transactions as detailed in Section III.1.10.7 and Section III.1.10.7.A of this Market Rule 1.

III.1.10.5 Dispatchable Asset Related Demand.

(a) External Transactions that are sales to an external Control Area are not eligible to be Dispatchable Asset Related Demands.

(b) A Market Participant with a Dispatchable Asset Related Demand in the New England Control Area must:

(i) notify the ISO of any outage (including partial outages) that may reduce the Dispatchable Asset Related Demand's ability to respond to Dispatch Instructions and the expected return date from the outage;

(ii) in accordance with the ISO New England Manuals and Operating Procedures, perform audit tests and submit the results to the ISO or provide to the ISO appropriate historical production data;

(iii) abide by the ISO maintenance coordination procedures; and

(iv) provide information reasonably requested by the ISO, including the name and location of the Dispatchable Asset Related Demand.

III.1.10.6 Electric Storage

A storage facility is a facility that is capable of receiving electricity from the grid and storing the energy for later injection of electricity back to the grid. A storage facility may participate in the New England Markets as described below.

(a) A storage facility that satisfies the requirements of this subsection (a) may participate in the New England Markets as an Electric Storage Facility. An Electric Storage Facility shall:

(i) comprise one or more storage facilities at the same point of interconnection;

(ii) have the ability to inject at least 0.1 MW and consume at least 0.1 MW;

(iii) be directly metered;

(iv) be registered as, and subject to all rules applicable to, a dispatchable Generator Asset;

(v) be registered as, and subject to all rules applicable to, a DARD that represents the same equipment as the Generator Asset;

(vi) settle its injection of electricity to the grid as a Generator Asset and its receipt of electricity from the grid as a DARD;

(vii) not be precluded from providing retail services so long as it is able to fulfill its wholesale Energy Market and Forward Capacity Market obligations including, but not limited to, satisfying meter data reporting requirements and notifying the ISO of any changes to operational capabilities; and

(viii) meet the requirements of either a Binary Storage Facility or a Continuous Storage Facility, as described in subsections (b) and (c) below.

(b) A storage facility that satisfies the requirements of this subsection (b) may participate in the New England Markets as a Binary Storage Facility. A Binary Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility; and

(ii) offer its Generator Asset and DARD into the Energy Market as Rapid Response Pricing Assets; and

(iii) be issued Dispatch Instructions in a manner that ensures the facility is not required to consume and inject simultaneously.

(c) A storage facility that satisfies the requirements of this subsection (c) may participate in the New England Markets as a Continuous Storage Facility. A Continuous Storage Facility shall:

(i) satisfy the requirements applicable to an Electric Storage Facility;

(ii) be registered as, may provide Regulation as, and is subject to all rules applicable to, an ATRR that represents the same equipment as the Generator Asset and DARD;

(iii) be capable of transitioning between the facility's maximum output and maximum consumption (and vice versa) in ten minutes or less;

(iv) not utilize storage capability that is shared with another Generator Asset, DARD or ATRR;

(v) specify in Supply Offers a zero MW value for Economic Minimum Limit and Emergency Minimum Limit (except for Generator Assets undergoing Facility and Equipment Testing or auditing); a zero time value for Minimum Run Time, Minimum Down Time, Notification Time, and Start-Up Time; and a zero cost value for Start-Up Fee and No-Load Fee;

(vi) specify in Demand Bids a zero MW value for Minimum Consumption Limit (except for DARDs undergoing Facility and Equipment Testing or auditing) and a zero time value for Minimum Run Time and Minimum Down Time;

(vii) be Self-Scheduled in the Day-Ahead Energy Market and Real-Time Energy Market, and operate in an on-line state, unless the facility is declared unavailable by the Market Participant; and

(viii) be issued a combined dispatch control signal equal to the Desired Dispatch Point (of the Generator Asset) minus the Desired Dispatch Point (of the DARD) plus the AGC SetPoint (of the ATRR).

(d) In clearing the Day-Ahead Energy Market, the ISO will respect Electric Storage Facility Initial State of Charge, Round Trip Efficiency, Maximum State of Charge, and Minimum State of Charge.

(e) A storage facility shall comply with all applicable registration, metering, and accounting rules including, but not limited to, the following:

(i) A Market Participant wishing to purchase energy from the ISO-administered wholesale markets must first, jointly with its Host Participant, register one or more wholesale Load Assets with the ISO as described in ISO New England Manual M-28 and ISO New England Manual M-RPA; where the Market Participant wishes to register an Electric Storage Facility, the registered Load Asset must be a DARD.

(ii) A storage facility's charging energy shall not qualify as, or be billed to, a Storage DARD if that facility's charging energy is included in another Load Asset. A storage facility registered as a DARD will be charged the nodal Locational Marginal Price by the ISO and the Market Participant will not pay twice for the same charging energy.

(iii) The registration and metering of all Assets must comply with ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18, including with the requirement that an Asset's revenue metering must comply with the accuracy requirements found in ISO New England Operating Procedure No. 18.

(iv) Pursuant to ISO New England Manual M-28, the Assigned Meter Reader, the Host Participant, and the ISO provide the data for use in the daily settlement process within the timelines described in the manual. The data may be five-minute interval data, and may be no more than hourly data, as described in Section III.3.2 and in ISO New England Manual M-28.

(v) Based on the Metered Quantity For Settlement and the Locational Marginal Price in the settlement interval, the ISO shall conduct all Energy Market accounting pursuant to Section III.3.2.1.

(f) A facility registered as a dispatchable Generator Asset, an ATRR, and a DARD that each represent the same equipment must participate as a Continuous Storage Facility.

(g) A storage facility not participating as an Electric Storage Facility may, if it satisfies the associated requirements, be registered as a Generator Asset (including a Settlement Only Resource) for settlement of its injection of electricity to the grid and as an Asset Related Demand for settlement of its wholesale load.

(h) A storage facility may, if it satisfies the associated requirements, be registered as a Demand Response Asset. (As described in Section III.8.1.1, a Demand Response Asset and a Generator Asset may not

be registered at the same end-use customer facility unless the Generator Asset is separately metered and reported and its output does not reduce the load reported at the Retail Delivery Point of the Demand Response Asset.)

(i) A storage device may, if it satisfies the associated requirements, be registered as a component of either an On-Peak Demand Resource or a Seasonal Peak Demand Resource.

(j) A storage facility may, if it satisfies the associated requirements, provide Regulation pursuant to Section III.14.

III.1.10.7 External Transactions.

The provisions of this Section III.1.10.7 do not apply to Coordinated External Transactions.

(a) Market Participants that submit an External Transaction in the Day-Ahead Energy Market must also submit a corresponding External Transaction in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market. Priced External Transactions for the Real-Time Energy Market must be submitted by the offer submission deadline for the Day-Ahead Energy Market.

(b) Priced External Transactions submitted in both the Day-Ahead Energy Market and the Real-Time Energy Market will be treated as Self-Scheduled External Transactions in the Real-Time Energy Market for the associated megawatt amounts that cleared the Day-Ahead Energy Market, unless the Market Participant modifies the price component of its Real-Time offer during the Re-Offer Period.

(c) Any External Transaction, or portion thereof, submitted to the Real-Time Energy Market that did not clear in the Day-Ahead Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency. External Transactions cleared in the Day-Ahead Energy Market and associated with a Real-Time Energy Market submission will continue to be scheduled in Real-Time prior to and during an Emergency, until the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, require a change in schedule.

(d) External Transactions submitted to the Real-Time Energy Market must contain the associated e-Tag ID and transmission reservation, if required, at the time the transaction is submitted to the Real-Time Energy Market.

(e) [Reserved.]

(f) External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below receive priority in the scheduling and curtailment of transactions as set forth in Section II.44 of the OATT. External Transaction sales meeting all of the criteria for any of the transaction types described in (i) through (iv) below are referred to herein and in the OATT as being supported in Real-Time.

(i) Capacity Export Through Import Constrained Zone Transactions:

(1) The External Transaction is exporting across an external interface located in an import-constrained Capacity Zone that cleared in the Forward Capacity Auction with price separation, as determined in accordance with Section III.12.4 and Section III.13.2.3.4 of Market Rule 1;

(2) The External Transaction is directly associated with an Export Bid or Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The External Node associated with the cleared Export Bid or Administrative Export De-List Bid is connected to the import-constrained Capacity Zone, and is not connected to a Capacity Zone that is not import-constrained;

(4) The Resource, or portion thereof, that is associated with the cleared Export Bid or Administrative Export De-List Bid is not located in the import-constrained Capacity Zone;

(5) The External Transaction has been submitted and cleared in the Day-Ahead Energy Market;

(6) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(ii) FCA Cleared Export Transactions:

(1) The External Transaction sale is exporting to an External Node that is connected only to an import-constrained Reserve Zone;

(2) The External Transaction sale is directly associated with an Export Bid or an Administrative Export De-List Bid that cleared in the Forward Capacity Auction, and the megawatt amount of the External Transaction is less than or equal to the megawatt amount of the cleared Export Bid;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation associated with the Export Bid or Administrative Export De-List Bid is located outside the import-constrained Reserve Zone;

(4) The External Transaction sale is submitted and cleared in the Day-Ahead Energy Market;

(5) A matching External Transaction has also been submitted into the Real-Time Energy Market by the end of the Re-Offer Period for Self-Scheduled External Transactions, and, in accordance with Section III.1.10.7(a), by the offer submission deadline for the Day-Ahead Energy Market for priced External Transactions.

(iii) Same Reserve Zone Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is connected only to the same Reserve Zone in which the associated Resource, or portion thereof, without a Capacity Supply Obligation is located;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(4) Neither the External Transaction sale nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(iv) Unconstrained Export Transactions:

(1) A Resource, or portion thereof, without a Capacity Supply Obligation is associated with the External Transaction sale, and the megawatt amount of the External Transaction is less than or equal to the portion of the Resource without a Capacity Supply Obligation;

(2) The External Node of the External Transaction sale is not connected only to an import-constrained Reserve Zone;

(3) The Resource, or portion thereof, without a Capacity Supply Obligation is not separated from the External Node by a transmission interface constraint as determined in Sections III.12.2.1(b) and III.12.2.2(b) of Market Rule 1 that was binding in the Forward Capacity Auction in the direction of the export;

(4) The Resource, or portion thereof, without a Capacity Supply Obligation is Self-Scheduled in the Real-Time Energy Market and online at a megawatt level greater than or equal to the External Transaction sale's megawatt amount;

(5) Neither the External Transaction sale, nor the portion of the Resource without a Capacity Supply Obligation is required to offer into the Day-Ahead Energy Market.

(g) Treatment of External Transaction sales in ISO commitment for local second contingency protection.

(i) Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: The transaction's export demand that clears in the Day-Ahead Energy Market will be explicitly considered as load in the exporting Reserve Zone by the ISO when committing Resources to provide local second contingency protection for the associated Operating Day.

(ii) The export demand of External Transaction sales not meeting the criteria in (i) above is not considered by the ISO when planning and committing Resources to provide local second contingency protection, and is assumed to be zero.

(iii) Same Reserve Zone Export Transactions and Unconstrained Export Transactions: If a Resource, or portion thereof, without a Capacity Supply Obligation is committed to be online during the Operating Day either through clearing in the Day-Ahead Energy Market or through Self-Scheduling subsequent to the Day-Ahead Energy Market and a Same Reserve Zone Export Transaction or Unconstrained Export Transaction is submitted before the end of the Re-Offer Period designating that Resource as supporting the transaction, the ISO will not utilize the portion of the Resource without a Capacity Supply Obligation supporting the export transaction to meet local second contingency protection requirements. The eligibility of Resources not meeting the foregoing criteria to be used to meet local second contingency protection requirements shall be in accordance with the relevant provisions of the ISO New England System Rules.

(h) Allocation of costs to Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions: Market Participants with Capacity Export Through Import Constrained Zone Transactions and FCA Cleared Export Transactions shall incur a proportional share of the charges described below, which are allocated to Market Participants based on Day-Ahead Load Obligation or Real-Time Load Obligation. The share shall be determined by including the Day-Ahead Load Obligation or Real-Time Load Obligation associated with the External Transaction, as applicable, in the total Day-Ahead Load Obligation or Real-Time Load Obligation for the appropriate Reliability Region, Reserve Zone, or Load Zone used in each cost allocation calculation:

(i) NCPC for Local Second Contingency Protection Resources allocated within the exporting Reliability Region, pursuant to Section III.F.3.3.

(ii) Forward Reserve Market charges allocated within the exporting Load Zone, pursuant to Section III.9.9.

(iii) Real-Time Reserve Charges allocated within the exporting Load Zone, pursuant to Section III.10.3.

(i) When action is taken by the ISO to reduce External Transaction sales due to a system wide capacity deficient condition or the forecast of such a condition, and an External Transaction sale designates a Resource, or portion of a Resource, without a Capacity Supply Obligation, to support the transaction, the ISO will review the status of the designated Resource. If the designated Resource is Self-Scheduled and online at a megawatt level greater than or equal to the External Transaction sale, that External Transaction sale will not be reduced until such time as Regional Network Load within the New England Control Area is also being reduced. When reductions to such transactions are required, the affected transactions shall be reduced pro-rata.

(j) Market Participants shall submit External Transactions as megawatt blocks with intervals of one hour at the relevant External Node. External Transactions will be scheduled in the Day-Ahead Energy Market as megawatt blocks for hourly durations. The ISO may dispatch External Transactions in the Real-Time Energy Market as megawatt blocks for periods of less than one hour, to the extent allowed pursuant to inter-Control Area operating protocols.

III.1.10.7.A Coordinated Transaction Scheduling.

The provisions of this Section III.1.10.7.A apply to Coordinated External Transactions, which are implemented at the New York Northern AC external Location.

(a) Market Participants that submit a Coordinated External Transaction in the Day-Ahead Energy Market must also submit a corresponding Coordinated External Transaction, in the form of an Interface Bid, in the Real-Time Energy Market in order to be eligible for scheduling in the Real-Time Energy Market.

(b) An Interface Bid submitted in the Real-Time Energy Market shall specify a duration consisting of one or more consecutive 15-minute increments. An Interface Bid shall include a bid price, a bid quantity, and a bid direction for each 15-minute increment. The bid price may be positive or negative. An Interface Bid may not be submitted or modified later than 75 minutes before the start of the clock hour for which it is offered.

(c) Interface Bids are cleared in economic merit order for each 15-minute increment, based upon the forecasted real-time price difference across the external interface. The total quantity of Interface Bids cleared shall determine the external interface schedule between New England and the adjacent Control Area. The total quantity of Interface Bids cleared shall depend upon, among other factors, bid production

costs of resources in both Control Areas, the Interface Bids of all Market Participants, transmission system conditions, and any real-time operating limits necessary to ensure reliable operation of the transmission system.

(d) All Coordinated External Transactions submitted either to the Day-Ahead Energy Market or the Real-Time Energy Market must contain the associated e-Tag ID at the time the transaction is submitted.

(e) Any Coordinated External Transaction, or portion thereof, submitted to the Real-Time Energy Market will not be scheduled in Real-Time if the ISO anticipates that the External Transaction would create or worsen an Emergency, unless the procedures governing the Emergency, as set forth in ISO New England Operating Procedure No. 9, permit the transaction to be scheduled.

III.1.10.8 ISO Responsibilities.

(a) The ISO shall use its best efforts to determine (i) the least-cost means of satisfying hourly purchase requests for energy, the projected hourly requirements for Operating Reserve, Replacement Reserve and other ancillary services of the Market Participants, including the reliability requirements of the New England Control Area, of the Day-Ahead Energy Market, and (ii) the least-cost means of satisfying the Operating Reserve, Replacement Reserve and other ancillary service requirements for any portion of the load forecast of the ISO for the Operating Day in excess of that scheduled in the Day-Ahead Energy Market. In making these determinations, the ISO shall take into account: (i) the ISO's forecasts of New England Markets and New England Control Area energy requirements, giving due consideration to the energy requirement forecasts and purchase requests submitted by Market Participants for the Day-Ahead Energy Market; (ii) the offers and bids submitted by Market Participants; (iii) the availability of Limited Energy Resources; (iv) the capacity, location, and other relevant characteristics of Self-Scheduled Resources; (v) the requirements of the New England Control Area for Operating Reserve and Replacement Reserve, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vi) the requirements of the New England Control Area for Regulation and other ancillary services, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; (vii) the benefits of avoiding or minimizing transmission constraint control operations, as specified in the ISO New England Manuals and ISO New England Administrative Procedures; and (viii) such other factors as the ISO reasonably concludes are relevant to the foregoing determination. The ISO shall develop a Day-Ahead Energy schedule based on the applicable portions of the foregoing determination, and shall determine the Day-Ahead Prices resulting from such schedule. (b)

Not later than 1:30 p.m. of the day before each Operating Day, or such earlier deadline as may be

specified by the ISO in the ISO New England Manuals and ISO New England Administrative Procedures or such later deadline as necessary to account for software failures or other events, the ISO shall: (i) post the aggregate Day-Ahead Energy schedule; (ii) post the Day-Ahead Prices; and (iii) inform the Market Participants of their scheduled injections and withdrawals. In the event of an Emergency, the ISO will notify Market Participants as soon as practicable if the Day-Ahead Energy Market can not be operated.

(c) Following posting of the information specified in Section III.1.10.8(b), the ISO shall revise its schedule of Resources to reflect updated projections of load, conditions affecting electric system operations in the New England Control Area, the availability of and constraints on limited energy and other Resources, transmission constraints, and other relevant factors.

(d) Market Participants shall pay and be paid for the quantities of energy scheduled in the Day-Ahead Energy Market at the Day-Ahead Prices.

III.1.10.9 Hourly Scheduling.

(a) Following the initial posting by the ISO of the Locational Marginal Prices resulting from the Day-Ahead Energy Market, and subject to the right of the ISO to schedule and dispatch Resources and to direct that schedules be changed to address an actual or potential Emergency, a Resource Re-Offer Period shall exist from the time of the posting specified in Section III.1.10.8(b) until 2:00 p.m. on the day before each Operating Day or such other Re-Offer Period as necessary to account for software failures or other events. During the Re-Offer Period, Market Participants may submit revisions to Supply Offers, revisions to Demand Reduction Offers, and revisions to Demand Bids for any Dispatchable Asset Related Demand. Resources scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices.

(b) During the Re-Offer Period, Market Participants may submit revisions to the price of priced External Transactions. External Transactions scheduled subsequent to the closing of the Re-Offer Period shall be settled at the applicable Real-Time Prices, and shall not affect the obligation to pay or receive payment for the quantities of energy scheduled in the Day-Ahead Energy Market at the applicable Day-Ahead Prices. A submission during the Re-Offer Period for any portion of a transaction that was cleared in the Day-Ahead Energy Market is subject to the provisions in Section III.1.10.7. A Market Participant may request to Self-Schedule an External Transaction and adjust the schedule on an hour-to-hour basis or request to reduce the quantity of a priced External Transaction. The ISO must be notified of the request not later than 60 minutes prior to the hour in which the adjustment is to take effect. The External

Transaction re-offer provisions of this Section III.1.10.9(b) shall not apply to Coordinated External Transactions, which are submitted pursuant to Section III.1.10.7.A.

(c) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may modify certain Supply Offer or Demand Bid parameters for a Generator Asset or a Dispatchable Asset Related Demand on an hour-to-hour basis, provided that the modification is made no later than 30 minutes prior to the beginning of the hour for which the modification is to take effect:

(i) For a Generator Asset, the Start-Up Fee, the No-Load Fee, the fuel type (for dual-fuel Generator Assets), and the quantity and price pairs of its Blocks may be modified.

(ii) For a Dispatchable Asset Related Demand, the quantity and price pairs of its Blocks may be modified.

(d) Following the completion of the initial Reserve Adequacy Analysis and throughout the Operating Day, a Market Participant may not modify any of the following Demand Reduction Offer parameters: price and demand reduction quantity pairs, Interruption Cost, Demand Response Resource Start-Up Time, Demand Response Resource Notification Time, Minimum Reduction Time, and Minimum Time Between Reductions.

(e) During the Operating Day, a Market Participant may request to Self-Schedule a Generator Asset or Dispatchable Asset Related Demand or may request to cancel a Self-Schedule for a Generator Asset or Dispatchable Asset Related Demand. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor a Self-Schedule request, a Generator Asset will be permitted to come online at its Economic Minimum Limit and a Dispatchable Asset Related Demand will be dispatched to its Minimum Consumption Limit. A Market Participant may not request to Self-Schedule a Demand Response Resource. A Market Participant may cancel the Self-Schedule of a Continuous Storage Generator Asset or a Continuous Storage DARD only by declaring the facility unavailable.

(f) During the Operating Day, in the event that in a given hour a Market Participant seeks to modify a Supply Offer or Demand Bid after the deadline for modifications specified in Section III.1.10.9(c), then:

(i) the Market Participant may request that a Generator Asset be dispatched above its Economic Minimum Limit at a specified output. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the

request, the Generator Asset will be dispatched as though it had offered the specified output for the hour in question at the Energy Offer Floor.

(ii) the Market Participant may request that a Dispatchable Asset Related Demand be dispatched above its Minimum Consumption Limit at a specified value. The ISO will honor the request so long as it will not cause or worsen a reliability constraint. If the ISO is able to honor the request, the Dispatchable Asset Related Demand will be dispatched at or above the requested amount for the hour in question.

(g) During the Operating Day, in any interval in which a Generator Asset is providing Regulation, the upper limit of its energy dispatch range shall be reduced by the amount of Regulation Capacity, and the lower limit of its energy dispatch range shall be increased by the amount of Regulation Capacity. Any such adjustment shall not affect the Real-Time Reserve Designation.

(h) During the Operating Day, in any interval in which a Continuous Storage ATRR is providing Regulation, the upper limit of the associated Generator Asset's energy dispatch range shall be reduced by the Regulation High Limit, and the associated DARD's consumption dispatch range shall be reduced by the Regulation Low Limit. Any such adjustment shall not affect the Real-Time Reserve Designation.

(i) For each hour in the Operating Day, as soon as practicable after the deadlines specified in the foregoing subsection of this Section III.1.10, the ISO shall provide Market Participants and parties to External Transactions with any revisions to their schedules for the hour.

III.1.11 Dispatch.

The following procedures and principles shall govern the dispatch of the Resources available to the ISO.

III.1.11.1 Resource Output or Consumption and Demand Reduction.

The ISO shall have the authority to direct any Market Participant to adjust the output, consumption or demand reduction of any Dispatchable Resource within the operating characteristics specified in the Market Participant's Offer Data, Supply Offer, Demand Reduction Offer or Demand Bid. The ISO may cancel its selection of, or otherwise release, Pool-Scheduled Resources. The ISO shall adjust the output, consumption or demand reduction of Resources as necessary: (a) for both Dispatchable Resources and Non-Dispatchable Resources, to maintain reliability, and subject to that constraint, for Dispatchable Resources, (b) to minimize the cost of supplying the energy, reserves, and other services required by the

Market Participants and the operation of the New England Control Area; (c) to balance supply and demand, maintain scheduled tie flows, and provide frequency support within the New England Control Area; and (d) to minimize unscheduled interchange that is not frequency related between the New England Control Area and other Control Areas.

III.1.11.2 Operating Basis.

In carrying out the foregoing objectives, the ISO shall conduct the operation of the New England Control Area and shall, in accordance with the ISO New England Manuals and ISO New England Administrative Procedures, (i) utilize available Operating Reserve and replace such Operating Reserve when utilized; and (ii) monitor the availability of adequate Operating Reserve.

III.1.11.3 Dispatchable Resources.

With the exception of Settlement Only Resources, Generator Assets that meet the size criteria to be Settlement Only Resources, External Transactions, nuclear-powered Resources and photovoltaic Resources, all Resources must be Dispatchable Resources in the Energy Market and meet the technical specifications in ISO New England Operating Procedure No. 14 and ISO New England Operating Procedure No. 18 for dispatchability.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market because the Resource is not connected to a remote terminal unit meeting the requirements of ISO New England Operating Procedure No. 18 shall take the following steps:

1. By January 15, 2017, the Market Participant shall submit to the ISO a circuit order form for the primary and secondary communication paths for the remote terminal unit.
2. The Market Participant shall work diligently with the ISO to ensure the Resource is able to receive and respond to electronic Dispatch Instructions within twelve months of the circuit order form submission.

A Market Participant that does not meet the requirement for a Dispatchable Resource to be dispatchable in the Energy Market by the deadline set forth above shall provide the ISO with a written plan for remedying the deficiencies, and shall identify in the plan the specific actions to be taken and a reasonable timeline for rendering the Resource dispatchable. The Market Participant shall complete the remediation in accordance with and under the timeline set forth in the written plan. Until a Resource is dispatchable, it may only be Self-Scheduled in the Real-Time Energy Market and shall otherwise be treated as a Non-Dispatchable Resource.

Dispatchable Resources in the Energy Market are subject to the following requirements:

(a) The ISO shall optimize the dispatch of energy from Limited Energy Resources by request to minimize the as-bid production cost for the New England Control Area. In implementing the use of Limited Energy Resources, the ISO shall use its best efforts to select the most economic hours of operation for Limited Energy Resources, in order to make optimal use of such Resources consistent with the dynamic load-following requirements of the New England Control Area and the availability of other Resources to the ISO.

(b) The ISO shall implement the dispatch of energy from Dispatchable Resources and the designation of Real-Time Operating Reserve to Dispatchable Resources, including the dispatchable portion of Resources which are otherwise Self-Scheduled, by sending appropriate signals and instructions to the entity controlling such Resources. Each Market Participant shall ensure that the entity controlling a Dispatchable Resource offered or made available by that Market Participant complies with the energy dispatch signals and instructions transmitted by the ISO.

(c) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed, and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(d) Market Participants shall exert all reasonable efforts to operate, or ensure the operation of, their Dispatchable Resources in the New England Control Area as close to dispatched output, consumption or demand reduction levels as practical, consistent with Good Utility Practice.

(e) Settlement Only Resources are not eligible to be DNE Dispatchable Generators.

Wind and hydro Intermittent Power Resources that are not Settlement Only Resources are required to receive and respond to Do Not Exceed Dispatch Points, except as follows:

(i) A wind or hydro Intermittent Power Resource not capable of receiving and responding to electronic Dispatch Instructions will be manually dispatched.

(ii) A Market Participant may elect, but is not required, to have a wind or hydro Intermittent Power Resource that is less than 5 MW and is connected through transmission facilities rated at less than 115 kV be dispatched as a DNE Dispatchable Generator.

(iii) A Market Participant with a hydro Intermittent Power Resource that is able to operate within a dispatchable range and is capable of responding to Dispatch Instructions to increase or decrease output within its dispatchable range may elect to have that resource dispatched as a DDP Dispatchable Resource.

(f) The ISO may request that dual-fuel Generator Assets that normally burn natural gas voluntarily take all necessary steps (within the limitations imposed by the operating limitations of their installed equipment and their environmental and operating permits) to prepare to switch to secondary fuel in anticipation of natural gas supply shortages. The ISO may request that Market Participants with dual-fuel Generator Assets that normally burn natural gas voluntarily switch to a secondary fuel in anticipation of natural gas supply shortages. The ISO may communicate with Market Participants with dual-fuel Generator Assets that normally burn natural gas to verify whether the Market Participants have switched or are planning to switch to an alternate fuel.

III.1.11.4 Emergency Condition.

If the ISO anticipates or declares an Emergency Condition, all External Transaction sales out of the New England Control Area that are not backed by a Resource may be interrupted, in accordance with the ISO New England Manuals, in order to serve load and Operating Reserve in the New England Control Area.

III.1.11.5 Dispatchability Requirements for Intermittent Power Resources.

(a) Intermittent Power Resources that are Dispatchable Resources with Supply Offers that do not clear in the Day-Ahead Energy Market and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market at the Resource's Economic Minimum Limit in order to operate in Real-Time.

(b) Intermittent Power Resources that are not Settlement Only Resources, are not Dispatchable Resources, and are not committed by the ISO prior to or during the Operating Day must be Self-Scheduled in the Real-Time Energy Market with the Resource's Economic Maximum Limit and Economic Minimum Limit redeclared to the same value in order to operate in Real-Time. Redeclarations must be updated throughout the Operating Day to reflect actual operating capabilities.

III.1.11.6 Non-Dispatchable Resources.

Non-Dispatchable Resources are subject to the following requirements:

(a) The ISO shall have the authority to modify a Market Participant's operational related Offer Data for a Non-Dispatchable Resource if the ISO observes that the Market Participant's Resource is not operating in accordance with such Offer Data. The ISO shall modify such operational related Offer Data based on observed performance and such modified Offer Data shall remain in effect until either (i) the affected Market Participant requests a test to be performed and coordinates the testing pursuant to the procedures specified in the ISO New England Manuals, and the results of the test justify a change to the Market Participant's Offer Data or (ii) the ISO observes, through actual performance, that modification to the Market Participant's Offer Data is justified.

(b) Market Participants with Non-Dispatchable Resources shall exert all reasonable efforts to operate or ensure the operation of their Resources in the New England Control Area as close to dispatched levels as practical when dispatched by the ISO for reliability, consistent with Good Utility Practice.

New England Governors, State Utility Regulators and Related Agencies*

Connecticut

The Honorable Ned Lamont
Office of the Governor
State Capitol
210 Capitol Ave.
Hartford, CT 06106
bob.clark@ct.gov

Connecticut Attorney General Office
55 Elm Street
Hartford, CT 06106
Seth.Hollander@ct.gov
Robert.Marconi@ct.gov

Connecticut Department of Energy and Environmental Protection
79 Elm Street
Hartford, CT 06106
steven.cadwallader@ct.gov
robert.luysterborghs@ct.gov

Connecticut Public Utilities Regulatory Authority
10 Franklin Square
New Britain, CT 06051-2605
michael.coyle@ct.gov

Maine

The Honorable Janet Mills
One State House Station
Office of the Governor
Augusta, ME 04333-0001
Jeremy.kennedy@maine.gov
Elise.baldacci@maine.gov

Maine Public Utilities Commission
18 State House Station
Augusta, ME 04333-0018
Maine.puc@maine.gov

Massachusetts

The Honorable Charles Baker
Office of the Governor
State House
Boston, MA 02133

Massachusetts Attorney General Office
One Ashburton Place
Boston, MA 02108
rebecca.tepper@state.ma.us

Massachusetts Department of Public Utilities
One South Station
Boston, MA 02110
Nancy.Stevens@state.ma.us
morgane.treanton@state.ma.us
Lindsay.griffin@mass.gov

New Hampshire

The Honorable Chris Sununu
Office of the Governor
26 Capital Street
Concord NH 03301
Jared.chicoine@nh.gov

New Hampshire Public Utilities Commission
21 South Fruit Street, Ste. 10
Concord, NH 03301-2429
tom.frantz@puc.nh.gov
george.mccluskey@puc.nh.gov
David.Shulock@puc.nh.gov
David.goyette@puc.nh.gov
RegionalEnergy@puc.nh.gov
kate.bailey@puc.nh.gov
amanda.noonan@puc.nh.gov
Corrine.lemay@puc.nh.gov

Rhode Island

The Honorable Gina Raimondo
Office of the Governor
82 Smith Street
Providence, RI 02903
Rosemary.powers@governor.ri.gov
christopher.kearns@energy.ri.gov
nicholas.ucci@energy.ri.gov

Rhode Island Public Utilities Commission
89 Jefferson Blvd.
Warwick, RI 02888
todd.bianco@puc.ri.gov
Marion.Gold@puc.ri.gov

Meredith Hatfield, Executive Director
New England Conference of Public Utilities Commissioners
72 N. Main Street
Concord, NH 03301
mhatfield@necpuc.org

Vermont

The Honorable Phil Scott
Office of the Governor
109 State Street, Pavilion
Montpelier, VT 05609
jason.gibbs@vermont.gov

Anthony Roisman, President
New England Conference of Public Utilities Commissioners
112 State Street – Drawer 20
Montpelier, VT05620
anthony.roisman@vermont.gov

Vermont Public Utility Commission
112 State Street
Montpelier, VT 05620-2701
mary-jo.krolewski@vermont.gov
sarah.hofmann@vermont.gov
Margaret.cheney@vermont.gov

Vermont Department of Public Service
112 State Street, Drawer 20
Montpelier, VT 05620-2601
bill.jordan@vermont.gov
june.tierney@vermont.gov
Ed.McNamara@vermont.gov

New England Governors, Utility Regulatory and Related Agencies

Jay Lucey
Coalition of Northeastern Governors
400 North Capitol Street, NW, Suite 370
Washington, DC 20001
coneg@sso.org

Heather Hunt, Executive Director
New England States Committee on Electricity
655 Longmeadow Street
Longmeadow, MA 01106
HeatherHunt@nescoe.com
JasonMarshall@nescoe.com