



# Transmission Planning for the Clean Energy Transition

---

## *Pilot Study Results*

Andrew Kniska and Meenakshi Saravanan

TRANSMISSION PLANNING



# Objectives of Today's Presentation

- Share further results from the Transmission Planning for the Clean Energy Transition (TPCET) Pilot Study since the June 16 PAC meeting
- Discuss various strategies to prevent DER from tripping due to transmission system faults
- Discuss future work and schedule for completion of the TPCET Pilot Study

*Note: in order to maximize stakeholder involvement, this presentation does not contain Critical Energy Infrastructure Information (CEII). As a result, information about the exact contingencies causing concerns is not being shared at this time.*



# TPCET PILOT STUDY OVERVIEW



# Overview of the TPCET Pilot Study

- New England continues to lead many industry trends
  - Development of Distributed Energy Resources (DER)
  - Integration of renewable resources, including offshore wind
  - Increasing imports via HVDC interconnections
  - Integration of battery energy storage resources
- To quantify trade-offs between cost and ability of the transmission system to accommodate high amounts of renewable resources, ISO-NE is conducting a “pilot” study of certain key system conditions
- The pilot study will aid in developing assumptions for use in future Needs Assessments, and will explore reliability concerns that may arise under these system conditions



# Past PAC Presentations on TPCET Efforts

- Sept. 2020: [Introductory Presentation](#)
- Nov. 2020: [Updated Assumptions and Pilot Study Proposal](#)
- Dec. 2020: [System Conditions and Dispatch Assumptions](#)
- Jan. 2021: [Generation Dispatch Details](#)
- June 2021: [Preliminary Results](#)




# STEADY-STATE RESULTS UPDATE



# Stoughton – K St. 345 kV Cable Loading

- Stoughton – K Street cables connect SEMA (high levels of offshore wind) with Boston (a major load center)
- June 2021 PAC presentation identified overloads on these cables in the Summer Weekday Mid-Day Peak Load (High Renewables) study condition



# Stoughton – K St. 345 kV Cable Loading

- Generation reductions in SEMA/RI are sufficient to relieve the overloads on the Stoughton – K Street cables
- Due to renewable resource additions in SEMA/RI, including over 3,100 MW of offshore wind and 2,300 MW of PV, reductions in fossil-fueled generation in the base case had already been focused in SEMA/RI
- In addition to these initial generation reductions, another 30 MW of fossil-fueled generation was reduced in SEMA/RI to alleviate the Stoughton – K Street cable overloads
- In total, 5,150 MW of fossil-fueled generation was kept offline in SEMA/RI to avoid Stoughton – K Street cable overloads





# Stoughton – K St. 345 kV Cable Loading

- Thermal overloads are relatively easily managed in real-time operations, and many options exist for generation reduction that would alleviate this constraint
  - Operators can easily identify post-contingency thermal overloads before a contingency occurs, and make system adjustments, such as reducing generation, to avoid overloads
- In a Needs Assessment, a thermal overload is not considered to be a need if it could be resolved by reducing generation
- Currently, enough capacity is available outside of SEMA/RI that this reduction does not cause a reliability concern
  - If significant generator retirements were to occur outside of SEMA/RI, some of this fossil-fueled capacity may be needed to serve load
- ISO-NE will continue the current practice of reducing generation when necessary to avoid overloads



# Other Steady-State Results

- The June 2021 PAC presentation identified a number of areas with steady-state high-voltage violations in the Spring Weekend Mid-Day Minimum Load study condition
- Further investigation of these high-voltage violations will occur once representative solutions to stability concerns have been developed
- A comparison between today's Needs Assessment cases and cases with similar generation outages and new load, solar, and wind assumptions will be presented at the August 2021 PAC meeting



# STABILITY RESULTS UPDATE

Meenakshi Saravanan

ENGINEER, TRANSMISSION PLANNING




# Stability Results Overview

- The June 2021 PAC presentation identified the loss of DER solar installations during and after transmission system faults as the primary stability concern in the TPCET Pilot Study
- Further analysis since June has examined different strategies for reducing the amount of DER tripped
- These results concentrate on “Fault 7” from the June PAC presentation
  - Fault 7 is a single-line-to-ground (SLG) fault with breaker failure on the SEMA/RI 345 kV system
  - This fault resulted in 1,855 MW of DER tripping in the Spring Weekend Mid-Day Minimum Load study condition, and 807 MW of DER tripping in the Summer Weekday Mid-Day Peak Load study condition
  - All other faults tested showed lower amounts of DER tripped



# Results: Spring Weekend Mid-Day Minimum Load


- DER solar output: 90% of nameplate (7,390 MW)
- Amount tripped due to SEMA/RI SLG fault with breaker failure: 1,855 MW



Each blue dot represents a substation where DER solar generation was tripped. DER in the New York system was not explicitly modeled.

# Results: Summer Weekday Mid-Day Peak Load (High Renewables)


- DER solar output: 65% of nameplate (5,340 MW)
- Amount tripped due to SEMA/RI SLG fault with breaker failure: 807 MW



Each blue dot represents a substation where DER solar generation was tripped. DER in the New York system was not explicitly modeled.

# Spring Weekend Mid-Day Minimum Load, Reduced PV Output

- In the spring weekend mid-day minimum load condition, DER solar output was reduced to 50% of nameplate (4,110 MW) and replaced with natural gas generation
- Amount tripped due to SEMA/RI SLG fault with breaker failure: 877 MW
- While some stations' DER now rides through the fault, most of the reduction is due to the lower amount of DER at each station



Green dots: DER tripped in this simulation  
Blue dots: DER tripped in the original minimum load case (on slide 13), but not in this simulation


# Spring Weekend Mid-Day Minimum Load, Reduced PV Output

- The reduced-PV minimum load condition shown on the previous slide is expected to occur somewhat frequently
  - Significant loss of DER for transmission system faults is a concern not only under extreme minimum load conditions
- Two things must occur simultaneously to see a condition similar to the reduced-PV minimum load condition:
  - PV output at or above the level in this condition
  - Synchronous generation (load – solar – wind) at or below the level in this condition
- Based on 2000-2019 data for load, wind, and solar, these two factors could occur with the following frequency:
  - 205 hours per year, with PV capacity based on the 2020 CELT forecast
  - 454 hours per year, with PV capacity based on the 2021 CELT forecast



# Minimum Load, Generators as Sync. Condensers

- In the mid-day minimum load condition, four gas-fired plants near the fault location were left online at 0 MW, acting as synchronous condensers
- Amount tripped due to SEMA/RI SLG fault with breaker failure: 1,620 MW
  - Slight improvement from original mid-day minimum load results
  - 235 MW of DER no longer tripping



Green dots: DER tripped in this simulation  
Blue dots: DER tripped in the original minimum load case (on slide 13), but not in this simulation

# Other Mitigation Strategies for DER Tripping

- If newer DERs are operated with voltage control capability, could they support distribution voltage during/after the fault and keep older DERs from tripping?
  - Simulations showed almost no difference in IEEE 1547-2003 DER tripping with IEEE 1547-2018 DER modeled with dynamic voltage control capability
- Will DER inverters eventually be replaced with inverters that comply with IEEE 1547-2018 and ISO-NE Source Requirements Document?
  - Virtually all DER tripped has inverters installed under IEEE 1547-2003
  - Replacement may occur gradually over time, eventually eliminating the risk of large amounts of DER tripping during most transmission system faults
  - However, the transmission system must be planned and operated securely in the meantime, before this replacement occurs
  - Even IEEE 1547-2018 DER will still enter temporary power reduction; further analysis is required to determine whether thousands of MW of DER temporarily reducing power poses a reliability risk

# Other Mitigation Strategies for DER Tripping

- Further analysis of the addition of synchronous condensers to the transmission system is ongoing
- Synchronous condensers remote from DER (i.e. on the 345 kV system) do not seem to be effective at keeping DER online
- Ongoing analysis is testing the effectiveness of synchronous condensers at locations electrically closer to DER



# NEXT STEPS & TENTATIVE TPCET SCHEDULE



# Further Analysis for TPCET Pilot Study

- Steady-State Analysis
  - Variations on peak load cases, reflecting generator dispatches similar to those in recent Needs Assessments
  - Mitigating measures for steady state high-voltage conditions at minimum load, following the addition of any stability-related dynamic devices
- Stability Analysis
  - Investigation into addition of synchronous condensers to reduce the amount of DER tripping for transmission system faults
  - Further investigation into acceptable megawatt limits on DER tripping



# Preliminary Plans for Future PAC Presentations

- August 2021: Final PAC presentation on steady-state and stability results, proposal for new study assumptions for load, solar generation, and wind generation
- September 2021: Finalize and document new study conditions for load, solar generation, and wind generation



# Questions

