



Brent Oberlin
Director, Transmission Planning

March 17, 2022

Mr. Robert Ide
New England Power Company
40 Sylvan Road
Waltham, MA 02451

Subject: V-148S 115 kV Line Upgrade – Proposed Plan Application (PPA) – NEP-22-T02

Dear Mr. Ide,

This letter is to inform you that, pursuant to review under Section I.3.9 of the ISO Tariff, no significant adverse effect has been identified with regard to the following PPA:

NEP-22-T02 – Transmission application from New England Power Company (NEP) for the rebuild of the V-148S 115 kV line (7.23 miles) between Washington and Read Street Substations by replacing the conductor and all structures. The proposed in service date of the project is April 30, 2023. The Reliability Committee (RC) reviewed the materials presented in support of the proposed project and did not identify a significant adverse effect on the reliability or operating characteristics of its transmission facilities, the transmission facilities of another Transmission Owner or the system of any other Market Participant.

Having given due consideration to the RC review, ISO New England has determined that implementation of the plan will not have a significant adverse effect upon the reliability or operating characteristics of the Transmission Owner's transmission facilities, the transmission facilities of another Transmission Owner, or the system of a Market Participant. A determination under Section I.3.9 of the ISO Tariff is limited to a review of the reliability impacts of a proposed project as submitted by Participants and does not constitute an approval of a proposed project under any other provisions of the ISO Tariff.

Sincerely,

/s/ Brent Oberlin

Brent Oberlin
Director, Transmission Planning

cc: Proposed Plan Applications