



November 8, 2022

**VIA ELECTRONIC FILING**

The Honorable Kimberly D. Bose, Secretary  
Federal Energy Regulatory Commission  
888 First Street, NE  
Washington, DC 20426

**Re: *ISO New England Inc., Docket No. ER23-\_\_\_-000, Filing of Installed Capacity Requirement, Hydro Quebec Interconnection Capability Credits and Related Values for the Seventeenth Forward Capacity Auction (Associated with the 2026-2027 Capacity Commitment Period)***

Dear Secretary Bose:

Pursuant to Section 205 of the Federal Power Act (“FPA”),<sup>1</sup> ISO New England Inc. (the “ISO”), joined by the New England Power Pool Participants Committee (“NEPOOL”),<sup>2</sup> hereby electronically submits to the Federal Energy Regulatory Commission (“FERC” or “Commission”) this transmittal letter and related materials that identify the following values for the 2026-2027 Capacity Commitment Period,<sup>3</sup> which is associated with Forward Capacity Auction (“FCA”) 17: (i) Installed Capacity Requirement (“ICR”),<sup>4</sup> (ii) Maximum Capacity Limits (“MCLs”) for the Maine (“Maine”) and Northern New England (“NNE”) Capacity Zones,<sup>5</sup> (iii) Hydro Quebec Interconnection Capability Credits (“HQICCs”); and (iv) Marginal Reliability Impact (“MRI”) Demand Curves.<sup>6</sup> The ICR, net ICR, the MCLs for the Maine and

---

<sup>1</sup> 16 U.S.C. § 824d (2021).

<sup>2</sup> Under New England’s RTO arrangements, the rights to make this filing under Section 205 of the Federal Power Act are the ISO’s. NEPOOL, which pursuant to the Participants Agreement provides the sole market participant stakeholder process for advisory voting on ISO matters, supported this filing and, accordingly, joins in this Section 205 filing.

<sup>3</sup> The 2026-2027 Capacity Commitment Period starts on June 1, 2026 and ends on May 31, 2027.

<sup>4</sup> Capitalized terms used but not otherwise defined in this filing have the meanings ascribed thereto in the ISO’s Transmission, Markets and Services Tariff (the “Tariff”).

<sup>5</sup> The NNE Capacity Zone includes the New Hampshire, Maine and Vermont Load Zones. The Maine Capacity Zone includes the Maine Load Zone.

<sup>6</sup> As explained in this filing letter, the MRI Demand Curves include the System-Wide Capacity Demand Curve, and

The Honorable Kimberly D. Bose, Secretary  
November 8, 2022  
Page 2

NNE Capacity Zones, HQICCs, and MRI demand curves are collectively referred to herein as the “ICR-Related Values.”<sup>7</sup>

The ISO is proposing the following ICR-Related Values for FCA 17:

ICR	31,306 MW
Net ICR (ICR minus HQICCs)	30,305 MW
MCL for Maine	4,065 MW
MCL for NNE	8,595 MW
HQICCs	1,001 MW


Along with the following MRI Demand Curves:

---


the export-constrained Capacity Zone Demand Curves for the Maine and NNE Capacity Zones.

<sup>7</sup> Pursuant to Section III.12.3 of the Tariff, the ICR must be filed 90 days prior to the applicable FCA. While FCA 17, which is the primary FCA for the 2026-2027 Capacity Commitment Period, was originally scheduled to commence on February 6, 2023, due to changes in the FCA 17 schedule, FCA 17 is scheduled to commence on March 6, 2023. The ISO changes to the FCA 17 schedule pursuant to a FERC order accepting the ISO’s exigent circumstances filing that was submitted after the FCA 16 results were delayed. *See ISO New England Inc., Exigent Circumstances Filing of Revisions to Section III.13 of the Tariff*, Docket No. ER22-1053-000 (filed Feb. 15, 2022).


1. System-Wide Capacity Demand Curve for FCA 17



2. Export-Constrained Capacity Zone Demand Curve for the Maine Capacity Zone for FCA 17



3. Export-Constrained Capacity Zone Demand Curve for the NNE Capacity Zone for FCA 17



Pursuant to the Tariff, the ISO must also calculate Local Sourcing Requirements (LSRs) for identified import Capacity Zone.<sup>8</sup> An LSR is the minimum amount of capacity that must be electrically located within an import-constrained Capacity Zone to meet the ICR.<sup>9</sup> Specifically, the LSR is calculated for an import-constrained Capacity Zone as the amount of capacity needed to satisfy the higher of (i) the Local Resource Adequacy (LRA) or (ii) the Transmission Security Analysis (TSA) requirements. For FCA 17, the import-constrained zone criteria testing conducted on the proposed Southeast New England (“SENE”)<sup>10</sup> import-constrained Capacity

<sup>8</sup> See Section III.12.4 of the Tariff.

<sup>9</sup> See Section III.12.2 of the Tariff.

<sup>10</sup> The proposed SENE import-constrained Capacity Zone includes the Southeast Massachusetts, Northeastern Massachusetts and Rhode Island Load Zones.

Zone did not trigger a need for the zone. This is mainly due to a decrease in the SENE load forecast and an increase in the N-1-1 import limit. Therefore, there are no import-constrained Capacity Zones for FCA 17<sup>11</sup> and, accordingly, the ISO did not have to calculate LSRs.

The derivation of the ICR-Related Values is discussed in Sections III-VI of this filing letter and in the attached Testimony of Manasa Kotha, Lead Engineer in the ISO's System Planning Department (the "Kotha Testimony"). The Kotha Testimony is solely sponsored by the ISO.

The methodology used to calculate the ICR-Related Values is the same Commission-approved methodology that was used to calculate the values submitted and accepted for the preceding FCA.<sup>12</sup> The proposed values are therefore the result of a well-developed process that improves, pursuant to the Commission's direction, on the processes utilized and approved by the Commission for the development of the ICR and related values in the past.<sup>13</sup> Accordingly, the Commission should accept the proposed values as just and reasonable without change to become effective on January 7, 2023.

## I. DESCRIPTION OF FILING PARTIES AND COMMUNICATIONS

The ISO is the private, non-profit entity that serves as the regional transmission organization ("RTO") for New England. The ISO operates and plans the New England bulk power system and administers New England's organized wholesale electricity market pursuant to the Tariff and the Transmission Operating Agreement with the New England Participating Transmission Owners. In its capacity as an RTO, the ISO has the responsibility to protect the

---

<sup>11</sup> See June 29, 2022 Zonal Modeling for FCA 17 presentation to the Power Supply Planning Committee, available at: [https://www.iso-ne.com/static-assets/documents/2022/06/a03\\_fca17\\_zone\\_formation.pptx](https://www.iso-ne.com/static-assets/documents/2022/06/a03_fca17_zone_formation.pptx)

<sup>12</sup> *ISO New England Inc.*, Docket No. ER22-378-000 (Nov. 9, 2021).

<sup>13</sup> *Id.*; see, also FERC orders approving prior ICR filings: 2025-2026 ICR: *ISO New England Inc.*, Docket No. ER22-378-000 (Dec. 21, 2021) (delegated letter order); 2024-2025 ICR: *ISO New England Inc.*, Docket No. ER21-371-000 (Jan. 7, 2021) (delegated letter order), 2023-2024 ICR: *ISO New England Inc.*, Docket No. ER20-311-000 (Jan. 3, 2020); 2022-2023 ICR: *ISO New England Inc.*, Docket No. ER19-291-000 (Jan. 4, 2019) (delegated letter order); 2021-2022 ICR: *ISO New England Inc.*, Docket No. ER18-263-000 (Dec. 18, 2017) (delegated letter order); 2020-2021 ICR: *ISO New England Inc.*, Docket No. ER17-320-000 (Dec. 6, 2017) (delegated letter order); 2019-2020 ICR: *ISO New England Inc.*, 154 FERC ¶ 61,008 (2016), *order on reh'g*, 155 FERC ¶ 61,145 (2016); 2018-2019 ICR: *ISO New England Inc.*, 150 FERC ¶ 61,003 (2015), *order on reh'g*, 150 FERC ¶ 61,155 (2015); 2017-2018 ICR: *ISO New England Inc.*, Docket No. ER14-328-000 (Dec. 30, 2013) (delegated letter order); 2016-2017 ICR: *ISO New England Inc.*, Docket No. ER13-334-000 (Dec. 31, 2012) (delegated letter order); 2015-2016 ICR: *ISO New England Inc.*, Docket No. ER12-756-000 (Feb. 23, 2012) (delegated letter order); 2014-2015 ICR: *ISO New England Inc.*, Docket No. ER11-3048-000, 135 FERC ¶ 61,135 (2011); 2013-2014 ICR: *ISO New England Inc.*, Docket No. ER10-1182-000 (June 25, 2010) (delegated letter order); 2012-2013 ICR: *ISO New England Inc.*, Docket No. ER09-1415-000 (Aug. 14, 2009) (delegated letter order); 2011-2012 ICR: *ISO New England Inc.*, 125 FERC ¶ 61,154 (2008).

short-term reliability of the New England Control Area and to operate the system according to reliability standards established by the Northeast Power Coordinating Council, Inc. (“NPCC”) and the North American Electric Reliability Corporation (“NERC”).

The signatories to the New England Power Pool Agreement, which was first entered into in 1971, are referred to collectively as “NEPOOL.” Currently, there are more than 520 signatories, which are referred to either as “members” or “Participants.” They include all of the electric utilities rendering or receiving services under the Tariff, as well as independent power generators, marketers, load aggregators, brokers, consumer-owned utility systems, demand response providers (including owners of distributed generation and aggregators of such generation), developers, end users, and a merchant transmission provider. Pursuant to revised governance provisions the Commission accepted in *ISO New England Inc., et al.*, 109 FERC ¶ 61,147 (2004), the Participants act through the NEPOOL Participants Committee. The Participants Committee is authorized by Section 6.1 of the Second Restated NEPOOL Agreement and Section 8.1.3(c) of the Participants Agreement to represent NEPOOL in proceedings before the Commission. Pursuant to Section 2.2 of the Participants Agreement, “NEPOOL provide[s] the sole Participant Processes for advisory voting on ISO matters and the selection of ISO Board members, except for input from state regulatory authorities and as otherwise may be provided in the Tariff, TOA and the Market Participant Services Agreement included in the Tariff.” All correspondence and communications in this proceeding should be addressed to the undersigned for the ISO as follows:

Margoth Caley, Esq.\*  
Senior Regulatory Counsel  
ISO New England Inc.  
One Sullivan Road  
Holyoke, MA 01040-2841  
Tel: (413) 535-4045  
Fax: (413) 535-4379  
Email: mcaley@iso-ne.com

And to NEPOOL as follows:

Robert Stein\*  
Vice Chair, NEPOOL Reliability Committee  
c/o Signal Hill Consulting Group  
110 Merchants Row, Suite 16  
Rutland, VT 05701  
Tel: (802) 236-4139  
Email: rstein206@aol.com

Eric K. Runge, Esq.\*  
Day Pitney LLP  
One Federal Street  
Boston, MA 02110  
Tel: (617) 345-4735  
Fax: (617) 345-4745  
Email: ekrunge@daypitney.com

\*Persons designated for service<sup>14</sup>

## II. STANDARD OF REVIEW

The ISO submits the proposed ICR-Related Values for FCA 17, which is associated with the 2026-2027 Capacity Commitment Period, pursuant to Section 205 of the Federal Power Act, which “gives a utility the right to file rates and terms for services rendered with its assets.”<sup>15</sup> Under Section 205, the Commission “plays ‘an essentially passive and reactive’ role”<sup>16</sup> whereby it “can reject [a filing] only if it finds that the changes proposed by the public utility are not ‘just and reasonable.’”<sup>17</sup> The Commission limits this inquiry “into whether the rates proposed by a utility are reasonable – and [this inquiry does not] extend to determining whether a proposed rate schedule is more or less reasonable than alternative rate designs.”<sup>18</sup> The ICR-Related Values submitted herein “need not be the only reasonable methodology, or even the most accurate.”<sup>19</sup> As a result, even if an intervenor or the Commission develops an alternative proposal, the Commission must accept this Section 205 filing if it is just and reasonable.<sup>20</sup>

## III. INSTALLED CAPACITY REQUIREMENT

### A. Description of the ICR

The ICR is a measure of the installed resources that are projected to be necessary to meet reliability standards in light of total forecasted load requirements for the New England Control Area and to maintain sufficient reserve capacity to meet reliability standards. More specifically, the ICR is the amount of resources needed to meet the reliability requirements defined for the New England Control Area of disconnecting non-interruptible customers (a loss of load expectation or “LOLE”) no more than once every ten years (a LOLE of 0.1 days per year). The

---

<sup>14</sup> Due to the joint nature of this filing, the Filing Parties respectfully request a waiver of Section 385.203(b)(3) of the Commission’s regulations to allow the inclusion of more than two persons on the service list in this proceeding.

<sup>15</sup> *Atlantic City Elec. Co. v. FERC*, 295 F.3d 1, 9 (D.C. Cir. 2002).

<sup>16</sup> *Id.* at 10 (quoting *City of Winnfield v. FERC*, 744 F.2d 871, 876 (D.C. Cir. 1984)).

<sup>17</sup> *Id.* at 9.

<sup>18</sup> *Cities of Bethany, et al. v. FERC*, 727 F.2d 1131, 1136 (D.C. Cir. 1984), *cert. denied*, 469 U.S. 917 (1984).

<sup>19</sup> *OXY USA, Inc. v. FERC*, 64 F.3d 679, 692 (D.C. Cir. 1995) (citing *Cities of Bethany*, 727 F.2d at 1136).

<sup>20</sup> *Cf. Southern California Edison Co., et al.*, 73 FERC ¶ 61,219 at 61,608 n.73 (1995) (“Having found the plan to be just and reasonable, there is no need to consider in any detail the alternative plans proposed by the Joint Protesters.” (citing *Cities of Bethany*, 727 F.2d at 1136)).



methodology for calculating the ICR is set forth in Section III.12 of the Tariff.

The ISO is proposing a 31,306 MW ICR for FCA 17, which is associated with the 2026-2027 Capacity Commitment Period. This value reflects tie benefits (emergency energy assistance) assumed obtainable from Quebec, Maritimes (New Brunswick), and New York in the aggregate amount of 2,100 MW. However, the 31,306 MW ICR value does not reflect a reduction in capacity requirements relating to HQICCs. The HQICC value of 1,001 MW per month is applied to reduce the portion of the ICR that is allocated to the Interconnection Rights Holders (“IRH”). Thus, the net ICR, after deducting the HQICC value, is 30,305 MW.<sup>21</sup>

## **B. Development of the ICR**

The methodology used to develop the ICR-Related Values for FCA 17 is the same as that used to calculate the values for the previous FCA. As in previous years, the values submitted in the instant filing are based on assumptions relating to expected system conditions for the associated Capacity Commitment Period. These assumptions include the load forecast, resource capacity ratings, resource availability, and relief assumed obtainable by implementation of operator actions during a capacity deficiency, which includes the amount of possible emergency assistance (tie benefits) obtainable from New England’s interconnections with neighboring Control Areas, load reduction from implementation of 5% voltage reductions, and maintaining a minimum level of operating reserve. All modeling assumptions have been updated to reflect expected changes in system conditions. These updated assumptions are described below.

### **1. Load Forecast**

The forecasted peak loads of the entire New England Control Area for the 2026-2027 Capacity Commitment Period are one major input into the calculation of the ICR-Related Values. For the purpose of calculating the ICR for FCA 17, which is associated with the 2026-2027 Capacity Commitment Period, the ISO used the load forecast published in the 2022-2031 Forecast Report of Capacity, Energy, Loads, and Transmission dated May 1, 2022 (“2022 CELT Report”).<sup>22</sup> As in previous years, the load forecast methodology reflects economic and demographic assumptions as reviewed by the NEPOOL Load Forecast Committee (“LFC”).<sup>23</sup>

The projected New England Control Area summer 50/50 peak load<sup>24</sup> for the 2026-2027

---

<sup>21</sup> The net ICR is used in the development of the MRI Demand Curves, which will be used to procure capacity in FCA 17.

<sup>22</sup> Kotha Testimony at 10-12.

<sup>23</sup> The methodology is reviewed periodically and updated when deemed necessary in consultation with the LFC.

<sup>24</sup> The New England Control Area is a summer-peaking system, meaning that the highest load occurs during the

Capacity Commitment Period is 27,298 MW. In determining the ICR, the load forecast is represented by a weekly probability distribution of daily peak loads. This probability distribution is meant to quantify the New England weekly system peak load's relationship to weather. The 50/50 peak load is used solely for reference purposes. In the ICR calculations, the methodology determines the amount of capacity resources needed to meet every expected peak load of the weekly distribution given the probability of occurrence associated with that load level.<sup>25</sup>

## 2. Resource Capacity Ratings

The ICR for FCA 17, which is associated with the 2026-2027 Capacity Commitment Period, is based on the latest available resource ratings<sup>26</sup> of Existing Capacity Resources that have qualified for FCA 17 at the time of the ICR calculation. These resources will be described in the qualification informational filing for FCA 17 that will be submitted to the Commission, pursuant to the revised schedule for FCA 17, on December 21, 2022.<sup>27</sup>

Resource additions and most resource attritions<sup>28</sup> are not assumed in the calculation of the ICR for FCA 17, pursuant to the Tariff, because there is no certainty regarding which new resource additions or existing resource attritions, if any, will clear the FCA. The use of the proxy unit for potential required resource additions when the system is short of capacity, and the additional load carrying capability adjustments to remove surplus capacity from the system, discussed in the Kotha Testimony, are designed to address these resource addition and attrition

---

summer. The 50/50 peak refers to the peak load having a 50% chance of being exceeded. The referenced value is the 2022 CELT "Net (with Reductions for BTM PV)" peak load forecast, as shown in CELT Section 1.1 Summer Peak Capabilities and Load Forecast.

<sup>25</sup> See Kotha Testimony at 10-11.

<sup>26</sup> The resource capacity ratings for FCA 17, which is associated with the 2026-2027 Capacity Commitment Period, were calculated in accordance with Section III.12.7.2 of the Tariff using the methods and procedures that were employed for calculating resource capacity ratings reflected in the Commission-approved ICRs for the sixteen FCAs conducted to date. See the 2015-2016 ICR Letter Order; the 2016-2017 ICR Letter Order; the 2017-2018 ICR Letter Order; the 2018-2019 ICR Letter Order; the 2019-2020 ICR Letter Order; the 2020-2021 ICR Letter Order; the 2021-2022 ICR Letter Order; the 2022-2023 ICR Letter Order; the 2023-2024 ICR Letter Order; the 2024-2025 ICR Letter Order; and the 2025-2026 ICR Letter Order.

<sup>27</sup> See, note 7, *supra*.

<sup>28</sup> Retirement De-List Bids that are at or above the FCA Starting Price and those retirements for resources that have elected unconditional treatment are deducted from the Existing Capacity Resources' qualified capacity data.

uncertainties.<sup>29</sup>

### **3. Resource Availability**

The proposed ICR value for FCA 17, which is associated with the 2026-2027 Capacity Commitment Period, reflects generating resource availability assumptions based on historical scheduled maintenance and forced outages of these capacity resources.<sup>30</sup> For generating resources, individual unit scheduled maintenance assumptions are based on each unit's most recent five-year historical average of scheduled maintenance. Each generating resource's forced outage assumptions are based on the resource's most recent five-year historical NERC Generator Availability Database System ("GADS") forced outage rate data submitted to the ISO. If the resource has been in commercial operation less than five years, then the NERC class average maintenance and forced outage data for the same class of units is used to substitute for the missing annual data.

The Qualified Capacity of an Intermittent Power Resource is the resource's median output during the Reliability Hours averaged over a period of five years. Based on the Intermittent Power Resources rating methodology, these resources are assumed to be 100% available because their availability impacts on reliability are already incorporated into the resource ratings.

### **4. Other Assumptions**

#### *a. Tie Benefits*

New England's Commission-approved method for establishing the ICR requires that assumptions be made regarding the tie benefits value to be used as an input in the calculation.<sup>31</sup> The tie benefits reflect the assumed amount of emergency assistance from neighboring Control Areas that New England could rely on, without jeopardizing reliability in New England or the neighboring Control Areas, in the event of a capacity shortage in New England. Assuming tie benefits as a resource to meet the 0.1 days/year LOLE criterion reduces the ICR and lowers the

---

<sup>29</sup> Kotha Testimony at 8-9.

<sup>30</sup> The assumed resource availability ratings for FCA 17 which is associated with the 2026-2027 Capacity Commitment Period, are discussed in the Kotha Testimony. The ratings were calculated in accordance with Section III.12.7.3 of the Tariff using the methods and procedures that were employed for calculating resource capacity ratings reflected in the Commission-approved ICRs for the first sixteen FCAs. *See* note 13, *supra*.

<sup>31</sup> *See* Section III.12.9 of the Tariff. The methodology for calculating tie benefits to be used in the Installed Capacity Requirement for FCA 17 is the same methodology used to calculate the tie benefits used in the ICR for Capacity Commitment Periods associated with prior FCAs.

amount of capacity to be procured in the FCA.

The ISO’s proposed ICR for FCA 17 reflects tie benefits calculated from the Quebec, Maritimes (New Brunswick), and New York Control Areas.<sup>32</sup> The ISO utilizes a probabilistic multi-area reliability model to calculate total tie benefits from these three Control Areas. Tie benefits from each individual Control Area are determined based on the results of individual probabilistic calculations performed for each of the three neighboring Control Areas. Specifically, the tie benefits methodology is comprised of two broad steps. In step one, the ISO develops necessary system load, transmission interface transfer capabilities and capacity assumptions. In step two, the ISO conducts simulations using the probabilistic GE MARS modeling program in order to determine tie benefits. In this step, the neighboring Control Areas are modeled using “*at criteria*” modeling assumptions which means that, when interconnected, all Control Areas are assumed to be at the 0.1 days/year reliability planning criteria.

The tie benefits methodology is described in detail in Section III.12.9 of the Tariff. The procedures associated with the tie benefits calculation methodology were also addressed in detail in the transmittal letter for the 2014-2015 ICR Filing.<sup>33</sup> The total tie benefits assumption and a breakdown of this value by Control Area are as follows:

Control Area	Tie Line	Tie Benefits (MW)
Quebec	HQ Phase I/II HVDC	1,001
Quebec	Highgate	150
Maritimes (New Brunswick)	New Brunswick	523
New York	NY AC Ties	426
New York	Cross Sound Cable	0
		<b>Total = 2,100</b>

Under Section III.12.9.2.4(a) of the Tariff, one factor in the calculation of tie benefits is the transfer capability of the interconnections for which tie benefits are calculated. In the first

---

<sup>32</sup> See 2014-2015 ICR Filing, Karl-Wong Testimony at 27, for an explanation of the methodology employed by the ISO in determining tie benefits for the 2014-2015 Capacity Commitment Period, which the ISO also used in determining tie benefits for the 2015-2016 Capacity Commitment Period, the 2016-2017 Capacity Commitment Period, the 2017-2018 Capacity Commitment Period, the 2018-2019 Capacity Commitment Period, the 2019-2020 Capacity Commitment Period, the 2020-2021 Capacity Commitment Period, the 2021-2022 Capacity Commitment Period, the 2022-2023 Capacity Commitment Period, the 2023-2024 Capacity Commitment Period, the 2024-2025 Capacity Commitment Period, and the 2025-2026 Capacity Commitment Period.

<sup>33</sup> *ISO New England Inc.*, Filing of Installed Capacity Requirement, Hydro Quebec Interconnection Capability Credits and Related Values for the 2014-2015 Capability Year, Docket No. ER11-3048-000 at 13-19 (2011).

half of 2022, the ISO reviewed the transfer limits of these external interconnections based on the latest available information regarding forecasted topology and load forecast information, and determined that no changes to the established external interface limits were warranted. The ISO established the following capacity transfer capability values for each interconnection including their assumed forced and scheduled outage rates:

<b>External Tie Line</b>	<b>External Interface Import Capability (MW)</b>	<b>Forced Outage Rate (%)</b>	<b>Maintenance (Weeks)</b>
HQ Phase I/II HVDC	1,400	2.0	2.1
Highgate	200	0.1	0.7
New Brunswick	700	0.2	2.5
NY AC Ties	1,400	0.3	6.6
Cross Sound Cable	0	0.3	8.1
	<b>Total = 3,700</b>	<b>N/A</b>	<b>N/A</b>

The other factor is the transfer capability of the internal transmission interfaces. In calculating tie benefits for the ICR for FCA 17, for internal transmission interfaces, the ISO used the transfer capability values from its most recent transfer capability analyses.

*b. Amount of System Reserves*

Pursuant to Section III.12.7.4 (c) of the Tariff, the amount of system reserves included in the determination of the ICR and related values must be consistent with those needed for reliable system operations during emergency conditions. Using a system reserve assumption in the ICR and related values calculations assumes that, during peak load conditions, under extremely tight capacity situations, while emergency capacity and energy operating plans are being used, ISO operations would have available the essential amount of operating reserves for transmission system protection, system load balancing, and tie control, prior to invoking manual load shedding. Starting in FCA 13, the ISO determined that the minimum amount of reserves to be assumed in the determination of the ICR and related values should be 700 MW. As a result, 700 MW of system reserves is the amount that the ISO used in the determination of the ICR-Related Values for FCA 17.

**IV. MAXIMUM CAPACITY LIMITS**

In the FCM, the ISO must also calculate MCLs.<sup>34</sup> An MCL is the maximum amount of

---

<sup>34</sup> See Section III.12.2.1 of the Tariff.

capacity that can be located in an export-constrained Capacity Zone to meet the ICR.<sup>35</sup> The general purpose MCLs is to identify capacity resource needs such that, when considered in combination with the transfer capability of the transmission system, they are electrically distributed within the New England Control Area contributing toward purchasing the right amount of resources in the FCA to meet NPCC's and the ISO's bulk power system reliability planning criteria.

As Ms. Kotha explains, in the determination of the MCL for an export-constrained Capacity Zone, a Local Resource Adequacy Requirement (which is the minimum amount of resources required for an area to satisfy its reliability criterion) is used to identify the minimum amount of resources required for the Rest of New England.<sup>36</sup>

For FCA 17, which is associated with the 2026-2027 Capacity Commitment Period, the ISO has determined that there are two export-constrained Capacity Zones of Maine and Northern New England (NNE). Therefore, the ISO calculated the following MCLs for the Maine and NNE Capacity Zones using the methodology reflected in Section III.12.2.2 of the Tariff:

<b>Export- Constrained Capacity Zone</b>	<b>MCL (MW)</b>
Maine	4,065
NNE	8,595

## V. HQICCs

HQICCs are capacity credits that are allocated to the IRH, which are the entities that pay for and, consequently, hold certain rights over the Hydro Quebec Phase I/II HVDC Transmission Facilities ("HQ Interconnection").<sup>37</sup> Pursuant to Sections III.12.9.5 and III.12.9.7 of the Tariff, the tie benefit value for the HQ Interconnection was established using the results of a

---

<sup>35</sup> *Id.*

<sup>36</sup> See Kotha Testimony at 30-31 (explaining the methodology for calculating the LRA for the Rest of New England).

<sup>37</sup> See Section I.2.2 of the Tariff (stating in the definition of "Hydro-Quebec Interconnection Capability Credit" that "[a]n appropriate share of the HQICC shall be assigned to an IRH if the Phase I/II HVDC-TF support costs are paid by that IRH and such costs are not included in the calculation of the Regional Network Service rate."). See also Section III.12.9.7 of the Tariff ("[t]he tie benefits from the Quebec Control Area over the HQ Phase I/II HVDC-TF calculated in accordance with Section III.12.9.1 shall be allocated to the Interconnection Rights Holders or their designees in proportion to their respective percentage shares of the HQ Phase I and the HQ Phase II facilities, in accordance with Section I of the Transmission, Markets and Services Tariff.").

probabilistic calculation of tie benefits with Quebec. The ISO calculates HQICCs, which are allocated to the IRH in proportion to their individual rights over the HQ Interconnection, and must file the HQICC values established for each Capacity Commitment Period's FCA. The HQICC value for FCA 17 is 1,001 MW per month.

## **VI. MRI DEMAND CURVES**


Starting with FCA 11, which was associated with the 2020-2021 Capacity Commitment Period, the ISO began using the MRI demand curve methodology to develop system-wide and zonal demand curves to be used in the FCA to procure needed capacity. Accordingly, as described below, the ISO has developed a System-Wide Capacity Demand Curve and Capacity Zone Demand Curves to be used in FCA 17.

### **A. System-Wide Capacity Demand Curve**

Under Section III.12.1.1 of the Tariff, prior to each FCA, the ISO must determine the system-wide MRI of capacity at various higher and lower capacity levels for the New England Control Area. For purposes of calculating these MRI values, the ISO must apply the same modeling assumptions and methodology used in determining the ICR. Using the values calculated pursuant to Section III.12.1.1.1, the ISO must determine the System-Wide Capacity Demand Curve pursuant to Section III.13.2.2.1 of the Tariff.<sup>38</sup> Below is the System-Wide Capacity Demand Curve for FCA 17.

---

<sup>38</sup> Additional details regarding the calculation of the System-Wide Capacity Demand Curve are included in the Kotha Testimony at 33-34.




### **B. Export-Constrained Capacity Zone Demand Curves**


Under Section III.12.2.2.1 of the Tariff, prior to each FCA, the ISO must determine the MRI of capacity, at various higher and lower capacity levels around the requirement, for each export-constrained Capacity Zone. For purposes of calculating these MRI values, the ISO must apply the same modeling assumptions and methodology used to determine the export-constrained Capacity Zone's MCL. Using the values calculated pursuant to Section III.12.2.2.1 of the Tariff, the ISO must determine the export-constrained Capacity Zone Demand Curves pursuant to Section III.13.2.2.3 of the Tariff. For FCA 17, there are two export-constrained Capacity Zone Demand Curves, Maine and NNE.

The following is the export-constrained Capacity Zone Demand Curve for the Maine Capacity Zone for FCA 17:





The following is the export-constrained Capacity Zone Demand Curve for the NNE Capacity Zone for FCA 17:



## VII. STAKEHOLDER PROCESS

The ISO, in consultation with NEPOOL and other interested parties, developed the proposed ICR-Related Values for FCA 17 through an extensive stakeholder process over the course of six months, during which the Power Supply Planning Committee (“PSPC”) and the Reliability Committee reviewed the calculation assumptions and methodologies, and discussed the proposed ICR-Related Values for FCA 17.

In addition, in 2007 the New England States Committee on Electricity (“NESCOE”) was formed.<sup>39</sup> Among other responsibilities, NESCOE is responsible for providing feedback on the

<sup>39</sup> *ISO New England Inc.*, Docket No. ER07-1324-000, Formation of the New England States Committee on Electricity (filed August 31, 2007) (proposing to add a new rate schedule to the Tariff for the purpose of recovering funding for NESCOE’s operation) (the “NESCOE Funding Filing”); *ISO New England Inc.*, 121 FERC ¶ 61,105

proposed ICR-Related Values at the relevant NEPOOL PSPC, Reliability Committee and Participants Committee meetings, and was in attendance for most meetings at which the ICR-Related Values for FCA 17 were discussed.

On September 20, 2022 the Reliability Committee voted to recommend that the Participants Committee support the HQICCs with 63.95% in favor. Also on September 20, 2022, the Reliability Committee voted to recommend, that the Participants Committee support the proposed ICR-Related Values (*i.e.* the ICR, net ICR, MCLs for the Maine and NNE Capacity Zones, and MRI demand curves) with 63.95% in favor.

On October 6, 2022, the Participants Committee supported the HQICCs with 72.17% in favor. Also on October 6, 2022, the Participants Committee supported the proposed ICR-Related Values (*i.e.* the ICR, net ICR, MCLs for the Maine and NNE Capacity Zones, and MRI demand curves) with 72.17% in favor.<sup>40</sup>

### **VIII. REQUESTED EFFECTIVE DATE**

The ISO requests that the Commission accept the proposed ICR-Related Values for FCA 17 to be effective on January 7, 2023 (which is 60 days from the filing date), so that the proposed values can be used as part of FCA 17, which will be conducted in March 2023.

### **IX. ADDITIONAL SUPPORTING INFORMATION**

This filing identifies ICR-Related Values for FCA 17 and is made pursuant to Section 205 of the FPA. Section 35.13 of the Commission's regulations generally requires public utilities to file certain cost and other information related to an examination of cost-of-service rates.<sup>41</sup> However, the proposed ICR-Related Values are not traditional "rates." Furthermore, the ISO is not a traditional investor-owned utility. Therefore, to the extent necessary, the ISO requests waiver of Section 35.13 of the Commission's regulations. Notwithstanding its request for waiver, the ISO submits the following additional information in compliance with the identified filing regulations of the Commission applicable to Section 205 filings.

35.13(b)(1) - Materials included herewith are as follows:

---

(2007) (order accepting the ISO's proposed rate schedule for funding of NESCOE's operations).

<sup>40</sup> The HQICC and ICR votes at the Participants Committee were taken together with the following sector percentages in favor: The motions passed in the single vote with a 72.17% Vote in favor (Generation Sector – 5.57%; Transmission Sector – 16.7%; Supplier Sector – 0%; AR Sector – 16.5%; Publicly Owned Entity Sector – 16.7%; End User Sector – 16.7%; and Provisional Members – 0%).

<sup>41</sup> 18 C.F.R. § 35.13.

- ◆ This transmittal letter;
- ◆ Attachment 1: Testimony of Manasa Kotha;
- ◆ Attachment 2: List of governors and utility regulatory agencies in Connecticut, Maine, Massachusetts, New Hampshire, Rhode Island and Vermont to which a copy of this filing has been emailed.

35.13(b)(2) – The ISO respectfully requests that the Commission accept this filing to become effective on January 7, 2023.

35.13(b)(3) – Pursuant to Section 17.11(e) of the Participants Agreement, Governance Participants are being served electronically rather than by paper copy. The names and addresses of the Governance Participants are posted on the ISO’s website at <https://www.iso-ne.com/participate/participant-asset-listings/directory?id=1&type=committee>. An electronic copy of this transmittal letter and the accompanying materials has also been sent to the governors and electric utility regulatory agencies for the six New England states which comprise the New England Control Area, and to the New England Conference of Public Utility Commissioners, Inc. The names and addresses of these governors and regulatory agencies are shown in Attachment 2. In accordance with Commission rules and practice, there is no need for the entities identified on Attachment 2 to be included on the Commission’s official service list in the captioned proceedings unless such entities become intervenors in this proceeding.

35.13(b)(4) - A description of the materials submitted pursuant to this filing is contained in this transmittal letter.

35.13(b)(5) - The reasons for this filing are discussed in Sections III-VI of this transmittal letter.

35.13(b)(6) - The ISO’s approval of the ICR-Related Values is evidenced by this filing. The ICR-Related Values reflect the results of the Participant Processes required by the Participants Agreement and reflect the support of the Participants Committee.

35.13(b)(7) - The ISO has no knowledge of any relevant expenses or costs of service that have been alleged or judged in any administrative or judicial proceeding to be illegal, duplicative, or unnecessary costs that are demonstrably the product of discriminatory employment practices.

35.13(c)(2) - The ISO does not provide services under other rate schedules that are similar to the sale for resale and transmission services it provides under the Tariff.

35.13(c)(3) - No specifically assignable facilities have been or will be installed or modified in order to supply service with respect to the proposed ICR and related values.

The Honorable Kimberly D. Bose, Secretary  
November 8, 2022  
Page 21

**X. CONCLUSION**

The ISO requests that the Commission accept the proposed ICR-Related Values reflected in this submission for filing without change to become effective January 7, 2023.

Respectfully submitted,

ISO NEW ENGLAND INC.

By: /s/ Margoth Caley  
Margoth Caley, Esq.  
ISO New England Inc.  
One Sullivan Road  
Holyoke, MA 01040-2841  
Tel: (413) 535-4045  
Fax: (413) 535-4379  
E-mail: mcaley@iso-ne.com

By: /s/ Eric K. Runge  
Eric K. Runge, Esq.  
Day Pitney LLP  
One Federal Street  
Boston, MA 02110  
Tel: (617) 345-4735  
Fax: (617) 345-4745  
Email: ekrunge@daypitney.com

Attachments

cc: Entities listed in Attachment 2

1  
2  
3  
4  
5  
6  
7  
8  
9  
10  
11  
12  
13

**UNITED STATES OF AMERICA  
BEFORE THE  
FEDERAL ENERGY REGULATORY COMMISSION**

ISO New England Inc.

)

Docket No. ER23-\_\_-000

14  
15  
16  
17  
18  
19  
20  
21  
22  
23  
24  
25  
26  
27

**PREPARED TESTIMONY OF  
MANASA KOTHA  
ON BEHALF OF ISO NEW ENGLAND INC.**

**I. INTRODUCTION**

**Q: PLEASE STATE YOUR NAME, TITLE, AND BUSINESS ADDRESS.**

**A:** My name is Manasa Kotha. I am a Lead Engineer in the System Planning Department at ISO New England Inc. (the “ISO”). My business address is One Sullivan Road, Holyoke, Massachusetts 01040-2841.

**Q: PLEASE DESCRIBE YOUR WORK EXPERIENCE AND EDUCATIONAL BACKGROUND.**

**A:** As mentioned above, I am currently a Lead Engineer in the System Planning Department at the ISO. In my current position, I am responsible for the development of the Installed Capacity Requirement (“ICR”) and related values for the Forward Capacity Auction (“FCA”) and the annual reconfiguration auctions (“ARAs”) conducted in the Forward Capacity Market (“FCM”).<sup>1</sup>

---

<sup>1</sup> Capitalized terms used but not otherwise defined in this testimony have the meanings ascribed to them in the ISO New England Transmission, Markets, and Services Tariff (the “Tariff”).

1 Since 2019, I have worked for the Resource Studies & Assessments group conducting  
2 ICR and related values studies for the FCM. I also performed resource adequacy studies  
3 to support the ISO's Regional System Plan and reliability reporting requirements of the  
4 Northeast Power Coordinating Council, Inc. ("NPCC") and the North American Electric  
5 Reliability Corporation ("NERC"). Prior to that, I worked for 10 years in the Resource  
6 Analysis & Integration group, which is part of the ISO's System Planning Department. I  
7 was responsible for the qualification of Generating Capacity Resources, Demand  
8 Resources, and Import Capacity Resources for participation in the FCM. Prior to joining  
9 the ISO, I worked as a Software Engineer for Neumeric Technologies, where I developed  
10 software, carried out impact analysis, enhanced solutions by providing flexible business  
11 logic, testing code, and implementing quality management systems.

12  
13 I have an M.S. in Electrical Engineering from the University of Missouri, Columbia, and  
14 a Bachelor of Technology in Electronics and Communication Engineering from Acharya  
15 Nagarjuna University, India.

16  
17 **Q: WHAT IS THE PURPOSE OF YOUR TESTIMONY?**

18 **A:** My testimony discusses the derivation of the ICR, net ICR, the Maximum Capacity  
19 Limits ("MCLs") for the Maine and Northern New England ("NNE") Capacity Zones,<sup>2</sup>

---

<sup>2</sup> In accordance with Section III.12.4 of the Tariff, the ISO determined that it will model three Capacity Zones in FCA 17: the Maine Capacity Zone, the NNE Capacity Zone and the Rest of Pool Capacity Zone. The NNE Capacity Zone includes the New Hampshire, Vermont, and Maine Load Zones. The Maine Load Zone will be modeled as a separate nested export-constrained Capacity Zone within NNE. NNE will be modeled as an export-constrained Capacity Zone. The Rest-of-Pool Capacity Zone includes the Connecticut, Northeast MA (NEMA), Southeast MA (SEMA), Western/Central Massachusetts, and Rhode Island Load Zones.

1 the Hydro-Quebec Interconnection Capability Credits (“HQICCs”), and the Marginal  
2 Reliability Impact (“MRI”) demand curves for the 2026-2027 Capacity Commitment  
3 Period, which is associated with FCA 17, to be conducted beginning on March 6, 2023.  
4 The 2026-2027 Capacity Commitment Period starts on June 1, 2026 and ends on May 31,  
5 2027. The ICR, the MCLs for the Maine and the NNE Capacity Zones, HQICCs and  
6 MRI demand curves for FCA 17 are collectively referred to herein as the “ICR-Related  
7 Values.”  
8

9 **Q: DID THE ISO CALCULATE LOCAL SOURCING REQUIREMENTS FOR FCA**  
10 **17?**

11 **A:** No. Pursuant to the Tariff, the ISO must also calculate Local Sourcing Requirements  
12 (LSRs) for identified import Capacity Zone.<sup>3</sup> An LSR is the minimum amount of  
13 capacity that must be electrically located within an import-constrained Capacity Zone to  
14 meet the ICR.<sup>4</sup> Specifically, the LSR is calculated for an import-constrained Capacity  
15 Zone as the amount of capacity needed to satisfy the higher of (i) the Local Resource  
16 Adequacy or (ii) the Transmission Security Analysis requirements. However, for FCA  
17 17, there are no import-constrained Capacity Zones. Thus, the ISO did not have to  
18 calculate LSRs and, accordingly, the methodologies described in this testimony do not  
19 include steps related to LSRs.  
20

---

<sup>3</sup> See Section III.12.4 of the Tariff.

<sup>4</sup> See Section III.12.2 of the Tariff.



1 **Q: PLEASE EXPLAIN WHY THERE WERE NO IMPORT-CONSTRAINED**  
2 **CAPACITY ZONES FOR FCA 17.**

3 **A:** The Import Constrained Zone criteria testing conducted on the proposed Southeast New  
4 England (“SENE”)<sup>5</sup> import-constrained Capacity Zone for FCA 17 did not trigger a need  
5 for the zone. This is mainly due to a decrease in the SENE load forecast and an increase  
6 in the N-1-1 import capability limit.<sup>6</sup>

7  
8 **Q. ARE THERE ANY CHANGES TO THE METHODOLOGY FOR DEVELOPING**  
9 **THE INSTALLED CAPACITY REQUIREMENT AND RELATED VALUES?**

10 **A.** No. The methodology used to calculate the ICR-Related Values is the same Commission-  
11 approved methodology that was used to calculate the values submitted and accepted for  
12 the preceding FCA.

13  
14 **II. INSTALLED CAPACITY REQUIREMENT**

15  
16 **A. DESCRIPTION OF THE INSTALLED CAPACITY REQUIREMENT**

17  
18 **Q: WHAT IS THE “INSTALLED CAPACITY REQUIREMENT?”**

19 **A:** The ICR is the minimum level of capacity required to meet the reliability requirements  
20 defined for the New England Control Area. These requirements are documented in

---

<sup>5</sup> The proposed SENE import-constrained Capacity Zone includes the Southeast Massachusetts, Northeastern Massachusetts, and Rhode Island Load Zones.

<sup>6</sup> See June 29, 2022 Zonal Modeling for FCA 17 presentation to the Power Supply Planning Committee, available at: [https://www.iso-ne.com/static-assets/documents/2022/06/a03\\_fca17\\_zone\\_formation.pptx](https://www.iso-ne.com/static-assets/documents/2022/06/a03_fca17_zone_formation.pptx)

1 Section III.12 of the Tariff, which states, in Section III.12.1, that “[t]he ISO shall  
2 determine the [ICR] such that the probability of disconnecting non-interruptible  
3 customers due to resource deficiency, on average, will be no more than once in ten years.  
4 Compliance with this resource adequacy planning criterion shall be evaluated  
5 probabilistically, such that the Loss of Load Expectation (“LOLE”) of disconnecting non-  
6 interruptible customers due to resource deficiencies shall be no more than 0.1 day[s] each  
7 year. The forecast ICR shall meet this resource adequacy planning criterion for each  
8 Capacity Commitment Period.” Section III.12 of the Tariff also details the calculation  
9 methodology and the guidelines for the development of assumptions used in the  
10 calculation of the ICR.

11  
12 The development of the ICR is consistent with NPCC’s Full Member Resource Adequacy  
13 Criterion (Resource Adequacy Requirement R4),<sup>7</sup> under which the ISO must  
14 probabilistically evaluate resource adequacy to demonstrate that the LOLE of  
15 disconnecting firm load due to resource deficiencies is, on average, no more than 0.1  
16 days per year, while making allowances for demand uncertainty, scheduled outages and  
17 deratings, forced outages and deratings, assistance over interconnections with  
18 neighboring Planning Coordinator Areas, transmission transfer capabilities, and capacity  
19 and/or load relief from available operating procedures.

---

<sup>7</sup> See *Regional Reliability Reference Directory # 1 Design and Operation of the Bulk Power System* available at: <https://www.npcc.org/content/docs/public/program-areas/standards-and-criteria/regional-criteria/directories/directory-01-design-and-operation-of-the-bulk-power-system.pdf>

1 **Q: PLEASE EXPLAIN THE GENERAL PROCESS FOR ESTABLISHING THE**  
2 **ICR-RELATED VALUES.**

3 **A:** The ISO established the ICR-Related Values in accordance with the calculation  
4 methodology prescribed in Section III.12 of the Tariff. The ICR-Related Values and the  
5 assumptions used to develop them were discussed with stakeholders. The stakeholder  
6 process consisted of discussions with the New England Power Pool (“NEPOOL”) Load  
7 Forecast Committee, Power Supply Planning Committee (“PSPC”) and Reliability  
8 Committee. These committees’ review and comment on the ISO’s development of load  
9 and resource assumptions and the ISO’s calculation of the ICR-Related Values were  
10 followed by advisory votes from the NEPOOL Reliability Committee and Participants  
11 Committee. State regulators also had the opportunity to review and comment on the  
12 ICR-Related Values as part of their participation on the PSPC, Reliability Committee,  
13 and Participants Committee. On October 6, 2022, the Participants Committee supported  
14 the HQICCs with 72.17% in favor. Also on October 6, 2022, the Participants Committee  
15 supported the rest of the proposed ICR-Related Values (*i.e.* the ICR, net ICR, MCLs for  
16 the Maine and NNE Capacity Zones, and MRI demand curves) with 72.17% in favor.

17  
18 **Q: PLEASE EXPLAIN IN MORE DETAIL THE PSPC’S INVOLVEMENT IN THE**  
19 **DETERMINATION AND REVIEW OF THE ICR-RELATED VALUES.**

20 **A:** The PSPC is a non-voting technical subcommittee that reports to the Reliability  
21 Committee. The ISO chairs the PSPC and its members are representatives of the  
22 NEPOOL Participants. The ISO engages the PSPC to assist with the review of key inputs  
23 used in the development of resource adequacy-based requirements such as ICRs, Local

1 Resource Adequacy Requirements (“LRAs”), MCLs and MRI demand curves, including  
2 appropriate assumptions relating to load, resources, and tie benefits for modeling the  
3 expected system conditions. Representatives of the six New England States’ public  
4 utilities regulatory commissions are also invited to attend and participate in the PSPC  
5 meetings.

6  
7 **Q: PLEASE IDENTIFY THE INSTALLED CAPACITY REQUIREMENT VALUE**  
8 **THAT THE ISO CALCULATED FOR FCA 17, WHICH IS ASSOCIATED WITH**  
9 **THE 2026-2027 CAPACITY COMMITMENT PERIOD.**

10 **A:** The ICR value for FCA 17, which is associated with the 2026-2027 Capacity  
11 Commitment Period, is 31,306 MW.

12  
13 **Q: IS THIS THE AMOUNT OF INSTALLED CAPACITY REQUIREMENT THAT**  
14 **WAS USED FOR THE DEVELOPMENT OF THE SYSTEM-WIDE CAPACITY**  
15 **DEMAND CURVE?**

16 **A:** No. The ISO developed the System-Wide Capacity Demand Curve based on the net ICR  
17 of 30,305 MW, which is the 31,306 MW of ICR minus 1,001 MW of HQICCs (which are  
18 allocated to the Interconnection Rights Holders in accordance with Section III.12.9.2 of  
19 the Tariff).

20  
21 **B. DEVELOPMENT OF THE INSTALLED CAPACITY REQUIREMENT**  
22

1 **Q: PLEASE EXPLAIN THE CALCULATION METHODOLOGY FOR**  
2 **ESTABLISHING THE INSTALLED CAPACITY REQUIREMENT.**

3 **A:** The ICR was established using the General Electric Multi-Area Reliability Simulation  
4 (“GE MARS”) model. GE MARS uses a sequential Monte Carlo simulation to compute  
5 the resource adequacy of a power system. This Monte Carlo process repeatedly simulates  
6 the year (multiple replications) to evaluate the impacts of a wide range of possible  
7 combinations of resource capacity and load levels taking into account random resource  
8 outages, load forecast uncertainty, and behind-the-meter photovoltaic (BTM PV) output  
9 uncertainty. For the ICR, the system is considered to be a one bus model, in that the New  
10 England transmission system is assumed to have no internal transmission constraints in  
11 this simulation. For each hour, the program computes the isolated area capacity available  
12 to meet demand based on the expected maintenance and forced outages of the resources  
13 and the expected demand. Based on the available capacity, the program determines the  
14 probability of loss of load for the system for each hour of the year. After simulating all  
15 hours of the year, the program sums the probability of loss of load for each hour to arrive  
16 at an annual probability of loss of load value. This value is tested for convergence, which  
17 is set to be 5% of the standard deviation of the average of the hourly loss of load values.  
18 If the simulation has not converged, it proceeds to another replication of the study year.  
19 Once the program has computed an annual reliability index, if the system is less reliable  
20 than the resource-adequacy criterion (*i.e.*, the LOLE is greater than 0.1 days per year),  
21 additional resources are needed to meet the criterion. Under the condition where New  
22 England is forecasted to be less reliable than the resource adequacy criterion, proxy  
23 resources are used within the model to meet this additional need. The methodology calls

1 for adding proxy units until the New England LOLE is less than 0.1 days per year. For  
2 the ICR-Related Values for FCA 17, which is associated with the 2026-2027 Capacity  
3 Commitment Period, New England did not need proxy units because there is adequate  
4 qualified capacity to meet the 0.1 days/year LOLE criterion.

5  
6 If the system is more reliable than the resource-adequacy criterion (*i.e.*, the system LOLE  
7 is less than or equal to 0.1 days per year), additional resources are not required, and the  
8 ICR is determined by increasing loads (additional load carrying capability or “ALCC”) so  
9 that New England’s LOLE is exactly at 0.1 days per year. This is how the single value  
10 that is called the ICR is established. The modeled New England system must meet the  
11 0.1 days per year reliability criterion.

12  
13 **Q: WHAT ARE THE MAIN ASSUMPTIONS UPON WHICH THE ICR-RELATED**  
14 **VALUES FOR FCA 17 ARE BASED?**

15 **A:** One of the first steps in the process of calculating the ICR-Related Values is for the ISO  
16 to determine the assumptions related to expected system conditions for the Capacity  
17 Commitment Period. These assumptions are explained in detail below and include the  
18 load forecast, resource capacity ratings, resource availability, and the amount of load  
19 and/or capacity relief obtainable from certain actions specified in ISO New England  
20 Operating Procedure No. 4, Action During a Capacity Deficiency (“Operating Procedure  
21 No. 4”), which system operators invoke in real-time to balance demand with system  
22 supply in the event of expected capacity shortage conditions. Relief available from  
23 Operating Procedure No. 4 actions includes the amount of possible emergency assistance

1 (tie benefits) obtainable from New England’s interconnections with neighboring Control  
2 Areas and load reduction from implementation of 5% voltage reductions.

3  
4 **1. LOAD FORECAST**

5  
6 **Q: PLEASE EXPLAIN HOW THE ISO DERIVES THE LOAD FORECAST**  
7 **ASSUMPTION USED IN DEVELOPING THE INSTALLED CAPACITY**  
8 **REQUIREMENT AND RELATED VALUES.**

9 **A:** For probabilistic-based calculations associated with ICR-Related Values, the ISO  
10 develops a forecasted distribution of typical daily peak loads for each week of the year  
11 based on 30 years of historical weather data and an econometrically estimated monthly  
12 model of typical daily peak loads. Each weekly distribution of typical daily peak loads  
13 includes the full range of daily peaks that could occur over the full range of weather  
14 experienced in that week and their associated probabilities. The 50/50 and the 90/10  
15 peak loads are points on this distribution and used as reference points. The probabilistic-  
16 based calculations take into account all possible forecast load levels for the year. From  
17 these weekly peak load forecast distributions, a set of seasonal load forecast uncertainty  
18 multipliers are developed and applied to a specific historical hourly load profile to  
19 provide seasonal load information about the probability of loads being higher, and lower,  
20 than the peak load found in the historical profile. These multipliers are developed for  
21 New England in its entirety or for each subarea.

1 **Q: PLEASE DESCRIBE THE FORECASTED LOAD WITHIN CAPACITY ZONES**  
2 **FOR FCA 17, WHICH IS ASSOCIATED WITH THE 2026-2027 CAPACITY**  
3 **COMMITMENT PERIOD.**

4 **A:** The ISO developed the forecasted load for the Maine Capacity Zone using the load  
5 forecast for the State of Maine.

6  
7 The ISO developed the forecasted load for the NNE Capacity Zone using the combined  
8 load forecasts for the states of New Hampshire, Vermont, and Maine.

9  
10 **Q: WHAT DOES THE ISO CURRENTLY PROJECT TO BE THE NEW ENGLAND**  
11 **AND CAPACITY ZONE 50/50 AND 90/10 PEAK LOAD FORECAST FOR THE**  
12 **2026-2027 CAPACITY COMMITMENT PERIOD?**

13 **A:** The following table<sup>8</sup> shows the 50/50 and 90/10 peak load forecast for the 2026-2027  
14 Capacity Commitment Period based on the 2022 load forecast as documented in the  
15 2022-2031 Forecast Report of Capacity, Energy, Loads, and Transmission (“2022 CELT  
16 Report”). These values are reported as the “Net (with reductions for BTM PV)” load  
17 forecast.

18 **Table 1 – 50/50 and 90/10 Peak Load Forecast (MW)**

	<b>50/50</b>	<b>90/10</b>
New England	27,298	29,066
Maine	2,126	2,244
NNE	5,522	5,799

19  

---

<sup>8</sup> The values presented in the tables in this testimony have been rounded off to the nearest whole number.



1 **Q: PLEASE DESCRIBE THE DEVELOPMENT OF THE BTM PV FORECAST AT**  
2 **A HIGH LEVEL.**

3 A: Each year since 2014, the ISO, in conjunction with the Distributed Generation Forecast  
4 Working Group (“DGFWG”) (which includes state agencies responsible for  
5 administering the New England states’ policies, incentive programs and tax credits that  
6 support BTM PV growth in New England), develops forecasts of future nameplate  
7 ratings of BTM PV installations anticipated over the 10-year planning horizon. These  
8 forecasts are created for each state based on policy drivers, recent BTM PV growth  
9 trends, and discount adjustments designed to represent a degree of uncertainty in future  
10 BTM PV commercialization.

11  
12 **Q: WHAT METHODOLOGY DID THE ISO USE TO REFLECT THE**  
13 **CONTRIBUTIONS OF BTM PV TO REDUCE THE LOAD FORECAST FOR**  
14 **FCA 17?**

15 A: For FCA 17, as was done for prior FCAs, the ISO used an “hourly profile” methodology  
16 to determine the amount of load reduction provided by BTM PV in all hours of the day  
17 and all days of the year. The BTM PV hourly profile models the forecast of PV output as  
18 the full hourly load reduction value of BTM PV in all 8,760 hours of the year. This  
19 reflects the actual impact of BTM PV installations in reducing system load and  
20 uncertainty associated with the BTM PV.

21  
22 **Q: HOW IS TRANSPORTATION ELECTRIFICATION REFLECTED IN THE ICR**  
23 **MODEL?**

1 **A:** Transportation electrification impacts both the summer and winter peak demands and  
2 monthly energy. As such, the impact of electric vehicle (“EV”) load is explicitly  
3 modeled in the ICR calculation using an hourly EV demand forecast that reflects: (1) the  
4 assumed seasonal and weekday charging patterns; and (2) an 8% gross up for assumed  
5 transmission and distribution losses. The hourly EV forecast is modeled deterministically  
6 without considering uncertainty.

7

8 **Q: HOW IS HEATING ELECTRIFICATION REFLECTED IN THE ICR MODEL?**

9 **A:** Because heating electrification is weather-sensitive, it carries the load uncertainty  
10 associated with weather. Heating electrification only affects peak demand and energy in  
11 the winter months. Hence, to model it in the ICR, heating electrification is added into the  
12 gross load forecast, reflecting both the impacts from its penetration level and the  
13 uncertainty associated with weather.

14

1                   **2.       RESOURCE CAPACITY RATINGS**

2

3   **Q:     PLEASE DESCRIBE THE RESOURCE DATA THAT THE ISO USED TO**  
4           **DEVELOP THE ICR-RELATED VALUES FOR FCA 17, WHICH IS**  
5           **ASSOCIATED WITH THE 2026-2027 CAPACITY COMMITMENT PERIOD.**

6   **A:**    The ISO developed the ICR-Related Values for FCA 17 based on the Existing Qualified  
7           Capacity Resources for the 2026-2027 Capacity Commitment Period. This assumption is  
8           based on the latest available data at the time of the ICR-Related Values calculation.

9

10 **Q:     WHAT ARE THE RESOURCE CAPACITY VALUES FOR THE 2026-2027**  
11 **CAPACITY COMMITMENT PERIOD?**

12 **A:**    The following tables illustrate the make-up of the 32,798 MW of capacity resources  
13           assumed in the calculation of the ICR-Related Values.

14 **Table 2 – Qualified Existing Non-Intermittent Generating Capacity Resources**  
15 **by Load Zone (MW)<sup>9</sup>**

<b>Load Zone</b>	<b>Summer</b>
MAINE	3,049
NEW HAMPSHIRE	4,002
VERMONT	188
CONNECTICUT	9,225
RHODE ISLAND	1,900
SEMA	4,844
WESTERN/CENTRAL MASSACHUSETTS	3,641
NEMA/BOSTON	1,320
<b>Total New England</b>	<b>28,167</b>

---

<sup>9</sup> Values reflect the existing resources with Qualified Capacity for FCA 17 at the time of the ICR calculation and reflect applicable resource retirements and resource terminations.

1 **Table 3 – Qualified Existing Intermittent Power Resources by Load Zone (MW)<sup>10</sup>**

<b>Load Zone</b>	<b>Summer</b>	<b>Winter</b>
MAINE	283	314
NEW HAMPSHIRE	78	163
VERMONT	56	98
CONNECTICUT	119	67
RHODE ISLAND	83	42
SEMA	319	372
WESTERN/CENTRAL MASSACHUSETTS	219	135
NEMA/BOSTON	58	43
<b>Total New England</b>	<b>1,216</b>	<b>1,234</b>

2

3 **Table 4 – Qualified Existing Import Capacity Resources (MW)**

4

<b>Import Resource</b>	<b>Summer</b>	<b>External Interface</b>
NYPA – CMR	68	New York AC Ties
Niagara and St. Lawrence	15	New York AC Ties
<b>Total New England</b>	<b>84</b>	

5

6 **Table 5 – Qualified Existing Demand Capacity Resources by Load Zone (Summer MW)**

7

<b>Load Zone</b>	<b>On-Peak</b>	<b>Seasonal Peak</b>	<b>Active Demand Capacity Resource (ADCR)</b>	<b>Total</b>
MAINE	178	0	138	315
NEW HAMPSHIRE	139	0	52	192
VERMONT	103	0	55	159
CONNECTICUT	253	450	206	910
RHODE ISLAND	181	0	49	230
SEMA	303	0	95	397
WESTERN/CENTRAL MASSACHUSETTS	339	18	121	478
NEMA/BOSTON	527	0	123	650
<b>Total New England</b>	<b>2,023</b>	<b>468</b>	<b>840</b>	<b>3,331</b>

<sup>10</sup> All resources have only their summer capacity rating modeled in the ICR-Related Values with the exception of Intermittent Power Resources which have both their summer and winter capacity ratings modeled.

1 Although capacity resource data are tabulated above under the eight settlement Load  
2 Zones, only Maine (the Maine Load Zone) and NNE (the combined New Hampshire,  
3 Vermont and Maine Load Zones) are relevant for FCA 17.

4  
5 **Q: WHAT ARE THE ASSUMPTIONS RELATING TO RESOURCE ADDITIONS**  
6 **(THOSE WITHOUT CAPACITY SUPPLY OBLIGATIONS) AND ATTRITIONS?**

7 **A:** Resource additions, beyond those classified as “Existing Capacity Resources,” and  
8 attritions (with the exception of those associated with permanent de-list bids,  
9 unconditional retirements and retirements below the Forward Capacity Auction Starting  
10 Price of \$12.761 \$/kW-month) are not assumed in the calculation of the ICR-Related  
11 Values for FCA 17, which is associated with the 2026-2027 Capacity Commitment  
12 Period, because there is no certainty that new resource additions or resource attritions  
13 below the Forward Capacity Auction Starting Price will clear the auction.

14  
15 **3. RESOURCE AVAILABILITY**

16  
17 **Q: PLEASE EXPLAIN THE RESOURCE AVAILABILITY ASSUMPTIONS**  
18 **UNDERLYING THE CALCULATIONS OF THE ICR-RELATED VALUES FOR**  
19 **FCA 17, WHICH IS ASSOCIATED WITH THE 2026-2027 CAPACITY**  
20 **COMMITMENT PERIOD.**

21 **A:** Resources are modeled at their Qualified Capacity values along with their associated  
22 resource availability in the calculation of the ICR-Related Values. For generating  
23 resources, scheduled maintenance assumptions are based on each unit’s historical five-

1 year average of scheduled maintenance. If the individual resource has not been  
2 operational for a total of five years, then NERC Generator Availability Database System  
3 (“GADS”) class average data is used to substitute for the missing annual data. In the  
4 ICR-Related Values model, it is assumed that maintenance outages of generating  
5 resources will not be scheduled during the peak load season of June through August.

6  
7 An individual generating resource’s forced outage assumption is based on the resource’s  
8 five-year historical data from the ISO’s database of NERC GADS. If the individual  
9 resource has not been operational for a total of five years, then NERC class average data  
10 is used to substitute for the missing annual data.

11  
12 The Qualified Capacity of an Intermittent Power Resource is based on the resource’s  
13 historical median output during the Reliability Hours averaged over a period of five  
14 years. The Reliability Hours are specific, defined hours during the summer and the  
15 winter, and hours during the year in which the ISO has declared a system-wide or a Load  
16 Zone-specific shortage event. Because this method already takes into account the  
17 resource’s availability, Intermittent Power Resources are assumed to be 100% available  
18 in the models at their “Qualified Capacity” and not based on “nameplate” ratings.  
19 Qualified Capacity is the amount of capacity that either a generating, demand, or import  
20 resource may provide in the summer or winter in a Capacity Commitment Period, as  
21 determined in the FCM qualification process.

22

1 Demand Capacity Resources in the On-Peak Demand and Seasonal Peak Demand  
2 categories are non-dispatchable resources that reduce load across pre-defined hours,  
3 typically by means of energy efficiency. These types of Demand Capacity Resources are  
4 assumed to be 100% available. The availability of Active Demand Capacity Resources is  
5 calculated on an annual basis for each Load Zone utilizing data from both summer and  
6 winter performance, weighing the seasons based on their relative duration throughout the  
7 year. A rolling average of the forced outage rate for Active Demand Capacity Resources  
8 will be developed as a five year-rolling average. However, this year, the ISO only has  
9 four years' worth of data. Starting in 2023, the average will use five years of data, which  
10 will then start rolling in 2024.

11  
12 **Q: PLEASE LIST THE FOUR CATEGORIES OF BATTERY STORAGE**  
13 **RESOURCES AND HOW THEY ARE MODELED IN ICR CALCULATIONS**  
14 **BASED ON THEIR FCM PARTICIPATION.**

15 **A:** Based on their FCM participation, the four categories of battery storage resources are:  
16 (1) Battery storage resources that participate as Intermittent Power Resources (these may  
17 be co-located with other Intermittent Power Resources and may participate in the FCM as  
18 a single Intermittent Power Resource). The ISO models these resources using the  
19 methodology it uses to model Intermittent Power Resources (*i.e.*, using Qualified  
20 Capacity values and 100% availability).  
21 (2) Co-located battery storage resources that participate as non-intermittent resources  
22 (these resources are co-located with Intermittent Power Resources, but participate as non-  
23 intermittent Generating Capacity Resources). The ISO models these co-located battery

1 storage resources that participate as non-intermittent Generating Capacity Resources in  
2 the FCM using the methodology that it uses to model non-Intermittent Power Resources.  
3 Specifically, the ISO uses the resources' Qualified Capacity values and assume 100%  
4 availability.

5 (3) Stand-alone battery storage resources, which participate in the FCM as non-  
6 intermittent Generating Capacity Resources. The ISO models these stand-alone battery  
7 storage resources using a class model. Specifically, all resources are modeled using the  
8 same typical design and operational parameters for the fleet. The parameters of the class  
9 model for GE MARS are:

- 10 • Maximum generation and charging rating: respective Qualified Capacity values
- 11 • Maximum energy: respective usable AC energy
- 12 • Round-trip efficiency: 84%
- 13 • Number of calls per day: 1
- 14 • Maximum energy per call: maximum energy x 98% (range between maximum  
15 and minimum usable state of charge).
- 16 • The EFORD of these battery storage resources is assumed to be 5% with zero  
17 weeks of maintenance;

18 (4) Battery storage resources that participate in the FCM as part of a Demand Capacity  
19 Resource.

20



1                   **4. OTHER ASSUMPTIONS**

2

3 **Q: PLEASE DESCRIBE THE ASSUMPTIONS RELATING TO INTERNAL**  
4 **TRANSMISSION TRANSFER CAPABILITIES FOR THE DEVELOPMENT OF**  
5 **ICR-RELATED VALUES FOR FCA 17.**

6 **A:** The assumed internal interface transfer capabilities for export constrained Capacity Zones  
7 modeled are shown in the table below.

8                   **Table 6 – Internal Interface Transfer Capabilities (MW)**

<b>Interface</b>	<b>Contingency</b>	<b>2026-2027</b>
Maine New Hampshire Export	N-1	1,900
Northern New England (North-South Interface)	N-1	2,725

9

10

11 **Q: PLEASE DISCUSS THE ISO’S ASSUMPTIONS REGARDING THE ACTIONS**  
12 **OF OPERATING PROCEDURE NO. 4 IN DEVELOPING THE ICR-RELATED**  
13 **VALUES FOR FCA 17.**

14 **A:** In the development of the ICR, MCLs and MRI demand curves, the ISO uses assumed  
15 emergency assistance (*i.e.* tie benefits, which are described below) available from  
16 neighboring Control Areas, and load reduction from implementation of 5% voltage  
17 reductions. These all constitute actions that system operators invoke under Operating  
18 Procedure No. 4 in real-time to balance system demand with supply under expected or  
19 actual capacity shortage conditions. The amount of load relief assumed obtainable from  
20 invoking 5% voltage reductions pursuant to Section III.12.7.4 (a) is 1%. Using the 1%  
21 reduction in system load demand, the assumed voltage reduction load relief values, which

1 offset against the ICR, are 257 MW for June through September 2026 and 209 MW for  
2 October 2026 through May 2027.

3  
4 **5. TIE BENEFITS**

5  
6 **Q: WHAT ARE TIE BENEFITS?**

7 **A:** Tie benefits represent the possible emergency energy assistance from the interconnected  
8 neighboring Control Areas when a capacity shortage occurs.

9  
10 **Q: WHAT IS THE ROLE OF EXTERNAL TRANSMISSION IMPORT TRANSFER**  
11 **CAPABILITIES IN DEVELOPING THE ICR-RELATED VALUES?**

12 **A:** While external transmission import transfer capabilities are not an input to the calculation  
13 of the ICR-Related Values, they do impact the tie benefit assumption. Specifically, the  
14 external transmission import transfer capabilities would impact the amount of emergency  
15 energy, if available, that could be imported into New England.

16  
17 **Q: ARE INTERNAL TRANSMISSION TRANSFER CAPABILITIES MODELED IN**  
18 **TIE BENEFITS STUDIES?**

19 **A:** Internal transmission transfer capability constraints that are not addressed by an MCL are  
20 modeled in the tie benefits study. The results of the tie benefits study are used as an input  
21 in the ICR, MCL, and MRI demand curves calculations.

1 **Q: PLEASE EXPLAIN HOW TIE BENEFITS FROM NEIGHBORING CONTROL**  
2 **AREAS ARE ACCOUNTED FOR IN DETERMINING THE INSTALLED**  
3 **CAPACITY REQUIREMENT.**

4 **A:** The New England resource planning reliability criterion requires that adequate capacity  
5 resources be planned and installed such that disconnection of firm load would not occur  
6 more often than once in ten years due to a capacity deficiency after taking into account  
7 the load and capacity relief obtainable from implementing Operating Procedure No. 4. In  
8 other words, load and capacity relief assumed obtainable from implementing Operating  
9 Procedure No. 4 actions are direct substitutes for capacity resources for meeting the once  
10 in 10 years disconnection of firm load criterion. Calling on neighboring Control Areas to  
11 provide emergency energy assistance (“tie benefits”) is one of the actions of Operating  
12 Procedure No. 4. Therefore, the amount of tie benefits assumed obtainable from the  
13 interconnected neighboring Control Areas directly displaces that amount of installed  
14 capacity resources needed to meet the resource planning reliability criterion. When  
15 determining the amount of tie benefits to assume in ICR calculations, it is necessary to  
16 recognize that, while reliance on tie benefits can reduce capacity resource needs, over-  
17 reliance on tie benefits decreases system reliability. System reliability would decrease  
18 because each time emergency assistance is requested, there is a possibility that the  
19 available assistance will not be sufficient to meet the capacity deficiency. The more tie  
20 benefits are relied upon to meet the resource planning reliability criterion, and the greater  
21 the amount of assistance requested, the greater the possibility that they will not be  
22 available or sufficient to avoid implementing deeper actions of Operating Procedure No.  
23 4, and interrupting firm load in accordance with ISO New England Operating Procedure

1 No. 7, Action in an Emergency. For example, some of the resources that New York has  
2 available to provide tie benefits are demand response resources that have limits on the  
3 number of times they can be activated. In addition, none of the neighboring Control  
4 Areas are conducting their planning, maintenance scheduling, unit commitment, or real-  
5 time operations with a goal of maintaining their emergency assistance at a level needed to  
6 maintain the reliability of the New England system.

7  
8 **Q: PLEASE DESCRIBE THE TIE BENEFITS ASSUMPTIONS UNDERLYING THE**  
9 **ICR-RELATED VALUES FOR FCA 17.**

10 **A:** Under Section III.12.9 of the Tariff, the ISO is required to perform a tie reliability  
11 benefits study for each FCA, which provides the total overall tie benefit value available  
12 from all interconnections with adjacent Control Areas, the contribution of tie benefits  
13 from each of these adjacent Control Areas, as well as the contribution from individual  
14 interconnections or qualifying groups of interconnections within each adjacent Control  
15 Area.

16  
17 Pursuant to Section III.12.9 of the Tariff, the ICR calculations for FCA 17 assume total  
18 tie benefits of 2,100 MW based on the results of the tie benefits study for the 2026-2027  
19 Capacity Commitment Period. A breakdown of this total value is as follows: 1,001 MW  
20 from Quebec over the Hydro-Quebec Phase I/II HVDC Transmission Facilities, 150 MW  
21 from Quebec over the Highgate interconnection, 523 MW from Maritimes (New  
22 Brunswick) over the New Brunswick interconnections, and 426 MW from New York  
23 over the AC interconnections. Tie benefits are assumed not available over the Cross

1 Sound Cable because the import capability of the Cross Sound Cable was determined to  
2 be 0 MW.

3  
4 **Q: IS THE ISO'S METHODOLOGY FOR CALCULATING TIE BENEFITS FOR**  
5 **FCA 17 THE SAME AS THE METHODOLOGY USED FOR FCA 16?**

6 **A:** Yes. The methodology for calculating the tie benefits used in the ICR for FCA 17 is the  
7 same methodology used to calculate the tie benefits used in the ICR for FCA 16. This  
8 methodology is described in detail in Section III.12.9 of the Tariff.

9  
10 **Q: DOES THIS CALCULATION METHODOLOGY CONFORM WITH INDUSTRY**  
11 **PRACTICE AND TARIFF REQUIREMENTS?**

12 **A:** Yes. This probabilistic calculation methodology is widely used by the electric industry.  
13 NPCC has been using a similar methodology for many years. The ISO has been using  
14 the GE MARS program and a similar probabilistic calculation methodology for tie  
15 benefits calculations since 2002. The calculation methodology conforms to the Tariff  
16 provisions filed with and accepted by the Commission.

17  
18 **Q: PLEASE EXPLAIN THE ISO'S METHODOLOGY FOR DETERMINING THE**  
19 **TIE BENEFITS FOR FCA 17.**

20 **A:** The ISO conducted the tie benefits study for FCA 17 using the probabilistic GE MARS  
21 program to model the expected system conditions of New England and its directly  
22 interconnected neighboring Control Areas of Quebec, New Brunswick, and New York.  
23 All of these Control Areas were assumed to be "at criterion," which means that the

1 capacity of all three neighboring Control Areas was adjusted so that they would each  
2 have a LOLE of once in ten years when interconnected to each other.

3  
4 The ISO applied the “at criterion” approach to represent the expected amounts of  
5 capacity in each Control Area since each of these areas has structured its planning  
6 processes and markets (where applicable) to achieve the “at criterion” level of reliability.  
7 The total tie benefits to New England from Quebec, Maritimes (New Brunswick) and  
8 New York were calculated first. To calculate total tie benefits, the ISO brought the  
9 interconnected system of New England and its directly interconnected neighboring  
10 Control Areas to 0.1 days per year LOLE and then compared to the LOLE of the isolated  
11 New England system. Total tie benefits equal the amount of firm capacity equivalents  
12 that must be added to the isolated New England Control Area to bring New England to  
13 0.1 days per year LOLE.

14  
15 Following the calculation of total tie benefits, the ISO calculated individual tie benefits  
16 from each of the three directly interconnected neighboring Control Areas. The ISO  
17 calculated tie benefits from each neighboring Control Area using a similar analysis, with  
18 tie benefits from the Control Area equaling the simple average of the tie benefits  
19 calculated from all possible interconnection states between New England and the target  
20 Control Area, subject to adjustment, if any, for capacity imports as described below.

21  
22 If the sum of the tie benefits from each Control Area does not equal the total tie benefits  
23 to New England, then each Control Area’s tie benefits is pro-rationed so that the sum of

1 each Control Area's tie benefits equals the total tie benefits for all Control Areas.  
2 Following this calculation, the ISO calculated tie benefits for each individual  
3 interconnection or qualifying group of interconnections, and a similar pro-rationing was  
4 performed if the sum of the tie benefits from individual interconnections or groups of  
5 interconnections does not equal their associated Control Area's tie benefits.

6  
7 After the pro-rationing, the ISO adjusted the tie benefits for each individual  
8 interconnection or group of interconnections to account for capacity imports. After the  
9 import capability and capacity import adjustments, the sum of the tie benefits of all  
10 individual interconnections and groups of interconnections for a Control Area then  
11 represents the tie benefits associated with that Control Area, and the sum of the tie  
12 benefits from all Control Areas then represents the total tie benefits available to New  
13 England.

14  
15 **Q: HOW DOES THE ISO DETERMINE WHICH INTERCONNECTIONS MAY BE**  
16 **ALLOCATED A SHARE OF TIE BENEFITS?**

17 **A:** Tie benefits are calculated for all interconnections for which a "discrete and material  
18 transfer capability" can be determined. This standard establishes that if an  
19 interconnection has any discernible transfer capability, it will be evaluated. If this  
20 nominal threshold is met, then the ISO evaluates the interconnection to determine  
21 whether it should be evaluated independently or as part of a group of interconnections.  
22 An interconnection will be evaluated with other interconnections as part of a "group of  
23 interconnections" if that interconnection is one of two or more AC interconnections that

1 operate in parallel to form a transmission interface in which there are significant  
2 overlapping contributions of each line toward establishing the transfer capability, such  
3 that the individual lines in the group of interconnections cannot be assigned individual  
4 contributions. This standard is contained in Section III.12.9.5 of the Tariff.

5  
6 Finally, one component of the tie benefits calculation for individual interconnections is  
7 the determination of the “transfer capability” of the interconnection. If the  
8 interconnection has minimal or no available transfer capability during times when the  
9 ISO will be relying on the interconnection for tie benefits, then the interconnection will  
10 be assigned minimal or no tie benefits.

11  
12 **Q: ARE THERE ANY INTERCONNECTIONS BETWEEN NEW ENGLAND AND**  
13 **ITS DIRECTLY INTERCONNECTED NEIGHBORING CONTROL AREAS FOR**  
14 **WHICH THE ISO HAS NOT CALCULATED TIE BENEFITS?**

15 **A:** No. The ISO calculated tie benefits for all interconnections between New England and  
16 its directly interconnected neighboring Control Areas, either individually or as part of a  
17 group of interconnections.

18  
19 **Q: WHAT IS THE TRANSFER CAPABILITY OF EACH OF THE**  
20 **INTERCONNECTIONS OR GROUPS OF INTERCONNECTIONS FOR WHICH**  
21 **TIE BENEFITS HAVE BEEN CALCULATED?**

22 **A:** The following table lists the external transmission interconnections and the transfer  
23 capability of each used for calculating tie benefits for FCA 17:



1

**Table 7 – External Interface Import Capability (MW)**

<b>External Transmission Interconnections/Interfaces</b>	<b>Capacity Import Capability into New England</b>
Hydro-Quebec Phase I/II HVDC Transmission Facilities	1,400
Highgate Interconnection	200
Maritimes (New Brunswick) Interconnections	700
Cross-Sound Cable	0
New York AC Interface	1,400

2

3

4

5

6

7

8

9

10

11

12

13

**6. AMOUNT OF SYSTEM RESERVE**

14

15

**Q: WHAT AMOUNT OF SYSTEM RESERVES IS REQUIRED TO BE INCLUDED**

16

**AS AN ASSUMPTION IN THE DETERMINATION OF THE ICR?**

1 **A:** Section III.12.7.4(c) of the Tariff requires that the determination of the ICR and related  
2 values include an amount of system reserves that is consistent with those needed for  
3 reliable system operations during emergency conditions.

4  
5 **Q: WHAT AMOUNT OF SYSTEM RESERVES DID THE ISO USE IN THE**  
6 **DETERMINATION OF THE PROBABILISTIC ICR-RELATED VALUES?**

7 **A:** The ISO used 700 MW as the amount of system reserve in the determination of the  
8 probabilistic ICR-Related Values, which is the same as the value it used for FCA 16.

9  
10 **III. MAXIMUM CAPACITY LIMITS**

11  
12  
13 **Q: WHAT IS THE MAXIMUM CAPACITY LIMIT?**

14 **A:** The MCL is the maximum amount of capacity that is electrically located in an export-  
15 constrained Capacity Zone used to meet the ICR.

16  
17 **Q: WHAT ARE EXPORT-CONSTRAINED CAPACITY ZONES?**

18 **A:** Export-constrained Capacity Zones are areas within New England where the available  
19 resources, after serving local load, may exceed the areas' transmission capability to  
20 export excess resource capacity.

21  
22 **Q: HOW IS AN EXPORT-CONSTRAINED CAPACITY ZONE DETERMINED?**

23 **A:** A separate export-constrained Capacity Zone is identified in the most recent annual  
24 assessment of transmission transfer capability pursuant to OATT Section II, Attachment

1 K, as a zone for which the MCL is less than the sum of the existing qualified capacity and  
2 proposed new capacity that could qualify to be procured in the export-constrained  
3 Capacity Zone, including existing and proposed new Import Capacity Resources on the  
4 export-constrained side of the interface.

5  
6 **Q: WHICH ZONES WILL BE MODELED AS EXPORT CONSTRAINED**  
7 **CAPACITY ZONES FOR FCA 17?**

8 **A:** After applying the export-constrained Capacity Zone objective criteria testing, it was  
9 determined that, for FCA 17, the Maine and NNE Capacity Zones will be modeled as  
10 separate export-constrained Capacity Zones. The Maine Capacity Zone consists of the  
11 Maine Load Zone. The NNE Capacity Zone consists of the combined New Hampshire,  
12 Vermont, and Maine Load Zones.

13  
14 **Q: WHAT IS THE LOCAL RESOURCE ADEQUACY (“LRA”) REQUIREMENT**  
15 **AND HOW IS IT RELATED TO THE DETERMINATION OF AN MCL?**

16 **A:** The LRA requirement is the minimum amount of resources required for an area to satisfy  
17 its reliability criterion. In the determination of the MCL of the export-constrained  
18 Capacity Zone of interest, the LRA requirement is used to identify the minimum amount  
19 of resources required for the “Rest of New England,” which refers to all areas except the  
20 export-constrained Capacity Zone under study.

21  
22 **Q: PLEASE DESCRIBE THE METHODOLOGY FOR CALCULATING THE LRA**  
23 **FOR THE REST OF NEW ENGLAND.**

1 **A:** The LRA requirement for the rest of New England is determined by modeling the export-  
2 constrained Capacity Zone under study vis-à-vis the Rest of New England. This, in  
3 effect, turns the modeling effort into a series of two-area reliability simulations. The  
4 reliability target of this analysis is a system-wide LOLE of 0.105 days per year when the  
5 transmission constraints between the two areas are included in the model. Because the  
6 LRA requirement is the minimum amount of resources that must be located in the Rest of  
7 New England to meet the system-reliability requirements, the excess capacity in the  
8 export-constrained Capacity Zone of interest is shifted to the Rest of New England until  
9 the reliability threshold, or target LOLE of 0.105,<sup>11</sup> is achieved.

10

11 **Q: WHAT ARE THE MAXIMUM CAPACITY LIMITS FOR THE EXPORT-  
12 CONSTRAINED CAPACITY ZONES FOR FCA 17 AND HOW WERE THEY  
13 CALCULATED?**

14 **A:** The MCL for the Maine Capacity Zone for FCA 17 is 4,065 MW and the MCL for the  
15 NNE Capacity Zone is 8,595 MW which also reflect the tie benefits assumed available  
16 over the Maritimes (New Brunswick) and Highgate interfaces. The ISO calculated the  
17 MCLs using the methodology that is reflected in Section III.12.2.2 of the Tariff.

18

19 In order to determine the MCLs, the New England net ICR and the LRA of the Rest of  
20 New England are needed. Given that the net ICR is the total amount of resources that the  
21 region needs to meet the 0.1 days/year LOLE, and the LRA for the Rest of New England

---

<sup>11</sup> An allowance for transmission-related LOLE of 0.005 days per year is applied when determining the Local Resource Adequacy Requirement of a capacity zone.

1 is the minimum amount of resources required for that area to satisfy its reliability  
2 criterion, the difference between the two is the maximum amount of resources that can be  
3 used within the export-constrained Capacity Zone to meet the 0.1 days/year LOLE.  
4

5 **V. HQICCs**

7 **Q: WHAT ARE HQICCs?**

8 **A:** HQICCs are capacity credits that are allocated to the Interconnection Rights Holders,  
9 which are entities that pay for and, consequently, hold certain rights over the Hydro  
10 Quebec Phase I/II HVDC Transmission Facilities (“HQ Interconnection”).<sup>12</sup> Pursuant to  
11 Sections III.12.9.5 and III.12.9.7 of the Tariff, the tie benefit value for the HQ  
12 Interconnection was established using the results of a probabilistic calculation of tie  
13 benefits with Quebec. The ISO calculates HQICCs, which are allocated to  
14 Interconnection Rights Holders in proportion to their individual rights over the HQ  
15 Interconnection, and must file the HQICC values established for each FCA.  
16

17 **Q: WHAT ARE THE HQICC VALUES FOR FCA 17, WHICH IS ASSOCIATED**  
18 **WITH THE 2026-2027 CAPACITY COMMITMENT PERIOD?**

---

<sup>12</sup> See Section I.2.2 of the Tariff (stating in the definition of “Hydro-Quebec Interconnection Capability Credit” that “[a]n appropriate share of the HQICC shall be assigned to an IRH if the Hydro Quebec (HQ) Phase I/II HVDC-TF support costs are paid by that IRH and such costs are not included in the calculation of the Regional Network Service rate.”). See also Section III.12.9.7 of the Tariff (“The tie benefits from the Quebec Control Area over the HQ Phase I/II HVDC-TF calculated in accordance with Section III.12.9.1 shall be allocated to the Interconnection Rights Holders or their designees in proportion to their respective percentage shares of the HQ Phase I and the HQ Phase II facilities, in accordance with Section I of the Transmission, Markets and Services Tariff.”).

1 **A:** The HQICC values are 1,001 MW for every month of the 2026-2027 Capacity  
2 Commitment Period.

3  
4 **VI. MRI DEMAND CURVES**

5  
6 **Q: PLEASE DESCRIBE THE METHODOLOGY USED FOR CALCULATING THE**  
7 **MRI DEMAND CURVES FOR FCA 17.**

8 **A:** To calculate the System-Wide Capacity Demand Curve and the export-constrained  
9 Capacity Zone Demand Curves for Maine and NNE for FCA 17, the ISO used the MRI  
10 methodology, which measures the marginal reliability impact (*i.e.* the MRI), associated  
11 with various capacity levels for the system and the Capacity Zones.

12  
13 To measure the MRI, the ISO uses a performance metric known as “expected energy not  
14 served” (“EENS,” which can be described as unserved load.) EENS is measured in MWh  
15 per year and can be calculated for any set of system and zonal installed capacity levels.  
16 The EENS values for system capacity levels are produced by the GE MARS model,<sup>13</sup> in  
17 10 MW increments, applying the same assumptions used in determining the ICR. These  
18 system EENS values are translated into MRI values by estimating how an incremental  
19 change in capacity impacts system reliability at various capacity levels, as measured by

---

<sup>13</sup> The GE MARS model is the same simulation system that is used to develop the ICR and other values that specify how much capacity is required for resource adequacy purposes from a system planning perspective. For the development of the MRI demand curves, the same GE MARS model is used to calculate reliability values using 10 MW additions above and 10 MW deductions below the calculated requirements until a sufficient set of values that covers the full range necessary to produce the MRI demand curves is determined.

1 EENS. An MRI curve is developed from these values with capacity represented on the  
2 X-axis and the corresponding MRI values on the Y-axis.

3  
4 MRI demand curve values at various capacity levels are also calculated for the Maine and  
5 NNE export-constrained Capacity Zones using the same modeling assumptions and  
6 methodology as those used to determine the LRA and the MCLs for those Capacity  
7 Zones. These MRI values are calculated to reflect the change in system reliability  
8 associated with transferring incremental capacity from the Rest of New England into the  
9 constrained capacity zone.

10  
11 **Q: PLEASE EXPLAIN THE USE OF A CAPACITY DEMAND CURVE SCALING**  
12 **FACTOR IN THE MRI DEMAND CURVE METHODOLOGY.**

13 **A:** In order to satisfy both the reliability needs of the system, which requires that the FCM  
14 procure sufficient capacity to meet the 0.1 days per year reliability criterion and produce  
15 a sustainable market such that the average market clearing price is sufficient to attract  
16 new entry of capacity when needed over the long term, the System-Wide Capacity  
17 Demand Curve and Capacity Zone Demand Curves for FCA 17 are set equal to the  
18 product of their MRI curves and a fixed demand curve scaling factor. The scaling factor  
19 is set equal to the lowest value at which the set of demand curves will simultaneously  
20 satisfy the planning reliability criterion and pay the estimated cost of new entry (“Net  
21 CONE”).<sup>14</sup> In other words, the scaling factor is equal to the value that produces a

---

<sup>14</sup> For FCA 17, Net CONE has been determined as \$7.359/kW-month.

1 System-Wide Capacity Demand Curve that specifies a price of Net CONE at the net ICR  
2 (ICR minus HQICCs).

3  
4 To satisfy this requirement, the demand curve scaling factor for FCA 17 was developed  
5 for the System-Wide Capacity Demand Curve and the export-constrained Capacity Zone  
6 Demand Curves for the Maine and NNE export-constrained Capacity Zones in  
7 accordance with Section III.13.2.2.4 of the Tariff. The demand curve scaling factor is set  
8 at the value such that, at the quantity specified by the System-Wide Capacity Demand  
9 Curve at a price of Net CONE, the LOLE is 0.1 days per year.

10  
11 **Q: PLEASE PROVIDE ADDITIONAL DETAILS REGARDING THE**  
12 **DEVELOPMENT OF THE EXPORT-CONSTRAINED CAPACITY ZONE**  
13 **DEMAND CURVES FOR THE MAINE AND NNE CAPACITY ZONES.**


14 **A:** Under Section III.12.2.2.1 of the Tariff, prior to each FCA, export-constrained Capacity  
15 Zone Demand Curves are calculated using the same modeling assumptions and  
16 methodology used to determine the export-constrained Capacity Zones' MCLs. Using  
17 the values calculated pursuant to Section III.12.2.2.1 of the Tariff, the ISO must  
18 determine the export-constrained Capacity Zone Demand Curves pursuant to Section  
19 III.13.2.2.3 of the Tariff. For FCA 17, the export-constrained Capacity Zones are Maine  
20 and NNE, and, therefore, there are two export-constrained Capacity Zone Demand  
21 Curves.

22  
23 **Q: WHAT MRI DEMAND CURVES HAS THE ISO CALCULATED FOR FCA 17?**



1 **A:** As required under Section III.12 of the Tariff, the ISO calculated the following MRI  
2 demand curves for FCA 17:


3 1. System-Wide Capacity Demand Curve for FCA 17



4  
5

1  
2


2. Export-constrained Capacity Zone Demand Curve for the Maine Capacity Zone for FCA 17



3

1  
2

3. Export-constrained Capacity Zone Demand Curve for the NNE Capacity Zone for FCA 17



3  
4  
5  
6  
7

**Q: DOES THIS CONCLUDE YOUR TESTIMONY?**

**A: Yes.**

1 I declare that the foregoing is true and correct.

2

3

4

*Manasa K*

5

Manasa Kotha

6

7 November 8, 2022

## New England Governors, State Utility Regulators and Related Agencies\*

### Connecticut

The Honorable Ned Lamont  
Office of the Governor  
State Capitol  
210 Capitol Ave.  
Hartford, CT 06106  
[bob.clark@ct.gov](mailto:bob.clark@ct.gov)

Connecticut Attorney General's Office  
165 Capitol Avenue  
Hartford, CT 06106  
[John.wright@ct.gov](mailto:John.wright@ct.gov)  
[Lauren.bidra@ct.gov](mailto:Lauren.bidra@ct.gov)

Connecticut Department of Energy and  
Environmental Protection  
79 Elm Street  
Hartford, CT 06106  
[Eric.annes@ct.gov](mailto:Eric.annes@ct.gov)  
[Robert.snook@ct.gov](mailto:Robert.snook@ct.gov)

Connecticut Public Utilities Regulatory Authority  
10 Franklin Square  
New Britain, CT 06051-2605  
[steven.cadwallader@ct.gov](mailto:steven.cadwallader@ct.gov)  
[robert.luysterborghs@ct.gov](mailto:robert.luysterborghs@ct.gov)  
[Seth.Hollander@ct.gov](mailto:Seth.Hollander@ct.gov)  
[Robert.Marconi@ct.gov](mailto:Robert.Marconi@ct.gov)

### Maine

The Honorable Janet Mills  
One State House Station  
Office of the Governor  
Augusta, ME 04333-0001  
[Jeremy.kennedy@maine.gov](mailto:Jeremy.kennedy@maine.gov)  
[Elise.baldacci@maine.gov](mailto:Elise.baldacci@maine.gov)

Maine Public Utilities Commission  
18 State House Station  
Augusta, ME 04333-0018  
[Maine.puc@maine.gov](mailto:Maine.puc@maine.gov)

### Massachusetts

The Honorable Charles Baker  
Office of the Governor  
State House  
Boston, MA 02133

Massachusetts Attorney General's Office

One Ashburton Place  
Boston, MA 02108  
[rebecca.tepper@state.ma.us](mailto:rebecca.tepper@state.ma.us)

Massachusetts Department of Energy  
Resources  
100 Cambridge Street, Suite 1020  
Boston, MA 02114  
[Robert.hoaglund@mass.gov](mailto:Robert.hoaglund@mass.gov)  
[ben.dobbs@state.ma.us](mailto:ben.dobbs@state.ma.us)

Massachusetts Department of Public Utilities  
One South Station  
Boston, MA 02110  
[Nancy.Stevens@state.ma.us](mailto:Nancy.Stevens@state.ma.us)  
[morgane.treanton@state.ma.us](mailto:morgane.treanton@state.ma.us)  
[William.J.Anderson2@mass.gov](mailto:William.J.Anderson2@mass.gov)  
[dpu.electricsupply@mass.gov](mailto:dpu.electricsupply@mass.gov)

### New Hampshire

The Honorable Chris Sununu  
Office of the Governor  
26 Capital Street  
Concord NH 03301

New Hampshire Department of Energy  
21 South Fruit Street, Ste 10  
Concord, NH 03301  
[Jared.S.Chicoine@energy.nh.gov](mailto:Jared.S.Chicoine@energy.nh.gov)  
[Christopher.j.ellmsjr@energy.nh.gov](mailto:Christopher.j.ellmsjr@energy.nh.gov)  
[Thomas.C.Frantz@energy.nh.gov](mailto:Thomas.C.Frantz@energy.nh.gov)  
[Karen.P.Cramton@energy.nh.gov](mailto:Karen.P.Cramton@energy.nh.gov)  
[Amanda.O.Noonan@energy.nh.gov](mailto:Amanda.O.Noonan@energy.nh.gov)  
[joshua.w.elliott@energy.nh.gov](mailto:joshua.w.elliott@energy.nh.gov)

New Hampshire Public Utilities Commission  
21 South Fruit Street, Ste. 10  
Concord, NH 03301-2429  
[david.j.shulock@energy.nh.gov](mailto:david.j.shulock@energy.nh.gov)  
[RegionalEnergy@puc.nh.gov](mailto:RegionalEnergy@puc.nh.gov)

### Rhode Island

The Honorable Daniel McKee  
Office of the Governor  
82 Smith Street  
Providence, RI 02903  
[Rosemary.powers@governor.ri.gov](mailto:Rosemary.powers@governor.ri.gov)

## **New England Governors, State Utility Regulators and Related Agencies\***

Rhode Island Office of Energy Resources  
One Capitol Hill  
Providence, RI 02908  
[christopher.kearns@energy.ri.gov](mailto:christopher.kearns@energy.ri.gov)  
[nicholas.ucci@energy.ri.gov](mailto:nicholas.ucci@energy.ri.gov)

Rhode Island Public Utilities Commission  
89 Jefferson Blvd.  
Warwick, RI 02888  
[ronald.gerwatowski@puc.ri.gov](mailto:ronald.gerwatowski@puc.ri.gov)  
[todd.bianco@puc.ri.gov](mailto:todd.bianco@puc.ri.gov)

### **Vermont**

The Honorable Phil Scott  
Office of the Governor  
109 State Street, Pavilion  
Montpelier, VT 05609  
[jason.gibbs@vermont.gov](mailto:jason.gibbs@vermont.gov)

Vermont Public Utility Commission  
112 State Street  
Montpelier, VT 05620-2701  
[mary-jo.krolewski@vermont.gov](mailto:mary-jo.krolewski@vermont.gov)  
[Margaret.cheney@vermont.gov](mailto:Margaret.cheney@vermont.gov)

Vermont Department of Public Service  
112 State Street, Drawer 20  
Montpelier, VT 05620-2601  
[bill.jordan@vermont.gov](mailto:bill.jordan@vermont.gov)  
[june.tierney@vermont.gov](mailto:june.tierney@vermont.gov)

### **New England Governors, Utility Regulatory and Related Agencies**

Jay Lucey  
Coalition of Northeastern Governors  
400 North Capitol Street, NW, Suite 370  
Washington, DC 20001  
[coneg@sso.org](mailto:coneg@sso.org)

Heather Hunt, Executive Director  
New England States Committee on Electricity  
424 Main Street  
Osterville, MA 02655  
[HeatherHunt@nescoe.com](mailto:HeatherHunt@nescoe.com)  
[JasonMarshall@nescoe.com](mailto:JasonMarshall@nescoe.com)  
[JeffBentz@nescoe.com](mailto:JeffBentz@nescoe.com)

Meredith Hatfield, Executive Director  
New England Conference of Public Utilities  
Commissioners  
72 N. Main Street  
Concord, NH 03301  
[mhatfield@necpuc.org](mailto:mhatfield@necpuc.org)

Matthew Nelson, President  
New England Conference of Public Utilities  
Commissioners  
One South Station  
Boston, MA 02110  
[matthew.nelson@mass.gov](mailto:matthew.nelson@mass.gov)